

NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

7/29/2016

Rick Rose
Medford School District
815 S Oakdale Ave
Medford, OR 97501

TEL: (541) 842-1138

FAX 541-842-1160

RE: 16-08 McLouglin Lead Study

Order No.: 1607523

Dear Rick Rose:

Neilson Research Corporation received 74 sample(s) on 7/13/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Medford School District
Project: 16-08 McLouglin Lead Study
Lab Order: 1607523

Date: 29-Jul-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-01A**

Collection Date: **7/13/2016 1:55:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11279

Collectors Name: John Jessen

Sample Location: Outside S Caf Ent DF Upper

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000289		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-02A**

Collection Date: **7/13/2016 1:57:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11269

Collectors Name: John Jessen

Sample Location: Outsdie S Caf Ent DF Lower

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000982		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-03A**

Collection Date: **7/13/2016 2:00:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11274

Collectors Name: John Jessen

Sample Location: Room 106 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	1.32	*	0.005	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	0.0294	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-04A**

Collection Date: **7/13/2016 2:02:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11384

Collectors Name: John Jessen

Sample Location: Room 107 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0248	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-05A**

Collection Date: **7/13/2016 2:05:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11282

Collectors Name: John Jessen

Sample Location: Room 108 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	1.24		0.005	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	0.0522	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-06A**

Collection Date: **7/13/2016 2:18:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11298

Collectors Name: John Jessen

Sample Location: Room 105 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0212	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-07A**

Collection Date: **7/13/2016 2:21:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11290

Collectors Name: John Jessen

Sample Location: Room 104 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0452	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-08A**

Collection Date: **7/13/2016 3:01:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11285

Collectors Name: John Jessen

Sample Location: Caf Snack Zone Ice Machine

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	2.02	*	0.005	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	0.0252	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-09A**

Collection Date: **7/13/2016 2:24:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11280

Collectors Name: John Jessen

Sample Location: Staff Brk Rm Sink

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	3.28	*	0.005	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	0.0583	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-10A**

Collection Date: **7/13/2016 2:28:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11272

Collectors Name: John Jessen

Sample Location: Room 103 DF (R-N Wall)

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0304	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-11A**

Collection Date: **7/13/2016 3:26:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11263

Collectors Name: John Jessen

Sample Location: Outside Athl Store Bldg DF L

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0146		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-12A**

Collection Date: **7/13/2016 3:27:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11288

Collectors Name: John Jessen

Sample Location: Outside Athl Store Bld DF R

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0220	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-13A**

Collection Date: **7/13/2016 3:21:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11289

Collectors Name: John Jessen

Sample Location: Outside Athl Store Bld Hose

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0123		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-14A**

Collection Date: **7/13/2016 3:13:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11300

Collectors Name: John Jessen

Sample Location: Black Gym DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	1.52	*	0.005	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	0.0519	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-15A**

Collection Date: **7/13/2016 3:16:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11266

Collectors Name: John Jessen

Sample Location: Wrestling Room DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000766		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-16A**

Collection Date: **7/13/2016 3:06:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11299

Collectors Name: John Jessen

Sample Location: Gold Gym DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	2.43	*	0.005	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	0.0525	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-17A**

Collection Date: **7/13/2016 2:10:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11278

Collectors Name: John Jessen

Sample Location: Caf DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000538		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-18A**

Collection Date: **7/13/2016 2:13:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11297

Collectors Name: John Jessen

Sample Location: Caf Snack Zone Sink

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00101		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-19A**

Collection Date: **7/13/2016 1:50:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11261

Collectors Name: John Jessen

Sample Location: Kitch Food Prep Sink S Wall

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	1.91	*	0.005	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	0.0611	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-20A**

Collection Date: **7/13/2016 1:48:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11246

Collectors Name: John Jessen

Sample Location: Kitch Food Prep Sink W Wall

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	1.93	*	0.005	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	0.0521	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-21A**

Collection Date: **7/13/2016 2:30:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11286

Collectors Name: John Jessen

Sample Location: Room 102 DF (L-N Wall)

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0141		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-22A**

Collection Date: **7/13/2016 2:33:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11273

Collectors Name: John Jessen

Sample Location: Room 101 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	1.62	*	0.005	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	0.0321	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-23A**

Collection Date: **7/13/2016 2:35:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #11276

Collectors Name: John Jessen

Sample Location: Room 100 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0225	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-24A**

Collection Date: **7/13/2016 2:41:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17021

Collectors Name: John Jessen

Sample Location: Outside Media Ctr Hall DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0115		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-25A**

Collection Date: **7/13/2016 3:02:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17091

Collectors Name: Gary Severe

Sample Location: Room 201 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000334		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-26A**

Collection Date: **7/13/2016 3:04:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17093

Collectors Name: Gary Severe

Sample Location: Room 203 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000205		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-27A**

Collection Date: **7/13/2016 3:06:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17046

Collectors Name: Gary Severe

Sample Location: Room 205 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000630		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-28A**

Collection Date: **7/13/2016 3:08:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #19460

Collectors Name: Gary Severe

Sample Location: Room 206 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00130		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-29A**

Collection Date: **7/13/2016 3:09:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17049

Collectors Name: Gary Severe

Sample Location: Room 207 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000259		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-30A**

Collection Date: **7/13/2016 3:11:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17047

Collectors Name: Gary Severe

Sample Location: Room 208 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000559		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-31A**

Collection Date: **7/13/2016 2:24:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #19458

Collectors Name: Gary Severe

Sample Location: Media Ctr DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00158		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-32A**

Collection Date: **7/13/2016 2:43:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17063

Collectors Name: Gary Severe

Sample Location: Band Rm Storage Rm DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000237		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-33A**

Collection Date: **7/13/2016 2:44:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17090

Collectors Name: Gary Severe

Sample Location: Room 110 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000337		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-34A**

Collection Date: **7/13/2016 2:46:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17065

Collectors Name: Gary Severe

Sample Location: Outside Rm 221 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000687		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-35A**

Collection Date: **7/13/2016 2:48:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17095

Collectors Name: Gary Severe

Sample Location: Rm 223 Cer DF N Island

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000377		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-36A**

Collection Date: **7/13/2016 2:50:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17096

Collectors Name: Gary Severe

Sample Location: Rm 224 DF E Wall Left

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000170		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-37A**

Collection Date: **7/13/2016 2:52:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17092

Collectors Name: Gary Severe

Sample Location: Rm 231 DF L West Wall

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0101		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-38A**

Collection Date: **7/13/2016 2:54:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17057

Collectors Name: Gary Severe

Sample Location: Rm 232 DF R West Wall

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00822		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-39A**

Collection Date: **7/13/2016 2:56:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17068

Collectors Name: Gary Severe

Sample Location: Room 200 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000850		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-40A**

Collection Date: **7/13/2016 2:57:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #19459

Collectors Name: Gary Severe

Sample Location: Room 202 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00870		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-41A**

Collection Date: **7/13/2016 3:00:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #19463

Collectors Name: Gary Severe

Sample Location: Room 204 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00113		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-42A**

Collection Date: **7/13/2016 2:29:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17094

Collectors Name: Gary Severe

Sample Location: Main Ofc Lg Conf Rm DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000421		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-43A**

Collection Date: **7/13/2016 2:30:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17029

Collectors Name: Gary Severe

Sample Location: Main Ofc Kitchen Sink

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000252		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-44A**

Collection Date: **7/13/2016 2:32:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17058

Collectors Name: Gary Severe

Sample Location: Health Room Sink

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000808		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-45A**

Collection Date: **7/13/2016 2:35:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17099

Collectors Name: Gary Severe

Sample Location: Room 114 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000575		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-46A**

Collection Date: **7/13/2016 2:37:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17067

Collectors Name: Gary Severe

Sample Location: Room 113 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000244		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-47A**

Collection Date: **7/13/2016 2:38:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17030

Collectors Name: Gary Severe

Sample Location: Room 112 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000323		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-48A**

Collection Date: **7/13/2016 2:40:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17097

Collectors Name: Gary Severe

Sample Location: Room 111 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	1.56	*	0.001	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.0390	*	0.0001	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-49A**

Collection Date: **7/13/2016 3:13:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17050

Collectors Name: Roger Moulard

Sample Location: Room 220B DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000378		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-50A**

Collection Date: **7/13/2016 3:14:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17051

Collectors Name: Roger Moulard

Sample Location: Room 220A DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000522		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-51A**

Collection Date: **7/13/2016 3:16:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17043

Collectors Name: Roger Moulard

Sample Location: Room 225 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000321		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-52A**

Collection Date: **7/13/2016 3:17:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17044

Collectors Name: Roger Moulard

Sample Location: Room 226 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000443		0.0001	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-53A**

Collection Date: **7/13/2016 3:18:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17045

Collectors Name: Roger Moulard

Sample Location: Room 227 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000385		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-54A**

Collection Date: **7/13/2016 3:20:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17048

Collectors Name: Roger Moulard

Sample Location: Room 217 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000166		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-55A**

Collection Date: **7/13/2016 3:21:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17053

Collectors Name: Roger Moulard

Sample Location: Room 218 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000337		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-56A**

Collection Date: **7/13/2016 3:22:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17056

Collectors Name: Roger Moulard

Sample Location: Room 216 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000287		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-57A**

Collection Date: **7/13/2016 3:24:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17066

Collectors Name: Roger Moulard

Sample Location: Room 215 SK A

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00417		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-58A**

Collection Date: **7/13/2016 3:25:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17069

Collectors Name: Roger Moulard

Sample Location: Room 215 DF B

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00125		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-59A**

Collection Date: **7/13/2016 3:38:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17015

Collectors Name: Roger Moulard

Sample Location: Room 209 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000528		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-60A**

Collection Date: **7/13/2016 3:40:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17019

Collectors Name: Roger Moulard

Sample Location: Room 211 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00417		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-61A**

Collection Date: **7/13/2016 3:41:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17042

Collectors Name: Roger Moulard

Sample Location: Room 213 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00796		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-62A**

Collection Date: **7/13/2016 3:42:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17035

Collectors Name: Roger Moulard

Sample Location: Room 210 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000631		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-63A**

Collection Date: **7/13/2016 3:43:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17040

Collectors Name: Roger Moulard

Sample Location: Room 212 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000736		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-64A**

Collection Date: **7/13/2016 3:44:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17036

Collectors Name: Roger Moulard

Sample Location: Room 214 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000303		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-65A**

Collection Date: **7/13/2016 3:25:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17071

Collectors Name: Roger Moulard

Sample Location: Room 215 SK B

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00280		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-66A**

Collection Date: **7/13/2016 3:26:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17073

Collectors Name: Roger Moulard

Sample Location: Room 215 SK C

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00408		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-67A**

Collection Date: **7/13/2016 3:28:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17039

Collectors Name: Roger Moulard

Sample Location: Room 215 SK D

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00154		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-68A**

Collection Date: **7/13/2016 3:28:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17025

Collectors Name: Roger Moulard

Sample Location: Room 215 SK E

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00224		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-69A**

Collection Date: **7/13/2016 3:29:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17061

Collectors Name: Roger Moulard

Sample Location: Room 215 SK F

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00309		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-70A**

Collection Date: **7/13/2016 3:29:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17026

Collectors Name: Roger Moulard

Sample Location: Room 215 SK G

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00179		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-71A**

Collection Date: **7/13/2016 3:31:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17038

Collectors Name: Roger Moulard

Sample Location: Room 229 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000607		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-72A**

Collection Date: **7/13/2016 3:33:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17028

Collectors Name: Roger Moulard

Sample Location: Room 230 DF N

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000653		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-73A**

Collection Date: **7/13/2016 3:33:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17037

Collectors Name: Roger Moulard

Sample Location: Room 230 DF S

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000574		0.000103	mg/L	0.020 AL	7/24/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave

Medford, OR 97501

Lab Order: **1607523**

NRC Sample ID: **1607523-74A**

Collection Date: **7/13/2016 3:36:00 PM**

Received Date: **7/13/2016 4:11:00 PM**

Reported Date: **7/29/2016 6:54:53 AM**

Sample Information:

16-08 McLouglin Lead Study

Client Sample ID: Bottle #17041

Collectors Name: Roger Moulard

Sample Location: Hall 230 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0109		0.0001	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation
DATA FLAGS

B	Analyte detected in the associated method blank.
BA	BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
C	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF	Results confirmed by re-analysis.
CU	Cleanup performed as specified by method.
D1	The diesel elution pattern for the sample is not typical.
D2	The sample appears to be a heavier hydrocarbon range than diesel.
D3	The sample appears to be a lighter hydrocarbon range than diesel.
D4	Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
D5	Detected hydrocarbons in the diesel range appear to be weathered diesel.
E	Estimated value.
ER	Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC	Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
G1	The gasoline elution pattern for the sample is not typical.
G2	The sample appears to be a heavier hydrocarbon range than gasoline.
G3	The sample appears to be a lighter hydrocarbon range than gasoline.
G4	Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
HP	Sample re-analysis performed outside of method specified holding time.
HR	Sample received outside of method specified holding time.
HS	Sample analyzed for volatile organics contained headspace.
HT	At the client's request, the sample was analyzed outside of method specified holding time.
H	Analysis performed outside of method specified holding time.
J	Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
MI	Surrogate or Matrix Spike recovery is out of control limits due to matrix interference. Sample results may be biased.
N	See Case Narrative on page 2 of report.
Q	Closing continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R	Relative percent difference (RPD) is outside of the accepted recovery limits.
R1	Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
R3	The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4	Duplicate analysis failed due to result being at or near method reporting limit.
S	Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1	Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC	Sub-contracted to another laboratory for analysis.
SP	Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
T	Toxicity Characteristic Leaching Procedure – Sample submitted contained < 0.5% solids. If the waste contains <0.5% dry solids, the liquid portion of the waste, after filtration, is defined as the TCLP extract.
#	Value exceeds regulatory level for TCLP contaminant.
X1	The motor oil elution pattern for the sample is not typical.
X2	The sample appears to be a heavier hydrocarbon range than motor oil.
X3	The sample appears to be a lighter hydrocarbon range than motor oil.
*	Value exceeds Maximum Contaminant Level or is outside the acceptable range.

NRC SOP QA-1104/AD-3100
Revision 3
Effective Date: 6/3/16

CLIENT: Medford School District
Work Order: 1607523
Project: 16-08 McLouglin Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	MB-35887	SampType:	MBLK	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88649		
Client ID:	ZZZZZ	Batch ID:	35887	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/21/2016	SeqNo:	1329451		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID	MB-35886	SampType:	MBLK	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88649		
Client ID:	ZZZZZ	Batch ID:	35886	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/21/2016	SeqNo:	1329473		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID	MB-35888	SampType:	MBLK	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88658		
Client ID:	ZZZZZ	Batch ID:	35888	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/22/2016	SeqNo:	1329904		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper ND 0.000500

Lead ND 0.000100

Sample ID	MB-35906	SampType:	MBLK	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687		
Client ID:	ZZZZZ	Batch ID:	35906	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330729		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID	MB-35907	SampType:	MBLK	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687		
Client ID:	ZZZZZ	Batch ID:	35907	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330757		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Qualifiers: E Value above quantitation range
ND Not Detected at the Minimum Reporting Limit

H Holding times for preparation or analysis exceeded
R RPD outside accepted recovery limits

J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1607523
Project: 16-08 McLouglin Lead Study

ANALYTICAL QC SUMMARY REPORT**TestCode: ICPMS_200.8_SCHOOL**

Sample ID	MB-35908	SampType:	MBLK	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687		
Client ID:	ZZZZZ	Batch ID:	35908	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330783		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID	MB-35935	SampType:	MBLK	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/25/2016	RunNo:	88716			
Client ID:	ZZZZZ	Batch ID:	35935	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/25/2016	SeqNo:	1331621			
Analyte		Result		MRL	SPK value	SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper ND 0.000500
Lead ND 0.000100

Sample ID	LCS-35887	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88649			
Client ID:	ZZZZZ	Batch ID:	35887	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/21/2016	SeqNo:	1329452			
Analyte		Result		MRL	SPK value	SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09845 0.000104 0.1 0 98.4 85 115

Sample ID	LCS-35886	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88649		
Client ID:	ZZZZZ	Batch ID:	35886	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/21/2016	SeqNo:	1329474		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09592 0.000104 0.1 0 95.9 85 115

Sample ID	LCS-35888	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88658			
Client ID:	ZZZZZ	Batch ID:	35888	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/22/2016	SeqNo:	1329905			
Analyte		Result		MRL	SPK value	SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper 0.09565 0.000500 0.1 0.00004246 95.6 85 115
Lead 0.09240 0.000100 0.1 0 92.4 85 115

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1607523
Project: 16-08 McLouglin Lead Study

ANALYTICAL QC SUMMARY REPORT**TestCode: ICPMS_200.8_SCHOOL**

Sample ID	LCS-35906	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687			
Client ID:	ZZZZZ	Batch ID:	35906	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330730			
Analyte		Result		MRL	SPK value	SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09702		0.000104	0.1	0		97.0	85	115				

Sample ID	LCS-35907	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687			
Client ID:	ZZZZZ	Batch ID:	35907	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330758			
Analyte		Result		MRL	SPK value	SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09687		0.000104	0.1	0		96.9	85	115				

Sample ID	LCS-35908	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687			
Client ID:	ZZZZZ	Batch ID:	35908	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330784			
Analyte		Result		MRL	SPK value	SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09689		0.000104	0.1	0		96.9	85	115				

Sample ID	LCS-35935	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/25/2016	RunNo:	88716			
Client ID:	ZZZZZ	Batch ID:	35935	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/25/2016	SeqNo:	1331622			
Analyte		Result		MRL	SPK value	SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper		0.09411		0.000500	0.1	0		94.1	85	115				
Lead		0.09171		0.000100	0.1	0		91.7	85	115				

Sample ID	1607523-24AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88649			
Client ID:	Bottle #17021	Batch ID:	35887	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/21/2016	SeqNo:	1329469			
Analyte		Result		MRL	SPK value	SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.1077		0.000104	0.1	0.01152		96.2	70	130				

Qualifiers: E Value above quantitation range
 ND Not Detected at the Minimum Reporting Limit

H Holding times for preparation or analysis exceeded
 R RPD outside accepted recovery limits

J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1607523
Project: 16-08 McLoughlin Lead Study

ANALYTICAL QC SUMMARY REPORT**TestCode: ICPMS_200.8_SCHOOL**

Sample ID	1607523-04AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88649		
Client ID:	Bottle #11384	Batch ID:	35886	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/21/2016	SeqNo:	1329488		
Analyte		Result	MRL	SPK value	SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.1195	0.000104	0.1	0.02483		94.7	70	130				

Sample ID	1607523-20AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88658	
Client ID:	Bottle #11246	Batch ID:	35888	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/22/2016	SeqNo:	1329926	
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.1434	0.000100	0.1	0.05212	91.3	70	130				

Sample ID	1607523-20AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88658		
Client ID:	Bottle #11246	Batch ID:	35888	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/22/2016	SeqNo:	1329935		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper		2.000		0.00500	0.1	1.93	70.0	70	130				

Sample ID	1607523-20AMSD	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88658		
Client ID:	Bottle #11246	Batch ID:	35888	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/22/2016	SeqNo:	1329936		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper		2.047		0.00500	0.1	1.93	117	70	130	2	2.32	0	

Sample ID	1607523-44AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687	
Client ID:	Bottle #17058	Batch ID:	35906	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330753	
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09612	0.000104	0.1	0.0008078	95.3	70	130				

Qualifiers: E Value above quantitation range
 ND Not Detected at the Minimum Reporting Limit

H Holding times for preparation or analysis exceeded
 R RPD outside accepted recovery limits

J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1607523
Project: 16-08 McLouglin Lead Study

ANALYTICAL QC SUMMARY REPORT**TestCode: ICPMS_200.8_SCHOOL**

Sample ID	1607523-64AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687		
Client ID:	Bottle #17036	Batch ID:	35907	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330779		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09470		0.000104	0.1	0.0003033	94.4	70	130				

Sample ID	1607615-02AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687	
Client ID:	ZZZZZ	Batch ID:	35908	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330799	
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09554	0.000104	0.1	0.001621	93.9	70	130				

Sample ID	1607780-38AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/25/2016	RunNo:	88716	
Client ID:	ZZZZZ	Batch ID:	35935	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/25/2016	SeqNo:	1331633	
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper		0.4626	0.000500	0.1	0.355	108	70	130				
Lead		0.1162	0.000100	0.1	0.02521	91.0	70	130				

Sample ID	1607523-24AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88649	
Client ID:	Bottle #17021	Batch ID:	35887	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/21/2016	SeqNo:	1329470	
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.1067	0.000104	0.1	0.01152	95.2	70	130	0.1077	0.970	20	

Sample ID	1607523-04AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88649		
Client ID:	Bottle #11384	Batch ID:	35886	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/21/2016	SeqNo:	1329489		
Analyte		Result		MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.1202		0.000104	0.1	0.02483	95.4	70	130	0.1195	0.607	20	

Qualifiers: E Value above quantitation range
 ND Not Detected at the Minimum Reporting Limit

H Holding times for preparation or analysis exceeded
 R RPD outside accepted recovery limits

J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1607523
Project: 16-08 McLouglin Lead Study

ANALYTICAL QC SUMMARY REPORT**TestCode: ICPMS_200.8_SCHOOL**

Sample ID	1607523-20AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/21/2016	RunNo:	88658	
Client ID:	Bottle #11246	Batch ID:	35888	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/22/2016	SeqNo:	1329927	
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.1492	0.000100	0.1	0.05212	97.1	70	130	0.1434	3.96	20	

Sample ID	1607523-44AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687	
Client ID:	Bottle #17058	Batch ID:	35906	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330754	
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09752	0.000104	0.1	0.0008078	96.7	70	130	0.09612	1.45	20	

Sample ID	1607523-64AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687	
Client ID:	Bottle #17036	Batch ID:	35907	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330780	
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09676	0.000104	0.1	0.0003033	96.5	70	130	0.0947	2.15	20	

Sample ID	1607615-02AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/22/2016	RunNo:	88687	
Client ID:	ZZZZZ	Batch ID:	35908	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/24/2016	SeqNo:	1330800	
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		0.09634	0.000104	0.1	0.001621	94.7	70	130	0.09554	0.824	20	

Sample ID	1607780-38AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/25/2016	RunNo:	88716	
Client ID:	ZZZZZ	Batch ID:	35935	TestNo:	EPA 200.8	(EPA 200.8)		Analysis Date:	7/25/2016	SeqNo:	1331634	
Analyte		Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper		0.4871	0.000500	0.1	0.355	132	70	130	0.4626	5.16	20	MI
Lead		0.1198	0.000100	0.1	0.02521	94.6	70	130	0.1162	3.05	20	

Qualifiers: E Value above quantitation range
 ND Not Detected at the Minimum Reporting Limit

H Holding times for preparation or analysis exceeded
 R RPD outside accepted recovery limits

J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits



Environmental Testing Laboratory
245 South Grape Street • Medford, OR 97501
(541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company Medford School District 549C
Address: 815 S. Oakdale,
Medford, Or, 97501
Email: rick.rose@medford.k12.or.us
Phone: 541.842.1138 Fax: 541.842.1160
Collected By (Print): Rick Rose
Collected By (Sign): [Signature]
Email Report ☒ Yes ☐ No Mail Report ☒ Yes ☐ No
Fax Report ☐ Yes ☒ No

Section B

Required Project Information

Project Name: 2016 Lead testing
Project Number: 16-08 McLoughlin
Report To: rick.rose@medford.k12.or.us
Copy To: ron.hayne@medford.k12.or.us

Section C

Invoice Information

Attention: Accounting
Company Name: Medford School
Address: 815 S. Oakdale
Medford, Or, 97501
P.O. # P112894

Section D

Rush Status (Subject to Scheduling)

Standard 10-14 Days
5 Business Days (50% surcharge)
3 Business Days (75% surcharge)
24 - 48 hours (100% surcharge)
Other _____
Authorized ☐ Yes ☒ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix	Date Collected	Time Collected	No. of Containers	Analyte Requested	NRC Workorder # (ask use only)	NRC Sample # (ask use only)
Off S. Oakdale DF (100%)	11271		7/13/16	1:55pm	1		16017533	
Off S. Oakdale DF (100%)	11269							
Rm 106 DF	11274			1:57pm	1			
Rm 107 DF	11384			2:00pm	1			
Rm 108 DF	11282			2:05pm	1			
Rm 105 DF	11298			2:18pm	1			
Rm 104 DF	11290			2:21pm	1			
Off. Stock Zone Ice Machine	11285			2:01pm	1			
Off. Stock Rm - Sink	11280			2:24pm	1			
Rm 103 DF (R-N Well)	11272			2:28pm	1			

Section F
Relinquished/Receive
Matrix: DW - Drinking Water NWW - Wastewater WJ - Water S - Soil/Solid SL - Sludge O - Oil WP - Waste OT - Other

Relinquished By:	Sign	Print	Date	Time
Received By:	[Signature]	John Rose	7/13/16	4:11pm
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:				

Section G

Lab Use Only

Temp: 112.1°C
4°C +/- 2°C: Yes No
Received on Ice: Yes No
Number of Bottles Received: 1
PH Checked: Yes No
COC Seal Intact: Yes No NA
Field Blank Included: Yes No
Received Via: UPS FedEx Other Hand
Payment: Invoice Cash VISA, MC Check # Amount



Environmental Testing Laboratory
245 South Grape Street • Medford, OR 97501
(541) 770-5678 Fax (541) 770-2901

Chain of Custody Record


Page 2 of 9

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A		Section B		Section C		Section D	
Required Client Information		Required Project Information		Invoice Information		Rush Status (Subject to Scheduling)	
Company: Medford School District 549C		Project Name: 2016 Lead testing		Attention: Accounting		Standard 10-14 Days	
Address: 815 S. Oakdale, Medford, Or, 97501		Project Number: 16-08 McLoughlin		Company Name: Medford School		5 Business Days (50% surcharge)	
Email: rick.rose@medford.k12.or.us		Report To: rick.rose@medford.k12.or.us		Address: 815 S. Oakdale Medford, Or, 97501		3 Business Days (75% surcharge)	
Phone: 541.842.1138 Fax 541.842.1160		Copy To: ronhavier@medford.k12.or.us		P.O. # P112894		24 - 48 hours (100% surcharge)	
Collected By (Print): <i>John Jessen</i>						Other	
Collected By (Sign): <i>[Signature]</i>						Authorized: Yes ___ No ___	
Email Report: X Yes ___ No ___							
Fax Report: ___ Yes ___ No ___							

Section E		Section F		Section G	
Sample Information		Relinquish/Receive		Lab Use Only	
Sample ID	Comparison	Matrix	Date Collected	Time Collected	No. of Containers
Outside A-HL Stn - 246 DF-41	11263		7/13/16	3:26 PM	1
Outside A-HL Stn 246 DF-1(R)	11288			3:28 PM	1
Outside A-HL Stn 246 DF-1(R)	11289			3:21 PM	1
Black Gun DF	11300			3:45 PM	1
Weathered Km-DF	11266			3:16 PM	1
Gold Gun DF	11249			3:06 PM	1
Gold DF	11278			2:10 PM	1
Get Shack Zone - Stn	11297			2:13 PM	1
Stn. Food Rep Stn (S. Wall)	11261			1:50 PM	1
Kitchen Food Rep Stn (W. Wall)	11246			1:48 PM	1
Matrix: DW - Drinking Water WM - Wastewater W - Water S - Solid Solid SL - Sludge O - Oil WP - Wipe OT - Other					
Relinquished By: <i>[Signature]</i>		Sign: <i>John Jessen</i>		Date: 7/13/16 Time: 4:17 PM	
Received By:					
Relinquished By:					
Received By:					
Relinquished By:					
Received By Laboratory:					

Section G	
Temp.	
Temp. +/- 2°C	Yes ___ No ___
Received on Ice	Yes ___ No ___
Number of Bottles Received	
pH Checked:	
GOC Swabs Initialed	Yes ___ No ___ NA
Field Blank Included	Yes ___ No ___
Received Via: UPS ___ FedEx ___ Other ___	
Payment: Invoice ___ Cash ___ VISA/MC ___ Check # ___	Amount: ___



Mac

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 3 of 9Section D
Rush Status (Subject to Scheduling)

Company: Medford School District 549C		Project Name: 2016 Lead testing		Attention: Accounting		☐ Standard 10-14 Days ☐ 5 Business Days (50% surcharge) ☐ 3 Business Days (75% surcharge) ☐ 24 - 48 hours (100% surcharge) ☐ Other _____	
Address: 815 S. Oakdale		Project Number: 16-08 McLoughlin		Company Name: Medford School			
Medford, Or, 97501		Report To: rick.rose@medford.k12.or.us		Address: 815 S.Oakdale			
Email: rick.rose@medford.k12.or.us		Copy To: ron.havmick@medford.k12.or.us		Medford, Or, 97501			
Phone: 541.842.1138 Fax 541.842.1160		P.O. # P112894					
Collected By (Print): <i>Donna Rose</i>							
Collected By (Sign): <i>[Signature]</i>							
Email Report ☒ Yes ☐ No		Mail Report ☒ Yes ☐ No					
Fax Report ☐ Yes ☐ No							
				Analysis Requested ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐			
				Authorized ☐ Yes ☐ No			

25116#

[illegible]

Print

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:	<i>[Signature]</i>	<i>John Doe</i>	7/13/16	4:11pm
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Received By Laboratory:	<i>[Signature]</i>	<i>Dennis New</i>	7/13/16	11:11

Section G
Lab Use Only

Temp:	4°C +/-. 2°C: <u> </u> Yes <u> </u> No
Received on Ice:	<u> </u> Yes <u> </u> No
Number of Bottles Received:	<u> </u>
pH Checked:	<u> </u>
COC Seals Intact:	<u> </u> Yes <u> </u> No <u> </u> NA
Field Blank Included:	<u> </u> Yes <u> </u> No
Received Via	UPS <u> </u> FedEx <u> </u> Other <u> </u> Hand
Payment:	Invoice <u> </u> Cash <u> </u> VISA <u> </u> M/C <u> </u> Check # <u> </u> Amount <u> </u>



Environmental Testing Laboratory
245 South Grape Street • Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

Page 4 of 9

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: Medford School District 549C	Project Name: 2016 Lead testing	Attention: Accounting	Standard 10-14 Days				
Address: 815 S. Oakdale,	Project Number: 16-08 McLoughlin	Company Name: Medford School	5 Business Days (50% surcharge)				
Medford, Or. 97501	Report To: rick.rose@medford.k12.or.us	Address: 815 S. Oakdale	3 Business Days (75% surcharge)				
Email: rick.rose@medford.k12.or.us	Copy To: ron.havmear@medford.k12.or.us	P.O. # P112894	24 - 48 hours (100% surcharge)				
Phone: 541.842.1138 Fax 541.842.1160			Other				
Collected By (Print): Gary Severe			Authorized Yes No				
Collected By (Sign): <i>[Signature]</i>							
Email Report Yes No Mail Report Yes No							
Fax Report Yes No							

Section E Sample Information		Section F Matrix		Section G Lab Use Only	
Sample ID	Completion	Date Collected	Time Collected	No. of Containers	Remarks/Field Data
RM 201 - DF	17041	7/13/16	3:02 PM	1	1607533
RM 203 - DF	17043			1	
RM 205 - DF	17046			1	
RM 206 - DF	19460			1	
RM 207 - DF	17049			1	
RM 208 - DF	17047			1	
Media CR - DF	19458			1	

Section F Relinquish/Receive		Section G Lab Use Only	
Sign	Date	Temp:	Remarks/Field Data
Relinquished By: <i>[Signature]</i>	7/13/16	3:19 PM	
Received By: <i>[Signature]</i>	7/13/16	3:19 PM	
Relinquished By: <i>[Signature]</i>	7/13/16	4:11 PM	
Received By: <i>[Signature]</i>	7/13/16		
Relinquished By: <i>[Signature]</i>	7/13/16		
Received By: <i>[Signature]</i>	7/13/16		

Section G Lab Use Only	
Temp: 4°C +/- 2°C: Yes No	Received on Ice: Yes No
Number of Bottles Received:	pH Checked:
COC Seals Intact: Yes No NA	Fold Blank Included: Yes No
Received Via: UPS FedEX Other Hand	Payment: Invoice Cash VISA M/C Check # Amount



Environmental Testing Laboratory
248 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

Page 2 of 2

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company	Medford School District 549C
Address:	815 S. Oakdale, Medford, Or, 97501
Email:	rick.rose@medford.k12.or.us
Phone:	541.842.1138 Fax 541.842.1160
Collected By (Print):	Ron Severe
Collected By (Sign):	<i>Ron Severe</i>
Email Report	☒ Yes ☐ No
Fax Report	☐ Yes ☐ No

Section B

Required Project Information

Project Name:	2016 Lead testing
Project Number:	16-08 McLoughlin
Report To:	rick.rose@medford.k12.or.us
Copy To:	ron.havinear@medford.k12.or.us

Section C

Invoice Information

Attention:	Accounting
Company Name:	Medford School
Address:	815 S. Oakdale Medford, Or, 97501
P.O. #	P112894

Section D

Rush Status (Subject to Scheduling)

Standard 10-14 Days	☐
5 Business Days (50% surcharge)	☐
3 Business Days (75% surcharge)	☐
24 - 48 hours (100% surcharge)	☐
Other	☐
Authorized	☐ Yes ☐ No

Section E

Sample Information

Sample ID	Containers	Matrix	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
RM 201 Storage RM - DF	170663		7/13/16	2:43 PM	1		16075233	32
RM 110 - DF	170910			2:44	1			33
outside RM 221 - DF	170615			2:46	1			34
RM 223 (ceramics) - DF North Island	170945			2:48	1			35
RM 224 DF (concrete/wall-left)	170946			2:50	1			36
RM 231 DF (left - west wall)	170942			2:52	1			37
RM 232 DF (Right - west wall)	170957			2:54	1			38
RM 200 DF	170618			2:56	1			39
RM 202 DF	19459			2:57	1			40
RM 204 DF	19463			3:00	1			41

Section F

Relinquish/Receive

Relinquish/Receive	Sign	Date	Time
Received By: <i>Ron Severe</i>	<i>Ron Severe</i>	7/13/16	3:19 PM
Relinquished By: <i>Ron Severe</i>	<i>Ron Severe</i>	7/13/16	3:19 PM
Received By:		7/13/16	4:11 PM
Relinquished By:			
Received By Laboratory: <i>Denise Del</i>		7/12/16	16:11

Section G

Lab Use Only

Temp:	
4°C +/- 2°C:	☐ Yes ☐ No
Received on ice:	☐ Yes ☐ No
Number of Bottles Received:	
pH Checked:	
COC Seals Intact:	☐ Yes ☐ No ☐ NA
Field Blank Included:	☐ Yes ☐ No
Received Via:	UPS ☐ FedEx ☐ Other ☐ Hand
Payment:	Invoice ☐ Cash ☐ VISA ☐ M/C ☐ Check # ☐ Amount ☐



Environmental Testing Laboratory
245 South Grape Street • Medford, OR 97501
(541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

Page 1 of 2

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company:	Medford School District 549C	Project Name:	2016 Lead testing	Attention:	Accounting	Standard 10-14 Days	
Address:	815 S. Oakdale, Medford, Or, 97501	Project Number:	16-08 McLoughlin	Company Name:	Medford School	5 Business Days (50% surcharge)	
Email:	rick.rose@medford.k12.or.us	Report To:	rick.rose@medford.k12.or.us	Address:	815 S. Oakdale Medford, Or, 97501	3 Business Days (75% surcharge)	
Phone:	541.842.1138 Fax 541.842.1160	Copy To:	ron.havtreat@medford.k12.or.us	P.O. #	P112894	24 - 48 hours (100% surcharge)	
Collected By (Print):	Gary Severe					Other _____	
Collected By (Sign):	<i>Gary Severe</i>					Authorized _____ Yes _____ No _____	
Email Report ☒ Yes ☐ No	Mail Report ☒ Yes ☐ No						
Fax Report ☐ Yes ☐ No							

Section E Sample Information			Section F Relinquish/Receive		Section G Lab Use Only	
Sample ID	Comp/Grab	Matrix	Date Collected	Time Collected	No. of Containers	Analysis Requested
RM 111 - DF	17098		7/13/16		1	
RM 112 - DF	17099				1	
RM 113 - DF	17094				1	
RM 114 - DF	17094				1	
RM 115 - DF	17094				1	
RM 116 - DF	17094				1	
RM 117 - DF	17094				1	
RM 118 - DF	17094				1	
RM 119 - DF	17094				1	
RM 120 - DF	17094				1	
RM 121 - DF	17094				1	
RM 122 - DF	17094				1	
RM 123 - DF	17094				1	
RM 124 - DF	17094				1	
RM 125 - DF	17094				1	
RM 126 - DF	17094				1	
RM 127 - DF	17094				1	
RM 128 - DF	17094				1	
RM 129 - DF	17094				1	
RM 130 - DF	17094				1	
RM 131 - DF	17094				1	
RM 132 - DF	17094				1	
RM 133 - DF	17094				1	
RM 134 - DF	17094				1	
RM 135 - DF	17094				1	
RM 136 - DF	17094				1	
RM 137 - DF	17094				1	
RM 138 - DF	17094				1	
RM 139 - DF	17094				1	
RM 140 - DF	17094				1	
RM 141 - DF	17094				1	
RM 142 - DF	17094				1	
RM 143 - DF	17094				1	
RM 144 - DF	17094				1	
RM 145 - DF	17094				1	
RM 146 - DF	17094				1	
RM 147 - DF	17094				1	
RM 148 - DF	17094				1	
RM 149 - DF	17094				1	
RM 150 - DF	17094				1	
RM 151 - DF	17094				1	
RM 152 - DF	17094				1	
RM 153 - DF	17094				1	
RM 154 - DF	17094				1	
RM 155 - DF	17094				1	
RM 156 - DF	17094				1	
RM 157 - DF	17094				1	
RM 158 - DF	17094				1	
RM 159 - DF	17094				1	
RM 160 - DF	17094				1	
RM 161 - DF	17094				1	
RM 162 - DF	17094				1	
RM 163 - DF	17094				1	
RM 164 - DF	17094				1	
RM 165 - DF	17094				1	
RM 166 - DF	17094				1	
RM 167 - DF	17094				1	
RM 168 - DF	17094				1	
RM 169 - DF	17094				1	
RM 170 - DF	17094				1	
RM 171 - DF	17094				1	
RM 172 - DF	17094				1	
RM 173 - DF	17094				1	
RM 174 - DF	17094				1	
RM 175 - DF	17094				1	
RM 176 - DF	17094				1	
RM 177 - DF	17094				1	
RM 178 - DF	17094				1	
RM 179 - DF	17094				1	
RM 180 - DF	17094				1	
RM 181 - DF	17094				1	
RM 182 - DF	17094				1	
RM 183 - DF	17094				1	
RM 184 - DF	17094				1	
RM 185 - DF	17094				1	
RM 186 - DF	17094				1	
RM 187 - DF	17094				1	
RM 188 - DF	17094				1	
RM 189 - DF	17094				1	
RM 190 - DF	17094				1	
RM 191 - DF	17094				1	
RM 192 - DF	17094				1	
RM 193 - DF	17094				1	
RM 194 - DF	17094				1	
RM 195 - DF	17094				1	
RM 196 - DF	17094				1	
RM 197 - DF	17094				1	
RM 198 - DF	17094				1	
RM 199 - DF	17094				1	
RM 200 - DF	17094				1	
RM 201 - DF	17094				1	
RM 202 - DF	17094				1	
RM 203 - DF	17094				1	
RM 204 - DF	17094				1	
RM 205 - DF	17094				1	
RM 206 - DF	17094				1	
RM 207 - DF	17094				1	
RM 208 - DF	17094				1	
RM 209 - DF	17094				1	
RM 210 - DF	17094				1	
RM 211 - DF	17094				1	
RM 212 - DF	17094				1	
RM 213 - DF	17094				1	
RM 214 - DF	17094				1	
RM 215 - DF	17094				1	
RM 216 - DF	17094				1	
RM 217 - DF	17094				1	
RM 218 - DF	17094				1	
RM 219 - DF	17094				1	
RM 220 - DF	17094				1	
RM 221 - DF	17094				1	
RM 222 - DF	17094				1	
RM 223 - DF	17094				1	
RM 224 - DF	17094				1	
RM 225 - DF	17094				1	
RM 226 - DF	17094				1	
RM 227 - DF	17094				1	
RM 228 - DF	17094				1	
RM 229 - DF	17094				1	
RM 230 - DF	17094				1	
RM 231 - DF	17094				1	
RM 232 - DF	17094				1	
RM 233 - DF	17094				1	
RM 234 - DF	17094				1	
RM 235 - DF	17094				1	
RM 236 - DF	17094				1	
RM 237 - DF	17094				1	
RM 238 - DF	17094				1	
RM 239 - DF	17094				1	
RM 240 - DF	17094				1	
RM 241 - DF	17094				1	
RM 242 - DF	17094				1	
RM 243 - DF	17094				1	
RM 244 - DF	17094				1	
RM 245 - DF	17094				1	
RM 246 - DF	17094				1	
RM 247 - DF	17094				1	
RM 248 - DF	17094				1	
RM 249 - DF	17094				1	
RM 250 - DF	17094				1	
RM 251 - DF	17094				1	
RM 252 - DF	17094				1	
RM 253 - DF	17094				1	
RM 254 - DF	17094				1	
RM 255 - DF	17094				1	
RM 256 - DF	17094				1	
RM 257 - DF	17094				1	
RM 258 - DF	17094				1	
RM 259 - DF	17094				1	
RM 260 - DF	17094				1	
RM 261 - DF	17094				1	
RM 262 - DF	17094				1	
RM 263 - DF	17094				1	
RM 264 - DF	17094				1	
RM 265 - DF	17094				1	
RM 266 - DF	17094				1	
RM 267 - DF	17094				1	
RM 268 - DF	17094				1	
RM 269 - DF	17094				1	
RM 270 - DF	17094				1	
RM 271 - DF	17094				1	
RM 272 - DF	17094				1	
RM 273 - DF	17094				1	
RM 274 - DF	17094				1	
RM 275 - DF	17094				1	
RM 276 - DF	17094				1	
RM 277 - DF	17094				1	
RM 278 - DF	17094				1	
RM 279 - DF	17094				1	
RM 280 - DF	17094				1	
RM 281 - DF	17094				1	
RM 282 - DF	17094				1	
RM 283 - DF	17094				1	
RM 284 - DF	17094				1	
RM 285 - DF	17094				1	
RM 286 - DF	17094				1	
RM 287 - DF	17094				1	
RM 288 - DF	17094				1	
RM 289 - DF	17094				1	
RM 290 - DF	17094				1	
RM 291 - DF	17094				1	
RM 292 - DF	17094				1	
RM 293 - DF	17094				1	
RM 294 - DF	17094				1	
RM 295 - DF	17094				1	
RM 296 - DF	17094				1	
RM 297 - DF	17094				1	
RM 298 - DF	17094				1	
RM 299 - DF	17094				1	
RM 300 - DF	17094				1	
RM 301 - DF	17094				1	
RM 302 - DF	17094				1	
RM 303 - DF	17094				1	
RM 304 - DF	17094				1	
RM 305 - DF	17094				1	
RM 306 - DF	17094				1	
RM 307 - DF	17094				1	
RM 308 - DF	17094				1	
RM 309 - DF	17094				1	
RM 310 - DF	17094				1	
RM 311 - DF	17094				1	
RM 312 - DF	17094				1	
RM 313 - DF	17094				1	
RM 314 - DF	17094				1	
RM 315 - DF	17094				1	
RM 316 - DF	17094				1	
RM 317 - DF	17094				1	
RM 318 - DF	17094				1	
RM 319 - DF	17094				1	
RM 320 - DF	17094				1	
RM 321 - DF	17094				1	
RM 322 - DF	17094				1	
RM 323 - DF	17094				1	
RM 324 - DF	17094				1	
RM 325 - DF	17094				1	
RM 326 - DF	17094				1	
RM 327 - DF	17094				1	
RM 328 - DF	17094				1	
RM 329 - DF	17094				1	
RM 330 - DF	17094				1	
RM 331 - DF	17094				1	
RM 332 - DF	17094				1	
RM 333 - DF	17094				1	
RM 334 - DF	17094				1	
RM 335 - DF	17094				1	
RM 336 - DF	17094				1	
RM 337 - DF	17094				1	
RM 338 - DF	17094				1	
RM 339 - DF	17094				1	
RM 340 - DF	17094				1	
RM 341 - DF	17094				1	
RM 342 - DF	17094				1	
RM 343 - DF	17094				1	
RM 344 - DF	17094				1	
RM 345 - DF	17094				1	



**NEILSON
RESEARCH
CORPORATION**
Environmental Testing Laboratory
245 South Grape Street • Medford, OR 97501
(541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 1 of 9

Section A

Required Client Information

Company:	Medford School District 549C
Address:	815 S. Oakdale, Medford, Or, 97501
Email:	rick.rose@medford.k12.or.us
Phone:	541.842.1138 Fax 541.842.1150
Collected By (Print):	<i>Roger Mowland</i>
Collected By (Sign):	<i>[Signature]</i>
Email Report ☒ Yes ☐ No	Mail Report ☒ Yes ☐ No
Fax Report ☐ Yes ☐ No	

Section B

Required Project Information

Project Name:	2016 Lead testing
Project Number:	16-08 McLoughlin
Report To:	rick.rose@medford.k12.or.us
Copy To:	ron.havneer@medford.k12.or.us
Attention:	Accounting
Company Name:	Medford School
Address:	815 S. Oakdale Medford, Or, 97501
P.O. #	P112894

Section C

Invoice Information

Standard 10-14 Days	
5 Business Days (50% surcharge)	
3 Business Days (75% surcharge)	
24 - 48 hours (100% surcharge)	
Other	
Authorized ☐ Yes ☐ No	

Section D

Sample Information

Sample ID	Comp/Cont	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
2208 DF	17050		7/13/16	3:13 PM	1		1607533	49
2204 DF	17051			3:14	1			50
225 DF	17048			3:16	1			51
226 DF	17044			3:17	1			52
227 DF	17043			3:18	1			53
217 DF	17048			3:20	1			54
218 DF	17053			3:21	1			55
216 DF	17056			3:22	1			56
215 SK B	17066			3:24	1			57
215 DF B	17069			3:25	1			58

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section E

Sign

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:	<i>[Signature]</i>	<i>Roger Mowland</i>	7-13-16	3:50 PM
Received By:	<i>[Signature]</i>	<i>John Jensen</i>	7/13/16	3:50 PM
Relinquished By:	<i>[Signature]</i>	<i>John Jensen</i>	7/13/16	4:11 PM
Received By:				
Relinquished By:				
Received By Laboratory:	<i>Denise Reed</i>	<i>Denise Reed</i>	7/13/16	10:11

Section F

Lab Use Only

Temp:	
4°C +/- 2°C	☐ Yes ☐ No
Received on Ice	☐ Yes ☐ No
Number of Bottles Received:	
pH Checked:	
COC Seals Intact:	☐ Yes ☐ No ☐ NA
Field Blank Included:	☐ Yes ☐ No

Received Via	UPS	FedEX	Other	Hand
Payment:	Invoice	Cash	VISA, M/C	Check #
Amount:				



Neilson
RESEARCH
CORPORATION
Environmental Testing Laboratory
245 South Grape Street • Medford, OR 97501
(541) 770-5678 fax (541) 770-2900

Mac

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company:	Medford School District 549C
Address:	815 S. Oakdale, Medford, Or. 97501
Email:	rick.rose@medford.k12.or.us
Phone:	541.842.1138 Fax 541.842.1160
Collected By (Print):	Rogers, Michael B
Collected By (Sign):	<i>[Signature]</i>
Email Report ☒ Yes ☐ No	Mail Report ☒ Yes ☐ No
Fax Report ☐ Yes ☐ No	

Section B

Required Project Information

Project Name:	2016 Lead testing
Project Number:	16-08 McLoughlin
Report To:	rick.rose@medford.k12.or.us
Copy To:	tom.havincat@medford.k12.or.us

Section C

Invoice Information

Attention:	Accounting
Company Name:	Medford School
Address:	815 S. Oakdale Medford, Or. 97501
P.O. #	P112894

Section D

Rush Status (Subject to Scheduling)

☐ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
Other ☐
Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix	Date Collected	Time Collected	No. of Containers	Analysis Requested
209 DF	17015		7/13/16	3:34 PM	1	
211	17019		7/13/16	3:41	1	
213	17042		7/13/16	3:42	1	
210	17035		7/13/16	3:43	1	
212	17040		7/13/16	3:44	1	
214	17036		7/13/16	3:44	1	

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	<i>[Signature]</i>	Print	Date	Time
Received By:	<i>[Signature]</i>	Rogers, Michael B	7/13/16	3:50 PM
Relinquished By:	<i>[Signature]</i>	John Jensen	7/13/16	4:11 PM
Received By:	<i>[Signature]</i>			
Relinquished By:	<i>[Signature]</i>			
Received By:	<i>[Signature]</i>			
Received By Laboratory:	<i>[Signature]</i>	DeVise Head	7/13/16	16:12

Section G

Lab Use Only

Temp: <i>AMEN</i>	
4°C +/- 2°C: ☐ Yes ☒ No	
Received on Ice: ☐ Yes ☒ No	
Number of Bottles Received: <i>14</i>	
pH Checked: ☐	
COC Seals Intact: ☐ Yes ☒ No	
Field Blank Included: ☐ Yes ☒ No	

Payment:	Invoice	Cash	VISA	M/C	Check	#	Amount
Received Via:	UPS	FedEx	Other	Hand			



Environmental Testing Laboratory
245 South Grape Street • Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

Page 9 of 9

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information			Section B Required Project Information			Section C Invoice Information			Section D Rush Status (Subject to Scheduling)		
Company:	Medford School District 549C	Project Name:	2016 Lead testing	Attention:	Accounting	Standard 10-14 Days					
Address:	815 S. Oakdale,	Project Number:	16-08 McLoughlin	Company Name:	Medford School	5 Business Days (50% surcharge)					
	Medford, Or. 97501	Report To:	rick.rose@medford.k12.or.us	Address:	815 S. Oakdale	3 Business Days (75% surcharge)					
Email:	rick.rose@medford.k12.or.us	Copy To:	ron.havthear@medford.k12.or.us	P.O. #	P112894	24 - 48 hours (100% surcharge)					
Phone:	541.842.1138 Fax 541.842.1160										
Collected By (Print):	Rick Rose										
Collected By (Sign):											
Email Report	X Yes ___ No	Main Report	X Yes ___ No								
Fax Report	___ Yes ___ No										
Authorized: ___ Yes ___ No											

Section E Sample Information				Analysis Requested				NRC Workorder #		NRC Sample #	
Sample ID	Completion	Matrix	Date Collected	Time Collected	No. of Containers					Remarks/Field Data	(Lab Use Only)
LM 215 SK B	17071		7/13/16	3:25 PM	1						1601533
	17073			3:26	1						160
	17039			3:27	1						161
	17025			3:28	1						162
	17061			3:29	1						163
	17026			3:29	1						164
229 DE	17038			3:31	1						165
230 DE N	17028			3:33	1						166
270 DE S	17037			3:33	1						167
270 DE	17041			3:34	1						168

Section F Relinquish/Receive			Section G Lab Use Only		
Relinquished By	Sign	Date	Temp:	4°C +/- 2°C	Yes ___ No ___
Received By:		7-13-16	7:50 AM		
Relinquished By:		7/13/16	3:50 PM		
Received By:		7/13/16	4:11 PM		
Relinquished By:					
Received By Laboratory		7/13/16	16:11		

Section H Payment			
Payment:	Invoice	Cash	Check #