

Central High School						
Lead Tests - Central High School - # 20482000						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20482000-001BF	20482000-001BF21A	Room 1101 - Restroom - Sink	10/7/2020	Passed with 0.00307	None.
2	20482000-002CF	20482000-002CF21A	Room 1102 - Sink	10/5/2020	Passed with 0.000111	None.
3	20482000-003DW	20482000-003DW21A	Room 1102 - Drinking Fountain	8/19/2020	Passed with 0.00747	None.
4	20482000-004CF	20482000-004CF21A	Room 1103 - Sink	10/5/2020	Passed with None Detected	None.
5	20482000-005DW	20482000-005DW21A	Room 1103 - Drinking Fountain	8/19/2020	Passed with 0.00218	None.
6	20482000-006CF	20482000-006CF21A	Room 1104 - Sink	10/5/2020	Passed with None Detected	None.
7	20482000-007DW	20482000-007DW21A	Room 1104 - Drinking Fountain	8/19/2020	Passed with 0.00103	None.
8	20482000-008OT	20482000-008OT21A	Room 1105 - Utility Sink	7/16/2021	Passed with 0.187 ppb	None.
9	20482000-009OT	20482000-009OT21A	Room 1105 - Coffee Machine	7/16/2021	Passed with 0.237 ppb	None.
10	20482000-010CF	20482000-010CF21A	Room 1107 - Sink	10/5/2020	Passed with None Detected	None.
11	20482000-011DW	20482000-011DW21A	Room 1107 - Drinking Fountain	8/19/2020	Passed with 0.000886	None.
12	20482000-012CF	20482000-012CF21A	Room 1108 - Sink	10/5/2020	Passed with None Detected	None.
13	20482000-013DW	20482000-013DW21A	Room 1108 - Drinking Fountain	8/19/2020	Passed with 0.000896	None.
14	20482000-014CF	20482000-014CF21A	Room 1109 - Sink	10/5/2020	Passed with None Detected	None.
15	20482000-015DW	20482000-015DW21A	Room 1109 - Drinking Fountain	8/19/2020	Passed with 0.000790	None.
16	20482000-016CF	20482000-016CF21A	Room 1110 - Sink	10/5/2020	Passed with None Detected	None.
17	20482000-017DW	20482000-017DW21A	Room 1110 - Drinking Fountain	8/19/2020	Passed with 0.000413	None.
18	20482000-018CF	20482000-018CF21A	Room 1111 - Sink	8/19/2020	Passed with 0.00181	None.
19	20482000-019DW	20482000-019DW21A	Room 1111 - Drinking Fountain	8/19/2020	Passed with 0.00102	None.
20	20482000-020CF	20482000-020CF21A	Room 1112 - Sink	8/19/2020	Passed with 0.00108	None.
21	20482000-021DW	20482000-021DW21A	Room 1112 - Drinking Fountain	8/19/2020	Passed with 0.00145	None.
22	20482000-022CF	20482000-022CF21A	Room 1113 - Sink	8/19/2020	Passed with 0.00249	None.
23	20482000-023DW	20482000-023DW21A	Room 1113 - Drinking Fountain	8/19/2020	Passed with 0.00163	None.
24	20482000-024CF	20482000-024CF21A	Room 1114 - Sink	8/19/2020	Passed with 0.0111	None.
25	20482000-025CF	20482000-025CF21A	Room 1118 - Sink	8/19/2020	Passed with 0.0108	None.
26	20482000-026DW	20482000-026DW21A	Room 1118 - Drinking Fountain	8/19/2020	Passed with 0.00936	None.
27	20482000-027CF	20482000-027CF21A	Room 1119 - Sink	10/5/2020	Passed with 0.000122	None.
28	20482000-028DW	20482000-028DW21A	Room 1119 - Drinking Fountain	8/19/2020	Passed with 0.00712	None.
29	20482000-029CF	20482000-029CF21A	Room 1120 - Sink	8/19/2020	Passed with 0.0110	None.
30	20482000-030CF	20482000-030CF21A	Room 1121 - Sink	8/19/2020	Passed with 0.00535	None.
31	20482000-031BF	20482000-031BF21A	Room 1121 - Unisex Restroom- Sink	8/19/2020	Passed with 0.00345	None.
32	20482000-032CF	20482000-032CF21A	Room 1122 - Sink	10/5/2020	Passed with 0.000148	None.
33	20482000-033DW	20482000-033DW21A	Room 1122 - Drinking Fountain	8/19/2020	Passed with 0.00625	None.
34	20482000-034CF	20482000-034CF21A	Room 1123 - Sink	10/5/2020	Passed with 0.000135	None.
35	20482000-035DW	20482000-035DW21A	Room 1123 - Drinking Fountain	10/5/2020	Passed with 0.000378	None.
36	20482000-036CF	20482000-036CF21A	Room 1124 - Sink	8/19/2020	Passed with 0.00791	None.
37	20482000-037DW	20482000-037DW21A	Room 1124 - Drinking Fountain	8/19/2020	Passed with 0.00651	None.
38	20482000-038OT	20482000-038OT21A	Room 1125 - Southeast Corner Room - Sink	8/19/2020	Passed with 0.00243	None.
Lead Tests - Central High School - # 20482001						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20482001-001BF	20482001-001BF21 A	Women's Restroom - Hand Wash Sink (Left)	8/19/2020	Passed with 0.00594	None.
2	20482001-002BF	20482001-002BF21A	Woman's Restroom - Hand Wash Sink (Right)	8/19/2020	Passed with 0.0106	None.
3	20482001-003BF	20482001-003BF21A	Men's Restroom - Hand Wash Sink (Left)	8/19/2020	Passed with 0.00700	None.
4	20482001-004BF	20482001-004BF21A	Men's Restroom - Hand Wash Sink (Right)	8/19/2020	Passed with 0.0103	None.

\*None Detected (ND) = .005 Or Less

	=
	=

\*The E.P.A. action level for lead in schools is 0.020. Oregon's action level for schools is 0.015 (Changed in 2019 in accordance with OAR 333-061-0400).

\*The E.P.A. action level for copper is 1.30

\*Lead test results will be posted on the MSD/Facilities website within 5 days.