



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

June 03, 2019

Andy Chasteen
Medford School District
815 S Oakdale Ave
Medford, OR 97501
TEL: 541-842-3646
FAX: 541-842-1160

RE: 18-01 North 2019 Lead Testing

Order No.: 19050350

Dear Andy Chasteen:

Neilson Research Corporation received 89 sample(s) on 5/8/2019 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Senior Project Manager
245 S Grape St
Medford, OR 97501



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 19050350
Date: 6/3/2019

CLIENT: Medford School District
Project: 18-01 North 2019 Lead Testing

WorkOrder Narrative:

19050350: The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analytical Comments for Test ICPMS_200.8_DW, Analytical RunNo 1328, Batch ID 614:

Sample 19050350-89AMS: The matrix spike is out of control limits due to equipment spiking issues during the sample preparation. The sample results are not affected.

Sample 19050350-89AMSD: The matrix spike duplicate relative percent difference (RPD) is out of control limits due to equipment spiking issues during the sample preparation. The sample results are not affected.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-01 **Client Sample ID:** Near Main Gym Lobby Mens RR-Sink L
Collection Date: 5/8/2019 5:40:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Near Main Gym Lobby Mens RR-Sink L

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000787		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-02 **Client Sample ID:** Near Main Gym Lobby Mens RR-Sink C
Collection Date: 5/8/2019 5:40:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Near Main Gym Lobby Mens RR-Sink C

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00122		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-03 **Client Sample ID:** Near Main Gym Lobby Mens RR-Sink R
Collection Date: 5/8/2019 5:40:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Near Main Gym Lobby Mens RR-Sink R

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00226		0.000103	mg/L	1	5/24/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-04 **Client Sample ID:** Near Main Gym Lobby Womens RR-Sink L
Collection Date: 5/8/2019 5:42:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Near Main Gym Lobby Womens RR-Sink L

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00243		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-05 **Client Sample ID:** Near Main Gym Lobby Womens RR-Sink C
Collection Date: 5/8/2019 5:42:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Near Main Gym Lobby Womens RR-Sink C

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00135		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-06 **Client Sample ID:** Near Main Gym Lobby Womens RR-Sink R
Collection Date: 5/8/2019 5:42:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Near Main Gym Lobby Womens RR-Sink R

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000957		0.000103	mg/L	1	5/24/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-07 **Client Sample ID:** Girls Locker Room-Sink RR
Collection Date: 5/8/2019 6:09:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Girls Locker Room-Sink RR

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0372	*	0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-08 **Client Sample ID:** Girls Locker Room-Coachs RR Sink
Collection Date: 5/8/2019 6:10:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Girls Locker Room-Coachs RR Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0228	*	0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-09 **Client Sample ID:** Girls Locker Room-Coachs RR Shower
Collection Date: 5/8/2019 6:10:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Girls Locker Room-Coachs RR Shower

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.279	*	0.000206	mg/L	2	5/28/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-10 **Client Sample ID:** Boys Locker Room-Sink L
Collection Date: 5/8/2019 5:50:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Boys Locker Room-Sink L

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00473		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-11 **Client Sample ID:** Boys Locker Room-Sink R
Collection Date: 5/8/2019 5:50:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Boys Locker Room-Sink R

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00411		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-12 **Client Sample ID:** Boys Locker Room-Coachs RR Sink
Collection Date: 5/8/2019 5:55:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Boys Locker Room-Coachs RR Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00279		0.000103	mg/L	1	5/24/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-13 **Client Sample ID:** Boys Locker Room-Coachs RR Shower
Collection Date: 5/8/2019 5:55:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Boys Locker Room-Coachs RR Shower

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00100		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-14 **Client Sample ID:** Commons Mens RR-Sink L
Collection Date: 5/8/2019 6:22:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Commons Mens RR-Sink L

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000927		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-15 **Client Sample ID:** Commons Mens RR-Sink C
Collection Date: 5/8/2019 6:23:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Commons Mens RR-Sink C

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000530		0.000103	mg/L	1	5/24/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-16 **Client Sample ID:** Commons Mens RR-Sink R
Collection Date: 5/8/2019 6:24:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Commons Mens RR-Sink R

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000762		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-17 **Client Sample ID:** Commons Womens RR-Sink L
Collection Date: 5/8/2019 6:27:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Commons Womens RR-Sink L

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00135		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-18 **Client Sample ID:** Commons Womens RR-Sink C
Collection Date: 5/8/2019 6:28:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Commons Womens RR-Sink C

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00101		0.000103	mg/L	1	5/24/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-19 **Client Sample ID:** Commons Womens RR-Sink R
Collection Date: 5/8/2019 6:29:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Commons Womens RR-Sink R

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000582		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-20 **Client Sample ID:** Media Center Staff Unisex RR-Sink
Collection Date: 5/8/2019 6:28:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Media Center Staff Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000972		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-21 **Client Sample ID:** Media Center Work Room-Sink
Collection Date: 5/8/2019 6:29:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Media Center Work Room-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000724		0.000103	mg/L	1	5/24/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-22 **Client Sample ID:** Baseball Field Mens RR-Sink
Collection Date: 5/8/2019 6:35:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Baseball Field Mens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00378		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-23 **Client Sample ID:** Baseball Field Womens RR-Sink
Collection Date: 5/8/2019 6:35:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Baseball Field Womens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00478		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-24 **Client Sample ID:** Near Track Unisex RR SW-Sink
Collection Date: 5/8/2019 6:17:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Near Track Unisex RR SW-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00405		0.000103	mg/L	1	5/24/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-25 **Client Sample ID:** Near Track Unisex RR NW-Sink
Collection Date: 5/8/2019 6:18:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Near Track Unisex RR NW-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00289		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-26 **Client Sample ID:** Near Track Training Rm Spa In It-Sink Utility
Collection Date: 5/8/2019 6:20:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Near Track Training Rm Spa In It-Sink Utility

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0438	*	0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-27 **Client Sample ID:** Near Track Mens RR SE-Sink
Collection Date: 5/8/2019 6:22:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Near Track Mens RR SE-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00546		0.000103	mg/L	1	5/24/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-28 **Client Sample ID:** Near Track Mens RR NE-Sink
Collection Date: 5/8/2019 6:24:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Near Track Mens RR NE-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00364		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-29 **Client Sample ID:** Trainers Room-Sink
Collection Date: 5/8/2019 5:53:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Trainers Room-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000830		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-30 **Client Sample ID:** Boys Locker Rm Coaches Lounge-Sink
Collection Date: 5/8/2019 5:57:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Boys Locker Rm Coaches Lounge-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0309	*	0.000100	mg/L	1	5/25/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-31 **Client Sample ID:** By Football Office Unisex RR-Sink
Collection Date: 5/8/2019 5:58:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** By Football Office Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00389		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-32 **Client Sample ID:** FA Lobby Mens RR-Sink L
Collection Date: 5/8/2019 5:22:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA Lobby Mens RR-Sink L

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000818		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-33 **Client Sample ID:** FA Lobby Mens RR-Sink R
Collection Date: 5/8/2019 5:22:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA Lobby Mens RR-Sink R

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000417		0.000103	mg/L	1	5/24/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-34 **Client Sample ID:** FA Lobby Womens RR-Sink L
Collection Date: 5/8/2019 5:24:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA Lobby Womens RR-Sink L

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000948		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-35 **Client Sample ID:** FA Lobby Womens RR-Sink R
Collection Date: 5/8/2019 5:24:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA Lobby Womens RR-Sink R

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000423		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-36 **Client Sample ID:** FA Lobby Unisex RR-Sink
Collection Date: 5/8/2019 5:25:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA Lobby Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00216		0.000103	mg/L	1	5/24/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-37 **Client Sample ID:** Computer Rm Outside FA-3-Sink
Collection Date: 5/8/2019 5:30:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Computer Rm Outside FA-3-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0133		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-38 **Client Sample ID:** Outside FA-3 Unisex RR-Sink
Collection Date: 5/8/2019 5:34:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Outside FA-3 Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00535		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-39 **Client Sample ID:** FA-5-Sink South Wall
Collection Date: 5/8/2019 5:43:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-5-Sink South Wall

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00132		0.000103	mg/L	1	5/24/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-40 **Client Sample ID:** FA-5-Sink North Wall
Collection Date: 5/8/2019 5:44:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-5-Sink North Wall

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00106		0.000103	mg/L	1	5/24/2019	0.0150	A

Lab ID: 19050350-41 **Client Sample ID:** FA-5 North Wall Trough Sink Fixture 1
Collection Date: 5/8/2019 6:10:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-5 North Wall Trough Sink Fixture 1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0354	*	0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-42 **Client Sample ID:** FA-5 North Wall Trough Sink Fixture 2
Collection Date: 5/8/2019 6:10:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-5 North Wall Trough Sink Fixture 2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0310	*	0.000103	mg/L	1	5/29/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-43 **Client Sample ID:** FA-5 North Wall Trough Sink Fixture 3
Collection Date: 5/8/2019 6:10:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-5 North Wall Trough Sink Fixture 3

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.113	*	0.000100	mg/L	1	5/25/2019	0.0150	A	

Lab ID: 19050350-44 **Client Sample ID:** FA-5 North Wall Trough Sink Fixture 4
Collection Date: 5/8/2019 6:09:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-5 North Wall Trough Sink Fixture 4

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0396	*	0.000103	mg/L	1	5/29/2019	0.0150	A	

Lab ID: 19050350-45 **Client Sample ID:** FA-5 North Wall Trough Sink Fixture 5
Collection Date: 5/8/2019 6:09:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-5 North Wall Trough Sink Fixture 5

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.268	*	0.000206	mg/L	2	5/30/2019	0.0150	A	

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-46 **Client Sample ID:** FA-5 North Wall Trough Sink Fixture 6
Collection Date: 5/8/2019 6:09:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-5 North Wall Trough Sink Fixture 6

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.733	*	0.00100	mg/L	10	5/28/2019	0.0150	A

Lab ID: 19050350-47 **Client Sample ID:** FA-5 Kiln Area-Sink Left Fixture
Collection Date: 5/8/2019 5:44:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-5 Kiln Area-Sink Left Fixture

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000896		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-48 **Client Sample ID:** FA-5 Kiln Area-Sink Right Fixture
Collection Date: 5/8/2019 5:44:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-5 Kiln Area-Sink Right Fixture

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00272		0.000103	mg/L	1	5/29/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-49 **Client Sample ID:** FA-6-Island Sink 1
Collection Date: 5/8/2019 5:49:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-6-Island Sink 1

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00186		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-50 **Client Sample ID:** FA-6-Island Sink 2
Collection Date: 5/8/2019 5:49:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-6-Island Sink 2

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000730		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-51 **Client Sample ID:** FA-6-Island Sink 3
Collection Date: 5/8/2019 5:50:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-6-Island Sink 3

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000655		0.000103	mg/L	1	5/29/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-52 **Client Sample ID:** FA-6-Island Sink 4
Collection Date: 5/8/2019 5:50:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-6-Island Sink 4

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00168		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-53 **Client Sample ID:** FA-6-Sink South Wall
Collection Date: 5/8/2019 5:49:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-6-Sink South Wall

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00689		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-54 **Client Sample ID:** FA-7 Entrance Mens RR-Sink
Collection Date: 5/8/2019 6:16:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-7 Entrance Mens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0113		0.000103	mg/L	1	5/29/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-55 **Client Sample ID:** FA-7 Entrance Womens RR-Sink
Collection Date: 5/8/2019 6:18:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-7 Entrance Womens RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00287		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-56 **Client Sample ID:** FA-8-Sink
Collection Date: 5/8/2019 6:22:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA-8-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00664		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-57 **Client Sample ID:** FA Outside Dressing Rooms-Paint Sink
Collection Date: 5/8/2019 6:25:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA Outside Dressing Rooms-Paint Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0199	*	0.000103	mg/L	1	5/29/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-58 **Client Sample ID:** FA Girls Dressing Room-Sink
Collection Date: 5/8/2019 6:27:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA Girls Dressing Room-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0284	*	0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-59 **Client Sample ID:** FA Girls Dressing Room RR-Sink
Collection Date: 5/8/2019 6:27:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA Girls Dressing Room RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00116		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-60 **Client Sample ID:** FA Boys Dressing Room-Sink
Collection Date: 5/8/2019 6:29:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA Boys Dressing Room-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00279		0.000103	mg/L	1	5/29/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-61 **Client Sample ID:** FA Boys Dressing Room RR-Sink
Collection Date: 5/8/2019 6:29:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** FA Boys Dressing Room RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00264		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-62 **Client Sample ID:** Outside H-9 Womens RR-Sink
Collection Date: 5/8/2019 5:23:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Outside H-9 Womens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000405		0.000100	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-63 **Client Sample ID:** Outside H-4 Mens RR-Sink
Collection Date: 5/8/2019 5:28:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Outside H-4 Mens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00151		0.000103	mg/L	1	5/29/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-64 **Client Sample ID:** Across From H-38 Mens RR-Sink 1
Collection Date: 5/8/2019 5:33:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Mens RR-Sink 1

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00259		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-65 **Client Sample ID:** Across From H-38 Mens RR-Sink 2
Collection Date: 5/8/2019 5:33:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Mens RR-Sink 2

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000391		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-66 **Client Sample ID:** Across From H-38 Mens RR-Sink 3
Collection Date: 5/8/2019 5:34:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Mens RR-Sink 3

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000537		0.000103	mg/L	1	5/29/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-67 **Client Sample ID:** Across From H-38 Mens RR-Sink 4
Collection Date: 5/8/2019 5:35:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Mens RR-Sink 4

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000620		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-68 **Client Sample ID:** Across From H-38 Mens RR-Sink 5
Collection Date: 5/8/2019 5:36:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Mens RR-Sink 5

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00108		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-69 **Client Sample ID:** Across From H-38 Mens RR-Sink 6
Collection Date: 5/8/2019 5:37:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Mens RR-Sink 6

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00495		0.000103	mg/L	1	5/29/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-70 **Client Sample ID:** Across From H-38 Mens RR-Sink 7
Collection Date: 5/8/2019 5:38:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Mens RR-Sink 7

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00114		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-71 **Client Sample ID:** Across From H-38 Mens RR-Sink 8
Collection Date: 5/8/2019 5:39:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Mens RR-Sink 8

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000877		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-72 **Client Sample ID:** Across From H-38 Womens RR-Sink 1
Collection Date: 5/8/2019 5:39:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Womens RR-Sink 1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000304		0.000103	mg/L	1	5/29/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-73 **Client Sample ID:** Across From H-38 Womens RR-Sink 2
Collection Date: 5/8/2019 5:41:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Womens RR-Sink 2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000342		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-74 **Client Sample ID:** Across From H-38 Womens RR-Sink 3
Collection Date: 5/8/2019 5:42:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Womens RR-Sink 3

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00114		0.000103	mg/L	1	5/29/2019	0.0150	A

Lab ID: 19050350-75 **Client Sample ID:** Across From H-38 Womens RR-Sink 4
Collection Date: 5/8/2019 5:43:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Womens RR-Sink 4

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000581		0.000103	mg/L	1	5/30/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-76 **Client Sample ID:** Across From H-38 Womens RR-Sink 5
Collection Date: 5/8/2019 5:43:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Womens RR-Sink 5

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00117		0.000103	mg/L	1	5/30/2019	0.0150	A

Lab ID: 19050350-77 **Client Sample ID:** Across From H-38 Womens RR-Sink 6
Collection Date: 5/8/2019 5:44:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Womens RR-Sink 6

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000434		0.000103	mg/L	1	5/30/2019	0.0150	A

Lab ID: 19050350-78 **Client Sample ID:** Across From H-38 Womens RR-Sink 7
Collection Date: 5/8/2019 5:44:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Womens RR-Sink 7

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000413		0.000103	mg/L	1	5/30/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-79 **Client Sample ID:** Across From H-38 Womens RR-Sink 8
Collection Date: 5/8/2019 5:45:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From H-38 Womens RR-Sink 8

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000294		0.000103	mg/L	1	5/30/2019	0.0150	A

Lab ID: 19050350-80 **Client Sample ID:** HC-6 Handwash-Sink
Collection Date: 5/8/2019 5:56:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** HC-6 Handwash-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00161		0.000103	mg/L	1	5/30/2019	0.0150	A

Lab ID: 19050350-81 **Client Sample ID:** HC-5-Sink
Collection Date: 5/8/2019 5:58:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** HC-5-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0116		0.000103	mg/L	1	5/30/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-82 **Client Sample ID:** HC Womans RR-Sink C
Collection Date: 5/8/2019 6:00:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** HC Womans RR-Sink C

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000458		0.000100	mg/L	1	5/30/2019	0.0150	A

Lab ID: 19050350-83 **Client Sample ID:** HC Womens RR-Sink R
Collection Date: 5/8/2019 6:00:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** HC Womens RR-Sink R

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00195		0.000103	mg/L	1	5/25/2019	0.0150	A

Lab ID: 19050350-84 **Client Sample ID:** HC Mens RR-Sink 1
Collection Date: 5/8/2019 6:04:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** HC Mens RR-Sink 1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.000103	mg/L	1	5/25/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-85 **Client Sample ID:** HC Mens RR-Sink 2
Collection Date: 5/8/2019 6:04:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** HC Mens RR-Sink 2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.000103	mg/L	1	5/25/2019	0.0150	A

Lab ID: 19050350-86 **Client Sample ID:** HC Mens RR-Sink 3
Collection Date: 5/8/2019 6:05:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** HC Mens RR-Sink 3

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.000103	mg/L	1	5/25/2019	0.0150	A

Lab ID: 19050350-87 **Client Sample ID:** HC Mens RR-Sink 4
Collection Date: 5/8/2019 6:05:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** HC Mens RR-Sink 4

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.000103	mg/L	1	5/25/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 19050350

Date Reported: 6/3/2019

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 19050350
Received Date: 5/8/2019 1:22:00 PM
Reported Date: 6/3/2019 3:17:53 PM

Sample Information:

Lab ID: 19050350-88 **Client Sample ID:** HC-3-Sink
Collection Date: 5/8/2019 6:09:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** HC-3-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00129		0.000103	mg/L	1	5/25/2019	0.0150	A

Lab ID: 19050350-89 **Client Sample ID:** HC Staff RR-Sink
Collection Date: 5/8/2019 6:10:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** HC Staff RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000163	N	0.000103	mg/L	1	5/25/2019	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 19050350
03-Jun-19

Client: Medford School District
Project: 18-01 North 2019 Lead Testing

TestCode: ICPMS_200.8_DW

Sample ID: MB-599	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1324
Client ID: PBW	Batch ID: 599	TestNo: E200.8	E200.8	Analysis Date: 5/24/2019	SeqNo: 24540
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.000103

Sample ID: LCS-599	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1324
Client ID: LCSW	Batch ID: 599	TestNo: E200.8	E200.8	Analysis Date: 5/24/2019	SeqNo: 24541
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.102 0.000104 0.1000 0 102 85 115

Sample ID: 19050350-20AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1324
Client ID: Media Center Staff U	Batch ID: 599	TestNo: E200.8	E200.8	Analysis Date: 5/24/2019	SeqNo: 24564
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.105 0.000104 0.1000 0.0009723 104 70 130

Sample ID: 19050350-20AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1324
Client ID: Media Center Staff U	Batch ID: 599	TestNo: E200.8	E200.8	Analysis Date: 5/24/2019	SeqNo: 24565
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.104 0.000104 0.1000 0.0009723 103 70 130 0.1053 1.13 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.	B Analyte detected in the associated Method Blank	C1 Sample container temperature is out of limit as s
E Value above quantitation range	H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix In
ND Not Detected at the Reporting Limit	PL Permit Limit	RL Reporting Detection Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 19050350
03-Jun-19

Client: Medford School District
Project: 18-01 North 2019 Lead Testing

TestCode: ICPMS_200.8_DW

Sample ID: MB-603	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1324
Client ID: PBW	Batch ID: 603	TestNo: E200.8	E200.8	Analysis Date: 5/24/2019	SeqNo: 24568
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.000103

Sample ID: LCS-603	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1324
Client ID: LCSW	Batch ID: 603	TestNo: E200.8	E200.8	Analysis Date: 5/24/2019	SeqNo: 24569
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.103 0.000104 0.1000 0 103 85 115

Sample ID: MB-608	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1324
Client ID: PBW	Batch ID: 608	TestNo: E200.8	E200.8	Analysis Date: 5/24/2019	SeqNo: 24595
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.000103

Sample ID: 19050350-40AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1328
Client ID: FA-5-Sink North Wall	Batch ID: 603	TestNo: E200.8	E200.8	Analysis Date: 5/25/2019	SeqNo: 24673
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.0995 0.000103 0.1000 0.001063 98.4 70 130

Qualifiers:

* Value exceeds Maximum Contaminant Level.	B Analyte detected in the associated Method Blank	C1 Sample container temperature is out of limit as s
E Value above quantitation range	H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix In
ND Not Detected at the Reporting Limit	PL Permit Limit	RL Reporting Detection Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 19050350
03-Jun-19

Client: Medford School District
Project: 18-01 North 2019 Lead Testing

TestCode: ICPMS_200.8_DW

Sample ID: 19050350-40AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1328						
Client ID: FA-5-Sink North Wall	Batch ID: 603	TestNo: E200.8	E200.8	Analysis Date: 5/25/2019	SeqNo: 24674						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.102	0.000104	0.1000	0.001063	101	70	130	0.09946	2.95	20	

Sample ID: MB-606	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1328						
Client ID: PBW	Batch ID: 606	TestNo: E200.8	E200.8	Analysis Date: 5/25/2019	SeqNo: 24677						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000100									

Sample ID: LCS-606	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1328						
Client ID: LCSW	Batch ID: 606	TestNo: E200.8	E200.8	Analysis Date: 5/25/2019	SeqNo: 24678						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.102	0.000100	0.1000	0	102	85	115				

Sample ID: 19050951-01AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1328						
Client ID: BatchQC	Batch ID: 606	TestNo: E200.8	E200.8	Analysis Date: 5/25/2019	SeqNo: 24696						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.100	0.000100	0.1000	0	100	70	130				

Qualifiers:
* Value exceeds Maximum Contaminant Level.
E Value above quantitation range
ND Not Detected at the Reporting Limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
PL Permit Limit

C1 Sample container temperature is out of limit as s
MI Recovery outside control limits due to Matrix In
RL Reporting Detection Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 19050350
03-Jun-19

Client: Medford School District
Project: 18-01 North 2019 Lead Testing

TestCode: ICPMS_200.8_DW

Sample ID: 19050951-01AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1328						
Client ID: BatchQC	Batch ID: 606	TestNo: E200.8	E200.8	Analysis Date: 5/25/2019	SeqNo: 24697						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.132	0.000100	0.1000	0	132	70	130	0.1000	27.6	20	N

Sample ID: MB-614	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1328						
Client ID: PBW	Batch ID: 614	TestNo: E200.8	E200.8	Analysis Date: 5/25/2019	SeqNo: 24714						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000103									

Sample ID: LCS-614	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1328						
Client ID: LCSW	Batch ID: 614	TestNo: E200.8	E200.8	Analysis Date: 5/25/2019	SeqNo: 24715						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.104	0.000104	0.1000	0	104	85	115				

Sample ID: 19050350-89AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1328						
Client ID: HC Staff RR-Sink	Batch ID: 614	TestNo: E200.8	E200.8	Analysis Date: 5/25/2019	SeqNo: 24723						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.137	0.000104	0.1000	0.0001627	137	70	130				N

Qualifiers: * Value exceeds Maximum Contaminant Level.
E Value above quantitation range
ND Not Detected at the Reporting Limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
PL Permit Limit

C1 Sample container temperature is out of limit as s
MI Recovery outside control limits due to Matrix In
RL Reporting Detection Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 19050350
03-Jun-19

Client: Medford School District
Project: 18-01 North 2019 Lead Testing

TestCode: ICPMS_200.8_DW

Sample ID: 19050350-89AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/24/2019	RunNo: 1328						
Client ID: HC Staff RR-Sink	Batch ID: 614	TestNo: E200.8	E200.8	Analysis Date: 5/25/2019	SeqNo: 24724						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.107	0.000104	0.1000	0.0001627	107	70	130	0.1371	24.5	20	N

Sample ID: MB-632	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/29/2019	RunNo: 1399						
Client ID: PBW	Batch ID: 632	TestNo: E200.8	E200.8	Analysis Date: 5/29/2019	SeqNo: 25844						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000103									

Sample ID: MB-638	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/29/2019	RunNo: 1399						
Client ID: PBW	Batch ID: 638	TestNo: E200.8	E200.8	Analysis Date: 5/29/2019	SeqNo: 25845						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000103									

Sample ID: LCS-632	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/29/2019	RunNo: 1399						
Client ID: LCSW	Batch ID: 632	TestNo: E200.8	E200.8	Analysis Date: 5/29/2019	SeqNo: 25846						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.102	0.000104	0.1000	0	102	85	115				

Qualifiers:

*	Value exceeds Maximum Contaminant Level.	B	Analyte detected in the associated Method Blank	C1	Sample container temperature is out of limit as s1
E	Value above quantitation range	H	Holding times for preparation or analysis exceeded	MI	Recovery outside control limits due to Matrix In
ND	Not Detected at the Reporting Limit	PL	Permit Limit	RL	Reporting Detection Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 19050350
03-Jun-19

Client: Medford School District
Project: 18-01 North 2019 Lead Testing

TestCode: ICPMS_200.8_DW

Sample ID: LCS-638	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/29/2019	RunNo: 1399						
Client ID: LCSW	Batch ID: 638	TestNo: E200.8	E200.8	Analysis Date: 5/29/2019	SeqNo: 25847						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.101	0.000104	0.1000	0	101	85	115				

Sample ID: 19050350-61AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/29/2019	RunNo: 1399						
Client ID: FA Boys Dressing R	Batch ID: 632	TestNo: E200.8	E200.8	Analysis Date: 5/29/2019	SeqNo: 26256						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.103	0.000103	0.1000	0.002665	100	70	130				

Sample ID: 19050350-61AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/29/2019	RunNo: 1399						
Client ID: FA Boys Dressing R	Batch ID: 632	TestNo: E200.8	E200.8	Analysis Date: 5/29/2019	SeqNo: 26257						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.104	0.000104	0.1000	0.002665	101	70	130	0.1028	0.724	20	

Sample ID: 19050350-81AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/29/2019	RunNo: 1399						
Client ID: HC-5-Sink	Batch ID: 638	TestNo: E200.8	E200.8	Analysis Date: 5/30/2019	SeqNo: 26282						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.112	0.000103	0.1000	0.01130	101	70	130				

Qualifiers: * Value exceeds Maximum Contaminant Level.
E Value above quantitation range
ND Not Detected at the Reporting Limit

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
PL Permit Limit

C1 Sample container temperature is out of limit as s
MI Recovery outside control limits due to Matrix In
RL Reporting Detection Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 19050350
03-Jun-19

Client: Medford School District
Project: 18-01 North 2019 Lead Testing

TestCode: ICPMS_200.8_DW

Sample ID: 19050350-81AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 5/29/2019	RunNo: 1399						
Client ID: HC-5-Sink	Batch ID: 638	TestNo: E200.8	E200.8	Analysis Date: 5/30/2019	SeqNo: 26283						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.117	0.000104	0.1000	0.01130	105	70	130	0.1120	4.16	20	

Qualifiers:

- * Value exceeds Maximum Contaminant Level.
- E Value above quantitation range
- ND Not Detected at the Reporting Limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- PL Permit Limit

- C1 Sample container temperature is out of limit as s
- MI Recovery outside control limits due to Matrix In
- RL Reporting Detection Limit

Original



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company:	MSD 549C
Address:	815 South Oakdale Avenue Medford, OR 97501
Email:	ron.havniar@medford.k12.or.us
Phone:	541-840-4315 Fax:
Collected By (Print):	
Collected By (Sign):	
Email Report ☐ Yes ☐ No	Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No	

Section B

Required Project Information

Project Name:	2019 Lead Testing
Project Number:	18-01 North
Report To	ron.havniar@medford.k12.or.us
Copy To	andy.chasteen@medford.k12.or.us

Section C

Invoice Information

Attention:	Accounting
Company Name:	Medford School District
Address:	815 South Oakdale Avenue Medford, OR 97501
P.O. #	61172

Section D

Rush Status (Subject to Scheduling)

☐ Standard 10-14 Days
☐ 5 Business Days (50% surcharge)
☐ 3 Business Days (75% surcharge)
☐ 24 - 48 hours (100% surcharge)
☐ Other

Authorized ☐ Yes ☐ No

Section E

Sample Information

Sample ID	Bottle #	Matrix*	Date Collected	Time Collected	No. of Containers
Near Main Gym Lobby Men's Restroom - Sink (Left)		DW	5/8/2019	5:40	1
Near Main Gym Lobby Men's Restroom - Sink (Center)		DW	5/8/2019	5:40	1
Near Main Gym Lobby Men's Restroom - Sink (Right)		DW	5/8/2019	5:40	1
Near Main Gym Lobby Women's Restroom - Sink (Left)		DW	5/8/2019	5:42	1
Near Main Gym Lobby Women's Restroom - Sink (Center)		DW	5/8/2019	5:42	1
Near Main Gym Lobby Women's Restroom - Sink (Right)		DW	5/8/2019	5:42	1
Girl's Locker Room - Sink (RR)		DW	5/8/2019	6:09	1
Girl's Locker Room - Coach's Rest Room - Sink		DW	5/8/2019	6:10	1
Girl's Locker Room - Coach's Rest Room - Shower		DW	5/8/2019	6:10	1
Boy's Locker Room - Sink (Left)		DW	5/8/2019	5:50	1
Boy's Locker Room - Sink (Right)		DW	5/8/2019	5:50	1
Boy's Locker Room - Coach's Rest Room - Sink		DW	5/8/2019	5:55	1
Boy's Locker Room - Coach's Rest Room - Shower		DW	5/8/2019	5:55	1
Common's Men's Restroom - Sink (Left)		DW	5/8/2019	6:22	1
Common's Men's Restroom - Sink (Center)		DW	5/8/2019	6:23	1
Common's Men's Restroom - Sink (Right)		DW	5/8/2019	6:24	1
Common's Women's Restroom - Sink (Left)		DW	5/8/2019	6:27	1
Common's Women's Restroom - Sink (Center)		DW	5/8/2019	6:28	1
Common's Women's Restroom - Sink (Right)		DW	5/8/2019	6:29	1
Media Center Staff Unisex Restroom - Sink		DW	5/8/2019	6:28	1
Media Center Work Room - Sink		DW	5/8/2019	6:29	1
Baseball Field - Men's Restroom - Sink		DW	5/8/2019	6:35	1
Baseball Field - Women's Restroom - Sink		DW	5/8/2019	6:35	1
Near Track Unisex Restroom (South West) - Sink		DW	5/8/2019	6:17	1
Near Track Unisex Restroom (North West) - Sink		DW	5/8/2019	6:18	1

NRC Workorder # 19050350

Remarks/Field Data

NRC Sample # (Lab Use Only)	01
	02
	03
	04
	05
	06
	07
	08
	09
	10
	11
	12
	13
	14
	15
	16
	17
	18
	19
	20
	21
	22
	23
	24
	25
	26
	27
	28
	29
	30



Chain of Custody Record

Environmental Testing Laboratory

245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Section A Required Client Information			Section B Required Project Information			Section C Invoice Information			Section D Rush Status (Subject to Scheduling)		
Company:	MSD 549C		Project Name:	2019 Lead Testing		Attention:	Accounting		☐ Standard 10-14 Days		
Address:	815 South Oakdale Avenue Medford, OR 97501		Project Number:	18-01 North		Company Name: Medford School District			☐ 5 Business Days (50% surcharge)		
Email:	ron.havniear@medford.k12.or.us		Report To:	ron.havniear@medford.k12.or.us		Address: 815 South Oakdale Avenue Medford, OR 97501			☐ 3 Business Days (75% surcharge)		
Phone:	541-840-4315 Fax:		Copy To:	andy.chasteen@medford.k12.or.us		P.O. # 61172			☐ 24 - 48 hours (100% surcharge)		
Collected By (Print):									☐ Other		
Collected By (Sign):									Authorized Yes No		
Email Report	Yes	No	Mail Report	Yes	No						
Fax Report	Yes	No									

Section E Sample Information				Analysis Requested										NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)	
Bottle #	Matrix*	Date Collected	Time Collected	No. of Containers										Remarks/Field Data		
FA - Lobby - Men's Restroom - Sink (Left)	DW	5/8/2019	5:22 AM	1												32
FA - Lobby - Men's Restroom - Sink (Right)	DW	5/8/2019	5:29 AM	1												33
FA - Lobby - Women's Restroom - Sink (Left)	DW	5/8/2019	5:29	1												34
FA - Lobby - Women's Restroom - Sink (Right)	DW	5/8/2019	5:29	1												35
FA - Lobby - Unisex Restroom - Sink	DW	5/8/2019	5:25	1												36
Computer Room Outside FA-3 - Sink	DW	5/8/2019	5:30	1												37
Computer Room Outside FA-3 - Spray Nozzle	DW	5/8/2019	5:37	1											0.8 Not Colored	
Outside FA-3 - Unisex Restroom - Sink	DW	5/8/2019	5:34	1												38
FA-4 - Sink (South Wall)	DW	5/8/2019	5:43	1												39
FA-5 - Sink (North Wall)	DW	5/8/2019	5:44	1												40
FA-5 - North Wall Trough Sink (Fixture 1)	DW	5/8/2019	6:10	1											These sink	41
FA-5 - North Wall Trough Sink (Fixture 2)	DW	5/8/2019	6:10	1											Did Not Have	42
FA-5 - North Wall Trough Sink (Fixture 3)	DW	5/8/2019	6:09	1											Handled &	43
FA-5 - North Wall Trough Sink (Fixture 4)	DW	5/8/2019	6:09	1											Place Pot Head	44
FA-5 - North Wall Trough Sink (Fixture 5)	DW	5/8/2019	6:09	1											Used in a	45
FA-5 - North Wall Trough Sink (Fixture 6)	DW	5/8/2019	6:09	1											Long Time	46
FA-5 - Kiln Area - Sink (Left Fixture)	DW	5/8/2019	5:44	1												47
FA-5 - Kiln Area - Sink (Right Fixture)	DW	5/8/2019	5:44	1												48
FA-6 - Island Sink (1)	DW	5/8/2019	5:49	1												49
FA-6 - Island Sink (2)	DW	5/8/2019	5:49	1												50
FA-6 - Island Sink (3)	DW	5/8/2019	5:49	1												51
FA-6 - Island Sink (4)	DW	5/8/2019	5:50	1												52
FA-6 - Island Sink (5)	DW	5/8/2019	5:50	1												53
FA-6 - Island Sink (6)	DW	5/8/2019	5:50	1												54
FA-6 - Island Sink (7)	DW	5/8/2019	5:50	1												55
FA-6 - Island Sink (8)	DW	5/8/2019	5:50	1												56
FA-6 - Island Sink (9)	DW	5/8/2019	5:50	1												



Page 1 of 3

Section A

Required Client Information

Company: MSD 549C

Address: 815 South Oakdale Avenue

Medford, OR 97501

Email: ron.haynjar@medford.k12.or.us

Phone: 541-840-4315 Fax:

Collected By (Print):

Collected By (Sian):

	Email Report	Yes	No	Mail Report	Yes	No
--	--------------	-----	----	-------------	-----	----

	Fax Report	Yes	No
--	------------	-----	----

Section E

Sample Information

Sample ID	Bottle #	Matrix*	Date Collected	Time Collected
Outside H-9 Women's Restroom - Sink	50104	DW	5/8/2019	0533
Between H-4/H-9 Unisex Restroom - Sink		DW	5/8/2019	
Outside H-4 Men's Restroom - Sink	60103	DW	5/8/2019	0538
Across From H-38 Men's Restroom - Sink (1)	50100	DW	5/8/2019	0533
Across From H-38 Men's Restroom - Sink (2)	50106	DW	5/8/2019	0533
Across From H-38 Men's Restroom - Sink (3)	50108	DW	5/8/2019	0534
Across From H-38 Men's Restroom - Sink (4)	50206	DW	5/8/2019	0535
Across From H-38 Men's Restroom - Sink (5)	50197	DW	5/8/2019	0538
Across From H-38 Men's Restroom - Sink (6)	50185	DW	5/8/2019	0537
Across From H-38 Men's Restroom - Sink (7)	50194	DW	5/8/2019	0538
Across From H-38 Men's Restroom - Sink (8)	50	DW	5/8/2019	0539
Across From H-38 Women's Restroom - Sink (1)		DW	5/8/2019	0541
Across From H-38 Women's Restroom - Sink (2)		DW	5/8/2019	0542
Across From H-38 Women's Restroom - Sink (3)		DW	5/8/2019	0543
Across From H-38 Women's Restroom - Sink (4)		DW	5/8/2019	0544
Across From H-38 Women's Restroom - Sink (5)		DW	5/8/2019	0543
Across From H-38 Women's Restroom - Sink (6)		DW	5/8/2019	0544
Across From H-38 Women's Restroom - Sink (7)		DW	5/8/2019	0545
Across From H-38 Women's Restroom - Sink (8)		DW	5/8/2019	0545
HC-6 - Hand Wash - Sink		DW	5/8/2019	0556
HC-5 - Sink		DW	5/8/2019	0558

[illegible]

NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
19050350		62
		63
		64
		65
		66
		67
		68
		69
		70
		71
		72
		73
		74
		75
		76
		77
		78
		79
		80
		81

HC women RL - sink center

[illegible]

-
- B Analyte detected in the associated method blank.
 - BA BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
 - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
 - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
 - CF Results confirmed by re-analysis.
 - CU Cleanup performed as specified by method.
 - D1 The diesel elution pattern for the sample is not typical.
 - D2 The sample appears to be a heavier hydrocarbon range than diesel.
 - D3 The sample appears to be a lighter hydrocarbon range than diesel.
 - D4 Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
 - D5 Detected hydrocarbons in the diesel range appear to be weathered diesel.
 - E Estimated value.
 - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
 - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
 - G1 The gasoline elution pattern for the sample is not typical.
 - G2 The sample appears to be a heavier hydrocarbon range than gasoline.
 - G3 The sample appears to be a lighter hydrocarbon range than gasoline.
 - G4 Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
 - HP Sample re-analysis performed outside of method specified holding time.
 - HR Sample received outside of method specified holding time.
 - HS Sample analyzed for volatile organics contained headspace.
 - HT ☐ At the client's request, the sample was analyzed outside of method specified holding time.
 - H Analysis performed outside of method specified holding time.
 - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
 - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
 - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
 - N See Case Narrative on page 2 of report.
 - NLR No Legionella Recovered.
 - PLR Presence of Legionella Recovered.
 - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
 - R Relative percent difference (RPD) is outside of the accepted recovery limits.
 - R1 Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
 - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
 - R4 Duplicate analysis failed due to result being at or near the method reporting limit.
 - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
 - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
 - SC Sub-contracted to another laboratory for analysis.
 - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
 - # Value exceeds regulatory level for TCLP contaminant.
 - X1 The motor oil elution pattern for the sample is not typical.
 - X2 The sample appears to be a heavier hydrocarbon range than motor oil.
 - X3 The sample appears to be a lighter hydrocarbon range than motor oil.
 - * Value exceeds Maximum Contaminant Level or is outside the acceptable range.