

South High School

Lead Tests - South High School - Main Building - # 20481600

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20481600-001BF	20481600-001BF23A	Main Office Staff Unisex Restroom - Sink	03/17/22	1.0	None.
2	20481600-002SF	20481600-002SF23A	Main Office Kitchenette - Sink	03/17/22	ND	None.
3	20481600-003BF	20481600-003BF23A	Health Room Restroom - Sink	03/17/22	1.0	None.
4	20481600-004DW	20481600-004DW23A	Across From Room A126 - Drinking Fountain (Upper)	03/17/22	ND	None.
5	20481600-005DW	20481600-005DW23A	Across From Room A126 - Drinking Fountain (Lower)	03/17/22	0.5	None.
6	20481600-006BF	20481600-006BF23A	Men's Restroom Room Across From A141 - Sink (Left)	03/17/22	2.9	None.
7	20481600-007BF	20481600-007BF23A	Men's Restroom Across From Room A141 - Sink (Right)	03/17/22	ND	None.
8	20481600-008BF	20481600-008BF23A	Women's Restroom Across From Room A141 - Sink (Left)	03/17/22	1.4	None.
9	20481600-009BF	20481600-009BF23A	Women's Restroom Across From Room A141 - Sink (Right)	03/17/22	0.9	None.
10	20481600-010CF	20481600-010CF23A	Room A201 - Sink	03/17/22	ND	None.
11	20481600-011BF	20481600-011BF23A	Unisex Restroom Outside Room A201 - Sink	03/17/22	1.4	None.
12	20481600-012DW	20481600-012DW23A	Outside Room A207 - Drinking Fountain (Upper)	03/17/22	1.6	None.
13	20481600-013DW	20481600-013DW23A	Outside Room A207 - Drinking Fountain (Lower)	03/17/22	1.0	None.
14	20481600-014BF	20481600-014BF23A	Men's Restroom Across From Room A213 - Sink (Left)	03/17/22	1.5	None.
15	20481600-015BF	20481600-015BF23A	Men's Restroom Across From Room A213 - Sink (Right)	03/17/22	1.3	None.
16	20481600-016BF	20481600-016BF23A	Women's Restroom Across From Room A213 - Sink (Left)	03/17/22	1.5	None.
17	20481600-017BF	20481600-017BF23A	Women's Restroom Across From Room A213 - Sink (Right)	03/17/22	0.6	None.
18	20481600-018BF	20481600-018BF23A	Room E101 Unisex Restroom (Left) - Sink	03/17/22	0.6	None.
19	20481600-019BF	20481600-019BF23A	Room E101 Unisex Restroom (Right) - Sink	03/17/22	2.0	None.
NA	N/A	N/A	Room E102 (Pottery) - Sink (1)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Room E102 (Pottery) - Sink (2)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Room E102 (Pottery) - Sink (3)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Room E102 (Pottery) - Sink (4)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Room E103 (Pottery) - Sink (1)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Room E103 (Pottery) - Sink (2)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Room E103 (Pottery) - Sink (3)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Room E103 (Pottery) - Sink (4)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Room E103 (Pottery) - Sink (5)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Room E103 (Pottery) - Sink (6)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
20	20481600-020BF	20481600-020BF23A	Outside Room E108 (Band) Unisex Restroom (Left) - Sink	03/17/22	1.7	None.
21	20481600-021BF	20481600-021BF23A	Outside Room E108 (Band) Unisex Restroom (Right) - Sink	03/17/22	2.3	None.
22	20481600-022DW	20481600-022DW23A	Outside Room E108 (Band) - Drinking Fountain (Upper)	03/17/22	ND	None.
23	20481600-023DW	20481600-023DW23A	Outside Room E108 (Band) - Drinking Fountain (Lower)	03/17/22	ND	None.
24	20481600-024CF	20481600-024CF23A	Inbetween Rooms E111(Metal) / E112(Auto) - Sink (Left)	03/17/22	0.6	None.
25	20481600-025CF	20481600-025CF23A	Inbetween Rooms E111(Metal) / E112(Auto) - Sink (Center)	03/17/22	0.7	None.
26	20481600-026CF	20481600-026CF23A	Inbetween Rooms E111(Metal) / E112(Auto) - Sink (Right)	03/17/22	1.1	None.
27	20481600-027SF	20481600-027SF23A	Autoshop Staff Bathroom Sink	03/17/22	1.5	Added 09/03/21.
28	20481600-028DW	20481600-028DW23A	Commons - Drinking Fountain (Upper)	03/17/22	ND	None.
29	20481600-029DW	20481600-029DW23A	Commons - Drinking Fountain (Lower)	03/17/22	0.9	None.
30	20481600-030WB	20481600-030WB23A	Commons - Drinking Fountain (Bottle Filler)	03/17/22	ND	This drinking fountain has a sediment filter on it.
31	20481600-134DF	20481600-134DF23A	Commons - Drinking Fountain (Bottle has Lower Fountain)	03/17/22	ND	Added 03/17/22
32	20481600-031OT	20481600-031OT23A	Commons - Sink (Hand Wash)	03/17/22	ND	None.
33	20481600-032OT	20481600-032OT23A	Room D104 Ticket/Concession - Sink	03/17/22	0.8	None.
34	20481600-033OT	20481600-033OT23A	Room D104 Ticket/Concession - Cappuccino Machine	03/17/22	8.6	None.
35	20481600-034OT	20481600-034OT23A	Room D104 Ticket/Concession - Coffe Machine	04/20/22	1.3	None.
na	20481600-035OT	20481600-035OT23A	Room D104 Ticket/Concession - Soda Machine	07/08/16	1.2	These are no longer present (09/03/21). We will reactivate if necessary.
36	20481600-036IM	20481600-036IM23A	Room D104 Ticket/Concession - Ice Machine	03/17/22	ND	This ice machine has a sediment filter on it.
37	20481600-037OT	20481600-037OT23A	Room D106 Student Store - Sink	03/17/22	1.7	None.
38	20481600-038DW	20481600-038DW23A	Hallway North of Gym - Drinking Fountain (Upper)	03/17/22	ND	None.
39	20481600-039DW	20481600-039DW23A	Hallway North of Gym - Drinking Fountain (Lower)	03/17/22	ND	None.
40	20481600-040WB	20481600-040WB23A	Hallway North of Gym - Drinking Fountain (Bottle Filler)	03/17/22	ND	now on lead tracker
41	20481600-041BF	20481600-041BF23A	Hallway North of Gym Men's Restroom - Sink (1) East	03/17/22	0.5	None.
42	20481600-042BF	20481600-042BF23A	Hallway North of Gym Men's Restroom - Sink (2)	03/17/22	ND	None.
43	20481600-043BF	20481600-043BF23A	Hallway North of Gym Men's Restroom - Sink (3)	03/17/22	3.1	None.
44	20481600-044BF	20481600-044BF23A	Hallway North of Gym Men's Restroom - Sink (4)	03/17/22	2.2	None.
45	20481600-045BF	20481600-045BF23A	Hallway North of Gym Men's Restroom - Sink (5)	03/17/22	3.6	None.
46	20481600-046BF	20481600-046BF23A	Hallway North of Gym Men's Restroom - Sink (6) West	03/17/22	0.7	None.
47	20481600-047BF	20481600-047BF23A	Hallway North of Gym Family Restroom - Sink	03/17/22	1.4	None.
48	20481600-048BF	20481600-048BF23A	Hallway North of Gym Women's Restroom - Sink (1) East	03/17/22	1.4	None.
49	20481600-049BF	20481600-049BF23A	Hallway North of Gym Women's Restroom - Sink (2)	03/17/22	1.4	None.
50	20481600-050BF	20481600-050BF23A	Hallway North of Gym Women's Restroom - Sink (3)	03/17/22	0.8	None.
51	20481600-051BF	20481600-051BF23A	Hallway North of Gym Women's Restroom - Sink (4)	03/17/22	0.9	None.

52	20481600-052BF	20481600-052BF23A	Hallway North of Gym Women's Restroom - Sink (5)	03/17/22	0.8	None.
53	20481600-053BF	20481600-053BF23A	Hallway North of Gym Women's Restroom - Sink (6)	03/17/22	ND	None.
54	20481600-054BF	20481600-054BF23A	Hallway North of Gym Women's Restroom - Sink (7)	03/17/22	ND	None.
55	20481600-055BF	20481600-055BF23A	Hallway North of Gym Women's Restroom - Sink (8) West	03/17/22	0.7	None.
56	20481600-056BF	20481600-056BF23A	Kitchen Staff Unisex Restroom - Sink	03/17/22	1.3	None.
57	20481600-057IM	20481600-057IM23A	Kitchen Snack - Ice Machine	05/20/22	ND	A factory filter was found on this machine 4/18/2022. Filter housing changed so as to change lead filter.
na	20481600-058KF	20481600-058KF23A	Kitchen Food Servery - West Soda Machine (Left)	07/08/16	0.5	These are no longer present (09/03/21). We will reactivate if necessary.
na	20481600-059KF	20481600-059KF23A	Kitchen Food Servery - West Soda Machine (Right)	07/08/16	0.4	These are no longer present (09/03/21). We will reactivate if necessary.
58	20481600-060KF	20481600-060KF23A	Kitchen Food Servery - East Soda Machine (Left)	03/17/22	3.7	None.
59	20481600-061IM	20481600-061IM23A	Kitchen Food Servery - East Soda Machine Ice Maker (Left)	03/17/22	7.2	None.
60	20481600-062KF	20481600-062KF23A	Kitchen Food Servery- East Soda Machine (Right)	03/17/22	0.7	None.
61	20481600-063IM	20481600-063IM23A	Kitchen Food Servery - East Soda Machine Ice Maker (Right)	03/17/22	12.8	None.
62	20481600-064KF	20481600-064KF23A	Kitchen Front Island - Hand Wash Sink (South)	03/17/22	1.4	None.
63	20481600-065KF	20481600-065KF23A	Kitchen Front Island - Hand Wash Sink (North)	03/17/22	0.7	None.
64	20481600-066KF	20481600-066KF23A	Kitchen North Wall Food Prep - Sink (Left)	03/17/22	3.9	None.
65	20481600-067KF	20481600-067KF23A	Kitchen North Wall Food Prep - Sink (Right)	03/17/22	6.5	None.
66	20481600-068KF	20481600-068KF23A	Kitchen Island Food Prep - Sink	03/17/22	2.1	None.
67	20481600-069KF	20481600-069KF23A	Kitchen West Wall - Hand Wash - Sink	03/17/22	5.3	None.
68	20481600-070KF	20481600-070KF23A	Kitchen West Wall Food Prep - Sink	03/17/22	1.5	None.
69	20481600-071KF	20481600-071KF23A	Kitchen Middle Island - Hand Wash - Sink	03/17/22	3.5	None.
70	20481600-072KF	20481600-072KF23A	Kitchen Small Steam Kettle - Faucet	03/17/22	2.8	None.
71	20481600-073KF	20481600-073KF23A	Kitchen Large Steam Kettle - Faucet	03/17/22	3.6	None.
72	20481600-074KF	20481600-074KF23A	Kitchen Steam - Oven (Upper)	05/20/22	5.5	This oven has a lead filter on it.
73	20481600-075KF	20481600-075KF23A	Kitchen Steam - Oven (Lower)	03/17/22	5.6	This oven has a lead filter on it.
74	20481600-076KF	20481600-076KF23A	Kitchen Hallway South Wall - Pre-rinse - Sink (Left)	03/17/22	1.8	None.
75	20481600-077KF	20481600-077KF23A	Kitchen Hallway South Wall - Pre-rinse - Sink (Right)	03/17/22	0.9	None.
76	20481600-078KF	20481600-078KF23A	Kitchen Hallway South Wall - Hand Wash - Sink	03/17/22	8.0	None.
77	20481600-079OT	20481600-079OT23A	Laundry Room (D121) - Sink (Utility)	03/17/22	0.9	None.
78	20481600-080DW	20481600-080DW23A	Outside Boy's Locker Room - Drinking Fountain (Upper)	03/17/22	ND	None.
79	20481600-081DW	20481600-081DW23A	Outside Boy's Locker Room - Drinking Fountain (Lower)	03/17/22	0.7	None.
80	20481600-082DW	20481600-082DW23A	Inside Boy's Locker Room - Drinking Fountain (Upper)	03/17/22	ND	None.
81	20481600-083DW	20481600-083DW23A	Inside Boy's Locker Room - Drinking Fountain (Lower)	03/17/22	0.5	None.
82	20481600-084BF	20481600-084BF23A	Boy's Locker Room Staff Restroom - Sink	03/17/22	1.8	None.
NA	N/A	N/A	Boy's Locker Room Staff Restroom - Shower	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (1)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (2)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (3)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (4)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (5)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (6)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (7)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (8)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (9)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (10)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (11)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (12)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (13)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (14)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (15)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Boy's Locker Room - Shower Head (16)	N/A	N/A	Water should not be consumed from the shower head.
83	20481600-085BF	20481600-085BF23A	Boy's Locker Room - Sink (1) South	03/17/22	1.4	None.
84	20481600-086BF	20481600-086BF23A	Boy's Locker Room - Sink (2)	03/17/22	1.4	None.
85	20481600-087BF	20481600-087BF23A	Boy's Locker Room - Sink (3)	03/17/22	2.2	None.
86	20481600-088BF	20481600-088BF23A	Boy's Locker Room - Sink (4)	03/17/22	2.3	None.
87	20481600-089BF	20481600-089BF23A	Boy's Locker Room - Sink (5)	03/17/22	2.3	None.
88	20481600-090BF	20481600-090BF23A	Boy's Locker Room - Sink (6) North	03/17/22	3.3	None.
89	20481600-091OT	20481600-091OT23A	Training Room - Sink	03/17/22	3.8	None.
90	20481600-092IM	20481600-092IM23A	Training Room - Ice Machine/Cooler Filler	03/17/22	1.1	Sediment filter installed on cooler filler 11/10/21.
91	20481600-093DW	20481600-093DW23A	Inside Girl's Locker Room - Drinking Fountain (Upper)	03/17/22	ND	None.
92	20481600-094DW	20481600-094DW23A	Inside Girl's Locker Room - Drinking Fountain (Lower)	03/17/22	1.1	None.
93	20481600-095BF	20481600-095BF23A	Girl's Locker Room Staff Restroom - Sink	03/17/22	2.3	None.
NA	N/A	N/A	Girl's Locker Room Staff Restroom - Shower	04/25/19	1.3	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (1)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (2)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (3)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (4)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (5)	N/A	N/A	Water should not be consumed from the shower head.

NA	N/A	N/A	Girl's Locker Room - Shower Head (6)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (7)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (8)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (9)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (10)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (11)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (12)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (13)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (14)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (15)	N/A	N/A	Water should not be consumed from the shower head.
NA	N/A	N/A	Girl's Locker Room - Shower Head (16)	N/A	N/A	Water should not be consumed from the shower head.
94	20481600-096BF	20481600-096BF23A	Girl's Locker Room - Sink (1) South	03/17/22	1.3	None.
95	20481600-097BF	20481600-097BF23A	Girl's Locker Room - Sink (2)	03/17/22	1.2	None.
96	20481600-098BF	20481600-098BF23A	Girl's Locker Room - Sink (3)	03/17/22	2.7	None.
97	20481600-099BF	20481600-099BF23A	Girl's Locker Room - Sink (4)	03/17/22	1.8	None.
98	20481600-100BF	20481600-100BF23A	Girl's Locker Room - Sink (5)	03/17/22	2.5	None.
99	20481600-101BF	20481600-101BF23A	Girl's Locker Room - Sink (6) North	03/17/22	3.4	None.
100	20481600-102DW	20481600-102DW23A	Gym Outside Room D214 - Drinking Fountain (Upper)	03/17/22	ND	None.
101	20481600-103DW	20481600-103DW23A	Gym Outside Room D214 - Drinking Fountain (Lower)	03/17/22	ND	None.
102	20481600-104DW	20481600-104DW23A	Gym Outside Wrestling Room - Drinking Fountain (Upper)	03/17/22	ND	This has lead/sediment filter. "Replaced Bubber"?
103	20481600-105DW	20481600-105DW23A	Gym Outside Wrestling Room - Drinking Fountain (Bottle Filler)	03/17/22	ND	This has lead/sediment filter. "Replaced Bubber"?
104	20481600-106BF	20481600-106BF23A	Men's Restroom Outside Room D205 - Sink (1)	03/17/22	2.1	None.
105	20481600-107BF	20481600-107BF23A	Men's Restroom Outside Room D205 - Sink (2)	03/17/22	0.7	None.
106	20481600-108BF	20481600-108BF23A	Men's Restroom Outside Room D205 - Sink (3)	03/17/22	1.1	None.
107	20481600-109BF	20481600-109BF23A	Men's Restroom Outside Room D205 - Sink (4)	03/17/22	2.2	None.
108	20481600-110BF	20481600-110BF23A	Men's Restroom Outside Room D205 - Sink (5)	03/17/22	4.0	None.
109	20481600-111BF	20481600-111BF23A	Women's Restroom Outside Room D205 - Sink (1)	03/17/22	0.1	None.
110	20481600-112BF	20481600-112BF23A	Women's Restroom Outside Room D205 - Sink (2)	03/17/22	9.0	None.
111	20481600-113BF	20481600-113BF23A	Women's Restroom Outside Room D205 - Sink (3)	03/17/22	4.8	None.
112	20481600-114BF	20481600-114BF23A	Women's Restroom Outside Room D205 - Sink (4)	03/17/22	1.6	None.
113	20481600-115BF	20481600-115BF23A	Women's Restroom Outside Room D205 - Sink (5)	03/17/22	4.4	None.
114	20481600-116SF	20481600-116SF23A	Staff Break Room (D202) - Sink	03/17/22	ND	None.
115	20481600-117BF	20481600-117BF23A	Staff Break Room (D202) Unisex Restroom (Left) - Sink	03/17/22	1.5	None.
116	20481600-118BF	20481600-118BF23A	Staff Break Room (D202) Unisex Restroom (Right) - Sink	03/17/22	2.0	None.
117	20481600-119BF	20481600-119BF23A	Staff Break Room (D202) Mother's Restroom - Sink	03/17/22	5.5	None.
118	20481600-120DW	20481600-120DW23A	Outside Staff Break Room (D202) - Drinking Fountain (Upper)	03/17/22	0.7	None.
119	20481600-121DW	20481600-121DW23A	Outside Staff Break Room (D202) - Drinking Fountain (Lower)	03/17/22	0.5	None.
120	20481600-122CF	20481600-122CF23A	Wood Shop (D109) Island - Sink (Left)	03/17/22	1.2	None.
121	20481600-123CF	20481600-123CF23A	Wood Shop (D109) Island - Sink (Right)	03/17/22	3.4	None.
122	20481600-124CF	20481600-124CF23A	Room Inbetween Room D109/108 - Sink	03/17/22	0.6	None.
123	20481600-125IM	20481600-125IM23A	Room Inbetween Room D109/108 - Ice Machine	03/17/22	1.2	None.
124	20481600-126CF	20481600-126CF23A	Culinary Arts (D108) Island - Sink (Left)	03/17/22	ND	None.
125	20481600-127CF	20481600-127CF23A	Culinary Arts (D108) Island - Sink (Right)	03/17/22	0.9	None.
126	20481600-128CF	20481600-128CF23A	Culinary Arts (D108) - Sink (1) East	03/17/22	ND	None.
127	20481600-129CF	20481600-129CF23A	Culinary Arts (D108) - Sink (2)	03/17/22	ND	None.
128	20481600-130CF	20481600-130CF23A	Culinary Arts (D108) - Sink (3)	03/17/22	ND	None.
129	20481600-131CF	20481600-131CF23A	Culinary Arts (D108) - Sink (4)	03/17/22	ND	None.
130	20481600-132CF	20481600-132CF23A	Culinary Arts (D108) - Sink (5)	03/17/22	ND	None.
131	20481600-133CF	20481600-133CF23A	Culinary Arts (D108) - Sink (6) West	03/17/22	ND	None.
NA	N/A	N/A	Culinary Arts (D109) - Sink (1)	07/08/16	0.3	This sink was removed to make the space a CTE classroom.
NA	N/A	N/A	Culinary Arts (D109) - Sink (2)	07/08/16	0.2	This sink was removed to make the space a CTE classroom.
NA	N/A	N/A	Culinary Arts (D109) - Sink (3)	07/08/16	1.4	This sink was removed to make the space a CTE classroom.
NA	N/A	N/A	Culinary Arts (D109) - Sink (4)	07/08/16	0.5	This sink was removed to make the space a CTE classroom.
NA	N/A	N/A	Culinary Arts (D109) - Sink (5)	07/08/16	0.3	This sink was removed to make the space a CTE classroom.
NA	N/A	N/A	Culinary Arts (D109) - Sink (6)	07/08/16	0.4	This sink was removed to make the space a CTE classroom.
Lead Tests - South High School - C Wing and Media Center Building - # 20481601						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20481601-001SF	20481601-001SF23A	Media Center Work Room - Sink	03/17/22	ND	None.
2	20481601-002BF	20481601-002BF23A	Media Center Unisex Restroom - Sink	03/17/22	ND	None.
3	20481601-003DW	20481601-003DW23A	Outside Room C111 - Drinking Fountain (Upper)	03/17/22	ND	None.
4	20481601-004DW	20481601-004DW23A	Outside Room C111 - Drinking Fountain (Lower)	03/17/22	0.8	None.
5	20481601-005BF	20481601-005BF23A	Men's Restroom Next To Room C111 - Sink (Left)	03/17/22	0.6	None.
6	20481601-006BF	20481601-006BF23A	Men's Restroom Next To Room C111 - Sink (Right)	03/17/22	0.5	None.
7	20481601-007BF	20481601-007BF23A	Women's Restroom Next To Room C111 - Sink (Left)	03/17/22	ND	None.
8	20481601-008BF	20481601-008BF23A	Women's Restroom Next To Room C111 - Sink (Right)	03/17/22	ND	None.
NA	N/A	N/A	Science Room C116 - Sink (1)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C116 - Sink (2)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.

[illegible]

NA	N/A	N/A	Science Room C216 - Sink (6)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C216 - Sink (7)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C216 - Sink (8)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C216 - Sink (9)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C216 - Sink (10)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C217 - Sink (1)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C217 - Sink (2)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C217 - Sink (3)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C217 - Sink (4)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C217 - Sink (5)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C217 - Sink (6)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C217 - Sink (7)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C217 - Sink (8)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C217 - Sink (9)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C217 - Sink (10)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C218 - Sink (1)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C218 - Sink (2)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C218 - Sink (3)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C218 - Sink (4)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C218 - Sink (5)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C218 - Sink (6)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C218 - Sink (7)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C218 - Sink (8)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C218 - Sink (9)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C218 - Sink (10)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C219 - Sink (1)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C219 - Sink (2)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C219 - Sink (3)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C219 - Sink (4)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C219 - Sink (5)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C219 - Sink (6)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C219 - Sink (7)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C219 - Sink (8)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C219 - Sink (9)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C219 - Sink (10)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C220 - Sink (1)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C220 - Sink (2)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C220 - Sink (3)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C220 - Sink (4)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C220 - Sink (5)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C220 - Sink (6)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C220 - Sink (7)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C220 - Sink (8)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C220 - Sink (9)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.
NA	N/A	N/A	Science Room C220 - Sink (10)	N/A	N/A	"Non-Potable Water" Sign Installed 15 Nov 2019.

Lead Tests - South High School - Tennis Storage Shed - # 20481602

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20481602-001OS	20481602-001OS23A	Tennis Storage Shed - Water Spigot (Wall Connection)	05/13/22	6.4	None.

Lead Tests - South High School - Tennis Court Restroom Building - # 20481603

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20481603-001BF	20481603-001BF23A	Tennis Court Men's Restroom - Sink	03/17/22	2.3	None.
2	20481603-002BF	20481603-002BF23A	Tennis Court Women's Restroom - Sink	03/17/22	1.9	None.
3	20481603-003DW	20481603-003DW23A	Tennis Court Restroom - Drinking Fountain (Upper)	03/17/22	3.6	None.
4	20481603-004DW	20481603-004DW23A	Tennis Court Restroom - Drinking Fountain (Lower)	04/22/22	12.5	

Lead Tests - South High School - Track Concession Stand Building - # 20481605

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20481605-001BF	20481605-001BF23A	Concession Stand Women's Restroom - Sink (1)	03/17/22	9.5	None.
2	20481605-002BF	20481605-002BF23A	Concession Stand Women's Restroom - Sink (2)	03/17/22	7.6	None.
3	20481605-003BF	20481605-003BF23A	Concession Stand Women's Restroom - Sink (3)	03/17/22	6.5	None.
4	20481605-004BF	20481605-004BF23A	Concession Stand Women's Restroom - Sink (4)	03/17/22	7.6	None.
5	20481605-005BF	20481605-005BF23A	Concession Stand Men's Restroom - Sink (1)	03/17/22	10.6	None.
6	20481605-006BF	20481605-006BF23A	Concession Stand Men's Restroom - Sink (2)	03/17/22	8.6	None.
7	20481605-007BF	20481605-007BF23A	Concession Stand Men's Restroom - Sink (3)	05/20/22	4.7	Lead filter added 5/19/2022.
8	20481605-008BF	20481605-008BF23A	Concession Stand Men's Restroom - Sink (4)	03/17/22	10.8	None.
9	20481605-009DW	20481605-009DW23A	Concession Stand - Drinking Fountain (Upper)	03/17/22	2.5	None.
10	20481605-010DW	20481605-010DW23A	Concession Stand - Drinking Fountain (Lower)	03/17/22	3.6	None.
11	20481605-011OT	20481605-011OT23A	Concession Stand - Sink (West Wall)	03/17/22	3.3	None.

12	20481605-012OT	20481605-012OT23A	Concession Stand - Sink (Hand Wash)	05/20/22	2.4	Lead filter added 5/19/2022.
13	20481605-013OT	20481605-013OT23A	Concession Stand - Coffee Machine	03/17/22	0.8	None.
NA	N/A	N/A	Concession Stand - Soda Machine	N/A	N/A	This machine does not currently have a water hook up.
Lead Tests - South High School - Baseball and Softball Storage Building - # 20481606						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20481606-001OT	20481606-001OT23A	Varsity Softball - Water Connection (In Vault)	04/22/22	ND	
Lead Tests - South High School - Track Storage Building - # 20481607						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20481607-001OS	20481607-001OS23A	Track Shed - Water Horse	05/24/22	5.9	None.

*None Detected (ND) = 0.10 Or Less PPB

= Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)

*ODE's required action level is 15 parts per billion (PPB)
*The E.P.A.'s recommended action level for lead in schools is 20 PPB. Oregon's action level for schools changed to 15 PPB in 2019 in accordance with OAR 333-061-0400. In 2021, ODE changed the unit of measurement for reporting to parts per billion (PPB).
*The E.P.A. action level for copper is 1.30
*Lead test results will be posted on the MSD/Facilities website within 5 days minus the school map for security purposes.