Medford Online Academy (MOA)

Lead Tests - Medford On Line Academy - 20481900

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1 (L)	20481900-001BF	20481900-001BF**21A**	Downstairs Men's Restroom - Sink (Left)	8/20/2020	Passed with 0.00244	None.
2 (R)	20481900-002BF	20481900-002BF**21A**	Downstairs Men's Restroom - Sink (Right)	8/20/2020	Passed with 0.00482	None.
3 (L)	20481900-003BF	20481900-003BF**21A**	Downstairs Women's Restroom - Sink (Left)	8/20/2020	Passed with 0.00309	None.
4 (R)	20481900-004BF	20481900-004BF**21A**	Downstairs Women's Restroom - Sink (Right)	8/20/2020	Passed with 0.00177	None.
5	20481900-005DW	20481900-005DW**21A**	Downstairs In Between Restrooms - Drinking Fountain	8/20/2020	Passed with 0.000318	None.
6 (L)	20481900-006BF	20481900-006BF**21A**	Upstairs Men's Restroom - Sink (Left)	8/20/2020	Passed with 0.00614	None.
7 (R)	20481900-007BF	20481900-007BF**21A**	Upstairs Men's Restroom - Sink (Right)	8/20/2020	Passed with 0.00357	None.
8 (L)	20481900-008BF	20481900-008BF**21A**	Upstairs Woman's Restroom - Sink (Left)	8/20/2020	Passed with 0.00354	None.
9 (R)	20481900-009BF	20481900-009BF**21A**	Upstairs Woman's Restroom - Sink (Right)	8/20/2020	Passed with 0.00268	None.
10	20481900-010DW	20481900-010DW**21A**	Upstairs In Between Restrooms - Drinking Fountain	8/20/2020	Passed with 0.000185	None.
11 (L)	20481900-011SF	20481900-011SF**21A**	Upstairs Staff Breakroom - Sink (Left)	8/20/2020	Passed with 0.00615	None.
12 (R)	20481900-012SF	20481900-012SF**21A**	Upstairs Staff Breakroom - Sink (Right)	8/20/2020	Passed with 0.00433	None.

***None Detected (ND) = .005 Or Less**

= **Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)**

Bold Border = **Has Been Spot Tested**

***The E.P.A. action level for lead in schools is 0.020.** **Oregon's action level for schools is 0.015 (Changed in 2019 in accordance with OAR 333-061-0400).**
***The E.P.A. action level for copper is 1.30**
***Lead test results will be posted on the MSD/Facilities website within 5 days.**