



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

June 11, 2019

Andy Chasteen  
Medford School District  
815 S Oakdale Ave  
Medford, OR 97501  
TEL: 541-842-3646  
FAX: 541-842-1160

RE: 18-00 Central 2019 Lead Testing

Order No.: 19050900

Dear Andy Chasteen:

Neilson Research Corporation received 201 sample(s) on 5/22/2019 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Senior Project Manager  
245 S Grape St  
Medford, OR 97501

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

## Case Narrative

WO#: 19050900  
Date: 6/11/2019

---

**CLIENT:** Medford School District

**Project:** 18-00 Central 2019 Lead Testing

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-001 **Client Sample ID:** Main Entrance Womens RR-Sink (1)  
**Collection Date:** 5/22/2019 5:45:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Main Entrance Womens RR-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00420		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-002 **Client Sample ID:** Main Entrance Womens RR-Sink (2)  
**Collection Date:** 5/22/2019 5:45:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Main Entrance Womens RR-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00468		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-003 **Client Sample ID:** Main Entrance Womens RR-Sink (3)  
**Collection Date:** 5/22/2019 5:45:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Main Entrance Womens RR-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00344		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-004 **Client Sample ID:** Main Entrance Womens RR-Sink (4)  
**Collection Date:** 5/22/2019 5:45:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Main Entrance Womens RR-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00445		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-005 **Client Sample ID:** Main Entrance Womens RR-Sink (5)  
**Collection Date:** 5/22/2019 5:45:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Main Entrance Womens RR-Sink (5)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00511		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-006 **Client Sample ID:** Main Entrance Womens RR-Sink (6)  
**Collection Date:** 5/22/2019 5:45:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Main Entrance Womens RR-Sink (6)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00435		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-007 **Client Sample ID:** Main Entrance Womens RR-Sink (7)  
**Collection Date:** 5/22/2019 5:45:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Main Entrance Womens RR-Sink (7)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00426		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-008 **Client Sample ID:** Rm 103-Sink (1)  
**Collection Date:** 5/22/2019 5:54:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Rm 103-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00332		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-009 **Client Sample ID:** Rm 103-Sink (2)  
**Collection Date:** 5/22/2019 5:54:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Rm 103-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00424		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-010  
Collection Date: 5/22/2019 5:54:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 103-Sink (3)  
**Collected By:** Bill Bartlett  
**Sample Location:** Rm 103-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00240		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-011  
Collection Date: 5/22/2019 5:54:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 103-Sink (4)  
**Collected By:** Bill Bartlett  
**Sample Location:** Rm 103-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00365		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-012  
Collection Date: 5/22/2019 5:55:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** In Between Rm 102/103-Sink  
**Collected By:** Bill Bartlett  
**Sample Location:** In Between Rm 102/103-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00295		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-013  
Collection Date: 5/22/2019 6:00:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 102-Sink (1)  
**Collected By:** Bill Bartlett  
**Sample Location:** Rm 102-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00199		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-014  
Collection Date: 5/22/2019 6:00:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 102-Sink (2)  
**Collected By:** Bill Bartlett  
**Sample Location:** Rm 102-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00730		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-015  
Collection Date: 5/22/2019 6:01:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 102-Sink (3)  
**Collected By:** Bill Bartlett  
**Sample Location:** Rm 102-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00475		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-016  
Collection Date: 5/22/2019 6:01:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 102-Sink (4)  
**Collected By:** Bill Bartlett  
**Sample Location:** Rm 102-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00324		0.000103	mg/L	1	6/6/2019	0.0150	

**Lab ID:** 19050900-017  
Collection Date: 5/22/2019 6:02:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 102-Sink (5)  
**Collected By:** Bill Bartlett  
**Sample Location:** Rm 102-Sink (5)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00443		0.000103	mg/L	1	6/6/2019	0.0150	

**Lab ID:** 19050900-018  
Collection Date: 5/22/2019 6:02:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 102-Sink (6)  
**Collected By:** Bill Bartlett  
**Sample Location:** Rm 102-Sink (6)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00509		0.000103	mg/L	1	6/6/2019	0.0150	

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-019      Client Sample ID: Rm 102-Sink (7)  
Collection Date: 5/22/2019 6:03:00 AM      Collected By: Bill Bartlett  
Matrix: Drinking Water      Sample Location: Rm 102-Sink (7)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00213		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-020      Client Sample ID: Rm 102-Sink (8)  
Collection Date: 5/22/2019 6:03:00 AM      Collected By: Bill Bartlett  
Matrix: Drinking Water      Sample Location: Rm 102-Sink (8)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0293	*	0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-021      Client Sample ID: By Rm 109 Unisex RR (L)-Sink  
Collection Date: 5/22/2019 6:08:00 AM      Collected By: Bill Bartlett  
Matrix: Drinking Water      Sample Location: By Rm 109 Unisex RR (L)-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00163		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-022 **Client Sample ID:** By Rm 109 Unisex RR (R)-Sink  
**Collection Date:** 5/22/2019 6:08:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** By Rm 109 Unisex RR (R)-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00219		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-023 **Client Sample ID:** By Rm 109 Mens RR-Sink (L)  
**Collection Date:** 5/22/2019 6:10:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** By Rm 109 Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00216		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-024 **Client Sample ID:** By Rm 109 Mens RR-Sink (Center)  
**Collection Date:** 5/22/2019 6:10:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** By Rm 109 Mens RR-Sink (Center)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00236		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-025      Client Sample ID: By Rm 109 Mens RR-Sink (R)  
Collection Date: 5/22/2019 6:10:00 AM      Collected By: Bill Bartlett  
Matrix: Drinking Water      Sample Location: By Rm 109 Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00279		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-026      Client Sample ID: By Rm 109 Womens RR-Sink (1)  
Collection Date: 5/22/2019 6:15:00 AM      Collected By: Bill Bartlett  
Matrix: Drinking Water      Sample Location: By Rm 109 Womens RR-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00332		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-027      Client Sample ID: By Rm 109 Womens RR-Sink (2)  
Collection Date: 5/22/2019 6:15:00 AM      Collected By: Bill Bartlett  
Matrix: Drinking Water      Sample Location: By Rm 109 Womens RR-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00312		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-028 **Client Sample ID:** By Rm 109 Womens RR-Sink (3)  
**Collection Date:** 5/22/2019 6:15:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** By Rm 109 Womens RR-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00282		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-029 **Client Sample ID:** By Rm 109 Womens RR-Sink (4)  
**Collection Date:** 5/22/2019 6:15:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** By Rm 109 Womens RR-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00246		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-030 **Client Sample ID:** Rm 106-Sink  
**Collection Date:** 5/22/2019 6:18:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Rm 106-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0275	*	0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-031 **Client Sample ID:** Rm 108 Little Theater Unisex RR-Sink  
**Collection Date:** 5/22/2019 6:20:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Rm 108 Little Theater Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00198		0.000103	mg/L	1	6/6/2019	0.0150	

**Lab ID:** 19050900-032 **Client Sample ID:** Main Custodial Office (Basement) RR-Sink  
**Collection Date:** 5/22/2019 6:22:00 AM **Collected By:** Bill Bartlett  
**Matrix:** Drinking Water **Sample Location:** Main Custodial Office (Basement) RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00221		0.000103	mg/L	1	6/6/2019	0.0150	

**Lab ID:** 19050900-033 **Client Sample ID:** Rm 141-Sink (1)  
**Collection Date:** 5/22/2019 5:38:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Rm 141-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00158		0.000103	mg/L	1	6/6/2019	0.0150	

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: 19050900  
Received Date: 5/22/2019 8:55:00 AM  
Reported Date: 6/11/2019

Sample Information:

Lab ID: 19050900-034 Client Sample ID: Rm 141-Sink (2)  
Collection Date: 5/22/2019 5:39:00 AM Collected By: Marlon Taylor  
Matrix: Drinking Water Sample Location: Rm 141-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00463		0.000103	mg/L	1	6/6/2019	0.0150		

Lab ID: 19050900-035 Client Sample ID: Rm 141-Sink (3)  
Collection Date: 5/22/2019 5:40:00 AM Collected By: Marlon Taylor  
Matrix: Drinking Water Sample Location: Rm 141-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00674		0.000103	mg/L	1	6/6/2019	0.0150		

Lab ID: 19050900-036 Client Sample ID: Rm 141-Sink (4)  
Collection Date: 5/22/2019 5:41:00 AM Collected By: Marlon Taylor  
Matrix: Drinking Water Sample Location: Rm 141-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00346		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-037  
Collection Date: 5/22/2019 5:42:00 AM  
Matrix: Drinking Water  
Client Sample ID: Rm 141-Sink (5)  
Collected By: Marlon Taylor  
Sample Location: Rm 141-Sink (5)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0122		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-038  
Collection Date: 5/22/2019 5:43:00 AM  
Matrix: Drinking Water  
Client Sample ID: Rm 141-Sink (6)  
Collected By: Marlon Taylor  
Sample Location: Rm 141-Sink (6)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00230		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-039  
Collection Date: 5/22/2019 5:48:00 AM  
Matrix: Drinking Water  
Client Sample ID: Outside Rm(160/161) Mens RR-Sink (L)  
Collected By: Marlon Taylor  
Sample Location: Outside Rm(160/161) Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00482		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-040 **Client Sample ID:** Outside Rm(160/161) Mens RR-Sink (R)  
**Collection Date:** 5/22/2019 5:49:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Outside Rm(160/161) Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00327		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-041 **Client Sample ID:** Outside Rm (160/161) Womens RR-Sink (L)  
**Collection Date:** 5/22/2019 5:50:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Outside Rm (160/161) Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00560		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-042 **Client Sample ID:** Outside Rm(160/161) Womens RR-Sink (R)  
**Collection Date:** 5/22/2019 5:51:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Outside Rm(160/161) Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00325		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-043 **Client Sample ID:** Kitchen-Sink (Pre-Rinse/Dishwasher)  
**Collection Date:** 5/22/2019 5:58:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Kitchen-Sink (Pre-Rinse/Dishwasher)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00168		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-044 **Client Sample ID:** Kitchen-Sink (Hand Wash)  
**Collection Date:** 5/22/2019 5:59:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Kitchen-Sink (Hand Wash)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00389		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-045 **Client Sample ID:** Kitchen Unisex RR-Sink  
**Collection Date:** 5/22/2019 6:00:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Kitchen Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00445		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: 19050900  
Received Date: 5/22/2019 8:55:00 AM  
Reported Date: 6/11/2019

Sample Information:

Lab ID: 19050900-046 Client Sample ID: Below Stg Near Dress Rms (Bsmt)-Sink (L)  
Collection Date: 5/22/2019 6:04:00 AM Collected By: Marlon Taylor  
Matrix: Drinking Water Sample Location: Below Stg Near Dress Rms (Bsmt)-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0283	*	0.000103	mg/L	1	6/6/2019	0.0150		

Lab ID: 19050900-047 Client Sample ID: Below Stg Near Dress Rms (Bsmt)-Sink (C)  
Collection Date: 5/22/2019 6:05:00 AM Collected By: Marlon Taylor  
Matrix: Drinking Water Sample Location: Below Stg Near Dress Rms (Bsmt)-Sink (C)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.363	*	0.00103	mg/L	10	6/6/2019	0.0150		

Lab ID: 19050900-048 Client Sample ID: Below Stg Near Dress Rms (Bsmt)-Sink (R)  
Collection Date: 5/22/2019 6:06:00 AM Collected By: Marlon Taylor  
Matrix: Drinking Water Sample Location: Below Stg Near Dress Rms (Bsmt)-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.214	*	0.000206	mg/L	2	6/10/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-049 **Client Sample ID:** Hall of Fame Mens RR-Sink (L)  
**Collection Date:** 5/22/2019 6:11:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Hall of Fame Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0141		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-050 **Client Sample ID:** Hall of Fame Mens RR-Sink (Center)  
**Collection Date:** 5/22/2019 6:12:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Hall of Fame Mens RR-Sink (Center)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00727		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-051 **Client Sample ID:** Hall of Fame Mens RR-Sink (R)  
**Collection Date:** 5/22/2019 6:13:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Hall of Fame Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00601		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-052      Client Sample ID: Hall of Fame Womens RR-Sink (L)  
Collection Date: 5/22/2019 6:15:00 AM      Collected By: Marlon Taylor  
Matrix: Drinking Water      Sample Location: Hall of Fame Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00334		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-053      Client Sample ID: Hall of Fame Womens RR-Sink (Center)  
Collection Date: 5/22/2019 6:16:00 AM      Collected By: Marlon Taylor  
Matrix: Drinking Water      Sample Location: Hall of Fame Womens RR-Sink (Center)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00426		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-054      Client Sample ID: Hall of Fame Womens RR-Sink (R)  
Collection Date: 5/22/2019 6:17:00 AM      Collected By: Marlon Taylor  
Matrix: Drinking Water      Sample Location: Hall of Fame Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00696		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: 19050900  
Received Date: 5/22/2019 8:55:00 AM  
Reported Date: 6/11/2019

Sample Information:

Lab ID: 19050900-055 Client Sample ID: Rm 279-Sink (1)  
Collection Date: 5/22/2019 6:26:00 AM Collected By: Marlon Taylor  
Matrix: Drinking Water Sample Location: Rm 279-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.166	*	0.000103	mg/L	1	6/8/2019	0.0150		

Lab ID: 19050900-056 Client Sample ID: Rm 279-Sink (2)  
Collection Date: 5/22/2019 6:27:00 AM Collected By: Marlon Taylor  
Matrix: Drinking Water Sample Location: Rm 279-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.489	*	0.000515	mg/L	5	6/10/2019	0.0150		

Lab ID: 19050900-057 Client Sample ID: Rm 279-Sink (3)  
Collection Date: 5/22/2019 6:28:00 AM Collected By: Marlon Taylor  
Matrix: Drinking Water Sample Location: Rm 279-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0867	*	0.000103	mg/L	1	6/8/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-058  
Collection Date: 5/22/2019 6:29:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 279-Sink (4)  
**Collected By:** Marlon Taylor  
**Sample Location:** Rm 279-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.119	*	0.000103	mg/L	1	6/8/2019	0.0150	

**Lab ID:** 19050900-059  
Collection Date: 5/22/2019 6:31:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Near 275 Mens RR-Sink (L)  
**Collected By:** Marlon Taylor  
**Sample Location:** Near 275 Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00328		0.000103	mg/L	1	6/6/2019	0.0150	

**Lab ID:** 19050900-060  
Collection Date: 5/22/2019 6:32:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Near 275 Mens RR-Sink (Center)  
**Collected By:** Marlon Taylor  
**Sample Location:** Near 275 Mens RR-Sink (Center)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00324		0.000103	mg/L	1	6/6/2019	0.0150	

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-061 **Client Sample ID:** Near 275 Mens RR-Sink (R)  
**Collection Date:** 5/22/2019 6:33:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Near 275 Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00337		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-062 **Client Sample ID:** Near 275 Womens RR-Sink (L)  
**Collection Date:** 5/22/2019 6:35:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Near 275 Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00282		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-063 **Client Sample ID:** Near 275 Womens RR-Sink (Center)  
**Collection Date:** 5/22/2019 6:36:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Near 275 Womens RR-Sink (Center)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00299		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-064 **Client Sample ID:** Near 275 Womens RR-Sink (R)  
**Collection Date:** 5/22/2019 6:37:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Near 275 Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00317		0.000103	mg/L	1	6/6/2019	0.0150	

**Lab ID:** 19050900-065 **Client Sample ID:** Rm 274-Sink  
**Collection Date:** 5/22/2019 6:38:00 AM **Collected By:** Marlon Taylor  
**Matrix:** Drinking Water **Sample Location:** Rm 274-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00252		0.000103	mg/L	1	6/6/2019	0.0150	

**Lab ID:** 19050900-066 **Client Sample ID:** Facilities Office Mens RR-Sink (L)  
**Collection Date:** 5/22/2019 5:33:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Facilities Office Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00277		0.000103	mg/L	1	6/6/2019	0.0150	

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-067 **Client Sample ID:** Facilities Office Mens RR-Sink (R)  
**Collection Date:** 5/22/2019 5:34:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Facilities Office Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00494		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-068 **Client Sample ID:** Facilities Office Womens RR-Sink (L)  
**Collection Date:** 5/22/2019 5:35:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Facilities Office Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00143		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-069 **Client Sample ID:** Facilities Office Womens RR-Sink (R)  
**Collection Date:** 5/22/2019 5:35:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Facilities Office Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00201		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-070 **Client Sample ID:** Warehouse Unisex RR-Sink  
**Collection Date:** 5/22/2019 5:37:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Warehouse Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000555		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-071 **Client Sample ID:** NTS Mens RR-Sink  
**Collection Date:** 5/22/2019 6:22:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** NTS Mens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00611		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-072 **Client Sample ID:** NTS Womens RR-Sink  
**Collection Date:** 5/22/2019 6:23:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** NTS Womens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0149		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-073 **Client Sample ID:** Mens RR O/S NTS (C2) Entrance-Sink (L)  
**Collection Date:** 5/22/2019 6:15:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Mens RR O/S NTS (C2) Entrance-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00181		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-074 **Client Sample ID:** Mens RR O/S NTS (C2) Entrance-Sink (M)  
**Collection Date:** 5/22/2019 6:16:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Mens RR O/S NTS (C2) Entrance-Sink (M)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0127		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-075 **Client Sample ID:** Mens RR O/S NTS (C2) Entrance-Sink (R)  
**Collection Date:** 5/22/2019 6:17:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Mens RR O/S NTS (C2) Entrance-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0155	*	0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-076 **Client Sample ID:** Womens RR O/S NTS (C2) Ent-Sink (L)  
**Collection Date:** 5/22/2019 6:20:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Womens RR O/S NTS (C2) Ent-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0845	*	0.000103	mg/L	1	6/8/2019	0.0150		

**Lab ID:** 19050900-077 **Client Sample ID:** Womens RR O/S NTS (C2) Ente-Sink (R)  
**Collection Date:** 5/22/2019 6:21:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Womens RR O/S NTS (C2) Ente-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0394	*	0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-078 **Client Sample ID:** Publications-Sink  
**Collection Date:** 5/22/2019 6:01:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Publications-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00371		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-079 **Client Sample ID:** Across Sodexo Break Rm Mens RR-Sink (L)  
**Collection Date:** 5/22/2019 5:59:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Across Sodexo Break Rm Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00130		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-080 **Client Sample ID:** Across Sodexo Break Rm Mens RR-Sink (R)  
**Collection Date:** 5/22/2019 5:59:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Across Sodexo Break Rm Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00631		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-081 **Client Sample ID:** Across Sodexo Break Rm Womens RR-Sink  
**Collection Date:** 5/22/2019 5:58:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Across Sodexo Break Rm Womens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00115		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-082 **Client Sample ID:** Upstairs (Police Training Rm)-Sink  
**Collection Date:** 5/22/2019 5:57:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Upstairs (Police Training Rm)-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0127		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-083 **Client Sample ID:** Sodexo/Paint Shop Mens RR-Sink (L)  
**Collection Date:** 5/22/2019 5:52:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Sodexo/Paint Shop Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0114		0.000103	mg/L	1	6/8/2019	0.0150		

**Lab ID:** 19050900-084 **Client Sample ID:** Sodexo/Paint Shop Mens RR-Sink (R)  
**Collection Date:** 5/22/2019 5:52:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Sodexo/Paint Shop Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00404		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-085 **Client Sample ID:** Sodexo/Paint Shop Womens RR-Sink (L)  
**Collection Date:** 5/22/2019 5:50:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Sodexo/Paint Shop Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0122		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-086 **Client Sample ID:** Sodexo/Paint Shop Womens RR-Sink (R)  
**Collection Date:** 5/22/2019 5:50:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Sodexo/Paint Shop Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00289		0.000103	mg/L	1	6/6/2019	0.0150		

**Lab ID:** 19050900-087 **Client Sample ID:** Paint Booth Shop-Sink (Utility)  
**Collection Date:** 5/22/2019 5:48:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Paint Booth Shop-Sink (Utility)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00362		0.000103	mg/L	1	6/6/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-088 **Client Sample ID:** Carpenter Shop Mens RR-Sink  
**Collection Date:** 5/22/2019 5:46:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Carpenter Shop Mens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00409		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-089 **Client Sample ID:** Metal Shop-Trough Sink (L Fixture)  
**Collection Date:** 5/22/2019 5:44:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Metal Shop-Trough Sink (L Fixture)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00249		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-090 **Client Sample ID:** Metal Shop-Trough Sink (R Fixture)  
**Collection Date:** 5/22/2019 5:44:00 AM **Collected By:** Gary Severe  
**Matrix:** Drinking Water **Sample Location:** Metal Shop-Trough Sink (R Fixture)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0230	*	0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-091  
Collection Date: 5/22/2019 6:05:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** IMC Break Rm Sink  
Collected By: Gary Severe  
Sample Location: IMC Break Rm Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00654		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-092  
Collection Date: 5/22/2019 7:13:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Unisex RR By Front Door-Sink  
Collected By: Mike Medal  
Sample Location: Unisex RR By Front Door-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00195		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-093  
Collection Date: 5/22/2019 7:13:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** NE Corner of Bldg-Sink (Utility)  
Collected By: Mike Medal  
Sample Location: NE Corner of Bldg-Sink (Utility)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00110		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-094      Client Sample ID: Unisex Staff RR (Near Clothes Closet)-Sink  
Collection Date: 5/22/2019 7:13:00 AM      Collected By: Mike Medal  
Matrix: Drinking Water      Sample Location: Unisex Staff RR (Near Clothes Closet)-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00284		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-095      Client Sample ID: Home Side S (Blue) Mens RR-Sink (L)  
Collection Date: 5/22/2019 5:58:00 AM      Collected By: Mike Medal  
Matrix: Drinking Water      Sample Location: Home Side S (Blue) Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0184	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-096      Client Sample ID: Home Side S (Blue) Mens RR-Sink (R)  
Collection Date: 5/22/2019 5:58:00 AM      Collected By: Mike Medal  
Matrix: Drinking Water      Sample Location: Home Side S (Blue) Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0436	*	0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-097 **Client Sample ID:** Home Side S (Blue) Womens RR-Sink (L)  
**Collection Date:** 5/22/2019 5:59:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** Home Side S (Blue) Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00160		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-098 **Client Sample ID:** Home Side S (Blue) Womens RR-Sink (R)  
**Collection Date:** 5/22/2019 5:59:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** Home Side S (Blue) Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00261		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-099 **Client Sample ID:** Home Side S Locker Rm-Trough Sink  
**Collection Date:** 5/22/2019 6:03:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** Home Side S Locker Rm-Trough Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00715		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-100 **Client Sample ID:** Home Side N Locker Rm-Sink  
**Collection Date:** 5/22/2019 6:05:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** Home Side N Locker Rm-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00319		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-101 **Client Sample ID:** Home Side N (Red) Mens RR-Sink (L)  
**Collection Date:** 5/22/2019 6:10:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** Home Side N (Red) Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0527	*	0.000103	mg/L	1	6/8/2019	0.0150		

**Lab ID:** 19050900-102 **Client Sample ID:** Home Side N (Red) Mens RR-Sink (R)  
**Collection Date:** 5/22/2019 6:10:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** Home Side N (Red) Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00286		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-103 **Client Sample ID:** Home Side N (Red) Womens RR-Sink (L)  
**Collection Date:** 5/22/2019 6:11:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** Home Side N (Red) Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0124		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-104 **Client Sample ID:** Home Side N (Red) Womens RR-Sink (R)  
**Collection Date:** 5/22/2019 6:11:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** Home Side N (Red) Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00981		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-105 **Client Sample ID:** E Side Visitors Locker Rm (N)-Sink (L Fix)  
**Collection Date:** 5/22/2019 6:25:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** E Side Visitors Locker Rm (N)-Sink (L Fix)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00279		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-106      Client Sample ID: Tunnel 11 Mens RR-Sink  
Collection Date: 5/22/2019 6:26:00 AM      Collected By: Mike Medal  
Matrix: Drinking Water      Sample Location: Tunnel 11 Mens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00355		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-107      Client Sample ID: Tunnel 12 Womens RR-Sink  
Collection Date: 5/22/2019 6:29:00 AM      Collected By: Mike Medal  
Matrix: Drinking Water      Sample Location: Tunnel 12 Womens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00143		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-108      Client Sample ID: Tunnel 12 Unisex RR-Sink  
Collection Date: 5/22/2019 6:30:00 AM      Collected By: Mike Medal  
Matrix: Drinking Water      Sample Location: Tunnel 12 Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00554		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-109 **Client Sample ID:** East Side S Locker Rm (St Marys)-Sink (L)  
**Collection Date:** 5/22/2019 6:36:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** East Side S Locker Rm (St Marys)-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0481	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-110 **Client Sample ID:** East Side S Locker Rm (St Marys)-Sink (R)  
**Collection Date:** 5/22/2019 6:36:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** East Side S Locker Rm (St Marys)-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00328		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-111 **Client Sample ID:** E Side S Locker Rm (St Marys)-Shr Hd (1)  
**Collection Date:** 5/22/2019 6:42:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** E Side S Locker Rm (St Marys)-Shr Hd (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00129		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-112      Client Sample ID: E Side S Locker Rm (St Marys)-Shr Hd (2)  
Collection Date: 5/22/2019 6:42:00 AM      Collected By: Mike Medal  
Matrix: Drinking Water      Sample Location: E Side S Locker Rm (St Marys)-Shr Hd (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000456		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-113      Client Sample ID: E Side S Locker Rm (St Marys)-Shr Hd (3)  
Collection Date: 5/22/2019 6:42:00 AM      Collected By: Mike Medal  
Matrix: Drinking Water      Sample Location: E Side S Locker Rm (St Marys)-Shr Hd (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00114		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-114      Client Sample ID: E Side S Locker Rm (St Marys)-Shr Hd (4)  
Collection Date: 5/22/2019 6:42:00 AM      Collected By: Mike Medal  
Matrix: Drinking Water      Sample Location: E Side S Locker Rm (St Marys)-Shr Hd (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00589		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-115 **Client Sample ID:** E Side S Locker Rm (St Marys)-Shr Hd (5)  
**Collection Date:** 5/22/2019 6:42:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** E Side S Locker Rm (St Marys)-Shr Hd (5)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0212	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-116 **Client Sample ID:** E Side S Locker Rm (St Marys)-Shr Hd (6)  
**Collection Date:** 5/22/2019 6:47:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** E Side S Locker Rm (St Marys)-Shr Hd (6)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0171	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-117 **Client Sample ID:** E Side S Locker Rm (St Marys)-Shr Hd (7)  
**Collection Date:** 5/22/2019 6:47:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** E Side S Locker Rm (St Marys)-Shr Hd (7)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00666		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-118 **Client Sample ID:** E Side S Locker Rm (St Marys)-Shr Hd (8)  
**Collection Date:** 5/22/2019 6:47:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** E Side S Locker Rm (St Marys)-Shr Hd (8)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00171		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-119 **Client Sample ID:** E Side S Locker Rm (St Marys)-Shr Hd (9)  
**Collection Date:** 5/22/2019 6:47:00 AM **Collected By:** Mike Medal  
**Matrix:** Drinking Water **Sample Location:** E Side S Locker Rm (St Marys)-Shr Hd (9)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00633		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-120 **Client Sample ID:** Rm 288-Sink (1)  
**Collection Date:** 5/22/2019 5:49:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Rm 288-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0701	*	0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-121  
Collection Date: 5/22/2019 5:49:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 288-Sink (2)  
**Collected By:** Roger Moulard  
**Sample Location:** Rm 288-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0285	*	0.000103	mg/L	1	6/7/2019	0.0150	

**Lab ID:** 19050900-122  
Collection Date: 5/22/2019 5:50:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 288-Sink (3)  
**Collected By:** Roger Moulard  
**Sample Location:** Rm 288-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0896	*	0.000103	mg/L	1	6/7/2019	0.0150	

**Lab ID:** 19050900-123  
Collection Date: 5/22/2019 5:50:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 288-Sink (4)  
**Collected By:** Roger Moulard  
**Sample Location:** Rm 288-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0317	*	0.000103	mg/L	1	6/7/2019	0.0150	

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: 19050900  
Received Date: 5/22/2019 8:55:00 AM  
Reported Date: 6/11/2019

Sample Information:

Lab ID: 19050900-124 Client Sample ID: Rm 288-Sink (5)  
Collection Date: 5/22/2019 5:51:00 AM Collected By: Roger Moulard  
Matrix: Drinking Water Sample Location: Rm 288-Sink (5)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0901	*	0.000103	mg/L	1	6/7/2019	0.0150	

Lab ID: 19050900-125 Client Sample ID: Rm 288-Sink (6)  
Collection Date: 5/22/2019 5:51:00 AM Collected By: Roger Moulard  
Matrix: Drinking Water Sample Location: Rm 288-Sink (6)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0663	*	0.000103	mg/L	1	6/7/2019	0.0150	

Lab ID: 19050900-126 Client Sample ID: Outside Rm 288 Womens RR-Sink (L)  
Collection Date: 5/22/2019 5:54:00 AM Collected By: Roger Moulard  
Matrix: Drinking Water Sample Location: Outside Rm 288 Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0132		0.000103	mg/L	1	6/7/2019	0.0150	

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-127 **Client Sample ID:** Outside Rm 288 Womens RR-Sink (Center)  
**Collection Date:** 5/22/2019 5:54:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Outside Rm 288 Womens RR-Sink (Center)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0133		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-128 **Client Sample ID:** Outside Rm 288 Womens RR-Sink (R)  
**Collection Date:** 5/22/2019 5:54:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Outside Rm 288 Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00441		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-129 **Client Sample ID:** Across From Rm 290 Mens RR-Sink  
**Collection Date:** 5/22/2019 5:57:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Across From Rm 290 Mens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00357		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-130      Client Sample ID: Rm 291-Sink  
Collection Date: 5/22/2019 5:54:00 AM      Collected By: Roger Moulard  
Matrix: Drinking Water      Sample Location: Rm 291-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00191		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-131      Client Sample ID: Rm 286-Sink  
Collection Date: 5/22/2019 6:02:00 AM      Collected By: Roger Moulard  
Matrix: Drinking Water      Sample Location: Rm 286-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00783		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-132      Client Sample ID: Rm 285 Unisex RR-Sink  
Collection Date: 5/22/2019 6:05:00 AM      Collected By: Roger Moulard  
Matrix: Drinking Water      Sample Location: Rm 285 Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0213	*	0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-133  
Collection Date: 5/22/2019 6:04:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 284-Sink  
**Collected By:** Roger Moulard  
**Sample Location:** Rm 284-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00859		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-134  
Collection Date: 5/22/2019 6:08:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Near Rm 280 Womens RR-Sink (L)  
**Collected By:** Roger Moulard  
**Sample Location:** Near Rm 280 Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00694		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-135  
Collection Date: 5/22/2019 6:08:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Near Rm 280 Womens RR-Sink (Center)  
**Collected By:** Roger Moulard  
**Sample Location:** Near Rm 280 Womens RR-Sink (Center)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00295		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-136 **Client Sample ID:** Near Rm 280 Womens RR-Sink (R)  
**Collection Date:** 5/22/2019 6:08:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Near Rm 280 Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00271		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-137 **Client Sample ID:** Lobby Mens RR-Sink (1)  
**Collection Date:** 5/22/2019 6:23:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Lobby Mens RR-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000788		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-138 **Client Sample ID:** Lobby Mens RR-Sink (2)  
**Collection Date:** 5/22/2019 6:23:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Lobby Mens RR-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00102		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-139 **Client Sample ID:** Lobby Mens RR-Sink (3)  
**Collection Date:** 5/22/2019 6:24:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Lobby Mens RR-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000934		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-140 **Client Sample ID:** Lobby Mens RR-Sink (4)  
**Collection Date:** 5/22/2019 6:24:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Lobby Mens RR-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00106		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-141 **Client Sample ID:** Lobby Mens RR-Sink (5)  
**Collection Date:** 5/22/2019 6:24:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Lobby Mens RR-Sink (5)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000587		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-142 **Client Sample ID:** Lobby Womens RR-Sink (1)  
**Collection Date:** 5/22/2019 6:26:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Lobby Womens RR-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000628		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-143 **Client Sample ID:** Lobby Womens RR-Sink (2)  
**Collection Date:** 5/22/2019 6:26:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Lobby Womens RR-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000748		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-144 **Client Sample ID:** Lobby Womens RR-Sink (3)  
**Collection Date:** 5/22/2019 6:26:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Lobby Womens RR-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000670		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-145 **Client Sample ID:** Lobby Womens RR-Sink (4)  
**Collection Date:** 5/22/2019 6:26:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Lobby Womens RR-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000808		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-146 **Client Sample ID:** Lobby Womens RR-Sink (5)  
**Collection Date:** 5/22/2019 6:27:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Lobby Womens RR-Sink (5)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00104		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-147 **Client Sample ID:** Girls Locker Rm-Sink (L)  
**Collection Date:** 5/22/2019 6:41:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Girls Locker Rm-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000927		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-148 **Client Sample ID:** Girls Locker Rm-Sink (Center)  
**Collection Date:** 5/22/2019 6:41:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Girls Locker Rm-Sink (Center)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00866		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-149 **Client Sample ID:** Girls Locker Rm-Sink (R)  
**Collection Date:** 5/22/2019 6:41:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Girls Locker Rm-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00465		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-150 **Client Sample ID:** Girls Locker Rm Coaches Area-Sink  
**Collection Date:** 5/22/2019 6:40:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Girls Locker Rm Coaches Area-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00547		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-151 **Client Sample ID:** Girls Locker Rm Training Rm-Sink  
**Collection Date:** 5/22/2019 6:42:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Girls Locker Rm Training Rm-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0441	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-152 **Client Sample ID:** Boys Locker Rm Training Rm-Sink  
**Collection Date:** 5/22/2019 6:43:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Boys Locker Rm Training Rm-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00988		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-153 **Client Sample ID:** Boys Locker Rm-Sink (1)  
**Collection Date:** 5/22/2019 6:47:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Boys Locker Rm-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0128		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

# Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford , OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-154 **Client Sample ID:** Boys Locker Rm-Sink (2)  
**Collection Date:** 5/22/2019 6:47:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Boys Locker Rm-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00941		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-155 **Client Sample ID:** Boys Locker Rm-Sink (3)  
**Collection Date:** 5/22/2019 6:47:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Boys Locker Rm-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0214	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-156 **Client Sample ID:** Boys Locker Rm-Sink (4)  
**Collection Date:** 5/22/2019 6:47:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Boys Locker Rm-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0182	*	0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-157 **Client Sample ID:** Boys Locker Rm Coaches Area-Sink  
**Collection Date:** 5/22/2019 6:48:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Boys Locker Rm Coaches Area-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0374	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-158 **Client Sample ID:** Upper Gym Mens RR-Sink (L)  
**Collection Date:** 5/22/2019 6:31:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Upper Gym Mens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000656		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-159 **Client Sample ID:** Upper Gym Mens RR-Sink (R)  
**Collection Date:** 5/22/2019 6:31:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Upper Gym Mens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000456		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-160 **Client Sample ID:** Upper Gym Womens RR-Sink (L)  
**Collection Date:** 5/22/2019 6:32:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Upper Gym Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000843		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-161 **Client Sample ID:** Upper Gym Womens RR-Sink (R)  
**Collection Date:** 5/22/2019 6:32:00 AM **Collected By:** Roger Moulard  
**Matrix:** Drinking Water **Sample Location:** Upper Gym Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00151		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-162 **Client Sample ID:** By Rm 144 Unisex RR-Sink (L)  
**Collection Date:** 5/22/2019 6:22:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** By Rm 144 Unisex RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00664		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-163 **Client Sample ID:** By Rm 144 Unisex RR-Sink (Center)  
**Collection Date:** 5/22/2019 6:22:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** By Rm 144 Unisex RR-Sink (Center)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00644		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-164 **Client Sample ID:** By Rm 144 Unisex RR-Sink (R)  
**Collection Date:** 5/22/2019 6:22:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** By Rm 144 Unisex RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0237	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-165 **Client Sample ID:** Rm 144-Sink (1)  
**Collection Date:** 5/22/2019 6:15:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** Rm 144-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0143		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-166  
Collection Date: 5/22/2019 6:16:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 144-Sink (2)  
**Collected By:** John Jordan  
**Sample Location:** Rm 144-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0285	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-167  
Collection Date: 5/22/2019 6:17:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 144-Sink (3-Island)  
**Collected By:** John Jordan  
**Sample Location:** Rm 144-Sink (3-Island)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.247	*	0.000206	mg/L	2	6/10/2019	0.0150		

**Lab ID:** 19050900-168  
Collection Date: 5/22/2019 6:18:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 144-Sink (4)  
**Collected By:** John Jordan  
**Sample Location:** Rm 144-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0279	*	0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: 19050900  
Received Date: 5/22/2019 8:55:00 AM  
Reported Date: 6/11/2019

Sample Information:

Lab ID: 19050900-169 Client Sample ID: Rm 144-Sink (5)  
Collection Date: 5/22/2019 6:19:00 AM Collected By: John Jordan  
Matrix: Drinking Water Sample Location: Rm 144-Sink (5)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0515	*	0.000103	mg/L	1	6/7/2019	0.0150		

Lab ID: 19050900-170 Client Sample ID: Rm 144 Storage Rm-Sink  
Collection Date: 5/22/2019 6:20:00 AM Collected By: John Jordan  
Matrix: Drinking Water Sample Location: Rm 144 Storage Rm-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.129	*	0.000103	mg/L	1	6/7/2019	0.0150		

Lab ID: 19050900-171 Client Sample ID: Rm 145-Sink (1)  
Collection Date: 5/22/2019 6:09:00 AM Collected By: John Jordan  
Matrix: Drinking Water Sample Location: Rm 145-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00641		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-172      Client Sample ID: Rm 145-Sink (2)  
Collection Date: 5/22/2019 6:10:00 AM      Collected By: John Jordan  
Matrix: Drinking Water      Sample Location: Rm 145-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0132		0.000103	mg/L	1	6/7/2019	0.0150	

**Lab ID:** 19050900-173      Client Sample ID: Rm 145-Sink (3)  
Collection Date: 5/22/2019 6:11:00 AM      Collected By: John Jordan  
Matrix: Drinking Water      Sample Location: Rm 145-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0345	*	0.000103	mg/L	1	6/7/2019	0.0150	

**Lab ID:** 19050900-174      Client Sample ID: Rm 145-Sink (4)  
Collection Date: 5/22/2019 6:12:00 AM      Collected By: John Jordan  
Matrix: Drinking Water      Sample Location: Rm 145-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0149		0.000103	mg/L	1	6/7/2019	0.0150	

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-175  
Collection Date: 5/22/2019 6:12:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 145-Sink (5)  
**Collected By:** John Jordan  
**Sample Location:** Rm 145-Sink (5)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0782	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-176  
Collection Date: 5/22/2019 6:13:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 145-Sink (6-Island)  
**Collected By:** John Jordan  
**Sample Location:** Rm 145-Sink (6-Island)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0156	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-177  
Collection Date: 5/22/2019 5:35:00 AM  
Matrix: Drinking Water  
**Client Sample ID:** Rm 142A (W)-Sink (1)  
**Collected By:** John Jordan  
**Sample Location:** Rm 142A (W)-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.166	*	0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-178 **Client Sample ID:** Rm 142A (W)-Sink (1-Bottle Filler)  
**Collection Date:** 5/22/2019 5:35:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** Rm 142A (W)-Sink (1-Bottle Filler)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.161	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-179 **Client Sample ID:** Rm 142A (W)-Sink (2)  
**Collection Date:** 5/22/2019 5:40:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** Rm 142A (W)-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.143	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-180 **Client Sample ID:** Rm 142A (W)-Sink (3-Island)  
**Collection Date:** 5/22/2019 6:45:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** Rm 142A (W)-Sink (3-Island)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.61	*	0.0206	mg/L	200	6/10/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-181      Client Sample ID: Rm 142A (W)-Sink (4)  
Collection Date: 5/22/2019 6:00:00 AM      Collected By: John Jordan  
Matrix: Drinking Water      Sample Location: Rm 142A (W)-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0317	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-182      Client Sample ID: Rm 142A (W)-Sink (5)  
Collection Date: 5/22/2019 6:02:00 AM      Collected By: John Jordan  
Matrix: Drinking Water      Sample Location: Rm 142A (W)-Sink (5)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.221	*	0.000206	mg/L	2	6/10/2019	0.0150		

**Lab ID:** 19050900-183      Client Sample ID: Rm 142A (W)-Sink (6)  
Collection Date: 5/22/2019 6:02:00 AM      Collected By: John Jordan  
Matrix: Drinking Water      Sample Location: Rm 142A (W)-Sink (6)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.342	*	0.000206	mg/L	2	6/10/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: 19050900  
Received Date: 5/22/2019 8:55:00 AM  
Reported Date: 6/11/2019

Sample Information:

Lab ID: 19050900-184 Client Sample ID: Rm 142A (W)-Sink (7)  
Collection Date: 5/22/2019 6:04:00 AM Collected By: John Jordan  
Matrix: Drinking Water Sample Location: Rm 142A (W)-Sink (7)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00440		0.000103	mg/L	1	6/7/2019	0.0150		

Lab ID: 19050900-185 Client Sample ID: Strg Rm Between Rms 142A/142B-Sink (N)  
Collection Date: 5/22/2019 6:05:00 AM Collected By: John Jordan  
Matrix: Drinking Water Sample Location: Strg Rm Between Rms 142A/142B-Sink (N)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00128		0.000103	mg/L	1	6/7/2019	0.0150		

Lab ID: 19050900-186 Client Sample ID: Strg Rm Between Rms 142A/142B-Sink (S)  
Collection Date: 5/22/2019 6:06:00 AM Collected By: John Jordan  
Matrix: Drinking Water Sample Location: Strg Rm Between Rms 142A/142B-Sink (S)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00222		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-187  
Collection Date: 5/22/2019 5:35:00 AM  
Matrix: Drinking Water  
Client Sample ID: Rm 142B (E)-Sink (1)  
Collected By: John Jordan  
Sample Location: Rm 142B (E)-Sink (1)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.199	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-188  
Collection Date: 5/22/2019 5:35:00 AM  
Matrix: Drinking Water  
Client Sample ID: Rm 142B (E)-Sink (2)  
Collected By: John Jordan  
Sample Location: Rm 142B (E)-Sink (2)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0376	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-189  
Collection Date: 5/22/2019 5:40:00 AM  
Matrix: Drinking Water  
Client Sample ID: Rm 142B (E)-Sink (3)  
Collected By: John Jordan  
Sample Location: Rm 142B (E)-Sink (3)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0726	*	0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: 19050900  
Received Date: 5/22/2019 8:55:00 AM  
Reported Date: 6/11/2019

Sample Information:

Lab ID: 19050900-190 Client Sample ID: Rm 142B (E)-Sink (4)  
Collection Date: 5/22/2019 5:40:00 AM Collected By: John Jordan  
Matrix: Drinking Water Sample Location: Rm 142B (E)-Sink (4)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0290	*	0.000103	mg/L	1	6/7/2019	0.0150		

Lab ID: 19050900-191 Client Sample ID: Rm 142B (E)-Sink (5-Island)  
Collection Date: 5/22/2019 6:46:00 AM Collected By: John Jordan  
Matrix: Drinking Water Sample Location: Rm 142B (E)-Sink (5-Island)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.448	*	0.000515	mg/L	5	6/10/2019	0.0150		

Lab ID: 19050900-192 Client Sample ID: Rm 142B (E)-Sink (6)  
Collection Date: 5/22/2019 5:55:00 AM Collected By: John Jordan  
Matrix: Drinking Water Sample Location: Rm 142B (E)-Sink (6)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.350	*	0.000206	mg/L	2	6/10/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-193 **Client Sample ID:** Rm 142B (E)-Sink (7)  
**Collection Date:** 5/22/2019 5:57:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** Rm 142B (E)-Sink (7)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0358	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-194 **Client Sample ID:** Rm 147-Sink (Double)  
**Collection Date:** 5/22/2019 6:25:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** Rm 147-Sink (Double)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0212	*	0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-195 **Client Sample ID:** Rm 147-Sink (S Wall)  
**Collection Date:** 5/22/2019 6:25:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** Rm 147-Sink (S Wall)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00351		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-196 **Client Sample ID:** O/S Rm 149 Unisex RR (148A)-Sink (L)  
**Collection Date:** 5/22/2019 6:30:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** O/S Rm 149 Unisex RR (148A)-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00440		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-197 **Client Sample ID:** O/S Rm 149 Unisex RR (148A)-Sink (R)  
**Collection Date:** 5/22/2019 6:30:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** O/S Rm 149 Unisex RR (148A)-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00844		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-198 **Client Sample ID:** Adjacent to Rm 149A Unisex RR-Sink  
**Collection Date:** 5/22/2019 6:35:00 AM **Collected By:** John Jordan  
**Matrix:** Drinking Water **Sample Location:** Adjacent to Rm 149A Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00293		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 19050900  
Date Reported: 6/11/2019

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

**Lab Order:** 19050900  
**Received Date:** 5/22/2019 8:55:00 AM  
**Reported Date:** 6/11/2019

Sample Information:

**Lab ID:** 19050900-199      Client Sample ID: Outside Rm 155 Mens RR-Sink  
Collection Date: 5/22/2019 6:40:00 AM      Collected By: John Jordan  
Matrix: Drinking Water      Sample Location: Outside Rm 155 Mens RR-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00155		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-200      Client Sample ID: Outside Rm 155 Womens RR-Sink (L)  
Collection Date: 5/22/2019 6:42:00 AM      Collected By: John Jordan  
Matrix: Drinking Water      Sample Location: Outside Rm 155 Womens RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00185		0.000103	mg/L	1	6/7/2019	0.0150		

**Lab ID:** 19050900-201      Client Sample ID: Outside Rm 155 Womens RR-Sink (R)  
Collection Date: 5/22/2019 6:41:00 AM      Collected By: John Jordan  
Matrix: Drinking Water      Sample Location: Outside Rm 155 Womens RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.000998		0.000103	mg/L	1	6/7/2019	0.0150		

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 19050900

11-Jun-19

Client: Medford School District

Project: 18-00 Central 2019 Lead Testing

TestCode: LEAD\_DW

Sample ID: 19050900-020AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 6/4/2019	RunNo: 1582						
Client ID: Rm 102-Sink (8)	Batch ID: 718	TestNo: E200.8	E200.8	Analysis Date: 6/6/2019	SeqNo: 29302						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.130	0.000104	0.1000	0.02931	100	70	130				
------	-------	----------	--------	---------	-----	----	-----	--	--	--	--

Sample ID: 19050900-020AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 6/4/2019	RunNo: 1582						
Client ID: Rm 102-Sink (8)	Batch ID: 718	TestNo: E200.8	E200.8	Analysis Date: 6/6/2019	SeqNo: 29303						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.133	0.000104	0.1000	0.02931	103	70	130	0.1295	2.30	20	
------	-------	----------	--------	---------	-----	----	-----	--------	------	----	--

Sample ID: <b>MB-719</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/4/2019</b>	RunNo: <b>1582</b>						
Client ID: <b>PBW</b>	Batch ID: <b>719</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29306</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.000103									
------	----	----------	--	--	--	--	--	--	--	--	--

Sample ID: <b>LCS-719</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/4/2019</b>	RunNo: <b>1582</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>719</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29307</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.101	0.000104	0.1000	0	101	85	115				
------	-------	----------	--------	---	-----	----	-----	--	--	--	--

Qualifiers:	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	H Holding times for preparation or analysis exceed
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit	PL Permit Limit
	RL Reporting Detection Limit		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 19050900

11-Jun-19

Client: Medford School District

Project: 18-00 Central 2019 Lead Testing

TestCode: LEAD\_DW

Sample ID: <b>MB-718</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/4/2019</b>	RunNo: <b>1582</b>						
Client ID: <b>PBW</b>	Batch ID: <b>718</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29314</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.000103									
------	----	----------	--	--	--	--	--	--	--	--	--

Sample ID: <b>LCS-718</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/4/2019</b>	RunNo: <b>1582</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>718</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29315</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.0992	0.000104	0.1000	0	99.2	85	115				
------	--------	----------	--------	---	------	----	-----	--	--	--	--

Sample ID: <b>19050900-040AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/4/2019</b>	RunNo: <b>1582</b>						
Client ID: <b>Outside Rm(160/161)</b>	Batch ID: <b>719</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29348</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.101	0.000104	0.1000	0.003268	97.3	70	130				
------	-------	----------	--------	----------	------	----	-----	--	--	--	--

Sample ID: <b>19050900-040AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/4/2019</b>	RunNo: <b>1582</b>						
Client ID: <b>Outside Rm(160/161)</b>	Batch ID: <b>719</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29349</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.100	0.000104	0.1000	0.003268	96.9	70	130	0.1005	0.316	20	
------	-------	----------	--------	----------	------	----	-----	--------	-------	----	--

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit	PL Permit Limit	
RL Reporting Detection Limit			

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 19050900

11-Jun-19

Client: Medford School District

Project: 18-00 Central 2019 Lead Testing

TestCode: LEAD\_DW

Sample ID: <b>MB-721</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/4/2019</b>	RunNo: <b>1582</b>						
Client ID: <b>PBW</b>	Batch ID: <b>721</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29352</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000103									

Sample ID: <b>LCS-721</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/4/2019</b>	RunNo: <b>1582</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>721</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29353</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.101	0.000104	0.1000	0	101	85	115				

Sample ID: 19050900-065AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 6/4/2019	RunNo: 1582						
Client ID: Rm 274-Sink	Batch ID: 721	TestNo: E200.8	E200.8	Analysis Date: 6/6/2019	SeqNo: 29376						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.101	0.000104	0.1000	0.002524	98.8	70	130				

Sample ID: 19050900-065AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 6/4/2019	RunNo: 1582						
Client ID: Rm 274-Sink	Batch ID: 721	TestNo: E200.8	E200.8	Analysis Date: 6/6/2019	SeqNo: 29377						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.105	0.000104	0.1000	0.002524	103	70	130	0.1014	3.74	20	

### Qualifiers:

\* Value exceeds Maximum Contaminant Level.  
MI Recovery outside control limits due to Matrix Interference  
RL Reporting Detection Limit

C1 Sample container temperature is out of limit as specified at testcode  
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceed  
PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 19050900

11-Jun-19

Client: Medford School District

Project: 18-00 Central 2019 Lead Testing

TestCode: LEAD\_DW

Sample ID: <b>MB-726</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1582</b>
Client ID: <b>PBW</b>	Batch ID: <b>726</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29380</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.000103

Sample ID: <b>LCS-726</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1582</b>
Client ID: <b>LCSW</b>	Batch ID: <b>726</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29381</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.0995 0.000104 0.1000 0 99.5 85 115

Sample ID: <b>19050900-087AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1582</b>
Client ID: <b>Paint Booth Shop-Si</b>	Batch ID: <b>726</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29404</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.103 0.000104 0.1000 0.003615 99.3 70 130

Sample ID: <b>19050900-087AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1582</b>
Client ID: <b>Paint Booth Shop-Si</b>	Batch ID: <b>726</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/6/2019</b>	SeqNo: <b>29405</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.100 0.000104 0.1000 0.003615 96.4 70 130 0.1029 2.81 20

**Qualifiers:** \* Value exceeds Maximum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceed  
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit PL Permit Limit  
RL Reporting Detection Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 19050900

11-Jun-19

Client: Medford School District

Project: 18-00 Central 2019 Lead Testing

TestCode: LEAD\_DW

Sample ID: <b>MB-758</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/6/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>PBW</b>	Batch ID: <b>758</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30112</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000103									

Sample ID: <b>LCS-758</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/6/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>758</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30113</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.102	0.000104	0.1000	0	102	85	115				

Sample ID: <b>19050900-107AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/6/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>Tunnel 12 Womens</b>	Batch ID: <b>758</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30136</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.105	0.000104	0.1000	0.001429	104	70	130				

Sample ID: 19050900-107AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 6/6/2019	RunNo: 1616						
Client ID: Tunnel 12 Womens	Batch ID: 758	TestNo: E200.8	E200.8	Analysis Date: 6/7/2019	SeqNo: 30137						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.106	0.000104	0.1000	0.001429	104	70	130	0.1050	0.706	20	

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level.
- MI Recovery outside control limits due to Matrix Interference
- RL Reporting Detection Limit

C1 Sample container temperature is out of limit as specified at testcode  
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceed  
PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 19050900

11-Jun-19

Client: Medford School District

Project: 18-00 Central 2019 Lead Testing

TestCode: LEAD\_DW

Sample ID: <b>MB-738</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>PBW</b>	Batch ID: <b>738</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30140</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID: <b>LCS-738</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>738</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30141</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.104 0.000104 0.1000 0 104 85 115

Sample ID: <b>19050900-128AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>Outside Rm 288 Wo</b>	Batch ID: <b>738</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30164</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.109 0.000104 0.1000 0.004407 104 70 130

Sample ID: <b>19050900-128AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>Outside Rm 288 Wo</b>	Batch ID: <b>738</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30165</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.110 0.000104 0.1000 0.004407 105 70 130 0.1088 1.04 20

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level.
- MI Recovery outside control limits due to Matrix Interference
- RL Reporting Detection Limit

C1 Sample container temperature is out of limit as specified at testcode

ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceed

PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 19050900

11-Jun-19

Client: Medford School District

Project: 18-00 Central 2019 Lead Testing

TestCode: LEAD\_DW

Sample ID: <b>MB-741</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>PBW</b>	Batch ID: <b>741</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30168</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.000103									
------	----	----------	--	--	--	--	--	--	--	--	--

Sample ID: <b>LCS-741</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>741</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30169</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.104	0.000104	0.1000	0	104	85	115				
------	-------	----------	--------	---	-----	----	-----	--	--	--	--

Sample ID: <b>19050900-148AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>Girls Locker Rm-Sin</b>	Batch ID: <b>741</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30192</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.111	0.000104	0.1000	0.008656	102	70	130				
------	-------	----------	--------	----------	-----	----	-----	--	--	--	--

Sample ID: <b>19050900-148AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>Girls Locker Rm-Sin</b>	Batch ID: <b>741</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30193</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.107	0.000104	0.1000	0.008656	98.6	70	130	0.1109	3.36	20	
------	-------	----------	--------	----------	------	----	-----	--------	------	----	--

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit	PL Permit Limit	
RL Reporting Detection Limit			

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 19050900

11-Jun-19

Client: Medford School District

Project: 18-00 Central 2019 Lead Testing

TestCode: LEAD\_DW

Sample ID: <b>MB-743</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>PBW</b>	Batch ID: <b>743</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30196</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000103									

Sample ID: <b>LCS-743</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1616</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>743</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30197</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.101	0.000104	0.1000	0	101	85	115				

Sample ID: 19050900-169AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 6/5/2019	RunNo: 1616						
Client ID: Rm 144-Sink (5)	Batch ID: 743	TestNo: E200.8	E200.8	Analysis Date: 6/7/2019	SeqNo: 30220						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.155	0.000104	0.1000	0.05151	103	70	130				

Sample ID: 19050900-169AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 6/5/2019	RunNo: 1616						
Client ID: Rm 144-Sink (5)	Batch ID: 743	TestNo: E200.8	E200.8	Analysis Date: 6/7/2019	SeqNo: 30221						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.159	0.000104	0.1000	0.05151	107	70	130	0.1549	2.53	20	

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level.
- MI Recovery outside control limits due to Matrix Interference
- RL Reporting Detection Limit

C1 Sample container temperature is out of limit as specified at testcode

ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceed

PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 19050900

11-Jun-19

Client: Medford School District

Project: 18-00 Central 2019 Lead Testing

TestCode: LEAD\_DW

Sample ID: <b>MB-744</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1640</b>						
Client ID: <b>PBW</b>	Batch ID: <b>744</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30911</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.000103									
------	----	----------	--	--	--	--	--	--	--	--	--

Sample ID: <b>LCS-744</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1640</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>744</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30912</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.110	0.000104	0.1000	0	110	85	115				
------	-------	----------	--------	---	-----	----	-----	--	--	--	--

Sample ID: <b>19050900-193AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1640</b>						
Client ID: <b>Rm 142B (E)-Sink (7)</b>	Batch ID: <b>744</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30935</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.129	0.000104	0.1000	0.03579	93.7	70	130				
------	-------	----------	--------	---------	------	----	-----	--	--	--	--

Sample ID: <b>19050900-193AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1640</b>						
Client ID: <b>Rm 142B (E)-Sink (7)</b>	Batch ID: <b>744</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30936</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.136	0.000104	0.1000	0.03579	101	70	130	0.1295	5.15	20	
------	-------	----------	--------	---------	-----	----	-----	--------	------	----	--

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit	PL Permit Limit	
RL Reporting Detection Limit			

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 19050900

11-Jun-19

Client: Medford School District

Project: 18-00 Central 2019 Lead Testing

TestCode: LEAD\_DW

Sample ID: <b>MB-746</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1640</b>						
Client ID: <b>PBW</b>	Batch ID: <b>746</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30939</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000103									

Sample ID: <b>LCS-746</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1640</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>746</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30940</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.101	0.000104	0.1000	0	101	85	115				

Sample ID: <b>19050900-201AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1640</b>						
Client ID: <b>Outside Rm 155 Wo</b>	Batch ID: <b>746</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30949</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.105	0.000104	0.1000	0.0009981	104	70	130				

Sample ID: <b>19050900-201AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/5/2019</b>	RunNo: <b>1640</b>						
Client ID: <b>Outside Rm 155 Wo</b>	Batch ID: <b>746</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/7/2019</b>	SeqNo: <b>30950</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.103	0.000104	0.1000	0.0009981	102	70	130	0.1052	1.76	20	

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level.
- MI Recovery outside control limits due to Matrix Interference
- RL Reporting Detection Limit

C1 Sample container temperature is out of limit as specified at testcode

ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceed

PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 19050900

11-Jun-19

Client: Medford School District

Project: 18-00 Central 2019 Lead Testing

TestCode: LEAD\_DW

Sample ID: <b>MB-773</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/7/2019</b>	RunNo: <b>1646</b>						
Client ID: <b>PBW</b>	Batch ID: <b>773</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/8/2019</b>	SeqNo: <b>31127</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.000103									
------	----	----------	--	--	--	--	--	--	--	--	--

Sample ID: <b>LCS-773</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/7/2019</b>	RunNo: <b>1646</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>773</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/8/2019</b>	SeqNo: <b>31128</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.104	0.000104	0.1000	0	104	85	115				
------	-------	----------	--------	---	-----	----	-----	--	--	--	--

Sample ID: <b>19050900-191AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/7/2019</b>	RunNo: <b>1698</b>						
Client ID: <b>Rm 142B (E)-Sink (5-</b>	Batch ID: <b>773</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/10/2019</b>	SeqNo: <b>32315</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.543	0.000520	0.1000	0.4315	112	70	130				
------	-------	----------	--------	--------	-----	----	-----	--	--	--	--

Sample ID: <b>19050900-191AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>mg/L</b>	Prep Date: <b>6/7/2019</b>	RunNo: <b>1698</b>						
Client ID: <b>Rm 142B (E)-Sink (5-</b>	Batch ID: <b>773</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>6/10/2019</b>	SeqNo: <b>32316</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.548	0.000520	0.1000	0.4315	116	70	130	0.5216	4.87	20	
------	-------	----------	--------	--------	-----	----	-----	--------	------	----	--

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	H Holding times for preparation or analysis exceed
MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit	PL Permit Limit	
RL Reporting Detection Limit			

Original





**Environmental Testing Laboratory**  
245 South Grape Street \* Medford, OR 97501  
(541) 770-5678 fax (541) 770-2901

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

## Section A

### Required Client Information

Company:	MSD 549C
Address:	815 South Oakdale Avenue Medford, OR 97501
Email:	<a href="mailto:ron.havnear@medford.k12.or.us">ron.havnear@medford.k12.or.us</a>
Phone:	541-840-4315 Fax:
Collected By (Print):	B. H. Bartlett
Collected By (Sign):	<i>B. H. Bartlett</i>
Email Report <input type="checkbox"/> Yes <input type="checkbox"/> No	Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No	

## Section B

### Required Project Information

Project Name:	2019 Lead Testing
Project Number:	18-00 Central
Report To:	<a href="mailto:ron.havnear@medford.k12.or.us">ron.havnear@medford.k12.or.us</a>
Copy To:	<a href="mailto:andy.chasteen@medford.k12.or.us">andy.chasteen@medford.k12.or.us</a>

## Section C

### Invoice Information

Attention:	Accounting
Company Name:	Medford School District
Address:	815 South Oakdale Avenue Medford, OR 97501
P.O. #	61172

## Section D

### Rush Status (Subject to Scheduling)

Standard	10-14 Days
5 Business Days (50% surcharge)	
3 Business Days (75% surcharge)	
24 - 48 hours (100% surcharge)	
Other	

Authorized ☐ Yes ☐ No

## Section E

### Sample Information

Sample ID	Bottle #	Matrix*	Date Collected	Time Collected
Main Entrance Women's Restroom - Sink (1)		DW	5/22/2019	5:45 am
Main Entrance Women's Restroom - Sink (2)		DW	5/23/2019	5:45 am
Main Entrance Women's Restroom - Sink (3)		DW	5/24/2019	5:45 am
Main Entrance Women's Restroom - Sink (4)		DW	5/25/2019	5:45 am
Main Entrance Women's Restroom - Sink (5)		DW	5/26/2019	5:45 am
Main Entrance Women's Restroom - Sink (6)		DW	5/27/2019	5:45 am
Main Entrance Women's Restroom - Sink (7)		DW	5/28/2019	5:45 am
Room 103 - Sink (1)		DW	5/29/2019	5:45 am
Room 103 - Sink (2)		DW	5/30/2019	5:45 am
Room 103 - Sink (3)		DW	5/31/2019	5:45 am
Room 103 - Sink (4)		DW	6/1/2019	5:45 am
Inbetween Room 102/103 - Sink		DW	6/2/2019	5:55 am
Room 102 - Sink (1)		DW	6/3/2019	6:00 am
Room 102 - Sink (2)		DW	6/4/2019	6:00 am
Room 102 - Sink (3)		DW	6/5/2019	6:01 am
Room 102 - Sink (4)		DW	6/6/2019	6:01 am
Room 102 - Sink (5)		DW	6/7/2019	6:02 am
Room 102 - Sink (6)		DW	6/8/2019	6:02 am
Room 102 - Sink (7)		DW	6/9/2019	6:03 am
Room 102 - Sink (8)		DW	6/10/2019	6:03 am
By Room 109 Unisex Restroom (Left) - Sink		DW	6/11/2019	6:08 am
By Room 109 Unisex Restroom (Right) - Sink		DW	6/12/2019	6:08 am
By Room 109 Men's Restroom - Sink (Left)		DW	6/13/2019	6:10 am
By Room 109 Men's Restroom - Sink (Center)		DW	6/14/2019	6:10 am
By Room 109 Men's Restroom - Sink (Right)		DW	6/15/2019	6:10 am

No. of Containers

### Analysis Requested

NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
1900900		061A
		002A
		003A
		004A
		005A
		006A
		007A
		008A
		009A
		010A
		011A
		012A
		013A
		014A
		015A
		016A
		017A
		018A
		019A
		020A
		021A
		022A
		023A
		024A
		025A







# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to)	
Company:	MSD 549C	Project Name:	2019 Lead Testing	Attention:	Accounting	Standard 10-14 Da	
Address:	815 South Oakdale Avenue Medford, OR 97501	Project Number:	18-00 Central	Company Name:	Medford School Distri	5 Business Days (5	
Email:	ron.havnear@medford.k12.or.us	Report To:	ron.havnear@medford.k12.or.us	Address:	815 South Oakdale Avenue Medford, OR 97501	3 Business Days (7	
Phone:	541-840-4315 Fax:	Copy To:	andy.chasteen@medford.k12.or.us	P.O. #	61172	24 - 48 hours (100	
Collected By (Print): <u>Morton Taylor</u>						Other	
Collected By (Sign): <u>Morton Taylor</u>						Authorized	
Email Report	Yes ___ No ___	Mail Report	Yes ___ No ___				
Fax Report	Yes ___ No ___						

Section E 18-01 North+A23:C46				Analysis Requested										No. of Containers		Remarks/Field Data	
Sample ID	Bottle #	Matrix*	Date Collected	Time Collected													
Room 141 - Sink (1)		DW	5/22/2019	5:38am											1		033A
Room 141 - Sink (2)		DW	5/22/2019	5:39am											1		034A
Room 141 - Sink (3)		DW	5/22/2019	5:40am											1		035A
Room 141 - Sink (4)		DW	5/22/2019	5:41am											1		036A
Room 141 - Sink (5)		DW	5/22/2019	5:42am											1		037A
Room 141 - Sink (6)		DW	5/22/2019	5:43am											1		038A
Outside Board Room (160/161) Men's Restroom - Sink (Left)		DW	5/22/2019	5:48am											1		039A
Outside Board Room (160/161) Men's Restroom - Sink (Right)		DW	5/22/2019	5:49am											1		040A
Outside Board Room (160/161) Women's Restroom - Sink (Left)		DW	5/22/2019	5:50am											1		041A
Outside Board Room (160/161) Women's Restroom - Sink (Right)		DW	5/22/2019	5:51am											1		042A
Kitchen - Sink (Pre-rinse/Dishwasher)		DW	5/22/2019	5:58am											1		043A
Kitchen - Sink (Hand Wash)		DW	5/22/2019	5:59am											1		044A
Kitchen Unisex Restroom - Sink		DW	5/22/2019	6:00am											1		045A
Below The Stage Near Dressing Rooms (Basement) - Sink (Left)		DW	5/22/2019	6:04am											1		046A
Below The Stage Near Dressing Rooms (Basement) - Sink (Center)		DW	5/22/2019	6:05am											1		047A
Below The Stage Near Dressing Rooms (Basement) - Sink (Right)		DW	5/22/2019	6:06am											1		048A
Hall of Fame Men's Restroom - Sink (Left)		DW	5/22/2019	6:11am											1		049A
Hall of Fame Men's Restroom - Sink (Center)		DW	5/22/2019	6:12am											1		050A
Hall of Fame Men's Restroom - Sink (Right)		DW	5/22/2019	6:13am											1		051A
Hall of Fame Women's Restroom - Sink (Left)		DW	5/22/2019	6:15am											1		052A
Hall of Fame Women's Restroom - Sink (Center)		DW	5/22/2019	6:16am											1		053A
Hall of Fame Women's Restroom - Sink (Right)		DW	5/22/2019	6:17am											1		054A
Room 279 - Sink (1)		DW	5/22/2019	6:26am											1		055A
Room 279 - Sink (2)		DW	5/22/2019	6:27am											1		056A
Room 279 - Sink (3)		DW	5/22/2019	6:28am											1		057A

19050900  
NRC Workorder #  
(Lab Use Only)









Environmental Testing Laboratory  
245 South Grape Street \* Medford, OR 97501  
(541) 770-5678 fax (541) 770-2901

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

## Section A

### Required Client Information

Company:	MSD 549C
Address:	815 South Oakdale Avenue Medford, OR 97501
Email:	ron.havnear@medford.k12.or.us
Phone:	541-840-4315 Fax:
Collected By (Print):	Gary Severe
Collected By (Sign):	<i>Gary Severe</i>
Email Report	Yes ___ No ___
Fax Report	Yes ___ No ___

## Section B

### Required Project Information

Project Name:	2019 Lead Testing
Project Number:	18-00 Central
Report To	ron.havnear@medford.k12.or.us
Copy To	andy.chasteen@medford.k12.or.us

## Section C

### Invoice Information

Attention:	Accounting
Company Name:	Medford School District
Address:	815 South Oakdale Avenue Medford, OR 97501
P.O. #	61172

## Section D

### Rush Status (Subject to Scheduling)

Standard 10-14 Days	___
5 Business Days (50% surcharge)	___
3 Business Days (75% surcharge)	___
24 - 48 hours (100% surcharge)	___
Other	___

Authorized	Yes ___ No ___
------------	----------------

## Section E

### Sample Information

Sample ID	Bottle #	Matrix*	Date Collected	Time Collected	No. of Containers
Facilities Office Men's Restroom - Sink (Left)		DW	5/22/2019	5:33 AM	1
Facilities Office Men's Restroom - Sink (Right)		DW	5/22/2019	5:34	1
Facilities Office Women's Restroom - Sink (Left)		DW	5/22/2019	5:35	1
Facilities Office Women's Restroom - Sink (Right)		DW	5/22/2019	5:35	1
Warehouse Unisex Restroom - Sink		DW	5/22/2019	5:37	1
NTS Men's Restroom - Sink		DW	5/22/2019	6:22	1
NTS Women's Restroom - Sink		DW	5/22/2019	6:23	1
Men's Restroom Outside NTS (C2) Entrance - Sink (Left)		DW	5/22/2019	6:15	1
Men's Restroom Outside NTS (C2) Entrance - Sink (Middle)		DW	5/22/2019	6:16	1
Men's Restroom Outside NTS (C2) Entrance - Sink (Right)		DW	5/22/2019	6:17	1
Women's Restroom Outside NTS (C2) Entrance - Sink (Left)		DW	5/22/2019	6:20	1
Women's Restroom Outside NTS (C2) Entrance - Sink (Right)		DW	5/22/2019	6:21	1
Publications - Sink		DW	5/22/2019	6:01	1
Across From Sodexo Break Room Men's Restroom - Sink (Left)		DW	5/22/2019	5:59	1
Across From Sodexo Break Room Men's Restroom - Sink (Right)		DW	5/22/2019	5:59	1
Across From Sodexo Break Room Women's Restroom - Sink		DW	5/22/2019	5:58	1
Upstairs (Police Training Room) - Sink		DW	5/22/2019	5:57	1
Sodexo/Paint Shop Men's Restroom - Sink (Left)		DW	5/22/2019	5:52	1
Sodexo/Paint Shop Men's Restroom - Sink (Right)		DW	5/22/2019	5:52	1
Sodexo/Paint Shop Women's Restroom - Sink (Left)		DW	5/22/2019	5:50	1
Sodexo/Paint Shop Women's Restroom - Sink (Right)		DW	5/22/2019	5:50	1
Paint Booth Shop - Sink (Utility)		DW	5/22/2019	5:48	1
Carpenter Shop Men's Restroom - Sink		DW	5/22/2019	5:46	1
Metal Shop - Trough Sink (Left Fixture)		DW	5/22/2019	5:44	1
Metal Shop - Trough Sink (Right Fixture)		DW	5/22/2019	5:44	1

NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
9050900	0010A	0008A
	0070A	0009A
	0080A	0010A
	0090A	0011A
	0100A	0012A
	0110A	0013A
	0120A	0014A
	0130A	0015A
	0140A	0016A
	0150A	0017A
	0160A	0018A
	0170A	0019A
	0180A	0020A
	0190A	0021A
	0200A	0022A
	0210A	0023A
	0220A	0024A
	0230A	0025A
	0240A	0026A
	0250A	0027A
	0260A	0028A
	0270A	0029A
	0280A	0030A
	0290A	0031A
	0300A	0032A
	0310A	0033A
	0320A	0034A
	0330A	0035A
	0340A	0036A
	0350A	0037A
	0360A	0038A
	0370A	0039A
	0380A	0040A
	0390A	0041A
	0400A	0042A



DW	5/22/19	605 AM
----	---------	--------

0917	0934
------	------

\*Matrix: DW - Drinking Water   WW - Wastewater   W - Water   S - Soil/Solid   SL - Sludge   O - Oil   WP - Wipe   OT - Other

## Section F

Relinquish/Receive

## Sign

Print

Date \_\_\_\_\_

Time

Section G  
Lab Use Only

Lab Use Only

Lab Use Only  
Temp: amb  
4°C +/- 2°C: Yes No

Lab Use Only  
Temp: amb  
4°C +/- 2°C: Yes  
Received on Ice: Yes  
Number of Bottles Received:

Lab Use Only

Temp: 4°C

4°C +/- 2°C: Yes No

Received on Ice: Yes No

Number of Bottles Received: \_\_\_\_\_

pH Checked: \_\_\_\_\_

COC Seals Intact: Yes No

NA

Received Via ☒ UPS ☐ FedEX ☐ Other ☒ Hand  
Document: ☒ Invoice ☐ Bill of Lading ☐ Packing Slip





# Chain of Custody Record

Page 1 of 3

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Authorized \_\_\_\_\_ Yes \_\_\_\_\_ No \_\_\_\_\_

Section E Sample Information				No. of Containers	NRC Workorder # 1909900		
Sample ID	Bottle #	Matrix*	Date Collected	Time Collected	Remarks/Field Data	NRC Sample # (Lab Use Only)	
Maslow							
Unisex Restroom By Front Door - Sink		DW	5/22/2019	7:13	092A	091A	
North East Corner of Building - Sink (Utility)		DW	5/22/2019	7:13	093A	092A	
Unisex Staff Restroom (Near Clothes Closet) - Sink		DW	5/22/2019	7:13	094A	093A	
Speigelburg							
Home Side South (Blue) Men's Restroom - Sink (Left)		DW	5/22/2019	5:58	095A	094A	
Home Side South (Blue) Men's Restroom - Sink (Right)		DW	5/22/2019	5:58	096A	095A	
Home Side South (Blue) Women's Restroom - Sink (Left)		DW	5/22/2019	5:59	097A	096A	
Home Side South (Blue) Women's Restroom - Sink (Right)		DW	5/22/2019	5:59	098A	097A	
Home Side South Locker Room - Trough Sink		DW	5/22/2019	6:03	099A	098A	
Home Side North Locker Room - Sink		DW	5/22/2019	6:05	100A	099A	
Home Side North (Red) Men's Restroom - Sink (Left)		DW	5/22/2019	6:10	101A	100A	
Home Side North (Red) Men's Restroom - Sink (Right)		DW	5/22/2019	6:10	102A	101A	
Home Side North (Red) Women's Restroom - Sink (Left)		DW	5/22/2019	6:11	103A	102A	
Home Side North (Red) Women's Restroom - Sink (Right)		DW	5/22/2019	6:11	104A	103A	
W/P Box On Homeside Roof Men's Restroom - Sink	N/E	DW	5/22/2019			105A	
W/P Box On Homeside Roof Women's Restroom - Sink	N/E	DW	5/22/2019			106A	
East Side Visitor's Locker Room (North) - Sink (Left Fixture)		DW	5/22/2019	6:15	107A	106A	
East Side Visitor's Locker Room (North) - Sink (Right Fixture)		DW	5/22/2019			108A	
Unisex 11 Men's Restroom - Sink		DW	5/22/2019	6:26	109A	108A	
Unisex 12 Women's Restroom - Sink		DW	5/22/2019	6:29	110A	109A	
Unisex 12 Unisex Restroom - Sink		DW	5/22/2019	6:30	111A	110A	
East Side South Locker Room (St. Mary's) - Sink (Left)		DW	5/22/2019	6:36	112A	111A	
East Side South Locker Room (St. Mary's) - Sink (Right)		DW	5/22/2019	6:36	113A	112A	
East Side South Locker Room (St. Mary's) - Shower Head (1)		DW	5/22/2019	6:42	114A	113A	









This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 1 of 3

**Environmental Testing Laboratory**  
245 South Grape Street \* Medford, OR 97501  
(541) 770-5678 fax (541) 770-2901

[illegible]

Section E Sample Information				No. of Conts							NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Sample ID	Bottle #	Matrix*	Date Collected									
Room 288 - Sink (1)		DW	5/22/2019	5:49	1						120A	22A
Room 288 - Sink (2)		DW	5/22/2019	5:49	1						121A	23A
Room 288 - Sink (3)		DW	5/22/2019	5:50	1						122A	24A
Room 288 - Sink (4)		DW	5/22/2019	5:50	1						123A	25A
Room 288 - Sink (5)		DW	5/22/2019	5:51	1						124A	26A
Room 288 - Sink (6)		DW	5/22/2019	5:51	1						125A	27A
Outside Room 288 Women's Restroom - Sink (Left)		DW	5/22/2019	5:54	1						126A	28A
Outside Room 288 Women's Restroom - Sink (Center)		DW	5/22/2019	5:54	1						127A	29A
Outside Room 288 Women's Restroom - Sink (Right)		DW	5/22/2019	5:54	1						128A	30A
Across From Room 290 Men's Restroom - Sink		DW	5/22/2019	5:57	1						129A	31A
Across From Room 290 Unisex Restroom - Sink		DW	5/22/2019		1						130A	32A
Room 291 - Sink		DW	5/22/2019	5:58	1						131A	33A
Room 286 - Sink		DW	5/22/2019	6:02	1						132A	34A
Room 285 Unisex Restroom - Sink		DW	5/22/2019	6:05	1						133A	35A
Room 284 - Sink		DW	5/22/2019	6:04	1						134A	36A
Near Room 280 Women's Restroom - Sink (Left)		DW	5/22/2019	6:08	1						135A	37A
Near Room 280 Women's Restroom - Sink (Center)		DW	5/22/2019	6:08	1						136A	38A
Near Room 280 Women's Restroom - Sink (Right)		DW	5/22/2019	6:08	1						137A	39A
Gym					1						138A	40A
Lobby Men's Restroom - Sink (1)		DW	5/22/2019	6:23	1						139A	41A
Lobby Men's Restroom - Sink (2)		DW	5/22/2019	6:23	1						140A	42A
Lobby Men's Restroom - Sink (3)		DW	5/22/2019	6:24	1						141A	43A
Lobby Men's Restroom - Sink (4)		DW	5/22/2019	6:24	1						142A	44A
Lobby Men's Restroom - Sink (5)		DW	5/22/2019	6:24	1						143A	45A
Lobby Women's Restroom - Sink (1)		DW	5/22/2019	6:26	1						144A	46A















---

B	Analyte detected in the associated method blank.
BA	BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
C	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF	Results confirmed by re-analysis.
CU	Cleanup performed as specified by method.
D1	The diesel elution pattern for the sample is not typical.
D2	The sample appears to be a heavier hydrocarbon range than diesel.
D3	The sample appears to be a lighter hydrocarbon range than diesel.
D4	Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
D5	Detected hydrocarbons in the diesel range appear to be weathered diesel.
E	Estimated value.
ER	Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC	Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
G1	The gasoline elution pattern for the sample is not typical.
G2	The sample appears to be a heavier hydrocarbon range than gasoline.
G3	The sample appears to be a lighter hydrocarbon range than gasoline.
G4	Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
HP	Sample re-analysis performed outside of method specified holding time.
HR	Sample received outside of method specified holding time.
HS	Sample analyzed for volatile organics contained headspace.
HT <input type="checkbox"/>	At the client's request, the sample was analyzed outside of method specified holding time.
H	Analysis performed outside of method specified holding time.
J	Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
L	Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
MI	Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
N	See Case Narrative on page 2 of report.
NLR	No Legionella Recovered.
PLR	Presence of Legionella Recovered.
Q	Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R	Relative percent difference (RPD) is outside of the accepted recovery limits.
R1	Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
R3	The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4	Duplicate analysis failed due to result being at or near the method reporting limit.
S	Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1	Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC	Sub-contracted to another laboratory for analysis.
SP	Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
#	Value exceeds regulatory level for TCLP contaminant.
X1	The motor oil elution pattern for the sample is not typical.
X2	The sample appears to be a heavier hydrocarbon range than motor oil.
X3	The sample appears to be a lighter hydrocarbon range than motor oil.
*	Value exceeds Maximum Contaminant Level or is outside the acceptable range.

---