



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779
T: 631.580.3191 • F: 631.580.3195 • W: envirohealth.org

August 17, 2022

Mr. Mark Finnerty
Eastern Suffolk BOCES
100 Barton Avenue
Patchogue, NY 11772

Re: **Islip Career Center (ICC) - Lead in Water Sampling & Analysis 2020 - 2022**

Dear Mr. Finnerty,

On August 12, 2022, EnviroScience Consultants performed new fixture lead in drinking water sampling of the newly renovated Culinary Kitchen at the Islip Career Center

First draw samples were collected in wide-mouth 250 milliliter containers and during the early morning, prior to any water sources being used. The samples were transported to New York Environmental Laboratory and were analyzed for lead concentration.

There were no exceedances.

Please see the attached updated outlet inventories for filing in your Lead in Drinking Water Sampling and Remediation Plan binder.

Should you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Shannon Gallagher".

Shannon Gallagher

Laboratory Report

NYE Report #: 2224146-22702

August 16, 2022

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Islip Career Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on August 15, 2022. New York Environmental analyzed the samples on August 16, 2022 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	12 Aug 2022
Date Received:	15 Aug 2022
Date Analyzed:	16 Aug 2022

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
220815L002	1	New Culinary Kitchen Dishwasher Station-SK, Initial	1.00	2.13	µg/L	
220815L003	2	New Culinary Kitchen Dishwasher Station-SPY, Initial	1.00	1.85	µg/L	
220815L004	3	New Culinary Kitchen 3-Bay-SK, Initial	1.00	1.90	µg/L	
220815L005	4	New Culinary Kitchen 3-Bay-SPY, Initial	1.00	<1.00	µg/L	
220815L006	5	New Culinary Kitchen Island A Potfiller-SP, Initial	1.00	14.6	µg/L	
220815L007	6	New Culinary Kitchen Island A @ A (closest to hall)-SK, Initial	1.00	<1.00	µg/L	
220815L008	7	New Culinary Kitchen Island A @ B-SK, Initial	1.00	1.98	µg/L	
220815L009	8	New Culinary Kitchen Island B Potfiller-SP, Initial	1.00	6.55	µg/L	
220815L010	9	New Culinary Kitchen Island B @ A-SK, Initial	1.00	1.82	µg/L	
220815L011	10	New Culinary Kitchen Island B @ B (rear)-SK, Initial	1.00	<1.00	µg/L	
220815L012	11	New Culinary Kitchen Ice Machine-IM, Initial	1.00	1.52	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Custodial Closet in IOC Wing	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1002-1	IOC Room 7 Office Bathroom	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1003-1	Hallway by IOC Faculty Room	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1003-2	Hallway by IOC Faculty Room	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1004-1	IOC Room 9 Bathroom	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1005-1	Custodial Closet by Room 4	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1006-1	Girl's Bathroom by Room 4 @ A	SK	App	3.61	2/20/2020	-	-	-	None	-	-	-
1006-2	Girl's Bathroom by Room 4 @ B	SK	App	11.3	2/20/2020	-	-	-	None	-	-	-
1006-3	Girl's Bathroom by Room 4 @ C	SK	App	13.5	2/20/2020	-	-	-	None	-	-	-
1007-1	Boy's Bathroom by Room 4	SK	App	2.2	2/20/2020	-	-	-	None	-	-	-
1008-1	Men's Bathroom by Room 4 @ A	SK	App	4.04	2/20/2020	-	-	-	None	-	-	-
1008-2	Men's Bathroom by Room 4 @ B	SK	App	3.82	2/20/2020	-	-	-	None	-	-	-
1009-1	Women's Bathroom by Room 4	SK	App	1.16	2/20/2020	-	-	-	None	-	-	-
1009-2	Women's Bathroom ADA by Room 4	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1010-1	Room 2	SK	App	5.43	2/20/2020	-	-	-	None	-	-	-
1011-1	Room 1	SK	App	1.32	2/20/2020	-	-	-	None	-	-	-
1011-2	Room1 Bathroom	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1012-1	New Culinary Kitchen Classroom	SK	App	<1.0	10/27/2021				None	-	-	-
1013-1	New Culinary Kitchen @ A (closest to hallway)	SK	App	<1.0	10/27/2021				None	Removed from Service Renovated 2022	-	-
1013-2	New Culinary Kitchen @ B	SK	App	1.36	10/27/2021				None	Removed from Service Renovated 2022	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1013-3	New Culinary Kitchen @C	SK	App	1.41	10/27/2021				None	Removed from Service Renovated 2022	-	-
1013-3	New Culinary Kitchen @D (rear)	SK	App	<1.0	10/27/2021				None	Removed from Service Renovated 2022	-	-
1013-3	New Culinary Kitchen Handwash Island @ A	SK	N/A		10/27/2021				None	Removed from Service Renovated 2022	-	-
1013-3	New Culinary Kitchen Handwash Island @ B	SK	N/A		10/27/2021				None	Removed from Service Renovated 2022	-	-
1013-3	New Culinary Kitchen Ice Machine	IM	App		10/27/2021				None	Removed from Service Renovated 2022	-	-
1013-3	New Culinary Kitchen Dishwasher Station	SK	N/A		10/27/2021				None	Removed from Service Renovated 2022	-	-
1013-3	New Culinary Kitchen Serving Line Handwash	SK	N/A		10/27/2021				None	Removed from Service Renovated 2022	-	-
1013-1	New Culinary Kitchen Steamer	SP	App		8/12/2022				None	Removed from Service	-	-
1013-2	New Culinary Kitchen Dishwasher Station	SK	App	2.13	8/12/2022				None	-	-	-
1013-3	New Culinary Kitchen Dishwasher Station	SPY	App	1.85	8/12/2022				None	-	-	-
1013-4	New Culinary Kitchen Handwash @ A	SK	N/A		8/12/2022				None	SIGN	-	-
1013-5	New Culinary Kitchen 3-Bay	SK	App	1.9	8/12/2022				None	-	-	-
1013-6	New Culinary Kitchen 3-Bay	SPY	App	<1.0	8/12/2022				None	-	-	-
1013-7	New Culinary Kitchen Ice Machine	IM	App	1.52	8/12/2022				None	-	-	-
1013-8	New Culinary Kitchen	SS	N/A		8/12/2022				None	SIGN	-	-
1013-9	New Culinary Kitchen Island A Handwash	SK	N/A		8/12/2022				None	SIGN	-	-
1013-10	New Culinary Kitchen Island A Potfiller	SP	App	14.6	8/12/2022				None	-	-	-
1013-11	New Culinary Kitchen Island A @ A (closest to hall)	SK	App	<1.0	8/12/2022				None	-	-	-
1013-12	New Culinary Kitchen Island A @ B	SK	App	1.98	8/12/2022				None	-	-	-
1013-13	New Culinary Kitchen Island B Handwash	SK	N/A		8/12/2022				None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1013-14	New Culinary Kitchen Island B Potfiller	SP	App	6.55	8/12/2022				None	-	-	-
1013-15	New Culinary Kitchen Island B @ A	SK	App	1.82	8/12/2022				None	-	-	-
1013-16	New Culinary Kitchen Island B @ B (rear)	SK	App	<1.0	8/12/2022				None	-	-	-
1014-1	Custodial Closet by New Culinary Kitchen	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1015-1	Custodial Closet by Room 21	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1015-2	Custodial Closet by Room 21 Bathroom	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1016-1	Room 23 Horticulture Unit @ A	SK	App	6.18	2/20/2020	-	-	-	None	-	-	-
1016-2	Room 23 Horticulture Unit @ B	SK	App	4.57	2/20/2020	-	-	-	None	-	-	-
1017-1	Room 22 Auto Body Trough Sink @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1017-2	Room 22 Auto Body Trough Sink @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1017-3	Room 22 Auto Body Trough Sink @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1018-1	Room 21 Auto Mechanics Trough sink @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1018-2	Room 21 Auto Mechanics Trough sink @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1018-3	Room 21 Auto Mechanics Trough sink @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1018-4	Room 21 Auto Mechanics	WF	N/A		2/20/2020	-	-	-	None	CAPPED	-	-
1019-1	Room 20 Auto Mechanics Trough Sink @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1019-2	Room 20 Auto Mechanics Trough Sink @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1019-3	Room 20 Auto Mechanics Trough Sink @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1019-4	Room 20 Auto Mechanics	WF	App	7.73	2/20/2020	-	-	-	None	-	-	-
1020-1	Room 19 Weight Room	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1021-1	Room 15 Unit 1 @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1021-2	Room 15 Unit 1 @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1021-3	Room 15 Unit 1 @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1021-4	Room 15 Unit 2 @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1021-5	Room 15 Unit 2 @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1021-6	Room 15 Unit 2 @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1021-7	Room 15	WF	App	7	2/20/2020	-	-	-	None	-	-	-
1022-1	Room 18	WF	App	34.4	2/20/2020				Additional Sampling Required	Aerator flushed	8.53	11.6/2020
1022-2	Room 18 Unit @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1022-3	Room 18 Unit @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1022-4	Room 18 Unit @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1023-1	Room 16 Unit @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1023-2	Room 16 Unit @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1023-3	Room 16 Unit @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1024-1	Room 14 Canine Careers Unit @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1024-2	Room 14 Canine Careers Unit @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1024-3	Room 14 Canine Careers Unit @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1025-1	Room 13 sink	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1026-1	Hallway by Room 13	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1026-2	Hallway by Room 13	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1027-1	Women's Bathroom by Room 13 @ A	SK	App	5.26	2/20/2020	-	-	-	None	-	-	-
1027-2	Women's Bathroom by Room 13 @ B	SK	App	4.96	2/20/2020	-	-	-	None	-	-	-
1028-1	Men's Bathroom by Nurse's Office	SK	N/A	49.1	2/20/2020	-	-	-	None	SIGN	-	-
1029-1	Nurse's Office @ A	SK	App	33.3	2/20/2020	-	-	-	Additional Sampling Required	Aerator flushed	9.32	10/9/2020
1029-2	Nurse's Office @ B	SK	App	16.8	10/9/2020	-	-	-	Additional Sampling Required	-	-	-
1030-1	Faculty Room	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1030-2	Faculty Room	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1030-3	Faculty Room	SK	App	5.33	2/20/2020	-	-	-	None	-	-	-
1030-4	Faculty Room	SKY	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1031-1	Room 11	SK	App	30.6	2/20/2020	-	-	-	Additional Sampling Required	Aerator flushed	8.98	10/9/2020
1031-2	Room 11	WF	N/A	-	2/20/2020	-	-	-	None	CAPPED	-	-
1032-1	Room 12 Retail Center	SK	App	9.76	2/20/2020	-	-	-	None	-	-	-
1032-2	Room 12 Retail Center-hot water dispenser	OS	N/A	-	2/20/2020	-	-	-	None	-	-	-
1032-3	Room 12 - Back Sink	SK	App	13.8	2/20/2020	-	-	-	None	-	-	-
1033-1	Room 9 Counter	SK	App	6.52	2/20/2020	-	-	-	None	-	-	-
1033-2	Room 9 Vanity @ A	SK	App	47.7	2/20/2020	-	-	-	Additional Sampling Required	Aerator flushed	6.53	10/9/2020
1033-3	Room 9 Vanity @ B	SK	App	17.8	2/20/2020	-	-	-	Additional Sampling Required	Aerator flushed	8.98	10/9/2020
1034-1	Kitchen Handwash	SK	App	12.7	2/20/2020	-	-	-	None	-	-	-
1034-2	Kitchen Opposite Stove	SK	App	11.5	2/20/2020	-	-	-	None	-	-	-
1034-3	Kitchen Dishwash @ A	SK	App	13.8	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1034-4	Kitchen Dishwash @ B	SK	App	23	2/20/2020				Additional Sampling Required		7.93	10/9/2020
1034-5	Kitchen Dishwash	SPY	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1035-1	Room 10 Cosmetology	WF	N/A		2/20/2020	-	-	-	None	CAPPED	-	-
1035-2	Room 10 Cosmetology	SK	App	27	2/20/2020				Additional Sampling Required		13.9	10/9/2020
1035-3	Room 10 Hair wash Station @ A	SPY	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1035-4	Room 10 Hair wash Station @ B	SPY	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1035-5	Room 10 Hair wash Station @ C	SPY	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1035-6	Room 10 by Hair wash Station	WF	N/A	20.8	2/20/2020				None	CAPPED		
1036-1	Room 7	WF	N/A		2/20/2020	-	-	-	None	CAPPED	-	-
1036-2	Room 7- sink by water fountain	SK	App	15.7	10/9/2020				Additional Sampling Required			
1036-3	Room 7- 3 Compartment sink	SK	App	7.74	2/20/2020	-	-	-	None	-	-	-
1036-4	Room 7 - Counter 1	SK	App	22.2	2/20/2020				Additional Sampling Required	Aerator flushed	1/4/00	10/9/2020
1036-5	Room 7 - Counter 2 by dishwasher	SK	App	5.39	2/20/2020	-	-	-	None	-	-	-
1037-1	Room 8	WF	App	11.1	2/20/2020	-	-	-	None	-	-	-
1037-2	Room 8	SK	App	13.2	2/20/2020	-	-	-	None	-	-	-
1038-1	Room 5	WF	App	43.6	2/20/2020				None	CAPPED		
1038-2	Room 5	SK	App	32.6	2/20/2020				Additional Sampling Required	Aerator flushed	9.08	10/9/2020
1039-1	Room 6	WF	App	44.3	2/20/2020				None	CAPPED		
1039-2	Room 6 - by water fountain	SK	App	61.5	2/20/2020				Additional Sampling Required	Aerator flushed	12.4	10/9/2020
1039-3	Room 6 Counter @ A	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1039-4	Room 6 Counter @ B	SK	App	1.41	2/20/2020	-	-	-	None	-	-	-
1039-5	Room 6 Dishwash @ A	SK	App	4.18	2/20/2020	-	-	-	None	-	-	-
1039-6	Room 6 Dishwash @ B	SPY	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1039-7	Room 6 closet	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1040-1	Custodial Closet by Room 6	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1041-1	Room 3	WF	N/A		2/20/2020	-	-	-	None	CAPPED	-	-
1041-2	Room 3	SK	App	9.07	2/20/2020	-	-	-	None	-	-	-
1042-1	Room 4	SK	App	25	2/20/2020				Additional Sampling Required	Aerator flushed	8.51	10/9/2020
1043-1	Room 2	SK	App	5.55	2/20/2020	-	-	-	None	-	-	-
1043-2	Room 2 Hair wash Station	SPY	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1044-1	Room 1 Counter 1- left	SK	App	3.78	2/20/2020	-	-	-	None	-	-	-
1044-2	Room 1 Counter 2- right	SK	App	1.55	2/20/2020	-	-	-	None	-	-	-



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779
T: 631.580.3191 • F: 631.580.3195 • W: envirohealth.org

August 17, 2023

Mr. Mark Finnerty
Eastern Suffolk BOCES
100 Barton Avenue
Patchogue, NY 11772

Re: **Tecumseh Elementary - Lead in Drinking Water Sampling & Analysis 2023-2025**

Dear Mr. Finnerty,

On August 11, 2023, EnviroScience Consultants, LLC performed a limited water sampling event at Eastern Suffolk BOCES. Samples were collected at Tecumseh Elementary School for a newly installed bottle filler / water fountain fixture.

First draw samples were collected in wide-mouth 250 milliliter containers and during the early morning, prior to any water sources being used. The samples were transported to New York Environmental Laboratory and were analyzed for lead concentration. The current limit for lead in drinking water is 5 parts per billion (ppb). There were no exceedances.

The following location was sampled:

- Cafeterium-WF / BF

Please see the attached Outlet Inventory table and lab reports for detailed results at each location. These locations have satisfied the requirement for the 2023-2025 Lead in Drinking Water sampling period.

Should you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Shannon Gallagher".

Shannon Gallagher
Environmental Inspector

Laboratory Report

NYE Report #: 234254-26071

August 16, 2023

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Eastern Suffolk BOCES; Tecumseh Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on August 14, 2023. New York Environmental analyzed the samples on August 15, 2023 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	11 Aug 2023
Date Received:	14 Aug 2023
Date Analyzed:	15 Aug 2023

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
230814L011	1	Cafeterium - WF	0.001	<0.001	mg/L	
230814L012	2	Cafeterium - BF	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1000-1	Kitchen 1 Bay Handwash by Bathroom	SK	App			-	-	-	-
	1000-2	Kitchen 2 Bay (Left)	SK	App			-	-	-	-
	1000-3	Kitchen 2 Bay (Right)	SK	App			-	-	-	-
	1000-4	Kitchen 1 Bay Handwash by Dishwashing Station	SK	App			-	-	-	-
	1000-5	Kitchen Dishwashing Station	SPY	App			-	-	-	-
	1000-6	Kitchen Pot Filler	PF	App			-	-	-	-
	1000-7	Kitchen Island	SK	App			-	-	-	-
	1000-8	Kitchen Bathroom	SK	N/A			-	-	-	Sign
	1000-9	Kitchen Can Wash Room 50C	SP	N/A			-	-	-	Sign
	1000-10	Kitchen Steamer Supply Spigot-Before Filter	SP	App			-	-	-	-
	1000-10	Kitchen Steamer Supply Spigot-After Filter	SP	App			-	-	-	-
	1001-1	Hall by Boiler Room 48	WF	App			-	-	-	-
	1002-1	Custodian Office 47	SK	N/A			-	-	-	Sign
	1002-2	Custodian Office 47	SS	N/A			-	-	-	Sign
	1003-1	Cafeterium	WF	App	<1.0	8/11/2023	-	-	-	-
	1003-2	Cafeterium	BF	App	<1.0	8/11/2023	-	-	-	-
	1004-1	Girls Locker Room Bathroom	SK	N/A			-	-	-	Sign
	1005-1	Main Office	SK	App			-	-	-	-
	1006-1	Nurses Office	SK	App			-	-	-	-
	1006-2	Nurses Office Bathroom	SK	App			-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1007-1	Mens Bathroom by Gym @ A	SK	N/A			-	-	-	Sign
	1007-2	Mens Bathroom by Gym @ B	SK	N/A			-	-	-	Sign
	1008-1	Hall by Gym	WF	App			-	-	-	-
	1008-2	Hall by Gym Bottle Filler	BF	App			-	-	-	-
	1009-1	Custodial Closet by Room 23	SS	N/A			-	-	-	Sign
	1010-1	Womens Bathroom by Room 23 @ A	SK	N/A			-	-	-	Sign
	1010-2	Womens Bathroom by Room 23 @ B	SK	N/A			-	-	-	Sign
	1011-1	Room 23	WF	App			-	-	-	-
	1011-2	Room 23	SK	App			-	-	-	-
	1012-1	Room 22	WF	App			-	-	-	-
	1012-2	Room 22	SK	App			-	-	-	-
	1013-1	Faculty Room 9	WF	App			-	-	-	-
	1013-2	Faculty Room 9	SK	App			-	-	-	-
	1014-1	Room 21	WF	App			-	-	-	-
	1014-2	Room 21	SK	App			-	-	-	-
	1015-1	Room 10	WF	App			-	-	-	-
	1015-2	Room 10	SK	App			-	-	-	-
	1016-1	Hall by Room 10	WF	App			-	-	-	-
	1017-1	Room 20	WF	App			-	-	-	-
	1017-2	Room 20	SK	App			-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1018-1	Room 11	WF	App			-	-	-	-
	1018-2	Room 11	SK	App			-	-	-	-
	1019-1	Room 19	WF	App			-	-	-	-
	1019-2	Room 19	SK	App			-	-	-	-
	1020-1	Room 12 Multi Purpose Room	WF	App			-	-	-	-
	1020-2	Room 12 Multi Purpose Room	SK	App			-	-	-	-
	1021-1	Room 18	WF	App			-	-	-	-
	1021-2	Room 18	SK	App			-	-	-	-
	1022-1	Art Room 17	WF	App			-	-	-	-
	1022-2	Art Room 17	SK	App			-	-	-	-
	1023-1	Room 16	WF	App			-	-	-	-
	1023-2	Room 16	SK	App			-	-	-	-
	1023-3	Room 16 Bathroom	SK	N/A			-	-	-	Sign
	1024-1	Room 15	WF	App			-	-	-	-
	1024-2	Room 15	SK	App			-	-	-	-
	1024-3	Room 15 Bathroom	SK	N/A			-	-	-	Sign
	1025-1	Room 14	WF	App			-	-	-	-
	1025-2	Room 14 @ A (Right)	SK	App			-	-	-	-
	1025-3	Room 14 @ B (Left)	SK	App			-	-	-	-
	1026-1	Room 13	WF	App			-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1026-2	Room 13 @ A (Left)	SK	App			-	-	-	-
	1026-3	Room 13 @ B (Right)	SK	App			-	-	-	-
	1027-1	Boys Locker Room Bathroom	SK	N/A			-	-	-	Sign
	1028-1	Room 25	WF	App			-	-	-	-
	1028-2	Room 25	SK	App			-	-	-	-
	1029-1	Room 26	WF	App			-	-	-	-
	1029-2	Room 26	SK	App			-	-	-	-
	1030-1	Room 27	WF	App			-	-	-	-
	1030-2	Room 27	SK	App			-	-	-	-
	1031-1	Room 28	WF	App			-	-	-	-
	1031-2	Room 28	SK	App			-	-	-	-
	1032-1	Room 29	WF	App			-	-	-	-
	1032-2	Room 29	SK	App			-	-	-	-
	1033-1	Room 30	WF	App			-	-	-	-
	1033-2	Room 30	SK	App			-	-	-	-
	1034-1	Room 31	WF	App			-	-	-	-
	1034-2	Room 31	SK	App			-	-	-	-
	1035-1	Room 32	WF	App			-	-	-	-
	1035-2	Room 32	SK	App			-	-	-	-
	1036-1	Room 33 OT/PT	WF	App			-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1036-2	Room 33 OT/PT	SK	App			-	-	-	-
	1037-1	Room 34	WF	App			-	-	-	-
	1037-2	Room 34	SK	App			-	-	-	-
	1038-1	Room 35	WF	App			-	-	-	-
	1038-2	Room 35	SK	App			-	-	-	-
	1039-1	Boys Bathroom by Room 35 @ A	SK	N/A			-	-	-	Sign
	1039-2	Boys Bathroom by Room 35 @ B	SK	N/A			-	-	-	Sign
	1039-3	Boys Bathroom by Room 35 @ C	SK	N/A			-	-	-	Sign
	1039-4	Boys Bathroom by Room 35 @ D	SK	N/A			-	-	-	Sign
	1040-1	Custodial Closet by Room 35	SS	N/A			-	-	-	Sign
	1041-1	Hall by Room 35	WF	App			-	-	-	-
	1041-2	Hall by Room 35 Bottle Filler	BF	App			-	-	-	-
	1042-1	Girls Bathroom by Room 35 @ A	SK	N/A			-	-	-	Sign
	1042-2	Girls Bathroom by Room 35 @ B	SK	N/A			-	-	-	Sign
	1042-3	Girls Bathroom by Room 35 @ C	SK	N/A			-	-	-	Sign
	1042-4	Girls Bathroom by Room 35 @ D	SK	N/A			-	-	-	Sign
	1043-1	Room 38	WF	App			-	-	-	-
	1043-2	Room 38	SK	App			-	-	-	-
	1044-1	Room 39	WF	App			-	-	-	-
	1044-2	Room 39	SK	App			-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1045-1	Boys Bathroom by Room 60 @ A	SK	N/A			-	-	-	Sign
	1045-2	Boys Bathroom by Room 60 @ B	SK	N/A			-	-	-	Sign
	1046-1	Custodial Closet by Room 60	SS	N/A			-	-	-	Sign
	1047-1	Girls Bathroom by Room 60 @ A	SK	N/A			-	-	-	Sign
	1047-2	Girls Bathroom by Room 60 @ B	SK	N/A			-	-	-	Sign
	1048-1	Hall by Room 60 (Right)	WF	App			-	-	-	-
	1048-2	Hall by Room 60 Bottle Filler (Right)	BF	App			-	-	-	-
	1048-3	Hall by Room 60 (Left)	WF	App			-	-	-	-
	1049-1	Room 60	WF	App			-	-	-	-
	1049-2	Room 60	SK	App			-	-	-	-
	1050-1	Room 59	WF	App			-	-	-	-
	1050-2	Room 59	SK	App			-	-	-	-
	1051-1	Room 58	WF	App			-	-	-	-
	1051-2	Room 58	SK	App			-	-	-	-
	1052-1	Room 57	WF	App			-	-	-	-
	1052-2	Room 57	SK	App			-	-	-	-
	1053-1	Room 56	WF	App			-	-	-	-
	1053-2	Room 56	SK	App			-	-	-	-
	1054-1	Room 55	WF	App			-	-	-	-
	1054-2	Room 55	SK	App			-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1055-1	Room 54	WF	App			-	-	-	-
	1055-2	Room 54	SK	App			-	-	-	-
	1056-1	Room 53	WF	App			-	-	-	-
	1056-2	Room 53	SK	App			-	-	-	-



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779
T: 631.580.3191 • F: 631.580.3195 • W: envirohealth.org

September 11, 2023

Mr. Mark Finnerty
Eastern Suffolk BOCES
100 Barton Avenue
Patchogue, NY 11772

Re: Tecumseh Elementary - Lead in Drinking Water Sampling & Analysis 2023-2025

Dear Mr. Finnerty,

On September 7, 2023, Envirosience Consultants, LLC performed a limited water sampling event at Eastern Suffolk BOCES. Samples were collected at Tecumseh Elementary School for a newly installed bottle filler / water fountain fixture.

First draw samples were collected in wide-mouth 250 milliliter containers and during the early morning, prior to any water sources being used. The samples were transported to New York Environmental Laboratory and were analyzed for lead concentration. The current limit for lead in drinking water is 5 parts per billion (ppb). There were no exceedances.

The following location was sampled:

- Hall by Room 10-WF / BF

Please see the attached Outlet Inventory table and lab reports for detailed results at each location. These locations have satisfied the requirement for the 2023-2025 Lead in Drinking Water sampling period.

Should you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Shannon Gallagher". The signature is written in a cursive, flowing style.

Shannon Gallagher
Environmental Inspector

Laboratory Report

NYE Report #: 234839-26424

September 11, 2023

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Tecumseh Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on September 08, 2023. New York Environmental analyzed the samples on September 10, 2023 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	07 Sep 2023
Date Received:	08 Sep 2023
Date Analyzed:	10 Sep 2023

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
230908K001	1	Hall by Room 10-BF, Initial	0.001	<0.001	mg/L	
230908K002	2	Hall by Room 10-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1000-1	Kitchen 1 Bay Handwash by Bathroom	SK	App			-	-	-	-
	1000-2	Kitchen 2 Bay (Left)	SK	App			-	-	-	-
	1000-3	Kitchen 2 Bay (Right)	SK	App			-	-	-	-
	1000-4	Kitchen 1 Bay Handwash by Dishwashing Station	SK	App			-	-	-	-
	1000-5	Kitchen Dishwashing Station	SPY	App			-	-	-	-
	1000-6	Kitchen Pot Filler	PF	App			-	-	-	-
	1000-7	Kitchen Island	SK	App			-	-	-	-
	1000-8	Kitchen Bathroom	SK	N/A			-	-	-	Sign
	1000-9	Kitchen Can Wash Room 50C	SP	N/A			-	-	-	Sign
	1000-10	Kitchen Steamer Supply Spigot-Before Filter	SP	App			-	-	-	-
	1000-10	Kitchen Steamer Supply Spigot-After Filter	SP	App			-	-	-	-
	1001-1	Hall by Boiler Room 48	WF	App			-	-	-	-
	1002-1	Custodian Office 47	SK	N/A			-	-	-	Sign
	1002-2	Custodian Office 47	SS	N/A			-	-	-	Sign
	1003-1	Cafeterium	WF	App	<1.0	8/11/2023	-	-	-	-
	1003-2	Cafeterium	BF	App	<1.0	8/11/2023	-	-	-	-
	1004-1	Girls Locker Room Bathroom	SK	N/A			-	-	-	Sign
	1005-1	Main Office	SK	App			-	-	-	-
	1006-1	Nurses Office	SK	App			-	-	-	-
	1006-2	Nurses Office Bathroom	SK	App			-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1007-1	Mens Bathroom by Gym @ A	SK	N/A			-	-	-	Sign
	1007-2	Mens Bathroom by Gym @ B	SK	N/A			-	-	-	Sign
	1008-1	Hall by Gym	WF	App			-	-	-	-
	1008-2	Hall by Gym Bottle Filler	BF	App			-	-	-	-
	1009-1	Custodial Closet by Room 23	SS	N/A			-	-	-	Sign
	1010-1	Womens Bathroom by Room 23 @ A	SK	N/A			-	-	-	Sign
	1010-2	Womens Bathroom by Room 23 @ B	SK	N/A			-	-	-	Sign
	1011-1	Room 23	WF	App			-	-	-	-
	1011-2	Room 23	SK	App			-	-	-	-
	1012-1	Room 22	WF	App			-	-	-	-
	1012-2	Room 22	SK	App			-	-	-	-
	1013-1	Faculty Room 9	WF	App			-	-	-	-
	1013-2	Faculty Room 9	SK	App			-	-	-	-
	1014-1	Room 21	WF	App			-	-	-	-
	1014-2	Room 21	SK	App			-	-	-	-
	1015-1	Room 10	WF	App			-	-	-	-
	1015-2	Room 10	SK	App			-	-	-	-
	1016-1	Hall by Room 10	WF	N/A			-	-	-	Removed from Service; Renovated Summer 2023
	1016-1	Hall by Room 10	WF	App	<1.0	9/7/2023	-	-	-	Renovated Summer 2023
	1016-2	Hall by Room 10	BF	App	<1.0	9/7/2023	-	-	-	Renovated Summer 2023

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1017-1	Room 20	WF	App			-	-	-	-
	1017-2	Room 20	SK	App			-	-	-	-
	1018-1	Room 11	WF	App			-	-	-	-
	1018-2	Room 11	SK	App			-	-	-	-
	1019-1	Room 19	WF	App			-	-	-	-
	1019-2	Room 19	SK	App			-	-	-	-
	1020-1	Room 12 Multi Purpose Room	WF	App			-	-	-	-
	1020-2	Room 12 Multi Purpose Room	SK	App			-	-	-	-
	1021-1	Room 18	WF	App			-	-	-	-
	1021-2	Room 18	SK	App			-	-	-	-
	1022-1	Art Room 17	WF	App			-	-	-	-
	1022-2	Art Room 17	SK	App			-	-	-	-
	1023-1	Room 16	WF	App			-	-	-	-
	1023-2	Room 16	SK	App			-	-	-	-
	1023-3	Room 16 Bathroom	SK	N/A			-	-	-	Sign
	1024-1	Room 15	WF	App			-	-	-	-
	1024-2	Room 15	SK	App			-	-	-	-
	1024-3	Room 15 Bathroom	SK	N/A			-	-	-	Sign
	1025-1	Room 14	WF	App			-	-	-	-
	1025-2	Room 14 @ A (Right)	SK	App			-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1025-3	Room 14 @ B (Left)	SK	App			-	-	-	-
	1026-1	Room 13	WF	App			-	-	-	-
	1026-2	Room 13 @ A (Left)	SK	App			-	-	-	-
	1026-3	Room 13 @ B (Right)	SK	App			-	-	-	-
	1027-1	Boys Locker Room Bathroom	SK	N/A			-	-	-	Sign
	1028-1	Room 25	WF	App			-	-	-	-
	1028-2	Room 25	SK	App			-	-	-	-
	1029-1	Room 26	WF	App			-	-	-	-
	1029-2	Room 26	SK	App			-	-	-	-
	1030-1	Room 27	WF	App			-	-	-	-
	1030-2	Room 27	SK	App			-	-	-	-
	1031-1	Room 28	WF	App			-	-	-	-
	1031-2	Room 28	SK	App			-	-	-	-
	1032-1	Room 29	WF	App			-	-	-	-
	1032-2	Room 29	SK	App			-	-	-	-
	1033-1	Room 30	WF	App			-	-	-	-
	1033-2	Room 30	SK	App			-	-	-	-
	1034-1	Room 31	WF	App			-	-	-	-
	1034-2	Room 31	SK	App			-	-	-	-
	1035-1	Room 32	WF	App			-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1035-2	Room 32	SK	App			-	-	-	-
	1036-1	Room 33 OT/PT	WF	App			-	-	-	-
	1036-2	Room 33 OT/PT	SK	App			-	-	-	-
	1037-1	Room 34	WF	App			-	-	-	-
	1037-2	Room 34	SK	App			-	-	-	-
	1038-1	Room 35	WF	App			-	-	-	-
	1038-2	Room 35	SK	App			-	-	-	-
	1039-1	Boys Bathroom by Room 35 @ A	SK	N/A			-	-	-	Sign
	1039-2	Boys Bathroom by Room 35 @ B	SK	N/A			-	-	-	Sign
	1039-3	Boys Bathroom by Room 35 @ C	SK	N/A			-	-	-	Sign
	1039-4	Boys Bathroom by Room 35 @ D	SK	N/A			-	-	-	Sign
	1040-1	Custodial Closet by Room 35	SS	N/A			-	-	-	Sign
	1041-1	Hall by Room 35	WF	App			-	-	-	-
	1041-2	Hall by Room 35 Bottle Filler	BF	App			-	-	-	-
	1042-1	Girls Bathroom by Room 35 @ A	SK	N/A			-	-	-	Sign
	1042-2	Girls Bathroom by Room 35 @ B	SK	N/A			-	-	-	Sign
	1042-3	Girls Bathroom by Room 35 @ C	SK	N/A			-	-	-	Sign
	1042-4	Girls Bathroom by Room 35 @ D	SK	N/A			-	-	-	Sign
	1043-1	Room 38	WF	App			-	-	-	-
	1043-2	Room 38	SK	App			-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1044-1	Room 39	WF	App			-	-	-	-
	1044-2	Room 39	SK	App			-	-	-	-
	1045-1	Boys Bathroom by Room 60 @ A	SK	N/A			-	-	-	Sign
	1045-2	Boys Bathroom by Room 60 @ B	SK	N/A			-	-	-	Sign
	1046-1	Custodial Closet by Room 60	SS	N/A			-	-	-	Sign
	1047-1	Girls Bathroom by Room 60 @ A	SK	N/A			-	-	-	Sign
	1047-2	Girls Bathroom by Room 60 @ B	SK	N/A			-	-	-	Sign
	1048-1	Hall by Room 60 (Right)	WF	App			-	-	-	-
	1048-2	Hall by Room 60 Bottle Filler (Right)	BF	App			-	-	-	-
	1048-3	Hall by Room 60 (Left)	WF	App			-	-	-	-
	1049-1	Room 60	WF	App			-	-	-	-
	1049-2	Room 60	SK	App			-	-	-	-
	1050-1	Room 59	WF	App			-	-	-	-
	1050-2	Room 59	SK	App			-	-	-	-
	1051-1	Room 58	WF	App			-	-	-	-
	1051-2	Room 58	SK	App			-	-	-	-
	1052-1	Room 57	WF	App			-	-	-	-
	1052-2	Room 57	SK	App			-	-	-	-
	1053-1	Room 56	WF	App			-	-	-	-
	1053-2	Room 56	SK	App			-	-	-	-

AHERA Space #	Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
	1054-1	Room 55	WF	App			-	-	-	-
	1054-2	Room 55	SK	App			-	-	-	-
	1055-1	Room 54	WF	App			-	-	-	-
	1055-2	Room 54	SK	App			-	-	-	-
	1056-1	Room 53	WF	App			-	-	-	-
	1056-2	Room 53	SK	App			-	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
3001-1	Room 323 Bathroom	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3002-1	Women's Bathroom by Room 323 @ A	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3002-2	Women's Bathroom by Room 323 @ B	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3002-3	Women's Bathroom by Room 323 @ C	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3002-4	Women's Bathroom by Room 323 @ D	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3002-5	Women's Bathroom by Room 323 @ E	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3003-1	3rd Floor Main Office Bathroom @ A	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3003-2	3rd Floor Main Office Bathroom @ B	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3004-1	Hall by Room 308	WF	App	<1.0	10/9/2020	-	-	-	None	-	-	-
3004-2	Hall by Room 308	BF	App	<1.0	10/9/2020	-	-	-	None	-	-	-
3005-1	Room 308 Bathroom	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3006-1	Men's Bathroom by Room 313 @ A	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3006-2	Men's Bathroom by Room 313 @ B	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3006-3	Men's Bathroom by Room 313 @ C	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3006-4	Men's Bathroom by Room 313 @ D	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3006-5	Men's Bathroom by Room 313 @ E	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
3007-1	Custodial Closet C-19	SS	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2001-1	Staff Bathroom by Room 201 @ A	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2001-2	Staff Bathroom by Room 201 @ B	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2001-3	Staff Bathroom by Room 201 Custodial Closet	SS	N/A		10/9/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
2002-1	Faculty Room	SK	App	1.95	10/9/2020	-	-	-	None	-	-	-
2003-1	Custodial Closet C-8	SS	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2004-1	Women's Bathroom by Room 221 @ A	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2004-2	Women's Bathroom by Room 221 @ B	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2004-3	Women's Bathroom by Room 221 @ C	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2005-1	Lab Storage by Room 217	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2006-1	West Laboratory SIM @ A	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2006-2	West Laboratory SIM @ B	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2006-3	West Laboratory SIM @ C	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2006-4	West Laboratory SIM @ D	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2007-1	Hall by 2nd Floor Main Office	WF	App	<1.0	10/9/2020	-	-	-	None	-	-	-
2007-2	Hall by 2nd Floor Main Office	BF	App	<1.0	10/9/2020	-	-	-	None	-	-	-
2008-1	Custodial Closet C-5	SS	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2009-1	Men's Bathroom by Room 217 @ A	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2009-2	Men's Bathroom by Room 217 @ B	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2009-3	Men's Bathroom by Room 217 @ C	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2010-1	East Laboratory Counter 1 @ A	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2010-2	East Laboratory Counter 1 @ B	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2010-3	East Laboratory Counter 2 @ A	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
2010-4	East Laboratory Counter 2 @ B	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Room 3 Station	SPY	N/A		10/9/2020	-	-	-	None	SIGN	-	-
1001-2	Room 3 Bathroom	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
1002-1	Room 4	SK	App	2.12	10/9/2020	-	-	-	None	-	-	-
1002-2	Room 4	SPY	App	<1.0	10/9/2020	-	-	-	None	-	-	-
1003-1	Custodial Closet C-4	SS	N/A		10/9/2020	-	-	-	None	SIGN	-	-
1004-1	Women's Bathroom by Auditorium @ A	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
1004-2	Women's Bathroom by Auditorium @ B	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
1004-3	Women's Bathroom by Auditorium @ C	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
1005-1	Men's Bathroom by Library @ A	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
1005-2	Men's Bathroom by Library @ B	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
1005-3	Men's Bathroom by Library @ C	SK	N/A		10/9/2020	-	-	-	None	SIGN	-	-
1005-4	Men's Bathroom by Library	WF	App		10/9/2020	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2204101-15839

October 12, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Adult Education Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on October 09, 2020. New York Environmental analyzed the samples on October 10, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	09 Oct 2020
Date Received:	09 Oct 2020
Date Analyzed:	10 Oct 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
201009P024	1	Hallway by Room 308-WF, Initial	1.00	<1.00	µg/L	
201009P025	2	Hallway by Room 308-BF, Initial	1.00	<1.00	µg/L	
201009P026	3	Faculty Room-SK, Initial	1.00	1.95	µg/L	
201009P027	4	Hall by Second Floor Main Office-WF, Initial	1.00	<1.00	µg/L	
201009P028	5	Hall by Second Floor Main Office-BF, Initial	1.00	<1.00	µg/L	
201009P029	6	Room 4-SK, Initial	1.00	2.12	µg/L	
201009P030	7	Room 4-SPY, Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix B

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Kitchen	SK	App	6.47	8/28/2020	-	-	-	None	-	-	-
1001-2	Kitchen	SPY	App	2.23	8/28/2020	-	-	-	None	-	-	-
1002-1	Men's Bathroom by Main Entrance (left)	SK	App	1.06	8/28/2020	-	-	-	None	-	-	-
1002-2	Men's Bathroom by Main Entrance (right)	SK	App	3.05	8/28/2020	-	-	-	None	-	-	-
1003-1	Receiving Warehouse	SK	App	5.95	8/28/2020	-	-	-	None	-	-	-
1004-1	Hall by Main Entrance	WF	App	<1.0	8/28/2020	-	-	-	None	-	-	-
1004-2	Hall by Main Entrance	BF	App	<1.0	8/28/2020	-	-	-	None	-	-	-
1005-1	Custodial Closet-First floor	SS	N/A		8/28/2020	-	-	-	None	SIGN	-	-
2001-1	Women's Bathroom-Second Floor (left)	SK	App	7.48	8/28/2020	-	-	-	None	-	-	-
2001-2	Women's Bathroom-Second Floor (right)	SK	App	1.16	8/28/2020	-	-	-	None	-	-	-
2002-1	Hall -Second Floor	WF	App	<1.0	8/28/2020	-	-	-	None	-	-	-
2002-2	Hall -Second Floor	BF	App	<1.0	8/28/2020	-	-	-	None	-	-	-
2003-1	Men's Bathroom-Second Floor (right)	SK	App	<1.0	8/28/2020	-	-	-	None	-	-	-
2003-2	Men's Bathroom-Second Floor (left)	SK	App	<1.0	8/28/2020	-	-	-	None	-	-	-
2004-1	Custodial Closet-Second Floor	SS	N/A	<1.0	8/28/2020	-	-	-	None	SIGN	-	-

Laboratory Report

NYE Report #: 2203316-15357

August 31, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Barton Avenue Armory Building, Eastern Suffolk Boces, NY

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on August 28, 2020. New York Environmental analyzed the samples on August 31, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	28 Aug 2020
Date Received:	28 Aug 2020
Date Analyzed:	31 Aug 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200828J011	1	Kitchen-SK; Initial	1.00	6.47	µg/L	
200828J012	2	Kitchen-SPY; Initial	1.00	2.23	µg/L	
200828J013	3	Men's Bathroom by Main Entrance (left)-SK; Initial	1.00	1.06	µg/L	
200828J014	4	Men's Bathroom by Main Entrance (right)-SK; Initial	1.00	3.05	µg/L	
200828J015	5	Receiving Warehouse-SK; Initial	1.00	5.95	µg/L	
200828J016	6	Hall by Main Entrance-WF; Initial	1.00	<1.00	µg/L	
200828J017	7	Hall by Main Entrance-BF; Initial	1.00	<1.00	µg/L	
200828J018	8	Women's Bathroom-Second Floor (left)-SK; Initial	1.00	7.48	µg/L	
200828J019	9	Women's Bathroom-Second Floor (right)-SK; Initial	1.00	1.16	µg/L	
200828J020	10	Hall -Second Floor-WF; Initial	1.00	<1.00	µg/L	
200828J021	11	Hall -Second Floor-BF; Initial	1.00	<1.00	µg/L	
200828J022	12	Men's Bathroom-Second Floor (right)-SK; Initial	1.00	<1.00	µg/L	
200828J023	13	Men's Bathroom-Second Floor (left)-SK; Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix C

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Room 418 Women's Bathroom	SK	App	3.66	9/19/2020	-	-	-	None	-	-	-
1001-2	Room 418 Men's Bathroom	SK	App	1.75	9/19/2020	-	-	-	None	-	-	-
1001-3	Room 418 Reception Area	WF	App	1.27	9/19/2020	-	-	-	None	-	-	-
1001-4	Room 418 Reception Area	BF	App	2.04	9/19/2020	-	-	-	None	-	-	-
1002-1	Room 408 Girl's Bathroom	SK	App	13	9/19/2020	-	-	-	None	-	-	-
1002-2	Room 408 Boy's Bathroom	SK	N/A	16.2	9/19/2020				None	SIGN		
1002-3	Room 408	WF	App	2.91	9/19/2020	-	-	-	None	-	-	-
1002-4	Room 408-Trough Sink-Left	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1002-5	Room 408-Trough Sink-Right	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1003-1	Room 406 Bathroom	SK	App	13	9/19/2020	-	-	-	None	-	-	-
1003-2	Room 406	WF	App	4.93	9/19/2020	-	-	-	None	-	-	-
1004-1	Room 413 Men's Bathroom	SK	App	11.7	9/19/2020	-	-	-	None	-	-	-
1004-2	Room 413-Double Sink-Right	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1004-3	Room 413-Double Sink-Left	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1005-1	Women's Bathroom Room 409	SK	App	6.95	9/19/2020	-	-	-	None	-	-	-
1006-1	Men's Bathroom Room 407	SK	App	4.59	9/19/2020	-	-	-	None	-	-	-
1007-1	Room 405-Double Sink-Right	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1007-2	Room 405-Double Sink-Left	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1007-3	Room 405 Bathroom	SK	App	2.25	9/19/2020	-	-	-	None	-	-	-
1007-4	Room 405-Slop Sink	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1008-1	Room 404-Room A	SK	App	1.58	9/19/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1008-2	Room 404- Room B	SK	App	8.69	9/19/2020	-	-	-	None	-	-	-
1008-3	Room 404-Laundry Room	SK	App	5.01	9/19/2020	-	-	-	None	-	-	-
1008-4	Room 404-Hospital Bed Room	SK	N/A		9/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1008-5	Room 404-Hospital Bed Room	SK	N/A		9/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1008-6	Room 404-Common Space	WF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1008-7	Room 404-Common Space	BF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1008-8	Room 404 Bathroom	SK	App	12.1	9/19/2020	-	-	-	None	-	-	-
1008-9	Room 404	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1009-1	Hallway by Room 403	WF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1009-2	Hallway by Room 403	BF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1010-1	Room 403	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1010-2	Room 403 Bathroom	SK	App	5.62	9/19/2020	-	-	-	None	-	-	-
1010-3	Room 403	WF	App	1.82	9/19/2020	-	-	-	None	-	-	-
1011-1	Room 402 Bathroom	SK	App	12.3	9/19/2020	-	-	-	None	-	-	-
1012-1	Room 316 Bathroom	SK	App	13.7	9/19/2020	-	-	-	None	-	-	-
1012-2	Room 316	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1012-3	Room 316	WF	App		9/19/2020	-	-	-	None	Removed from Service	-	-
1013-1	Hallway by Room 311	WF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1013-2	Hallway by Room 311	BF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1014-1	Room 311 Common Area	SK	App	1.07	9/19/2020	-	-	-	None	-	-	-
1014-2	Room 311 Bathroom	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1015-1	Room 314 Bathroom	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1016-1	Bathroom by Room 308	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1017-1	Room 308 Bathroom	SK	App	13.3	9/19/2020	-	-	-	None	-	-	-
1017-2	Room 308	WF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1017-3	Room 308	BF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1017-4	Room 308-Laundry Room	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1018-1	Room 309 Bathroom	SK	App	12	9/19/2020	-	-	-	None	-	-	-
1018-2	Room 309	WF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1018-3	Room 309-Grooming Table-Left	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1018-4	Room 309-Grooming Table-Middle	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1018-5	Room 309-Grooming Table-Right	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1018-6	Room 309-Animal Food Dish Sink	SK	App	<1.0	11/6/2020	-	-	-	None	-	-	-
1018-7	Room 309-Animal Sink	SK	App	1.36	11/6/2020	-	-	-	None	-	-	-
1019-1	Room 305-Aquarium Room-3 Sink-Left	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1019-2	Room 305-Aquarium Room-3 Sink-Right	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1019-3	Room 305-Aquarium Room-Grooming Table	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1019-4	Room 305-Lesson Room-Left	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1019-5	Room 305-Lesson Room-Right	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1019-6	Room 305 Bathroom	SK	App	3.56	9/19/2020	-	-	-	None	-	-	-
1020-1	Room 306	WF	App	6.37	9/19/2020	-	-	-	None	-	-	-
1020-2	Room 306-Trough-2 Sink-Right	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1020-3	Room 306-Trough-2 Sink-Left	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1020-4	Room 306 Bathroom	SK	N/A	16.7	9/19/2020				None	SIGN		
1021-1	Room 303	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1021-2	Room 303 Bathroom	SK	App	9.86	9/19/2020	-	-	-	None	-	-	-
1021-3	Room 303-Half Circle Trough	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1022-1	Room 202 Bathroom	SK	App	4.41	9/19/2020	-	-	-	None	-	-	-
1022-2	Room 202	WF	App	13.5	9/19/2020	-	-	-	None	-	-	-
1022-3	Room 202	SK	App	15.1	9/19/2020				Additional Sampling Required	Aerator Flushed	<1.0	10/9/2020
1022-4	Room 202-Room 1	SK	App	2.32	9/19/2020	-	-	-	None	-	-	-
1022-5	Room 202-Room 2	SK	App	2.98	9/19/2020	-	-	-	None	-	-	-
1022-6	Room 202 Kitchenette	SK	App	16.9	10/9/2020				Additional Sampling Required			
1022-7	Room 202 Bathroom	SK	App	1.98	9/19/2020	-	-	-	None	-	-	-
1022-8	Room 202-Medication Room	SK	App	23.3	10/9/2020				Additional Sampling Required			
1023-1	Room 206	WF	App		9/19/2020	-	-	-	None	Removed from Service	-	-
1023-2	Room 206 Bathroom	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1023-3	Room 206	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1024-1	Room 208 Men's Bathroom	SK	App	7.71	9/19/2020	-	-	-	None	-	-	-
1024-2	Room 208 Women's Bathroom	SK	App	10.5	9/19/2020	-	-	-	None	-	-	-
1025-1	Room 212 Bathroom	SK	App	5.1	9/19/2020	-	-	-	None	-	-	-
1025-2	Room 212-Development Room	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1025-3	Room 212-Chemical Room-Left	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1025-4	Room 212-Chemical Room-Right	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1025-5	Room 212-Dark Room	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1026-1	Hallway by Room 212	WF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1026-2	Hallway by Room 212	BF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1027-1	Room 214 Bathroom	SK	App	10.7	9/19/2020	-	-	-	None	-	-	-
1027-2	Room 214	SK	App	17.4	9/19/2020				Additional Sampling Required	Aerator Flushed	13.2	10/9/2020
1028-1	Room 219 Boy's Bathroom	SK	App	4.85	9/19/2020	-	-	-	None	-	-	-
1028-2	Room 219 Girl's Bathroom	SK	App	12.9	9/19/2020	-	-	-	None	-	-	-
1029-1	Room 217	WF	App		9/19/2020	-	-	-	None	Removed from Service	-	-
1029-2	Room 217 Bathroom	SK	App	8.54	9/19/2020	-	-	-	None	-	-	-
1029-3	Room 217	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1030-1	Room 215 Girl's Bathroom	SK	App	1.43	9/19/2020	-	-	-	None	-	-	-
1030-2	Room 215 Boy's Bathroom	SK	App	3.74	9/19/2020	-	-	-	None	-	-	-
1030-3	Room 215-Left	SK	App	4.02	9/19/2020	-	-	-	None	-	-	-
1030-4	Room 215-Right	SK	App	4.11	9/19/2020	-	-	-	None	-	-	-
1031-1	Room 213 Bathroom	SK	App	3.69	9/19/2020	-	-	-	None	-	-	-
1032-1	Bathroom by Room 207	SK	App	11.9	9/19/2020	-	-	-	None	-	-	-
1033-1	Room 207	SK	App	4.65	9/19/2020	-	-	-	None	-	-	-
1034-1	Room 205	WF	App	14.1	9/19/2020	-	-	-	None	-	-	-
1034-2	Room 205 Boy's Bathroom	SK	App	12.5	9/19/2020	-	-	-	None	-	-	-
1034-3	Room 205 Girl's Bathroom	SK	App	2.13	9/19/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1035-1	Room 203 Girl's Bathroom	SK	App	14.5	9/19/2020	-	-	-	None	-	-	-
1035-2	Room 203 Boy's Bathroom	SK	App	12.3	9/19/2020	-	-	-	None	-	-	-
1035-3	Room 203	SK	App	3.83	9/19/2020	-	-	-	None	-	-	-
1035-4	Room 203	WF	App		9/19/2020	-	-	-	None	Removed from Service	-	-
1036-1	Room 139 Bathroom	SK	App	4.59	9/19/2020	-	-	-	None	-	-	-
1036-2	Room 139	WF	App	6.96	9/19/2020	-	-	-	None	-	-	-
1036-3	Room 139-Sink #2	SK	App	10.3	9/19/2020	-	-	-	None	-	-	-
1036-4	Room 139-Sink #3	SK	App	14.8	9/19/2020	-	-	-	None	-	-	-
1036-5	Room 139-Sink #1	SK	App	14.9	9/19/2020	-	-	-	None	-	-	-
1036-6	Room 139 Dental Chair 1-Bowl Rinse	OS	N/A	1.55	11/6/22020	-	-	-	Plastic components Sampling Not Required	External potable water source to be used	-	-
1036-7	Room 139 Dental Chair 1-Cup Filler	OS	N/A		11/6/22020	-	-	-	Plastic components Sampling Not Required	External potable water source to be used	-	-
1036-8	Room 139 Dental Chair 2-Bowl Rinse	OS	N/A	8.11	11/6/22020				Plastic components Sampling Not Required	External potable water source to be used		
1036-9	Room 139 Dental Chair 2-Cup Filler	OS	N/A	11.1	11/6/22020				Plastic components Sampling Not Required	External potable water source to be used		
1036-10	Room 139 Dental Chair 3-Bowl Rinse	OS	N/A	2.4	11/6/22020				Plastic components Sampling Not Required	External potable water source to be used		
1036-11	Room 139 Dental Chair 3-Cup Filler	OS	N/A	19.8	11/6/22020				Plastic components Sampling Not Required	External potable water source to be used		
1036-12	Room 139 Dental Chair 4-Bowl Rinse	OS	N/A		11/6/22020				Plastic components Sampling Not Required	External potable water source to be used		
1036-13	Room 139 Dental Chair 4-Cup Filer	OS	N/A		11/6/22020				Plastic components Sampling Not Required	External potable water source to be used		
1037-1	Room 128	WF	App		9/19/2020	-	-	-	None	Removed from Service	-	-
1037-2	Room 128 Bathroom	SK	App	5.34	9/19/2020	-	-	-	None	-	-	-
1037-3	Room 128	SK	App	4.76	9/19/2020	-	-	-	None	-	-	-
1038-1	Room 137 Bathroom	SK	App	4.28	9/19/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1039-1	Room 135-Back Space-Left	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1039-2	Room 135-Back Space-Right	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1039-3	Room 135-Middle Space	SK	App	17.7	9/19/2021				Additional Sampling Required	Aerator Flushed	3.5	10/9/2020
1039-4	Room 135 Men's Bathroom	SK	App	12	9/19/2020	-	-	-	None	-	-	-
1039-5	Room 135 Women's Bathroom	SK	App	4.93	9/19/2020	-	-	-	None	-	-	-
1040-1	Room 126 Men's Bathroom	SK	App	10.7	9/19/2020	-	-	-	None	-	-	-
1040-2	Room 126-Left	SK	App	11.2	9/19/2020	-	-	-	None	-	-	-
1040-3	Room 126-Right	SK	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1040-4	Room 126 Women's Bathroom	SK	App	10.4	9/19/2020	-	-	-	None	-	-	-
1040-5	Room 126	WF	App		9/19/2020	-	-	-	None	Removed from Service	-	-
1041-1	Room 133 Bathroom	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1041-2	Room 133	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1041-3	Room 133-Back Space-Left	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1041-4	Room 133-Back Space-Right	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1041-5	Room 133-Side Room	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1042-1	Room 122-Culinary Arts-2 Sink Unit	SK	App	15.5	9/19/2020				None	Aerator Flushed	1.78	10/9/2020
1042-2	Room 122-Culinary Arts-Dishwasher	SPY	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1042-3	Room 122-Culinary Arts-Laundry Room	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1042-4	Room 122-Culinary Arts-Bathroom	SK	App	8.74	9/19/2020	-	-	-	None	-	-	-
1042-5	Room 122-Culinary Arts	IM	App	3.77	9/19/2020	-	-	-	None	-	-	-
1042-6	Room 122-Culinary Arts-3 Sink-Right	SK	App	2.17	9/19/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1042-7	Room 122-Culinary Arts-3 Sink-Left	SK	App	7.12	9/19/2020	-	-	-	None	-	-	-
1042-8	Room 122-Culinary Arts-3 Sink	SPY	App	13.4	9/19/2020	-	-	-	None	-	-	-
1042-9	Room 122-Culinary Arts-Handwash Sink by 3 Sink	SK	App	1.96	9/19/2020	-	-	-	None	-	-	-
1042-10	Room 122-Culinary Arts-Handwash Sink by Prep Block	SK	App	4.06	9/19/2020	-	-	-	None	-	-	-
1043-1	Room 114 Bathroom-Left	SK	N/A	27.4	9/19/2020				None	SIGN		
1043-2	Room 114 Bathroom-Right	SK	App	2.27	9/19/2020	-	-	-	None	-	-	-
1043-3	Room 114	WF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1043-4	Room 114	BF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1044-1	Faculty Room Bathroom	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1044-2	Faculty Room Kitchenette	SK	App	5.72	9/19/2020	-	-	-	None	-	-	-
1045-1	Room 129 Laundry	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1045-2	Room 129 Hair Wash-Left	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1045-3	Room 129 Hair Wash-Right	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1045-4	Room 129 Bathroom	SK	App	4.68	9/19/2020	-	-	-	None	-	-	-
1046-1	Room 127 Women's Bathroom-Left	SK	App		9/19/2020	-	-	-	None	Removed from Service	-	-
1046-2	Room 127 Women's Bathroom-Right	SK	App	6.55	9/19/2020	-	-	-	None	-	-	-
1047-1	Room 125 Men's Bathroom-Left	SK	N/A	16.7	9/19/2020				None	SIGN		
1047-2	Room 125 Men's Bathroom-Right	SK	N/A	24.9	9/19/2020				None	SIGN		
1048-1	Hallway by Men's Bathroom	WF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1048-2	Hallway by Men's Bathroom	BF	App	<1.0	9/19/2020	-	-	-	None	-	-	-
1049-1	Room 123 Bathroom-Left	SK	App	11.4	9/19/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1049-2	Room 123 Bathroom-Right	SK	App	9.51	9/19/2020	-	-	-	None	-	-	-
1049-3	Room 123 Kitchenette	SK	App	6.18	9/19/2020	-	-	-	None	-	-	-
1050-1	Room 117 Staff Only-Women's Bathroom	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1051-1	Room 117 Staff Only-Men's Bathroom	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1052-1	Room 101 Kitchenette	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1052-2	Room 101 Bathroom	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1053-1	Room 102-Custodial	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1053-2	Room 102-Custodial Kitchenette	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1053-3	Room 102-Custodial Bathroom	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1053-4	Room 102-Custodial Bathroom	SK	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1054-1	Custodial Closet-D Wing	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1055-1	Custodial Closet-C Wing	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1056-1	Custodial Closet-B Wing	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-
1057-1	Custodial Closet-A Wing	SS	N/A		9/19/2020	-	-	-	None	SIGN	-	-

Laboratory Report

NYE Report #: 2203745-15612

September 23, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Bixhorn Technical Center, Eastern Suffolk BOCES, NY

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on September 21, 2020. New York Environmental analyzed the samples on September 22, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	19 Sep 2020
Date Received:	21 Sep 2020
Date Analyzed:	22 Sep 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200921R001	1	Room 418 Women's Bathroom-SK; Initial	1.00	3.66	µg/L	
200921R002	2	Room 418 Men's Bathroom-SK; Initial	1.00	1.75	µg/L	
200921R003	3	Room 418 Reception Area-WF; Initial	1.00	1.27	µg/L	
200921R004	4	Room 418 Reception Area-BF; Initial	1.00	2.04	µg/L	
200921R005	5	Room 408 Girl's Bathroom-SK; Initial	1.00	13.0	µg/L	
200921R006	6	Room 408 Boy's Bathroom-SK; Initial	1.00	16.2	µg/L	H
200921R007	7	Room 408-WF; Initial	1.00	2.91	µg/L	
200921R008	8	Room 406 Bathroom-SK; Initial	1.00	13.0	µg/L	
200921R009	9	Room 406-WF; Initial	1.00	4.93	µg/L	
200921R010	10	Room 413 Men's Bathroom-SK; Initial	1.00	11.7	µg/L	
200921R011	11	Women's Bathroom Room 409-SK; Initial	1.00	6.95	µg/L	
200921R012	12	Men's Bathroom Room 407-SK; Initial	1.00	4.59	µg/L	
200921R013	13	Room 405 Bathroom-SK; Initial	1.00	2.25	µg/L	
200921R014	14	Room 404-Room A-SK; Initial	1.00	1.58	µg/L	
200921R015	15	Room 404- Room B-SK; Initial	1.00	8.69	µg/L	
200921R016	16	Room 404-Laundry Room-SK; Initial	1.00	5.01	µg/L	
200921R017	17	Room 404-Common Space-WF; Initial	1.00	<1.00	µg/L	
200921R018	18	Room 404-Common Space-BF; Initial	1.00	<1.00	µg/L	
200921R019	19	Room 404 Bathroom-SK; Initial	1.00	12.1	µg/L	
200921R020	20	Hallway by Room 403-WF; Initial	1.00	<1.00	µg/L	
200921R021	21	Hallway by Room 403-BF; Initial	1.00	<1.00	µg/L	
200921R022	22	Room 403 Bathroom-SK; Initial	1.00	5.62	µg/L	
200921R023	23	Room 403-WF; Initial	1.00	1.82	µg/L	
200921R024	24	Room 402 Bathroom-SK; Initial	1.00	12.3	µg/L	
200921R025	25	Room 316 Bathroom-SK; Initial	1.00	13.7	µg/L	
200921R026	26	Hallway by Room 311-WF; Initial	1.00	<1.00	µg/L	



Date Collected:	19 Sep 2020
Date Received:	21 Sep 2020
Date Analyzed:	22 Sep 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200921R027	27	Hallway by Room 311-BF; Initial	1.00	<1.00	µg/L	
200921R028	28	Room 311 Common Area-SK; Initial	1.00	1.07	µg/L	
200921R029	29	Room 308 Bathroom-SK; Initial	1.00	13.3	µg/L	
200921R030	30	Room 308-WF; Initial	1.00	<1.00	µg/L	
200921R031	31	Room 308-BF; Initial	1.00	<1.00	µg/L	
200921R032	32	Room 309 Bathroom-SK; Initial	1.00	12.0	µg/L	
200921R033	33	Room 309-WF; Initial	1.00	<1.00	µg/L	
200921R034	34	Room 305 Bathroom-SK; Initial	1.00	3.56	µg/L	
200921R035	35	Room 306-WF; Initial	1.00	6.37	µg/L	
200921R036	36	Room 306 Bathroom-SK; Initial	1.00	16.7	µg/L	H
200921R037	37	Room 303 Bathroom-SK; Initial	1.00	9.86	µg/L	
200921R038	38	Room 202 Bathroom-SK; Initial	1.00	4.41	µg/L	
200921R039	39	Room 202-WF; Initial	1.00	13.5	µg/L	
200921R040	40	Room 202-SK; Initial	1.00	15.1	µg/L	H
200921R041	41	Nurse's Office-Exam Room #1-SK; Initial	1.00	2.32	µg/L	
200921R042	42	Nurse's Office-Exam Room #2-SK; Initial	1.00	2.98	µg/L	
200921R043	43	Nurse's Office Kitchenette-SK; Initial	1.00	21.4	µg/L	H
200921R044	44	Nurse's Office Bathroom-SK; Initial	1.00	1.98	µg/L	
200921R045	45	Nurse's Office-Medication Room-SK; Initial	1.00	17.2	µg/L	H
200921R046	46	Room 208 Men's Bathroom-SK; Initial	1.00	7.71	µg/L	
200921R047	47	Room 208 Women's Bathroom-SK; Initial	1.00	10.5	µg/L	
200921R048	48	Room 212 Bathroom-SK; Initial	1.00	5.10	µg/L	
200921R049	49	Hallway by Room 212-WF; Initial	1.00	<1.00	µg/L	
200921R050	50	Hallway by Room 212-BF; Initial	1.00	<1.00	µg/L	
200921R051	51	Room 214 Bathroom-SK; Initial	1.00	10.7	µg/L	
200921R052	52	Room 214-SK; Initial	1.00	17.4	µg/L	H
200921R053	53	Room 219 Boy's Bathroom-SK; Initial	1.00	4.85	µg/L	



Date Collected:	19 Sep 2020
Date Received:	21 Sep 2020
Date Analyzed:	22 Sep 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200921R054	54	Room 219 Girl's Bathroom-SK; Initial	1.00	12.9	µg/L	
200921R055	55	Room 217 Bathroom-SK; Initial	1.00	8.54	µg/L	
200921R056	56	Room 215 Girl's Bathroom-SK; Initial	1.00	1.43	µg/L	
200921R057	57	Room 215 Boy's Bathroom-SK; Initial	1.00	3.74	µg/L	
200921R058	58	Room 215-Left-SK; Initial	1.00	4.02	µg/L	
200921R059	59	Room 215-Right-SK; Initial	1.00	4.11	µg/L	
200921R060	60	Room 213 Bathroom-SK; Initial	1.00	3.69	µg/L	
200921R061	61	Bathroom by Room 207-SK; Initial	1.00	11.9	µg/L	
200921R062	62	Room 207-SK; Initial	1.00	4.65	µg/L	
200921R063	63	Room 205-WF; Initial	1.00	14.1	µg/L	
200921R064	64	Room 205 Boy's Bathroom-SK; Initial	1.00	12.5	µg/L	
200921R065	65	Room 205 Girl's Bathroom-SK; Initial	1.00	2.13	µg/L	
200921R066	66	Room 203 Girl's Bathroom-SK; Initial	1.00	14.5	µg/L	
200921R067	67	Room 203 Boy's Bathroom-SK; Initial	1.00	12.3	µg/L	
200921R068	68	Room 203-SK; Initial	1.00	3.83	µg/L	
200921R069	69	Room 139 Bathroom-SK; Initial	1.00	4.59	µg/L	
200921R070	70	Room 139-WF; Initial	1.00	6.96	µg/L	
200921R071	71	Room 139-Sink #2-SK; Initial	1.00	10.3	µg/L	
200921R072	72	Room 139-Sink #3-SK; Initial	1.00	14.8	µg/L	
200921R073	73	Room 139-Sink #1-SK; Initial	1.00	14.9	µg/L	
200921R074	74	Room 128 Bathroom-SK; Initial	1.00	5.34	µg/L	
200921R075	75	Room 128-SK; Initial	1.00	4.76	µg/L	
200921R076	76	Room 137 Bathroom-SK; Initial	1.00	4.28	µg/L	
200921R077	77	Room 135-Middle Space-SK; Initial	1.00	17.7	µg/L	H
200921R078	78	Room 135 Men's Bathroom-SK; Initial	1.00	12.0	µg/L	
200921R079	79	Room 135 Women's Bathroom-SK; Initial	1.00	4.93	µg/L	
200921R080	80	Room 126 Men's Bathroom-SK; Initial	1.00	10.7	µg/L	

Date Collected:	19 Sep 2020
Date Received:	21 Sep 2020
Date Analyzed:	22 Sep 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200921R081	81	Room 126-Left-SK; Initial	1.00	11.2	µg/L	
200921R082	82	Room 126-Right-SK; Initial	1.00	<1.00	µg/L	
200921R083	83	Room 126 Women's Bathroom-SK; Initial	1.00	10.4	µg/L	
200921R084	84	Room 122-Culinary Arts-2 Sink Unit-SK; Initial	1.00	15.5	µg/L	H
200921R085	85	Room 122-Culinary Arts-Bathroom-SK; Initial	1.00	8.74	µg/L	
200921R086	86	Room 122-Culinary Arts-IM; Initial	1.00	3.77	µg/L	
200921R087	87	Room 122-Culinary Arts-3 Sink-Right-SK; Initial	1.00	2.17	µg/L	
200921R088	88	Room 122-Culinary Arts-3 Sink-Left-SK; Initial	1.00	7.12	µg/L	
200921R089	89	Room 122-Culinary Arts-3 Sink-SPY; Initial	1.00	13.4	µg/L	
200921R090	90	Room 122-Culinary Arts-Handwash Sink by 3 Sink-SK; Initial	1.00	1.96	µg/L	
200921R091	91	Room 122-Culinary Arts-Handwash Sink by Prep Block-SK; Initial	1.00	4.06	µg/L	
200921R092	92	Room 114 Bathroom-Left-SK; Initial	1.00	27.4	µg/L	H
200921R093	93	Room 114 Bathroom-Right-SK; Initial	1.00	2.27	µg/L	
200921R094	94	Room 114-WF; Initial	1.00	<1.00	µg/L	
200921R095	95	Room 114-BF; Initial	1.00	<1.00	µg/L	
200921R096	96	Room 129 Bathroom-SK; Initial	1.00	4.68	µg/L	
200921R097	97	Room 127 Women's Bathroom-Right-SK; Initial	1.00	6.55	µg/L	
200921R098	98	Room 125 Men's Bathroom-Left-SK; Initial	1.00	16.7	µg/L	H
200921R099	99	Room 125 Men's Bathroom-Right-SK; Initial	1.00	24.9	µg/L	H
200921R100	100	Hallway by Men's Bathroom-WF; Initial	1.00	<1.00	µg/L	
200921R101	101	Hallway by Men's Bathroom-BF; Initial	1.00	<1.00	µg/L	
200921R102	102	Room 123 Bathroom-Left-SK; Initial	1.00	11.4	µg/L	
200921R103	103	Room 123 Bathroom-Right-SK; Initial	1.00	9.51	µg/L	
200921R104	104	Room 123 Kitchenette-SK; Initial	1.00	6.18	µg/L	
200921R105	105	Faculty Room Kitchenette-SK; Initial	1.00	5.72	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Laboratory Report

NYE Report #: 2204102-15840

October 12, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Bixhorn Technical Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on October 09, 2020. New York Environmental analyzed the samples on October 10, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	09 Oct 2020
Date Received:	09 Oct 2020
Date Analyzed:	10 Oct 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
201009P031	1	Room 202-SK, Initial	1.00	<1.00	µg/L	
201009P032	2	Nurse's Office Kitchenette-SK, Initial	1.00	16.9	µg/L	H
201009P033	3	Nurse's Office-Medication Room-SK, Initial	1.00	23.3	µg/L	H
201009P034	4	Room 214-SK, Initial	1.00	13.2	µg/L	
201009P035	5	Room 135-Middle Space-SK, Initial	1.00	3.50	µg/L	
201009P036	6	Room 122-Culinary Arts-2 Sink Unit-SK, Initial	1.00	1.78	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2204448-16119

November 9, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Bixhorn Technical Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on November 06, 2020. New York Environmental analyzed the samples on November 07, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	06 Nov 2020
Date Received:	06 Nov 2020
Date Analyzed:	07 Nov 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
201106M165	1	Rm 139-Dental Chair-Left-Bowl Rinse-OS; Initial	1.00	1.55	µg/L	
201106M166	2	Rm 139-Dental Chair-Left Middle-Cup Filler-OS; Initial	1.00	11.1	µg/L	
201106M167	3	Rm 139-Dental Chair-Left Middle-Bowl Rinse-OS; Initial	1.00	8.11	µg/L	
201106M168	4	Rm 139-Dental Chair-Right Middle-Cup Filler-OS; Initial	1.00	19.8	µg/L	H
201106M169	5	Rm 139-Dental Chair-Right Middle-Bowl Rinse-OS; Initial	1.00	2.40	µg/L	
201106M170	6	Rm 309-Animal Care Sink-SK; Initial	1.00	1.36	µg/L	
201106M171	7	Rm 309-Animal Food Dish-SK; Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Appendix D

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Kitchen Handwash @ A	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1001-2	Kitchen 3 Bay Dishwash - left	SK	App	6.96	2/29/2020	-	-	-	None	-	-	-
1001-3	Kitchen 3 Bay Dishwash - right	SK	App	2.45	2/29/2020	-	-	-	None	-	-	-
1001-4	Kitchen 3 Bay Dishwash	SPY	App	1.54	2/29/2020	-	-	-	None	-	-	-
1001-5	Kitchen Handwash @ B	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1001-6	Kitchen Pot Filler	SK	App	16.9	2/29/2020				Additional Sampling Required	Fixture flushed	10.2	11/5/2020
1001-7	Kitchen Prep	SK	App	1.75	2/29/2020	-	-	-	None	-	-	-
1001-8	Kitchen Custodial Closet	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1002-1	Serving Line Handwash	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1002-2	Serving Line	SK	App	5.2	2/29/2020	-	-	-	None	-	-	-
1003-1	Faculty Room by Kitchen	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1003-2	Faculty Room Bathroom	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1004-1	Bathroom by Faculty Room	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1005-1	Nurse's Office	SK	App	11.1	2/29/2020	-	-	-	None	-	-	-
1005-2	Nurse's Office Bathroom	SK	App	2.68	2/29/2020	-	-	-	None	-	-	-
1006-1	Women's Faculty Bathroom by Lobby @ A	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1006-2	Women's Faculty Bathroom by Lobby @ B	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1006-3	Women's Faculty Bathroom by Lobby @ C	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1006-4	Women's Faculty Bathroom by Lobby @ D	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1006-5	Women's Faculty Bathroom by Lobby @ E	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1007-1	Lobby	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1007-2	Lobby	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1008-1	Men's Faculty Bathroom by Lobby @ A	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1008-2	Men's Faculty Bathroom by Lobby @ B	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1008-3	Men's Faculty Bathroom by Lobby @ C	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1008-4	Men's Faculty Bathroom by Lobby @ D	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1008-5	Men's Faculty Bathroom by Lobby @ E	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1009-1	Room 614	SK	App	5.93	2/29/2020	-	-	-	None	-	-	-
1010-1	Room 611	SK	App	5.65	2/29/2020	-	-	-	None	-	-	-
1011-1	Room 604	SK	App	4.45	2/29/2020	-	-	-	None	-	-	-
1012-1	Room 602	SK	App	56.4	11/5/2020				Additional Sampling Required			
1013-1	Hallway by Gym	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1013-2	Hallway by Gym	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1014-1	Custodial Closet by Room 512	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1015-1	Women's Bathroom by Room 512 @ A	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1015-2	Women's Bathroom by Room 512 @ B	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1015-3	Women's Bathroom by Room 512 @ C	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1015-4	Women's Bathroom by Room 512 @ D	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1015-5	Women's Bathroom by Room 512 @ E	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1016-1	Girl's Bathroom by Room 512	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1017-1	Boy's Bathroom by Room 512	SK	App	1.63	2/29/2020	-	-	-	None	-	-	-
1018-1	Men's Bathroom by Room 512 @ A	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1018-2	Men's Bathroom by Room 512 @ B	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1018-3	Men's Bathroom by Room 512 @ C	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1018-4	Men's Bathroom by Room 512 @ D	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1018-5	Men's Bathroom by Room 512 @ E	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1019-1	Room 510	SK	App	6.57	2/29/2020	-	-	-	None	-	-	-
1020-1	Room 508	SK	App	6.98	2/29/2020	-	-	-	None	-	-	-
1021-1	Hallway across Room 502	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1021-2	Hallway across Room 502	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2201053-14119

March 4, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Bellport Academic Center 19365

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on March 02, 2020. New York Environmental analyzed the samples on March 03, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	02 Mar 2020
Date Received:	02 Mar 2020
Date Analyzed:	03 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200302Q121	1	Kitchen 3 Bay Dishwash - left-SK; Initial	1.00	6.96	µg/L	
200302Q122	2	Kitchen 3 Bay Dishwash - right-SK; Initial	1.00	2.45	µg/L	
200302Q123	3	Kitchen 3 Bay Dishwash -SPY; Initial	1.00	1.54	µg/L	
200302Q124	4	Kitchen Pot Filler-SK; Initial	1.00	16.9	µg/L	H
200302Q125	5	Kitchen Prep-SK; Initial	1.00	1.75	µg/L	
200302Q126	6	Serving Line -SK; Initial	1.00	5.20	µg/L	
200302Q127	7	Faculty Room by Kitchen-SK; Initial	1.00	<1.00	µg/L	
200302Q128	8	Nurse's Office-SK; Initial	1.00	11.1	µg/L	
200302Q129	9	Nurse's Office Bathroom-SK; Initial	1.00	2.68	µg/L	
200302Q130	10	Lobby-BF; Initial	1.00	<1.00	µg/L	
200302Q131	11	Lobby-WF; Initial	1.00	<1.00	µg/L	
200302Q132	12	Room 614-SK; Initial	1.00	5.93	µg/L	
200302Q133	13	Room 611-SK; Initial	1.00	5.65	µg/L	
200302Q134	14	Room 604-SK; Initial	1.00	4.45	µg/L	
200302Q135	15	Room 602-SK; Initial	1.00	18.2	µg/L	H
200302Q136	16	Hallway by Gym-BF; Initial	1.00	<1.00	µg/L	
200302Q137	17	Hallway by Gym-WF; Initial	1.00	<1.00	µg/L	
200302Q138	18	Boy's Bathroom by Room 512-SK; Initial	1.00	1.63	µg/L	
200302Q139	19	Room 510-SK; Initial	1.00	6.57	µg/L	
200302Q140	20	Room 508-SK; Initial	1.00	6.98	µg/L	
200302Q141	21	Hallway across Room 502-BF; Initial	1.00	<1.00	µg/L	
200302Q142	22	Hallway across Room 502-WF; Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Laboratory Report

NYE Report #: 2201053-14119

March 4, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Bellport Academic Center 19365

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on March 02, 2020. New York Environmental analyzed the samples on March 03, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	02 Mar 2020
Date Received:	02 Mar 2020
Date Analyzed:	03 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200302Q121	1	Kitchen 3 Bay Dishwash - left-SK; Initial	1.00	6.96	µg/L	
200302Q122	2	Kitchen 3 Bay Dishwash - right-SK; Initial	1.00	2.45	µg/L	
200302Q123	3	Kitchen 3 Bay Dishwash -SPY; Initial	1.00	1.54	µg/L	
200302Q124	4	Kitchen Pot Filler-SK; Initial	1.00	16.9	µg/L	H
200302Q125	5	Kitchen Prep-SK; Initial	1.00	1.75	µg/L	
200302Q126	6	Serving Line -SK; Initial	1.00	5.20	µg/L	
200302Q127	7	Faculty Room by Kitchen-SK; Initial	1.00	<1.00	µg/L	
200302Q128	8	Nurse's Office-SK; Initial	1.00	11.1	µg/L	
200302Q129	9	Nurse's Office Bathroom-SK; Initial	1.00	2.68	µg/L	
200302Q130	10	Lobby-BF; Initial	1.00	<1.00	µg/L	
200302Q131	11	Lobby-WF; Initial	1.00	<1.00	µg/L	
200302Q132	12	Room 614-SK; Initial	1.00	5.93	µg/L	
200302Q133	13	Room 611-SK; Initial	1.00	5.65	µg/L	
200302Q134	14	Room 604-SK; Initial	1.00	4.45	µg/L	
200302Q135	15	Room 602-SK; Initial	1.00	18.2	µg/L	H
200302Q136	16	Hallway by Gym-BF; Initial	1.00	<1.00	µg/L	
200302Q137	17	Hallway by Gym-WF; Initial	1.00	<1.00	µg/L	
200302Q138	18	Boy's Bathroom by Room 512-SK; Initial	1.00	1.63	µg/L	
200302Q139	19	Room 510-SK; Initial	1.00	6.57	µg/L	
200302Q140	20	Room 508-SK; Initial	1.00	6.98	µg/L	
200302Q141	21	Hallway across Room 502-BF; Initial	1.00	<1.00	µg/L	
200302Q142	22	Hallway across Room 502-WF; Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Laboratory Report

NYE Report #: 2204426-16102

November 6, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Bellport Academic Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on November 05, 2020. New York Environmental analyzed the samples on November 06, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	05 Nov 2020
Date Received:	05 Nov 2020
Date Analyzed:	06 Nov 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
201105M001	1	Kitchen Pot Filler-SK; Initial	1.00	10.2	µg/L	
201105M002	2	Room 602-SK; Initial	1.00	56.4	µg/L	E,H

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Appendix E

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Room 1	WF	N/A		2/29/2020	-	-	-	None	CAPPED	-	-
1001-2	Room 1	SK	App	3.12	2/29/2020	-	-	-	None		-	-
1002-1	Room 2	SK	App	1.03	2/29/2020	-	-	-	None	-	-	-
1002-2	Room 2	WF	N/A		2/29/2020	-	-	-	None	CAPPED	-	-
1003-1	Room 3	SK	App	8.66	2/29/2020	-	-	-	None	-	-	-
1004-1	Room 4 Station 1	BF	App		2/29/2020	-	-	-	None	Removed from Service	-	-
1004-2	Room 4 Station 1	SK	App	2.62	2/29/2020	-	-	-	None	-	-	-
1004-3	Room 4 Station 1	SPY	App	5	2/29/2020	-	-	-	None	-	-	-
1004-4	Room 4 Station 2	BF	App		2/29/2020	-	-	-	None	Removed from Service	-	-
1004-5	Room 4 Station 2	SK	App	2.49	2/29/2020	-	-	-	None	-	-	-
1004-6	Room 4 Station 2	SPY	App		2/29/2020	-	-	-	None	Removed from Service	-	-
1004-7	Room 4	WF	N/A		2/29/2020	-	-	-	None	CAPPED	-	-
1004-8	Room 4	SK	App	1.65	2/29/2020	-	-	-	None	-	-	-
1005-1	Room 5	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1005-2	Room 5	SK	App	4.76	2/29/2020	-	-	-	None	-	-	-
1006-1	Room 6 @A	SK	App	3.71	2/29/2020	-	-	-	None	-	-	-
1006-2	Room 6 Counter 1	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1006-3	Room 6 Counter 2	BF	App	10.3	2/29/2020	-	-	-	None	-	-	-
1006-4	Room 6 Counter 2	SK	App	1.59	2/29/2020	-	-	-	None	-	-	-
1006-5	Room 6	WF	N/A		2/29/2020	-	-	-	None	CAPPED	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1007-1	Room 7	SK	App	6.38	2/29/2020	-	-	-	None	-	-	-
1007-2	Room 7	WF	App	1.8	2/29/2020	-	-	-	None	-	-	-
1008-1	Room 9	WF	N/A		2/29/2020	-	-	-	None	CAPPED	-	-
1008-2	Room 9	SK	App	1.08	2/29/2020	-	-	-	None	-	-	-
1009-1	OT/PT Room Unit @A	SK	App	3.85	2/29/2020	-	-	-	None	-	-	-
1009-2	OT/PT Room Unit	SPY	App	52	10/9/2020				Additional Sampling Required			
1009-3	OT/PT Room Unit	BF	App	6.77	2/29/2020	-	-	-	None	-	-	-
1009-4	OT/PT Room Unit @B	SK	App	3.02	2/29/2020	-	-	-	None	-	-	-
1010-1	Room 11	SK	App	1.81	2/29/2020	-	-	-	None	-	-	-
1011-1	Faculty Room	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1012-1	Custodian Office	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1013-1	Hallway by Women's Staff Bathroom	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1013-2	Hallway by Women's Staff Bathroom	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1014-1	Women's Bathroom by Room 12 @A	SK	App	7.24	2/29/2020	-	-	-	None	-	-	-
1014-2	Women's Bathroom by Room 12 @B	SK	App	4.02	2/29/2020	-	-	-	None	-	-	-
1015-1	Men's Bathroom by Room 12	SK	App	2.98	2/29/2020	-	-	-	None	-	-	-
1016-1	Room 12 Handwash	SK	App	4.8	2/29/2020	-	-	-	None	-	-	-
1016-2	Room 12 Counter @A	SK	App	6.04	2/29/2020	-	-	-	None	-	-	-
1016-3	Room 12 Counter @B	SK	App	2.01	2/29/2020	-	-	-	None	-	-	-
1017-1	Room 13 Lobby Handwash	SK	App	2.9	2/29/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1017-2	Room 13 Workshop	SK	App	1.66	2/29/2020	-	-	-	None	-	-	-
1017-3	Room 13 Workshop	SPY	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1017-4	Room 13 Workshop Conference Room	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1018-1	Room 14 Counter @A	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1018-2	Room 14 Counter @B	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1018-3	Room 14 Counter @C	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1018-4	Room 14 Counter @D	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1018-5	Room 14 Counter @E	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1019-1	Room 15 Lobby	SK	App	9.25	2/29/2020	-	-	-	None	-	-	-
1019-2	Room 15 Kitchen Handwash @A	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1019-3	Room 15 Sanitizer	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1019-4	Room 15 Sanitizer	SPY	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1019-5	Room 15 Kitchen	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1019-6	Room 15 Kitchen Handwash @B	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1020-1	Room 16	SK	App	8.6	2/29/2020	-	-	-	None	-	-	-
1021-1	Boy's Bathroom by Room 17	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1022-1	Room 17D Closet Unit @A	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1022-2	Room 17D Closet Unit @B	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1023-1	Room 19 Bathroom	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1024-1	Hallway by Room 18	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1024-2	Hallway by Room 18	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1025-1	Room 18 Bathroom	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1026-1	Custodian Closet by Room 18	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-

Laboratory Report

NYE Report #: 2201050-14117

March 4, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Brookhaven Learning Center- East

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on March 02, 2020. New York Environmental analyzed the samples on March 03, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	02 Mar 2020
Date Received:	02 Mar 2020
Date Analyzed:	03 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200302Q042	1	Room 1-SK; Initial	1.00	3.12	µg/L	
200302Q043	2	Room 2-SK; Initial	1.00	1.03	µg/L	
200302Q044	3	Room 3-SK; Initial	1.00	8.66	µg/L	
200302Q045	4	Room 4 Station 1-SK; Initial	1.00	2.62	µg/L	
200302Q046	5	Room 4 Station 1-SPY; Initial	1.00	5.00	µg/L	
200302Q047	6	Room 4 Station 2-SK; Initial	1.00	2.49	µg/L	
200302Q048	7	Room 4-SK; Initial	1.00	1.65	µg/L	
200302Q049	8	Room 5 -WF; Initial	1.00	<1.00	µg/L	
200302Q050	9	Room 5 -SK; Initial	1.00	4.76	µg/L	
200302Q051	10	Room 6 @A-SK; Initial	1.00	3.71	µg/L	
200302Q052	11	Room 6 Counter 1-SK; Initial	1.00	<1.00	µg/L	
200302Q053	12	Room 6 Counter 2-BF; Initial	1.00	10.3	µg/L	
200302Q054	13	Room 6 Counter 2-SK; Initial	1.00	1.59	µg/L	
200302Q055	14	Room 7-SK; Initial	1.00	6.38	µg/L	
200302Q056	15	Room 7-WF; Initial	1.00	1.80	µg/L	
200302Q057	16	Room 9-SK; Initial	1.00	1.08	µg/L	
200302Q058	17	OT/PT Room Unit @A-SK; Initial	1.00	3.85	µg/L	
200302Q059	18	OT/PT Room Unit-SPY; Initial	1.00	25.3	µg/L	H
200302Q060	19	OT/PT Room Unit-BF; Initial	1.00	6.77	µg/L	
200302Q061	20	OT/PT Room Unit @B-SK; Initial	1.00	3.02	µg/L	
200302Q062	21	Room 11-SK; Initial	1.00	1.81	µg/L	
200302Q063	22	Faculty Room-SK; Initial	1.00	<1.00	µg/L	
200302Q064	23	Hallway by Women's Staff Bathroom-BF; Initial	1.00	<1.00	µg/L	
200302Q065	24	Hallway by Women's Staff Bathroom-WF; Initial	1.00	<1.00	µg/L	
200302Q066	25	Women's Bathroom by Room 12 @A-SK; Initial	1.00	7.24	µg/L	
200302Q067	26	Women's Bathroom by Room 12 @B-SK; Initial	1.00	4.02	µg/L	



Date Collected:	02 Mar 2020
Date Received:	02 Mar 2020
Date Analyzed:	03 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200302Q068	27	Men's Bathroom by Room 12-SK; Initial	1.00	2.98	µg/L	
200302Q069	28	Room 12 Handwash-SK; Initial	1.00	4.80	µg/L	
200302Q070	29	Room 12 Counter @A-SK; Initial	1.00	6.04	µg/L	
200302Q071	30	Room 12 Counter @B-SK; Initial	1.00	2.01	µg/L	
200302Q072	31	Room 13 Lobby Handwash-SK; Initial	1.00	2.90	µg/L	
200302Q073	32	Room 13 Workshop-SK; Initial	1.00	1.66	µg/L	
200302Q074	33	Room 13 Workshop-SPY; Initial	1.00	<1.00	µg/L	
200302Q075	34	Room 13 Workshop Conference Room-SK; Initial	1.00	<1.00	µg/L	
200302Q076	35	Room 14 Counter @A-SK; Initial	1.00	<1.00	µg/L	
200302Q077	36	Room 14 Counter @B-SK; Initial	1.00	<1.00	µg/L	
200302Q078	37	Room 14 Counter @C-SK; Initial	1.00	<1.00	µg/L	
200302Q079	38	Room 14 Counter @D-SK; Initial	1.00	<1.00	µg/L	
200302Q080	39	Room 14 Counter @E-BF; Initial	1.00	<1.00	µg/L	
200302Q081	40	Room 15 Lobby-SK; Initial	1.00	9.25	µg/L	
200302Q082	41	Room 15 Kitchen Handwash @A-SK; Initial	1.00	<1.00	µg/L	
200302Q083	42	Room 15 Sanitizer-SK; Initial	1.00	<1.00	µg/L	
200302Q084	43	Room 15 Sanitizer-SPY; Initial	1.00	<1.00	µg/L	
200302Q085	44	Room 15 Kitchen-SK; Initial	1.00	<1.00	µg/L	
200302Q086	45	Room 15 Kitchen Handwash @B-SK; Initial	1.00	<1.00	µg/L	
200302Q087	46	Room 16-SK; Initial	1.00	8.60	µg/L	
200302Q088	47	Boy's Bathroom by Room 17-SK; Initial	1.00	<1.00	µg/L	
200302Q089	48	Room 19 Bathroom-SK; Initial	1.00	<1.00	µg/L	
200302Q090	49	Hallway by Room 18-BF; Initial	1.00	<1.00	µg/L	
200302Q091	50	Hallway by Room 18-WF; Initial	1.00	<1.00	µg/L	
200302Q092	51	Room 18 Bathroom-SK; Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Laboratory Report

NYE Report #: 2204096-15834

October 12, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Brookhaven Learning Center - East

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on October 09, 2020. New York Environmental analyzed the samples on October 10, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	09 Oct 2020
Date Received:	09 Oct 2020
Date Analyzed:	10 Oct 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
201009P017	1	OT/PT Room Unit-SPY, Initial	1.00	52.0	µg/L	E,H

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Appendix F

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Room 21	SK	App	2.11	2/29/2020	-	-	-	None	-	-	-
1002-1	Room 22	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1003-1	Room 24	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1004-1	Room 23	SK	App	1.08	2/29/2020	-	-	-	None	-	-	-
1005-1	Room 25	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1006-1	Room 26 by Stove	SK	App	1.68	2/29/2020	-	-	-	None	-	-	-
1006-2	Room 26 by Stove	SPY	App	2.18	2/29/2020	-	-	-	None	-	-	-
1006-3	Room 26	SK	App	1.87	2/29/2020	-	-	-	None	-	-	-
1007-1	Hallway by Utility Room	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1007-2	Hallway by Utility Room	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1008-1	Changing Room Girl's @A	SK	App	2.87	2/29/2020	-	-	-	None	-	-	-
1008-2	Changing Room Girl's @B	SK	App	3.21	2/29/2020	-	-	-	None	-	-	-
1009-1	Utility Room by Main Office	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1010-1	Men's Bathroom by Main Office	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1011-1	Women's Bathroom by Main Entrance @A	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1011-2	Women's Bathroom by Main Entrance @B	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1012-1	Kitchen 2 Piece Food Prep	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1012-2	Kitchen 3 Piece-Left	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1012-3	Kitchen 3 Piece-Right	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1013-1	Serving Line Handwash	SK	App	20.9	2/29/2020				Additional Sampling Required	Aerator Flushed	4.66	10/9/20

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1014-1	Unisex Bathroom by Assistant Principle's Office	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1015-1	Nurse's Office	SK	App	1.38	2/29/2020	-	-	-	None	-	-	-
1015-2	Nurse's Office	SPY	App	4.15	2/29/2020	-	-	-	None	-	-	-
1015-3	Nurse's Office Bathroom	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1016-1	Changing Room Boy's @A	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1016-2	Changing Room Boy's @B	SK	App	2.09	2/29/2020	-	-	-	None	-	-	-
1017-1	Hallway by Electric Room	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1017-2	Hallway by Electric Room	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1018-1	Room 28	SK	App	2.07	2/29/2020	-	-	-	None	-	-	-
1019-1	Room 30	SK	App	1.02	2/29/2020	-	-	-	None	-	-	-
1020-1	Room 29	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1021-1	Room 32	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1022-1	Room 31	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1023-1	Room 33	SK	App	1.08	2/29/2020	-	-	-	None	-	-	-
1024-1	Weight Room	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2201052-14118

March 4, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Brookhaven Learning Center- West 19367

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on March 02, 2020. New York Environmental analyzed the samples on March 03, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	02 Mar 2020
Date Received:	02 Mar 2020
Date Analyzed:	03 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200302Q093	1	Room 21-SK; Initial	1.00	2.11	µg/L	
200302Q094	2	Room 22-SK; Initial	1.00	<1.00	µg/L	
200302Q095	3	Room 24-SK; Initial	1.00	<1.00	µg/L	
200302Q096	4	Room 23-SK; Initial	1.00	1.08	µg/L	
200302Q097	5	Room 25-SK; Initial	1.00	<1.00	µg/L	
200302Q098	6	Room 26 by Stove-SK; Initial	1.00	1.68	µg/L	
200302Q099	7	Room 26 by Stove-SPY; Initial	1.00	2.18	µg/L	
200302Q100	8	Room 26-SK; Initial	1.00	1.87	µg/L	
200302Q101	9	Hallway by Utility Room-BF; Initial	1.00	<1.00	µg/L	
200302Q102	10	Hallway by Utility Room-WF; Initial	1.00	<1.00	µg/L	
200302Q103	11	Changing Room Girl's @A-SK; Initial	1.00	2.87	µg/L	
200302Q104	12	Changing Room Girl's @B-SK; Initial	1.00	3.21	µg/L	
200302Q105	13	Kitchen 2 Piece Food Prep-SK; Initial	1.00	<1.00	µg/L	
200302Q106	14	Serving Line Handwash-SK; Initial	1.00	20.9	µg/L	H
200302Q107	15	Nurse's Office-SK; Initial	1.00	1.38	µg/L	
200302Q108	16	Nurse's Office-SPY; Initial	1.00	4.15	µg/L	
200302Q109	17	Nurse's Office Bathroom-SK; Initial	1.00	<1.00	µg/L	
200302Q110	18	Changing Room Boy's @A-SK; Initial	1.00	<1.00	µg/L	
200302Q111	19	Changing Room Boy's @B-SK; Initial	1.00	2.09	µg/L	
200302Q112	20	Hallway by Electric Room-BF; Initial	1.00	<1.00	µg/L	
200302Q113	21	Hallway by Electric Room-WF; Initial	1.00	<1.00	µg/L	
200302Q114	22	Room 28-SK; Initial	1.00	2.07	µg/L	
200302Q115	23	Room 30-SK; Initial	1.00	1.02	µg/L	
200302Q116	24	Room 29-SK; Initial	1.00	<1.00	µg/L	
200302Q117	25	Room 32-SK; Initial	1.00	<1.00	µg/L	
200302Q118	26	Room 31-SK; Initial	1.00	1.72	µg/L	



Date Collected:	02 Mar 2020
Date Received:	02 Mar 2020
Date Analyzed:	03 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
200302Q119	27	Room 33-SK; Initial	1.00	1.08	µg/L	
200302Q120	28	Weight Room-SK; Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2204105-15843

October 12, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Brookhaven Learning Center - West

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on October 09, 2020. New York Environmental analyzed the samples on October 12, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	09 Oct 2020
Date Received:	09 Oct 2020
Date Analyzed:	12 Oct 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
201009Q009	1	Serving Line Handwash-SK, Initial	1.00	4.66	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix G

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Custodial Office	SK	App	13.9	2/29/2020	-	-	-	None	-	-	-
1001-2	Custodial Office Men's Bathroom	SK	App	6.65	2/29/2020	-	-	-	None	-	-	-
1001-3	Custodial Office Women's Bathroom	SK	N/A	15.3	2/29/2020				None	SIGN		
1001-4	Custodial Office	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1002-1	Room 101 Kitchenette	SK	App	1.62	2/29/2020	-	-	-	None	-	-	-
1002-2	Room 101	SK	App	4.45	2/29/2020	-	-	-	None	-	-	-
1002-3	Room 101 Bathroom	SK	N/A		2/29/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1003-1	ADA Bathroom by Main Office	SK	App	5.99	2/29/2020	-	-	-	None	-	-	-
1004-1	Women's Bathroom by Main Office	SK	App	7.64	2/29/2020	-	-	-	None	-	-	-
1005-1	Main Office Kitchenette	SK	App	1.91	2/29/2020	-	-	-	None	-	-	-
1006-1	Guidance Men's Bathroom	SK	App	10.3	2/29/2020	-	-	-	None	-	-	-
1006-2	Guidance Women's Bathroom @ A	SK	N/A	18.6	2/29/2020				None	SIGN		
1006-3	Guidance Women's Bathroom @ B	SK	N/A	21.1	2/29/2020				None	SIGN		
1007-1	Nurse's Office	SK	App	7.01	2/29/2020	-	-	-	None	-	-	-
1007-2	Nurse's Office	SPY	App	12.4	2/29/2020	-	-	-	None	-	-	-
1007-3	Nurse's Office Bathroom	SK	App	6.02	2/29/2020	-	-	-	None	-	-	-
1008-1	"A" Hallway	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1008-2	"A" Hallway	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1009-1	Men's Bathroom by Nurse's Office @ A	SK	App	3.05	2/29/2020	-	-	-	None	-	-	-
1009-2	Men's Bathroom by Nurse's Office @ B	SK	N/A	23.8	2/29/2020				None	SIGN		

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1010-1	Women's Bathroom by Nurse's Office @ A	SK	App	10.2	2/29/2020	-	-	-	None	-	-	-
1010-2	Women's Bathroom by Nurse's Office @ B	SK	App	14.3	2/29/2020	-	-	-	None	-	-	-
1011-1	Room 112	SK	App	13.8	2/29/2020	-	-	-	None	-	-	-
1011-2	Room 112 Bathroom	SK	App	1.96	2/29/2020	-	-	-	None	-	-	-
1012-1	Room 116 Bathroom	SK	App	11.5	2/29/2020	-	-	-	None	-	-	-
1012-2	Room 116	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1013-1	Room 129	SK	App	2.68	2/29/2020	-	-	-	None	-	-	-
1013-2	Room 129 Bathroom	SK	App	1.65	2/29/2020	-	-	-	None	-	-	-
1013-3	Room 129 Station 1	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1013-4	Room 129 Station 2	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1013-5	Room 129 Station 3	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1013-6	Room 129 Station 4	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1013-7	Room 129 Station 5	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1013-8	Room 129 Station 6	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1014-1	Room 118 Bathroom	SK	App	11.2	2/29/2020	-	-	-	None	-	-	-
1015-1	Room 122 Kitchen Prep by Storage	SK	App	3.54	2/29/2020	-	-	-	None	-	-	-
1015-2	Room 122 Kitchen Prep by Stove	SK	App	3.13	2/29/2020	-	-	-	None	-	-	-
1015-3	Room 122 Kitchen Cleveland	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1015-4	Room 122 Kitchen Potfiller	PF	App	8.24	2/29/2020	-	-	-	None	-	-	-
1015-5	Room 122 Kitchen 2-Bay @ A	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1015-6	Room 122 Kitchen 2-Bay @ B	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1015-7	Room 122 Kitchen 3-Bay @ A	SK	App	3.22	2/29/2020	-	-	-	None	-	-	-
1015-8	Room 122 Kitchen 3-Bay @ B	SK	App	2.51	2/29/2020	-	-	-	None	-	-	-
1015-9	Room 122 Kitchen Dishwash	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1015-10	Room 122 Kitchen Coffee @ A	CF	App	4.41	2/29/2020	-	-	-	None	-	-	-
1015-11	Room 122 Kitchen Coffee @ B	CF	App		2/29/2020	-	-	-	None	Removed from Service	-	-
1015-12	Room 122 Kitchen Handwash	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1015-13	Room 122 Kitchen 3-Bay by coffee maker	SK	App	36.7	11/6/2020				Fixture Replacement			
1015-14	Room 122 Kitchen Grindmaster	CF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1015-15	Room 122 Kitchen Island	SK	App		2/29/2020	-	-	-	None	Removed from Service	-	-
1015-16	Room 122 Kitchen Bathroom	SK	App	2.97	2/29/2020	-	-	-	None	-	-	-
1015-17	Room 122 Kitchen	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1015-18	Room 122 Kitchen	IM	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1016-1	Room 133	SK	App	3.25	2/29/2020	-	-	-	None	-	-	-
1016-2	Room 133 Bathroom	SK	App	8.57	2/29/2020	-	-	-	None	-	-	-
1016-3	Room 133 Station 1	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1016-4	Room 133 Station 2	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1016-5	Room 133 Station 3	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1016-6	Room 133 Station 4	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1016-7	Room 133 Station 5	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1016-8	Room 133 Station 6	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1017-1	"A" Hallway	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1018-1	Room 126	SK	App	1.27	2/29/2020	-	-	-	None	-	-	-
1018-2	Room 126 Bathroom	SK	App	2.91	10/9/2020	-	-	-	None	-	-	-
1018-3	Room 126 Bathroom by Door	SK	App	4.06	2/29/2020	-	-	-	None	-	-	-
1018-4	Room 126	WF	App		2/29/2020	-	-	-	None	Removed from Service	-	-
1019-1	Room 135	SK	App	19.1	10/9/2020				Additional Sampling Required	Permanent Sign Posted		
1019-2	Room 135 Bathroom	SK	App	3.91	2/29/2020	-	-	-	None	-	-	-
1019-3	Room 135 Station 1	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1019-4	Room 135 Station 2	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1019-5	Room 135 Station 3	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1019-6	Room 135 Station 4	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1019-7	Room 135 Station 5	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1020-1	Bathroom by Room 135	SK	App	5.53	2/29/2020	-	-	-	None	-	-	-
1021-1	Room 128 Kitchen	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1021-2	Room 128 Kitchen	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1021-3	Room 128 Kitchen Handsink	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1021-4	Room 128 Kitchen Steamer	SPY	App	5.65	10/9/2020	-	-	-	None	-	-	-
1021-5	Room 128 Kitchen Dishwash	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1021-6	Room 128 Kitchen Dishwash	SK	App	2.81	2/29/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1021-7	Room 128 Kitchen 2-Bay @ A	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1021-8	Room 128 Kitchen 2-Bay @ B	SK	App	2.1	2/29/2020	-	-	-	None	-	-	-
1021-9	Room 128 Kitchen	IM	App		2/29/2020	-	-	-	None	Removed from Service	-	-
1021-10	Room 128 Kitchen Island Handwash @ A	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1021-11	Room 128 Kitchen Island Prep @ A	SK	App	3.4	2/29/2020	-	-	-	None	-	-	-
1021-12	Room 128 Kitchen Island Prep @ B	SK	App	3.2	2/29/2020	-	-	-	None	-	-	-
1021-13	Room 128 Kitchen Island Handwash @ B	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1021-14	Room 128 Kitchen Island Prep @ C	SK	App	3.49	2/29/2020	-	-	-	None	-	-	-
1021-15	Room 128 Kitchen Island Prep @ D	SK	App	6.25	2/29/2020	-	-	-	None	-	-	-
1021-16	Room 128 Kitchen Island Prep @ E	SK	App	4.38	2/29/2020	-	-	-	None	-	-	-
1021-17	Room 128 Kitchen Bathroom	SK	App	5.97	2/29/2020	-	-	-	None	-	-	-
1021-18	Room 128 Kitchen	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1022-1	Room 137 Stock Room	SK	App	33.9	10/9/2020				Additional Sampling Required	Permanent Sign Posted		
1022-2	Room 137 / Room 139	WF	App	1.35	2/29/2020	-	-	-	None	-	-	-
1022-3	Room 137 / Room 139 Women's Bathroom	SK	App	3.23	2/29/2020	-	-	-	None	-	-	-
1022-4	Room 137 / Room 139 Men's Bathroom	SK	App	14.3	2/29/2020	-	-	-	None	-	-	-
1023-1	Room 203 Counter @ A	SK	App	11.3	2/29/2020	-	-	-	None	-	-	-
1023-2	Room 203 Counter @ A Eyewash	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1023-3	Room 203 Counter @ B	SK	App	11.7	2/29/2020	-	-	-	None	-	-	-
1023-4	Room 203 Counter @ C	SK	App	9.41	2/29/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1023-5	Room 203 Counter @ D	SK	App	33.2	10/9/2020				Additional Sampling Required	Permanent Sign Posted		
1023-6	Room 203 Women's Bathroom	SK	App	4.63	2/29/2020	-	-	-	None	-	-	-
1023-7	Room 203 Men's Bathroom	SK	App	9.98	2/29/2020	-	-	-	None	-	-	-
1024-1	Room 202	SK	App	65.9	10/9/2020				Additional Sampling Required	Permanent Sign Posted		
1024-2	Room 202 Women's Bathroom	SK	App	12.9	2/29/2020	-	-	-	None	-	-	-
1024-3	Room 202 Men's Bathroom	SK	App	12.2	2/29/2020	-	-	-	None	-	-	-
1025-1	Room 204 Bradley	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1025-2	Room 204	WF	App	12.3	2/29/2020	-	-	-	None	-	-	-
1025-3	Room 204 Women's Bathroom	SK	App	4.83	2/29/2020	-	-	-	None	-	-	-
1025-4	Room 204 Men's Bathroom	SK	App	7.13	2/29/2020	-	-	-	None	-	-	-
1026-1	Room 205 Women's Bathroom	SK	App	2.01	2/29/2020	-	-	-	None	-	-	-
1026-2	Room 205 Men's Bathroom	SK	N/A	16.6	2/29/2020				None	SIGN		
1027-1	"B" Hallway	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1027-2	"B" Hallway	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1028-1	"B" Hallway Women's Bathroom	SK	N/A	15.9	2/29/2020				None	SIGN		
1029-1	"B" Hallway Custodial Closet	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1030-1	"B" Hallway ADA Bathroom	SK	N/A	18.9	2/29/2020				None	SIGN		
1031-1	Room 208	WF	App	17.5	2/29/2020				None	Removed from Service		
1031-2	Room 208 Women's Bathroom	SK	App	4.81	2/29/2020	-	-	-	None	-	-	-
1031-3	Room 208 Men's Bathroom	SK	App	10	2/29/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1032-1	Room 207	SK	App	4.14	2/29/2020	-	-	-	None	-	-	-
1032-2	Room 207 Women's Bathroom	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1032-3	Room 207 Men's Bathroom	SK	App	1.56	2/29/2020	-	-	-	None	-	-	-
1033-1	Room 217	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1033-2	Room 217 Bathroom	SK	App	3.81	2/29/2020	-	-	-	None	-	-	-
1033-3	Room 217	WF	App	68.1	2/29/2020				None	Removed from Service		
1034-1	Room 210 Counter @ A	SK	App	1.55	2/29/2020	-	-	-	None	-	-	-
1034-2	Room 210 Counter @ B	SK	App	1.27	2/29/2020	-	-	-	None	-	-	-
1034-3	Room 210 Bathroom	SK	App	1.76	2/29/2020	-	-	-	None	-	-	-
1034-4	Room 210	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1035-1	Room 212 Counter @ A	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1035-2	Room 212 Counter @ B	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1035-3	Room 212 Bathroom	SK	App	3.3	2/29/2020	-	-	-	None	-	-	-
1035-4	Room 212	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1036-1	Room 219 Counter @ A	SK	App	2.46	2/29/2020	-	-	-	None	-	-	-
1036-2	Room 219 Counter @ B	SK	App	2.8	2/29/2020	-	-	-	None	-	-	-
1036-3	Room 219	WF	App	1.14	2/29/2020	-	-	-	None	-	-	-
1036-4	Room 219	SS	App	12.6	2/29/2020	-	-	-	None	-	-	-
1036-5	Room 219 Bathroom	SK	App	5.96	2/29/2020	-	-	-	None	-	-	-
1037-1	Room 303 Bradley	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1037-2	Room 303 Bathroom	SK	N/A	18.6	2/29/2020				None	SIGN		
1037-3	Room 303	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1038-1	Room 305 Unit @ A	SS	App	2.84	2/29/2020	-	-	-	None	-	-	-
1038-2	Room 305 Unit @ B	SS	App	1.45	2/29/2020	-	-	-	None	-	-	-
1038-3	Room 305 Bathroom	SK	N/A	17.9	2/29/2020				None	SIGN		
1038-4	Room 305	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1039-1	Room 306 Bradley	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1039-2	Room 306	WF	App	5.51	2/29/2020	-	-	-	None	-	-	-
1039-3	Room 306 Bathroom	SK	App	7.27	2/29/2020	-	-	-	None	-	-	-
1039-4	Room 306	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1040-1	"C" Hallway	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1040-2	"C" Hallway	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1041-1	Room 309 Unit @ A	SS	App	3.51	2/29/2020	-	-	-	None	-	-	-
1041-2	Room 309 Unit @ B	SS	App	2.05	2/29/2020	-	-	-	None	-	-	-
1041-3	Room 309 Bathroom	SK	App	4.04	2/29/2020	-	-	-	None	-	-	-
1042-1	Room 308 Bradley	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1042-2	Room 308	WF	App		2/29/2020	-	-	-	None	Removed from Service	-	-
1042-3	Room 308 Bathroom	SK	App	6.01	2/29/2020	-	-	-	None	-	-	-
1042-4	Room 308	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1043-1	"C" Hallway ADA Bathroom	SK	App	7.08	2/29/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1044-1	"C" Hallway Custodial Closet	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1045-1	"C" Hallway Bathroom	SK	N/A	85.4	2/29/2020				None	SIGN		
1046-1	Room 311 Bradley	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1046-2	Room 311	WF	App		2/29/2020	-	-	-	None	Removed from Service	-	-
1046-3	Room 311 Bathroom	SK	App	7.14	2/29/2020	-	-	-	None	-	-	-
1047-1	Room 316 Bradley	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1047-2	Room 316	WF	App	4.89	2/29/2020	-	-	-	None	-	-	-
1047-3	Room 316 Bathroom	SK	N/A	52	2/29/2020				None	SIGN		
1048-1	Room 403	SK	App	8.92	2/29/2020	-	-	-	None	-	-	-
1048-2	Room 403 Bradley	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1048-3	Room 403	WF	App		2/29/2020	-	-	-	None	Removed from Service	-	-
1048-4	Room 403 Bathroom	SK	App	10.6	2/29/2020	-	-	-	None	-	-	-
1048-5	Room 403	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1049-1	Room 402	SS	App	3.43	2/29/2020	-	-	-	None	-	-	-
1049-2	Room 402	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1049-3	Room 402 Bathroom	SK	App	7.16	2/29/2020	-	-	-	None	-	-	-
1049-4	Room 402	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1050-1	Room 405A	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1050-2	Room 405A Station 1	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1050-3	Room 405A Station 2	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1050-4	Room 405A Station 3	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1050-5	Room 405A Station 4	SPY	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1051-1	Room 405B Bradley	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1051-2	Room 405B	WF	App		2/29/2020	-	-	-	None	Removed from Service	-	-
1051-3	Room 405B Bathroom	SK	App	2.41	2/29/2020	-	-	-	None	-	-	-
1051-4	Room 405B	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1052-1	"D" Hallway ADA Bathroom	SK	N/A	34.4	2/29/2020				None	SIGN		
1053-1	"D" Hallway Women's Bathroom	SK	App	9.95	2/29/2020	-	-	-	None	-	-	-
1054-1	"D" Hallway Custodial Closet	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1055-1	Room 404 Unit @ A	SS	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1055-2	Room 404 Unit @ B	SS	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1055-3	Room 404	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1055-4	Room 404	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1055-5	Room 404 Bathroom	SK	App	5.93	2/29/2020	-	-	-	None	-	-	-
1056-1	"D" Hallway	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1056-2	"D" Hallway	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1057-1	Room 413 Bradley	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1057-2	Room 413 Bathroom	SK	App	6.96	2/29/2020	-	-	-	None	-	-	-
1057-3	Room 413	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1058-1	Room 406 Bradley	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1058-2	Room 406 Women's Bathroom	SK	N/A	15.2	2/29/2020				None	SIGN		
1058-3	Room 406 Men's Bathroom	SK	App	2.08	2/29/2020	-	-	-	None	-	-	-
1059-1	Room 415 Bathroom	SK	App	1.72	2/29/2020	-	-	-	None	-	-	-
1059-2	Room 415 Fridge	SP	App	<1.0	2/29/2020	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2201073-14138

March 9, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Edward Milliken Technical Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on March 03, 2020. New York Environmental analyzed the samples on March 04, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	29 Feb 2020
Date Received:	03 Mar 2020
Date Analyzed:	04 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200303O001	1	Custodial Office-SK; Initial	1.00	13.9	µg/L	
200303O002	2	Custodial Office Men's Bathroom-SK; Initial	1.00	6.65	µg/L	
200303O003	3	Custodial Office Women's Bathroom-SK; Initial	1.00	15.3	µg/L	H
200303O004	4	Room 101 Kitchenette-SK; Initial	1.00	1.62	µg/L	
200303O005	5	Room 101-SK; Initial	1.00	4.45	µg/L	
200303O006	6	ADA Bathroom by Main Office-SK; Initial	1.00	5.99	µg/L	
200303O007	7	Women's Bathroom by Main Office-SK; Initial	1.00	7.64	µg/L	
200303O008	8	Main Office Kitchenette-SK; Initial	1.00	1.91	µg/L	
200303O009	9	Guidance Men's Bathroom-SK; Initial	1.00	10.3	µg/L	
200303O010	10	Guidance Women's Bathroom @ A-SK; Initial	1.00	18.6	µg/L	H
200303O011	11	Guidance Women's Bathroom @ B-SK; Initial	1.00	21.1	µg/L	H
200303O012	12	Nurse's Office-SK; Initial	1.00	7.01	µg/L	
200303O013	13	Nurse's Office-SPY; Initial	1.00	12.4	µg/L	
200303O014	14	Nurse's Office Bathroom-SK; Initial	1.00	6.02	µg/L	
200303O015	15	"A" Hallway -WF; Initial	1.00	<1.00	µg/L	
200303O016	16	"A" Hallway -BF; Initial	1.00	<1.00	µg/L	
200303O017	17	Men's Bathroom by Nurse's Office @ A-SK; Initial	1.00	3.05	µg/L	
200303O018	18	Men's Bathroom by Nurse's Office @ B-SK; Initial	1.00	23.8	µg/L	H
200303O019	19	Women's Bathroom by Nurse's Office @ A-SK; Initial	1.00	10.2	µg/L	
200303O020	20	Women's Bathroom by Nurse's Office @ B-SK; Initial	1.00	14.3	µg/L	
200303O021	21	Room 112-SK; Initial	1.00	13.8	µg/L	
200303O022	22	Room 112 Bathroom-SK; Initial	1.00	1.96	µg/L	
200303O023	23	Room 116 Bathroom-SK; Initial	1.00	11.5	µg/L	
200303O024	24	Room 129-SK; Initial	1.00	2.68	µg/L	
200303O025	25	Room 129 Bathroom-SK; Initial	1.00	1.65	µg/L	
200303O026	26	Room 118 Bathroom-SK; Initial	1.00	11.1	µg/L	



Date Collected:	29 Feb 2020
Date Received:	03 Mar 2020
Date Analyzed:	04 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200303O027	27	Room 122 Kitchen Prep by Storage-SK; Initial	1.00	3.54	µg/L	
200303O028	28	Room 122 Kitchen Prep by Stove-SK; Initial	1.00	3.13	µg/L	
200303O029	29	Room 122 Kitchen Cleveland-SK; Initial	1.00	<1.00	µg/L	
200303O030	30	Room 122 Kitchen Potfiller-PF; Initial	1.00	8.24	µg/L	
200303O031	31	Room 122 Kitchen 2-Bay @ A-SK; Initial	1.00	<1.00	µg/L	
200303O032	32	Room 122 Kitchen 2-Bay @ B-SK; Initial	1.00	<1.00	µg/L	
200303O033	33	Room 122 Kitchen 3-Bay @ A-SK; Initial	1.00	3.22	µg/L	
200303O034	34	Room 122 Kitchen 3-Bay @ B-SK; Initial	1.00	2.51	µg/L	
200303O035	35	Room 122 Kitchen Coffee @ A-CF; Initial	1.00	4.41	µg/L	
200303O036	36	Room 122 Kitchen 3-Bay-SK; Initial	1.00	28.5	µg/L	H
200303O037	37	Room 122 Kitchen Grindmaster-CF; Initial	1.00	<1.00	µg/L	
200303O038	38	Room 122 Kitchen Bathroom-SK; Initial	1.00	2.97	µg/L	
200303O039	39	Room 122 Kitchen-IM; Initial	1.00	<1.00	µg/L	
200303O040	40	Room 133-SK; Initial	1.00	3.25	µg/L	
200303O041	41	Room 133 Bathroom-SK; Initial	1.00	8.57	µg/L	
200303O042	42	Room 126-SK; Initial	1.00	1.27	µg/L	
200303O043	43	Room 126 Bathroom -SK; Initial	1.00	16.9	µg/L	H
200303O044	44	Room 126 Bathroom by Door-SK; Initial	1.00	4.06	µg/L	
200303O045	45	Room 135-SK; Initial	1.00	38.7	µg/L	H
200303O046	46	Room 135 Bathroom-SK; Initial	1.00	3.91	µg/L	
200303O047	47	Bathroom by Room 135-SK; Initial	1.00	5.53	µg/L	
200303O048	48	Room 128 Kitchen-WF; Initial	1.00	<1.00	µg/L	
200303O049	49	Room 128 Kitchen-BF; Initial	1.00	<1.00	µg/L	
200303O050	50	Room 128 Kitchen Steamer-SP; Initial	1.00	50.4	µg/L	E,H
200303O051	51	Room 128 Kitchen Dishwash-SK; Initial	1.00	2.81	µg/L	
200303O052	52	Room 128 Kitchen 2-Bay @ A-SK; Initial	1.00	<1.00	µg/L	
200303O053	53	Room 128 Kitchen 2-Bay @ B-SK; Initial	1.00	2.10	µg/L	



Date Collected:	29 Feb 2020
Date Received:	03 Mar 2020
Date Analyzed:	04 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200303O054	54	Room 128 Kitchen Island Prep @ A-SK; Initial	1.00	3.40	µg/L	
200303O055	55	Room 128 Kitchen Island Prep @ B-SK; Initial	1.00	3.20	µg/L	
200303O056	56	Room 128 Kitchen Island Prep @ C-SK; Initial	1.00	3.49	µg/L	
200303O057	57	Room 128 Kitchen Island Prep @ D-SK; Initial	1.00	6.25	µg/L	
200303O058	58	Room 128 Kitchen Island Prep @ E-SK; Initial	1.00	4.38	µg/L	
200303O059	59	Room 128 Kitchen Bathroom-SK; Initial	1.00	5.97	µg/L	
200303O060	60	Room 137 Stock Room-SK; Initial	1.00	23.2	µg/L	H
200303O061	61	Room 137 / Room 139 -WF; Initial	1.00	1.35	µg/L	
200303O062	62	Room 137 / Room 139 Women's Bathroom-SK; Initial	1.00	3.23	µg/L	
200303O063	63	Room 137 / Room 139 Men's Bathroom-SK; Initial	1.00	14.3	µg/L	
200303O064	64	Room 203 Counter @ A-SK; Initial	1.00	11.3	µg/L	
200303O065	65	Room 203 Counter @ B-SK; Initial	1.00	11.7	µg/L	
200303O066	66	Room 203 Counter @ C-SK; Initial	1.00	9.41	µg/L	
200303O067	67	Room 203 Counter @ D-SK; Initial	1.00	15.5	µg/L	H
200303O068	68	Room 203 Women's Bathroom-SK; Initial	1.00	4.63	µg/L	
200303O069	69	Room 203 Men's Bathroom-SK; Initial	1.00	9.98	µg/L	
200303O070	70	Room 202-SK; Initial	1.00	57.6	µg/L	E,H
200303O071	71	Room 202 Women's Bathroom-SK; Initial	1.00	12.9	µg/L	
200303O072	72	Room 202 Men's Bathroom-SK; Initial	1.00	12.2	µg/L	
200303O073	73	Room 204-WF; Initial	1.00	12.3	µg/L	
200303O074	74	Room 204 Women's Bathroom-SK; Initial	1.00	4.83	µg/L	
200303O075	75	Room 204 Men's Bathroom-SK; Initial	1.00	7.13	µg/L	
200303O076	76	Room 205 Women's Bathroom-SK; Initial	1.00	2.01	µg/L	
200303O077	77	Room 205 Men's Bathroom-SK; Initial	1.00	16.6	µg/L	H
200303O078	78	"B" Hallway-WF; Initial	1.00	<1.00	µg/L	
200303O079	79	"B" Hallway-BF; Initial	1.00	<1.00	µg/L	
200303O080	80	"B" Hallway Women's Bathroom-SK; Initial	1.00	15.9	µg/L	H



Date Collected:	29 Feb 2020
Date Received:	03 Mar 2020
Date Analyzed:	04 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200303O081	81	"B" Hallway ADA Bathroom-SK; Initial	1.00	18.9	µg/L	H
200303O082	82	Room 208-WF; Initial	1.00	17.5	µg/L	H
200303O083	83	Room 208 Women's Bathroom-SK; Initial	1.00	4.81	µg/L	
200303O084	84	Room 208 Men's Bathroom-SK; Initial	1.00	10.0	µg/L	
200303O085	85	Room 207-SK; Initial	1.00	4.14	µg/L	
200303O086	86	Room 207 Women's Bathroom-SK; Initial	1.00	<1.00	µg/L	
200303O087	87	Room 207 Men's Bathroom-SK; Initial	1.00	1.56	µg/L	
200303O088	88	Room 217 Bathroom-SK; Initial	1.00	3.81	µg/L	
200303O089	89	Room 217 -WF; Initial	1.00	68.1	µg/L	E,H
200303O090	90	Room 210 Counter @ A-SK; Initial	1.00	1.55	µg/L	
200303O091	91	Room 210 Counter @ B-SK; Initial	1.00	1.27	µg/L	
200303O092	92	Room 210 Bathroom-SK; Initial	1.00	1.76	µg/L	
200303O093	93	Room 212 Counter @ A-SK; Initial	1.00	<1.00	µg/L	
200303O094	94	Room 212 Counter @ B-SK; Initial	1.00	<1.00	µg/L	
200303O095	95	Room 212 Bathroom-SK; Initial	1.00	3.30	µg/L	
200303O096	96	Room 219 Counter @ A-SK; Initial	1.00	2.46	µg/L	
200303O097	97	Room 219 Counter @ B-SK; Initial	1.00	2.80	µg/L	
200303O098	98	Room 219-WF; Initial	1.00	1.14	µg/L	
200303O099	99	Room 219-SS; Initial	1.00	12.6	µg/L	
200303O100	100	Room 219 Bathroom-SK; Initial	1.00	5.96	µg/L	
200303O101	101	Room 303 Bathroom-SK; Initial	1.00	18.6	µg/L	H
200303O102	102	Room 305 Unit @ A-SS; Initial	1.00	2.84	µg/L	
200303O103	103	Room 305 Unit @ B-SS; Initial	1.00	1.45	µg/L	
200303O104	104	Room 305 Bathroom-SK; Initial	1.00	17.9	µg/L	H
200303O105	105	Room 306-WF; Initial	1.00	5.51	µg/L	
200303O106	106	Room 306 Bathroom-SK; Initial	1.00	7.27	µg/L	
200303O107	107	"C" Hallway-WF; Initial	1.00	<1.00	µg/L	



Date Collected:	29 Feb 2020
Date Received:	03 Mar 2020
Date Analyzed:	04 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200303O108	108	"C" Hallway-BF; Initial	1.00	<1.00	µg/L	
200303O109	109	Room 309 Unit @ A-SS; Initial	1.00	3.51	µg/L	
200303O110	110	Room 309 Unit @ B-SS; Initial	1.00	2.05	µg/L	
200303O111	111	Room 309 Bathroom-SK; Initial	1.00	4.04	µg/L	
200303O112	112	Room 308 Bathroom-SK; Initial	1.00	6.01	µg/L	
200303O113	113	"C" Hallway ADA Bathroom-SK; Initial	1.00	7.08	µg/L	
200303O114	114	"C" Hallway Bathroom-SK; Initial	1.00	85.4	µg/L	E,H
200303O115	115	Room 311 Bathroom-SK; Initial	1.00	7.14	µg/L	
200303O116	116	Room 316-WF; Initial	1.00	4.89	µg/L	
200303O117	117	Room 316 Bathroom-SK; Initial	1.00	52.0	µg/L	E,H
200303O118	118	Room 403-SK; Initial	1.00	8.92	µg/L	
200303O119	119	Room 403 Bathroom-SK; Initial	1.00	10.6	µg/L	
200303O120	120	Room 402-SS; Initial	1.00	3.43	µg/L	
200303O121	121	Room 402-WF; Initial	1.00	<1.00	µg/L	
200303O122	122	Room 402 Bathroom-SK; Initial	1.00	7.16	µg/L	
200303O123	123	Room 405A-SK; Initial	1.00	<1.00	µg/L	
200303O124	124	Room 405B Bathroom-SK; Initial	1.00	2.41	µg/L	
200303O125	125	"D" Hallway ADA Bathroom-SK; Initial	1.00	34.4	µg/L	H
200303O126	126	"D" Hallway Women's Bathroom-SK; Initial	1.00	9.95	µg/L	
200303O127	127	Room 404 Unit @ A-SS; Initial	1.00	<1.00	µg/L	
200303O128	128	Room 404 Unit @ B-SS; Initial	1.00	<1.00	µg/L	
200303O129	129	Room 404-WF; Initial	1.00	<1.00	µg/L	
200303O130	130	Room 404-BF; Initial	1.00	<1.00	µg/L	
200303O131	131	Room 404 Bathroom-SK; Initial	1.00	5.93	µg/L	
200303O132	132	"D" Hallway-WF; Initial	1.00	<1.00	µg/L	
200303O133	133	"D" Hallway-BF; Initial	1.00	<1.00	µg/L	
200303O134	134	Room 413 Bathroom-SK; Initial	1.00	6.96	µg/L	



Date Collected:	29 Feb 2020
Date Received:	03 Mar 2020
Date Analyzed:	04 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
200303O135	135	Room 406 Women's Bathroom-SK; Initial	1.00	15.2	µg/L	H
200303O136	136	Room 406 Men's Bathroom-SK; Initial	1.00	2.08	µg/L	
200303O137	137	Room 415 Bathroom-SK; Initial	1.00	1.72	µg/L	
200303O138	138	Room 415 Fridge-SP; Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2204132-15866

October 14, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Edward Milliken Technical Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on October 13, 2020. New York Environmental analyzed the samples on October 14, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	09 Oct 2020
Date Received:	13 Oct 2020
Date Analyzed:	14 Oct 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
201013Q121	1	Room 126 Bathroom-SK, Initial	1.00	2.91	µg/L	
201013Q122	2	Room 135-SK, Initial	1.00	19.1	µg/L	H
201013Q123	3	Room 128 Kitchen Steamer-SPY, Initial	1.00	5.65	µg/L	
201013Q124	4	Room 137 Stock Room-SK, Initial	1.00	33.9	µg/L	H
201013Q125	5	Room 203 Counter @ D-SK, Initial	1.00	33.2	µg/L	H
201013Q126	6	Room 202-SK, Initial	1.00	65.9	µg/L	E,H

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2204452-16123

November 9, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Milliken Technical Center

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on November 06, 2020. New York Environmental analyzed the samples on November 07, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

Li Tsang, Laboratory Director

Date Collected:	06 Nov 2020
Date Received:	06 Nov 2020
Date Analyzed:	07 Nov 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
201106M180	1	Room 122 Kitchen 3 Bay - Single Faucet by Coffee Maker-SK; Initial	1.00	36.7	µg/L	H

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Appendix H

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Building 1 - Lobby	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1001-2	Building 1 - Lobby	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1002-1	Building 1 - Room 116	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1002-2	Building 1 - Room 116 Bathroom	SK	App	6.46	2/20/2020	-	-	-	None	-	-	-
1002-3	Building 1 - Room 116 Kitchen	SK	App	2.51	2/20/2020	-	-	-	None	-	-	-
1002-4	Building 1 - Room 116 Kitchen	SPY	App	1.58	2/20/2020	-	-	-	None	-	-	-
1003-1	Building 1 - Mens Bathroom 105 @ A	SK	App	2.31	2/20/2020	-	-	-	None	-	-	-
1003-2	Building 1 - Mens Bathroom 105 @ B	SK	App	1.59	2/20/2020	-	-	-	None	-	-	-
1003-3	Building 1 - Mens Bathroom 105 @ C	SK	App	5.88	2/20/2020	-	-	-	None	-	-	-
1004-1	Building 1 - Room 107	SK	App	5.04	2/20/2020	-	-	-	None	-	-	-
1004-2	Building 1 - Room 107 Mens Bathroom	SK	App	1.92	2/20/2020	-	-	-	None	-	-	-
1004-3	Building 1 - Room 107 Womens Bathroom	SK	App	2.42	2/20/2020	-	-	-	None	-	-	-
1005-1	Building 1 - Custodial Closet 109	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1006-1	Building 1 - Womens Bathroom 111 @ A	SK	App	5.07	2/20/2020	-	-	-	None	-	-	-
1006-2	Building 1 - Womens Bathroom 111 @B	SK	App	1.4	2/20/2020	-	-	-	None	-	-	-
1006-3	Building 1 - Womens Bathroom 111 @C	SK	App	1.36	2/20/2020	-	-	-	None	-	-	-
1006-4	Building 1 - Womens Bathroom 111 @D	SK	App	1.42	2/20/2020	-	-	-	None	-	-	-
1007-1	Building 1 - Room 118 Station 1	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1007-2	Building 1 - Room 118 Station 2	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1007-3	Building 1 - Room 118 Station 3	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1007-4	Building 1 - Room 118 Station 4	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1007-5	Building 1 - Room 118	SK	App	5.34	2/20/2020	-	-	-	None	-	-	-
1008-1	Building 1 - Room 113	SK	App	3.04	2/20/2020	-	-	-	None	-	-	-
1008-2	Building 1 - Room 113 Station 1	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1008-3	Building 1 - Room 113 Station 2	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1008-4	Building 1 - Room 113 Station 3	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1008-5	Building 1 - Room 113 Station 4	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1008-6	Building 1 - Room 113 Station 5	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1009-1	Building 1 - Room 115	SK	App	19.3	2/20/2020				Additional Sampling Required	Aerator Flushed	3.5	11/5/2020
1009-2	Building 1 - Room 115 Station 1	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1009-3	Building 1 - Room 115 Station 2	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1009-4	Building 1 - Room 115 Station 3	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1009-5	Building 1 - Room 115 Station 4	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1009-6	Building 1 - Room 115 Station 5	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1009-7	Building 1 - Room 115 Station 6	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1010-1	Building 1 - Room 117	SK	App	16.9	2/20/2020				Additional Sampling Required	Aerator Flushed	5.63	11/5/2020
1010-2	Building 1 - Room 117	SPY	App	11.5	2/20/2020	-	-	-	None	-	-	-
1010-3	Building 1 - Room 117	SP	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1011-1	Building 1 - Nurse's Office Bathroom	SK	App	4.19	2/20/2020	-	-	-	None	-	-	-
1012-1	Building 1 - Custodial Closet 124	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1013-1	Building 1 - Room 128	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1014-1	Building 1 - Girls Bathroom 130 @ A	SK	App	17.4	11/5/2020				Additional Sampling Required	Permanent Sign Posted		
1014-2	Building 1 - Girls Bathroom 130 @ B	SK	App	10.7	2/20/2020	-	-	-	None	-	-	-
1015-1	Building 1 - Hall between 130 / 132	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1015-2	Building 1 - Hall between 130 / 132	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1016-1	Building 1 - Boys Bathroom 132	SK	App	2.81	2/20/2020	-	-	-	None	-	-	-
1017-1	Building 1 - Room 134 @ A	SK	App	3.83	2/20/2020	-	-	-	None	-	-	-
1017-2	Building 1 - Room 134 @ B	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1018-1	Building 1 - Room 136 @ A	SK	App	2.45	2/20/2020	-	-	-	None	-	-	-
1018-2	Building 1 - Room 136 @ B	SK	App	2.45	2/20/2020	-	-	-	None	-	-	-
1019-1	Building 1 - Room 138 Bathroom	SK	App	3.3	2/20/2020	-	-	-	None	-	-	-
5001-1	Building 5 - Room 507	SK	App	4.47	2/20/2020	-	-	-	None	-	-	-
2001-2	Building 5 - Room 507 Coffee Maker	CF	App	1.15	2/20/2020	-	-	-	None	-	-	-
5002-1	Building 5 - Room 509 Bathroom	SK	App	3.39	2/20/2020	-	-	-	None	-	-	-
5002-2	Building 5 - Room 509 Unit @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
5002-3	Building 5 - Room 509 Unit @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
5003-1	Building 5 - Custodial Closet 511	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
5004-1	Building 5 - Bathroom 513	SK	App	3.46	2/20/2020	-	-	-	None	-	-	-
5005-1	Building 5 - Mens Bathroom 515	SK	App	1.18	2/20/2020	-	-	-	None	-	-	-
5006-1	Building 5 - Room 517	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
5006-2	Building 5 - Room 517 Station 1	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
5006-3	Building 5 - Room 517 Station 2	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
5006-4	Building 5 - Room 517 Station 3	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
5007-1	Building 5 - Room 525 @ A	SK	App	3.09	2/20/2020	-	-	-	None	-	-	-
5007-2	Building 5 - Room 525 @ B	SK	App	4.51	2/20/2020	-	-	-	None	-	-	-
5008-1	Building 5 - Room 528	SK	App	4.18	2/20/2020	-	-	-	None	-	-	-
5009-1	Building 5 - Hall by 517	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
5009-2	Building 5 - Hall by 517	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
5010-1	Building 5 - Womens Bathroom 506 @ A	SK	App	3.22	2/20/2020	-	-	-	None	-	-	-
5010-2	Building 5 - Womens Bathroom 506 @ B	SK	App	2	2/20/2020	-	-	-	None	-	-	-
4001-1	Building 4 - Room 404	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
4001-2	Building 4 - Room 404 Unit @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
4001-3	Building 4 - Room 404 Unit @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
4001-4	Building 4 - Room 404 Unit @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
4001-5	Building 4 - Room 404 Bathroom	SK	App	1.64	2/20/2020	-	-	-	None	-	-	-
4002-1	Building 4 - Room 403	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
4002-2	Building 4 - Room 403	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
4002-3	Building 4 - Room 403 Unit @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
4002-4	Building 4 - Room 403 Unit @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
4002-5	Building 4 - Room 403 Bathroom	SK	App	1.59	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
4003-1	Building 4 - Custodial Closet 404	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
4004-1	Building 4 - Lobby Girls Bathroom	SK	App	4.57	2/20/2020	-	-	-	None	-	-	-
4005-1	Building 4 - Lobby Boys Bathroom	SK	App	2.56	2/20/2020	-	-	-	None	-	-	-
4006-1	Building 4 - Room 401	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
4006-2	Building 4 - Room 401	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
4006-3	Building 4 - Room 401 Unit @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
4006-4	Building 4 - Room 401 Unit @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
4006-5	Building 4 - Room 401 Unit @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
4006-6	Building 4 - Room 401 Bathroom	SK	App	3.47	2/20/2020	-	-	-	None	-	-	-
3001-1	Building 3 - Boys Bathroom 301	SK	App	17.4	2/20/2020				Additional Sampling Required	Aerator Flushed	1.94	11/5/2020
3002-1	Building 3 - Room 303 Unit @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
3002-2	Building 3 - Room 303 Unit @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
3003-1	Building 3 - Custodial Closet 305	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
3004-1	Building 3 - Bathroom 307	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
3005-1	Building 3 - Hall by Room 306	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
3005-2	Building 3 - Hall by Room 306	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
3006-1	Building 3 - Room 306 Bathroom	SK	App	2.56	2/20/2020	-	-	-	None	-	-	-
3006-2	Building 3 - Room 306 Laundry	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
3006-3	Building 3 - Room 306 Pet Shower @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
3006-4	Building 3 - Room 306 Pet Shower @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
3006-5	Building 3 - Room 306	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
3007-1	Building 3 - Girls Bathroom 302	SK	App	4.37	2/20/2020	-	-	-	None	-	-	-
8003-1	Roanoke House - 2nd Floor Bathroom	SK	App	2.81	2/20/2020	-	-	-	None	-	-	-
8001-1	Roanoke House - Kitchen	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
8002-1	Roanoke House - 1st Floor Bathroom	SK	App	2.68	2/20/2020	-	-	-	None	-	-	-
6001-1	Building 6 - Womens Bathroom 607	SK	App	60.4	2/20/2020				Additional Sampling Required	Aerator Flushed	8.4	11/5/2020
6002-1	Building 6 - Mens Bathroom 609	SK	App	8.66	2/20/2020	-	-	-	None	-	-	-
6003-1	Building 6 - Custodial Closet 615	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
6004-1	Building 6 - Room 602	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
7001-1	Building 7 - Custodial Closet 703	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
7002-1	Building 7 - Room 707	WF	App	1.59	2/20/2020	-	-	-	None	-	-	-
7002-2	Building 7 - Room 707 Bathroom	SK	App	5.81	2/20/2020	-	-	-	None	-	-	-
7003-1	Building 7 - Room 710	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
7003-2	Building 7 - Room 710 Bathroom	SK	App	15.8	2/20/2020				Additional Sampling Required	Aerator Flushed	13	11/5/2020
7004-1	Building 7 - Lobby	SK	App	5.4	2/20/2020	-	-	-	None	-	-	-
7005-1	Building 7 - Bathroom 708	SK	App	1.6	2/20/2020	-	-	-	None	-	-	-
7006-1	Building 7 - Bathroom 706	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
2001-1	Building 2 - Room 211 Womens Bathroom	SK	App	3.04	2/20/2020	-	-	-	None	-	-	-
2001-2	Building 2 - Room 211 Mens Bathroom	SK	App	1.32	2/20/2020	-	-	-	None	-	-	-
2002-1	Building 2 - Bathroom 213 @ A	SK	App	8.94	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
2002-2	Building 2 - Bathroom 213 @ B	SK	App	4.98	2/20/2020	-	-	-	None	-	-	-
2003-1	Building 2 - Hall by Bathroom 213	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
2003-2	Building 2 - Hall by Bathroom 213	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
2004-1	Building 2 - Custodial Closet 215	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
2005-1	Building 2 - Mens Bathroom 217	SK	App	2.05	2/20/2020	-	-	-	None	-	-	-
2006-1	Building 2 - Womens Bathroom by Room 219	SK	App	1.49	2/20/2020	-	-	-	None	-	-	-
2007-1	Building 2 - Room 223 Bathroom	SK	App	9.98	2/20/2020	-	-	-	None	-	-	-
2008-1	Building 2 - Culinary Lobby	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
2008-2	Building 2 - Culinary Lobby	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
2009-1	Building 2 - Womens Bathroom at Culinary Lobby	SK	App	2.46	2/20/2020	-	-	-	None	-	-	-
2010-1	Building 2 - Mens Bathroom at Culinary Lobby	SK	App	1.31	2/20/2020	-	-	-	None	-	-	-
2011-1	Building 2 - Room 202	SK	App	4.8	2/20/2020	-	-	-	None	-	-	-
2011-2	Building 2 - Room 202 Handwash	SK	App	3.05	2/20/2020	-	-	-	None	-	-	-
2011-3	Building 2 - Room 202 Coffee Maker	CF	App	3.16	2/20/2020	-	-	-	None	-	-	-
2012-1	Building 2 - Room 207	IM	App	<1.0	2/20/2020	-	-	-	None	-	-	-
2012-2	Building 2 - Room 207 Dishwash	SPY	App	6.89	2/20/2020	-	-	-	None	-	-	-
2012-3	Building 2 - Room 207 Handwash @ A	SK	App	2.86	2/20/2020	-	-	-	None	-	-	-
2012-4	Building 2 - Room 207 3-Bay	SPY	App	1.5	2/20/2020	-	-	-	None	-	-	-
2012-5	Building 2 - Room 207 Custodial Closet	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
2012-6	Building 2 - Room 207 Handwash @ B	SK	App	1.29	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
2012-7	Building 2 - Room 207 3-Bay @ A	SK	App	2	2/20/2020	-	-	-	None	-	-	-
2012-8	Building 2 - Room 207 3-Bay @ B	SPY	App	1.74	2/20/2020	-	-	-	None	-	-	-
2012-9	Building 2 - Room 207 2-Bay Knife Sink	SPY	App	3.14	2/20/2020	-	-	-	None	-	-	-
2012-10	Building 2 - Room 207 Handwash @ C	SPY	App	2.3	2/20/2020	-	-	-	None	-	-	-
2012-11	Building 2 - Room 207 Handwash @ D	SK	App	3.13	2/20/2020	-	-	-	None	-	-	-
2012-12	Building 2 - Room 207 Island	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
2012-13	Building 2 - Room 207 by Baker's Pride	SK	App	8.75	2/20/2020	-	-	-	None	-	-	-
2012-14	Building 2 - Room 207 Potfiller	PF	App	115	2/20/2020				Additional Sampling Required	Fixture flushed	11.8	11/5/2020
2012-15	Building 2 - Room 207 by Ovens	SK	App	4	2/20/2020	-	-	-	None	-	-	-
2013-1	Building 2 - Mens Bathroom by Room 207	SK	App	2.55	2/20/2020	-	-	-	None	-	-	-
2014-1	Building 2 - Custodial Closet by Room 207	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
2015-1	Building 2 - Womens Bathroom by Room 207	SK	App	1.36	2/20/2020	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2200871-14035

February 26, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Hb Ward Technical Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 24, 2020. New York Environmental analyzed the samples on February 25, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	20 Feb 2020
Date Received:	24 Feb 2020
Date Analyzed:	25 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200224P017	1	Building 1 - Lobby-BF; Initial	1.00	<1.00	µg/L	
200224P018	2	Building 1 - Lobby-WF; Initial	1.00	<1.00	µg/L	
200224P019	3	Building 1 - Room 116-SK; Initial	1.00	<1.00	µg/L	
200224P020	4	Building 1 - Room 116 Bathroom-SK; Initial	1.00	6.46	µg/L	
200224P021	5	Building 1 - Room 116 Kitchen-SK; Initial	1.00	2.51	µg/L	
200224P022	6	Building 1 - Room 116 Kitchen-SPY; Initial	1.00	1.58	µg/L	
200224P023	7	Building 1 - Mens Bathroom 105 @ A-SK; Initial	1.00	2.31	µg/L	
200224P024	8	Building 1 - Mens Bathroom 105 @ B-SK; Initial	1.00	1.59	µg/L	
200224P025	9	Building 1 - Mens Bathroom 105 @ C-SK; Initial	1.00	5.88	µg/L	
200224P026	10	Building 1 - Room 107-SK; Initial	1.00	5.04	µg/L	
200224P027	11	Building 1 - Room 107 Mens Bathroom-SK; Initial	1.00	1.92	µg/L	
200224P028	12	Building 1 - Room 107 Womens Bathroom-SK; Initial	1.00	2.42	µg/L	
200224P029	13	Building 1 - Womens Bathroom 111 @ A-SK; Initial	1.00	5.07	µg/L	
200224P030	14	Building 1 - Womens Bathroom 111 @B-SK; Initial	1.00	1.40	µg/L	
200224P031	15	Building 1 - Womens Bathroom 111 @C-SK; Initial	1.00	1.36	µg/L	
200224P032	16	Building 1 - Womens Bathroom 111 @D-SK; Initial	1.00	1.42	µg/L	
200224P033	17	Building 1 - Room 118-SK; Initial	1.00	5.34	µg/L	
200224P034	18	Building 1 - Room 113-SK; Initial	1.00	3.04	µg/L	
200224P035	19	Building 1 - Room 115-SK; Initial	1.00	19.3	µg/L	H
200224P036	20	Building 1 - Room 117-SK; Initial	1.00	16.9	µg/L	H
200224P037	21	Building 1 - Room 117-SPY; Initial	1.00	11.5	µg/L	
200224P038	22	Building 1 - Room 117-SP; Initial	1.00	<1.00	µg/L	
200224P039	23	Building 1 - Nurse's Office Bathroom-SK; Initial	1.00	4.19	µg/L	
200224P040	24	Building 1 - Girls Bathroom 130 @ A-SK; Initial	1.00	21.5	µg/L	H
200224P041	25	Building 1 - Girls Bathroom 130 @ B-SK; Initial	1.00	10.7	µg/L	
200224P042	26	Building 1 - Hall between 130 / 132-BF; Initial	1.00	<1.00	µg/L	



Date Collected:	20 Feb 2020
Date Received:	24 Feb 2020
Date Analyzed:	25 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200224P043	27	Building 1 - Hall between 130 / 132-WF; Initial	1.00	<1.00	µg/L	
200224P044	28	Building 1 - Boys Bathroom 132 -SK; Initial	1.00	2.81	µg/L	
200224P045	29	Building 1 - Room 134 @ A-SK; Initial	1.00	3.83	µg/L	
200224P046	30	Building 1 - Room 134 @ B-SK; Initial	1.00	<1.00	µg/L	
200224P047	31	Building 1 - Room 136 @ A-SK; Initial	1.00	2.45	µg/L	
200224P048	32	Building 1 - Room 136 @ B-SK; Initial	1.00	2.45	µg/L	
200224P049	33	Building 1 - Room 138 Bathroom-SK; Initial	1.00	3.30	µg/L	
200224P050	34	Building 5 - Room 507-SK; Initial	1.00	4.47	µg/L	
200224P051	35	Building 5 - Room 507 Coffee Maker-CF; Initial	1.00	1.15	µg/L	
200224P052	36	Building 5 - Room 509 Bathroom-SK; Initial	1.00	3.39	µg/L	
200224P053	37	Building 5 - Bathroom 513-SK; Initial	1.00	3.46	µg/L	
200224P054	38	Building 5 - Mens Bathroom 515-SK; Initial	1.00	1.18	µg/L	
200224P055	39	Building 5 - Room 517-SK; Initial	1.00	<1.00	µg/L	
200224P056	40	Building 5 - Room 525 @ A-SK; Initial	1.00	3.09	µg/L	
200224P057	41	Building 5 - Room 525 @ B-SK; Initial	1.00	4.51	µg/L	
200224P058	42	Building 5 - Room 528-SK; Initial	1.00	4.18	µg/L	
200224P059	43	Building 5 - Hall by 517-BF; Initial	1.00	<1.00	µg/L	
200224P060	44	Building 5 - Hall by 517-WF; Initial	1.00	<1.00	µg/L	
200224P061	45	Building 5 - Womens Bathroom 506 @ A-SK; Initial	1.00	3.22	µg/L	
200224P062	46	Building 5 - Womens Bathroom 506 @ B-SK; Initial	1.00	2.00	µg/L	
200224P063	47	Building 4 - Room 404-WF; Initial	1.00	<1.00	µg/L	
200224P064	48	Building 4 - Room 404 Bathroom-SK; Initial	1.00	1.64	µg/L	
200224P065	49	Building 4 - Room 403-BF; Initial	1.00	<1.00	µg/L	
200224P066	50	Building 4 - Room 403-WF; Initial	1.00	<1.00	µg/L	
200224P067	51	Building 4 - Room 403 Bathroom-SK; Initial	1.00	1.59	µg/L	
200224P068	52	Building 4 - Lobby Girls Bathroom-SK; Initial	1.00	4.57	µg/L	
200224P069	53	Building 4 - Lobby Boys Bathroom-SK; Initial	1.00	2.56	µg/L	



Date Collected:	20 Feb 2020
Date Received:	24 Feb 2020
Date Analyzed:	25 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200224P070	54	Building 4 - Room 401-BF; Initial	1.00	<1.00	µg/L	
200224P071	55	Building 4 - Room 401-WF; Initial	1.00	<1.00	µg/L	
200224P072	56	Building 4 - Room 401 Bathroom-SK; Initial	1.00	3.47	µg/L	
200224P073	57	Building 3 - Boys Bathroom 301-SK; Initial	1.00	17.4	µg/L	H
200224P074	58	Building 3 - Hall by Room 306-BF; Initial	1.00	<1.00	µg/L	
200224P075	59	Building 3 - Hall by Room 306-WF; Initial	1.00	<1.00	µg/L	
200224P076	60	Building 3 - Room 306 Bathroom-SK; Initial	1.00	2.56	µg/L	
200224P077	61	Building 3 - Girls Bathroom 302-SK; Initial	1.00	4.37	µg/L	
200224P078	62	Roanoke House - 2nd Floor Bathroom-SK; Initial	1.00	2.81	µg/L	
200224P079	63	Roanoke House - Kitchen-SK; Initial	1.00	<1.00	µg/L	
200224P080	64	Roanoke House - 1st Floor Bathroom-SK; Initial	1.00	2.68	µg/L	
200224P081	65	Building 6 - Womens Bathroom 607-SK; Initial	1.00	60.4	µg/L	E,H
200224P082	66	Building 6 - Mens Bathroom 609-SK; Initial	1.00	8.66	µg/L	
200224P083	67	Building 6 - Room 602-SK; Initial	1.00	<1.00	µg/L	
200224P084	68	Building 7 - Room 707-WF; Initial	1.00	1.59	µg/L	
200224P085	69	Building 7 - Room 707 Bathroom-SK; Initial	1.00	5.81	µg/L	
200224P086	70	Building 7 - Room 710-WF; Initial	1.00	<1.00	µg/L	
200224P087	71	Building 7 - Room 710 Bathroom-SK; Initial	1.00	15.8	µg/L	H
200224P088	72	Building 7 - Lobby-SK; Initial	1.00	5.40	µg/L	
200224P089	73	Building 7 - Bathroom 708-SK; Initial	1.00	1.60	µg/L	
200224P090	74	Building 7 - Bathroom 706-SK; Initial	1.00	<1.00	µg/L	
200224P091	75	Building 2 - Room 211 Womens Bathroom-SK; Initial	1.00	3.04	µg/L	
200224P092	76	Building 2 - Room 211 Mens Bathroom-SK; Initial	1.00	1.32	µg/L	
200224P093	77	Building 2 - Bathroom 213 @ A-SK; Initial	1.00	8.94	µg/L	
200224P094	78	Building 2 - Bathroom 213 @ B-SK; Initial	1.00	4.98	µg/L	
200224P095	79	Building 2 - Hall by Bathroom 213-BF; Initial	1.00	<1.00	µg/L	
200224P096	80	Building 2 - Hall by Bathroom 213-WF; Initial	1.00	<1.00	µg/L	



Date Collected:	20 Feb 2020
Date Received:	24 Feb 2020
Date Analyzed:	25 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200224P097	81	Building 2 - Mens Bathroom 217-SK; Initial	1.00	2.05	µg/L	
200224P098	82	Building 2 - Womens Bathroom by Room 219-SK; Initial	1.00	1.49	µg/L	
200224P099	83	Building 2 - Room 223 Bathroom-SK; Initial	1.00	9.98	µg/L	
200224P100	84	Building 2 - Culinary Lobby-BF; Initial	1.00	<1.00	µg/L	
200224P101	85	Building 2 - Culinary Lobby-WF; Initial	1.00	<1.00	µg/L	
200224P102	86	Building 2 - Womens Bathroom at Culinary Lobby-SK; Initial	1.00	2.46	µg/L	
200224P103	87	Building 2 - Mens Bathroom at Culinary Lobby-SK; Initial	1.00	1.31	µg/L	
200224P104	88	Building 2 - Room 202-SK; Initial	1.00	4.80	µg/L	
200224P105	89	Building 2 - Room 202 Handwash-SK; Initial	1.00	3.05	µg/L	
200224P106	90	Building 2 - Room 202 Coffee Maker-CF; Initial	1.00	3.16	µg/L	
200224P107	91	Building 2 - Room 207 -IM; Initial	1.00	<1.00	µg/L	
200224P108	92	Building 2 - Room 207 Dishwash-SPY; Initial	1.00	6.89	µg/L	
200224P109	93	Building 2 - Room 207 Handwash @ A-SK; Initial	1.00	2.86	µg/L	
200224P110	94	Building 2 - Room 207 3-Bay-SPY; Initial	1.00	1.50	µg/L	
200224P111	95	Building 2 - Room 207 Handwash @ B-SK; Initial	1.00	1.29	µg/L	
200224P112	96	Building 2 - Room 207 3-Bay @ A-SK; Initial	1.00	2.00	µg/L	
200224P113	97	Building 2 - Room 207 3-Bay @ B-SPY; Initial	1.00	1.74	µg/L	
200224P114	98	Building 2 - Room 207 2-Bay Knife Sink-SPY; Initial	1.00	3.14	µg/L	
200224P115	99	Building 2 - Room 207 Handwash @ C-SPY; Initial	1.00	2.30	µg/L	
200224P116	100	Building 2 - Room 207 Handwash @ D-SK; Initial	1.00	3.13	µg/L	
200224P117	101	Building 2 - Room 207 Island-SK; Initial	1.00	<1.00	µg/L	
200224P118	102	Building 2 - Room 207 by Baker's Pride-SK; Initial	1.00	8.75	µg/L	
200224P119	103	Building 2 - Room 207 Potfiller-PF; Initial	1.00	115	µg/L	E,H
200224P120	104	Building 2 - Room 207 by Ovens-SK; Initial	1.00	4.00	µg/L	
200224P121	105	Building 2 - Mens Bathroom by Room 207-SK; Initial	1.00	2.55	µg/L	
200224P122	106	Building 2 - Womens Bathroom by Room 207-SK; Initial	1.00	1.36	µg/L	



Date Collected:	20 Feb 2020
Date Received:	24 Feb 2020
Date Analyzed:	25 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID **CID** **Sample Location/Description** **LOQ** **Result** **Units** **Flag**

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.



Laboratory Report

NYE Report #: 2204427-16103

November 6, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: HB Ward Technical Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on November 05, 2020. New York Environmental analyzed the samples on November 06, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	05 Nov 2020
Date Received:	05 Nov 2020
Date Analyzed:	06 Nov 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
201105M003	1	Building 1-Room 115-SK	1.00	3.50	µg/L	
201105M004	2	Building 1-Room 117-SK	1.00	5.63	µg/L	
201105M005	3	Building 1-Girls' Bathroom 130 @ A	1.00	17.4	µg/L	H
201105M006	4	Building 2-Room 207-PF	1.00	11.8	µg/L	
201105M007	5	Building 7-Room710 Bathroom-SK	1.00	13.0	µg/L	
201105M008	6	Building 6-Women's Bathroom 607-SK	1.00	8.40	µg/L	
201105M009	7	Building 3-Boy's Bathroom 301-SK	1.00	1.94	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Appendix I

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Room W-9 Handwash	SK	App	8.57	2/20/2020	-	-	-	None	-	-	-
1001-2	Room W-9 Dishwash	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1002-1	Shop Room	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1003-1	Room W-7 Hair Wash Station	SPY	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1003-2	Room W-7	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1004-1	Room W-5	SK	App	9.5	2/20/2020	-	-	-	None	-	-	-
1005-1	Room W-6	SK	App	6.24	2/20/2020	-	-	-	None	-	-	-
1006-1	Room W-3	SK	App	8.52	10/9/2020	-	-	-	None	-	-	-
1007-1	Room W-4	SK	App	8.5	10/9/2020	-	-	-	None	-	-	-
1008-1	Room W-1	SK	App	12	10/9/2020	-	-	-	None	-	-	-
1009-1	Room W-2	SK	App	8.94	10/9/2020	-	-	-	None	-	-	-
1010-1	Hallway by Room W-2	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1010-2	Hallway by Room W-2	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1011-1	Custodial Closet by Room W-2	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1012-1	Boy's Bathroom by Main Office @ A	SK	App	1.51	2/20/2020	-	-	-	None	-	-	-
1012-2	Boy's Bathroom by Main Office @ B	SK	App	1.62	2/20/2020	-	-	-	None	-	-	-
1013-1	Girl's Bathroom by Gym @ A	SK	App	87.7	2/20/2020				None	SIGN		
1013-2	Girl's Bathroom by Gym @ B	SK	App	6.01	2/20/2020	-	-	-	None	-	-	-
1014-1	Kitchen Dishwash @ A	SK	App	1.21	2/20/2020	-	-	-	None	-	-	-
1014-2	Kitchen Dishwash @ A	SPY	App	1.17	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1014-3	Kitchen Dishwash @ B	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1014-4	Kitchen Handwash	SK	App	2.58	2/20/2020	-	-	-	None	-	-	-
1015-1	Women's Staff Bathroom	SK	App	1.73	2/20/2020	-	-	-	None	-	-	-
1016-1	Men's Staff Bathroom	SK	App	3.45	2/20/2020	-	-	-	None	-	-	-
1017-1	Nurse's Office	SK	App	10.7	10/9/2020	-	-	-	None	-	-	-
1017-2	Nurse's Office Bathroom	SK	App	3	2/20/2020	-	-	-	None	-	-	-
1018-1	Hallway by Faculty Room	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1018-2	Hallway by Faculty Room	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1019-1	Faculty Room	SK	App	4.09	2/20/2020	-	-	-	None	-	-	-
1020-1	Room E-1	SK	App	9.57	2/20/2020	-	-	-	None	-	-	-
1021-1	Room E-3	SK	App	4.91	2/20/2020	-	-	-	None	-	-	-
1022-1	Room E-2	SK	App	4.58	10/9/2020	-	-	-	None	-	-	-
1023-1	Room E-4	SK	App	8.75	2/20/2020	-	-	-	None	-	-	-
1024-1	Room E-5	SK	App	10.1	2/20/2020	-	-	-	None	-	-	-
1025-1	Room E-7	SK	App	6.44	10/9/2020	-	-	-	None	-	-	-
1026-1	Room E-6	SK	App	5.66	2/20/2020	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2200872-14036

February 26, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Islip Academic Center

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 24, 2020. New York Environmental analyzed the samples on February 25, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

Li Tsang, Laboratory Director

Date Collected:	20 Feb 2020
Date Received:	24 Feb 2020
Date Analyzed:	25 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200224P123	1	Room W-9 Handwash - SK; Initial	1.00	8.57	µg/L	
200224P124	2	Room W-9 Dishwash - SK; Initial	1.00	<1.00	µg/L	
200224P125	3	Room W-7 - SK; Initial	1.00	<1.00	µg/L	
200224P126	4	Room W-5 - SK; Initial	1.00	9.15	µg/L	
200224P127	5	Room W-6 - SK; Initial	1.00	6.24	µg/L	
200224P128	6	Room W-3 - SK; Initial	1.00	28.3	µg/L	H
200224P129	7	Room W-4 - SK; Initial	1.00	22.2	µg/L	H
200224P130	8	Room W-1 - SK; Initial	1.00	29.4	µg/L	H
200224P131	9	Room W-2 - SK; Initial	1.00	66.9	µg/L	E,H
200224P132	10	Hallway by Room W-2 - WF; Initial	1.00	<1.00	µg/L	
200224P133	11	Hallway by Room W-2 - BF; Initial	1.00	<1.00	µg/L	
200224P134	12	Boy's Bathroom by Main Office @ A - SK; Initial	1.00	1.51	µg/L	
200224P135	13	Boy's Bathroom by Main Office @ B - SK; Initial	1.00	1.62	µg/L	
200224P136	14	Girl's Bathroom by Gym @ A - SK; Initial	1.00	87.7	µg/L	E,H
200224P137	15	Girl's Bathroom by Gym @ B - SK; Initial	1.00	6.01	µg/L	
200224P138	16	Kitchen Dishwash @ A - SK; Initial	1.00	1.21	µg/L	
200224P139	17	Kitchen Dishwash @ A - SPY; Initial	1.00	1.17	µg/L	
200224P140	18	Kitchen Dishwash @ B - SK; Initial	1.00	<1.00	µg/L	
200224P141	19	Kitchen Handwash - SK; Initial	1.00	2.58	µg/L	
200224P142	20	Women's Staff Bathroom - SK; Initial	1.00	1.73	µg/L	
200224P143	21	Men's Staff Bathroom - SK; Initial	1.00	3.45	µg/L	
200224P144	22	Nurse's Office - SK; Initial	1.00	37.7	µg/L	H
200224P145	23	Nurse's Office Bathroom - SK; Initial	1.00	3.00	µg/L	
200224P146	24	Hallway by Faculty Room - WF; Initial	1.00	<1.00	µg/L	
200224P147	25	Hallway by Faculty Room - BF; Initial	1.00	<1.00	µg/L	
200224P148	26	Faculty Room - SK; Initial	1.00	4.09	µg/L	



Date Collected:	20 Feb 2020
Date Received:	24 Feb 2020
Date Analyzed:	25 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
200224P149	27	Room E-1 - SK; Initial	1.00	9.57	µg/L	
200224P150	28	Room E-3 - SK; Initial	1.00	4.91	µg/L	
200224P151	29	Room E-2 - SK; Initial	1.00	17.6	µg/L	H
200224P152	30	Room E-4 - SK; Initial	1.00	8.75	µg/L	
200224P153	31	Room E-5 - SK; Initial	1.00	10.1	µg/L	
200224P154	32	Room E-7 - SK; Initial	1.00	15.7	µg/L	H
200224P155	33	Room E-6 - SK; Initial	1.00	5.66	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2204103-15841

October 12, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Islip Academic Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on October 09, 2020. New York Environmental analyzed the samples on October 10, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	09 Oct 2020
Date Received:	09 Oct 2020
Date Analyzed:	10 Oct 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
201009P037	1	Nurse's Office-SK, Initial	1.00	10.7	µg/L	
201009P038	2	Room E-2-SK, Initial	1.00	4.58	µg/L	
201009P039	3	Room E-7-SK, Initial	1.00	6.44	µg/L	
201009P040	4	Room W-1-SK, Initial	1.00	12.0	µg/L	
201009P041	5	Room W-2-SK, Initial	1.00	8.94	µg/L	
201009P042	6	Room W-3-SK, Initial	1.00	8.52	µg/L	
201009P043	7	Room W-4-SK, Initial	1.00	8.50	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix J

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Custodial Closet in IOC Wing	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1002-1	IOC Room 7 Office Bathroom	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1003-1	Hallway by IOC Faculty Room	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1003-2	Hallway by IOC Faculty Room	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1004-1	IOC Room 9 Bathroom	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1005-1	Custodial Closet by Room 4	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1006-1	Girl's Bathroom by Room 4 @ A	SK	App	3.61	2/20/2020	-	-	-	None	-	-	-
1006-2	Girl's Bathroom by Room 4 @ B	SK	App	11.3	2/20/2020	-	-	-	None	-	-	-
1006-3	Girl's Bathroom by Room 4 @ C	SK	App	13.5	2/20/2020	-	-	-	None	-	-	-
1007-1	Boy's Bathroom by Room 4	SK	App	2.2	2/20/2020	-	-	-	None	-	-	-
1008-1	Men's Bathroom by Room 4 @ A	SK	App	4.04	2/20/2020	-	-	-	None	-	-	-
1008-2	Men's Bathroom by Room 4 @ B	SK	App	3.82	2/20/2020	-	-	-	None	-	-	-
1009-1	Women's Bathroom by Room 4	SK	App	1.16	2/20/2020	-	-	-	None	-	-	-
1009-2	Women's Bathroom ADA by Room 4	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1010-1	Room 2	SK	App	5.43	2/20/2020	-	-	-	None	-	-	-
1011-1	Room 1	SK	App	1.32	2/20/2020	-	-	-	None	-	-	-
1011-2	Room1 Bathroom	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1012-1	ICC Cafeteria	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1012-2	ICC Cafeteria	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1012-3	ICC Cafeteria	SK	App	23.3	2/20/2020				Additional Sampling Required	Removed from Service		

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1013-1	Computer Lab/Lunch Room	SK	App	1.42	2/20/2020	-	-	-	None	-	-	-
1014-1	Custodial Closet by Cafeteria	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1015-1	Custodial Closet by Room 21	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1015-2	Custodial Closet by Room 21 Bathroom	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1016-1	Room 23 Horticulture Unit @ A	SK	App	6.18	2/20/2020	-	-	-	None	-	-	-
1016-2	Room 23 Horticulture Unit @ B	SK	App	4.57	2/20/2020	-	-	-	None	-	-	-
1017-1	Room 22 Auto Body Trough Sink @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1017-2	Room 22 Auto Body Trough Sink @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1017-3	Room 22 Auto Body Trough Sink @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1018-1	Room 21 Auto Mechanics Trough sink @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1018-2	Room 21 Auto Mechanics Trough sink @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1018-3	Room 21 Auto Mechanics Trough sink @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1018-4	Room 21 Auto Mechanics	WF	N/A		2/20/2020	-	-	-	None	CAPPED	-	-
1019-1	Room 20 Auto Mechanics Trough Sink @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1019-2	Room 20 Auto Mechanics Trough Sink @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1019-3	Room 20 Auto Mechanics Trough Sink @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1019-4	Room 20 Auto Mechanics	WF	App	7.73	2/20/2020	-	-	-	None	-	-	-
1020-1	Room 19 Weight Room	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1021-1	Room 15 Unit 1 @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1021-2	Room 15 Unit 1 @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1021-3	Room 15 Unit 1 @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1021-4	Room 15 Unit 2 @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1021-5	Room 15 Unit 2 @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1021-6	Room 15 Unit 2 @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1021-7	Room 15	WF	App	7	2/20/2020	-	-	-	None	-	-	-
1022-1	Room 18	WF	App	34.4	2/20/2020				Additional Sampling Required	Aerator flushed	8.53	11.6/2020
1022-2	Room 18 Unit @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1022-3	Room 18 Unit @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1022-4	Room 18 Unit @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1023-1	Room 16 Unit @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1023-2	Room 16 Unit @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1023-3	Room 16 Unit @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1024-1	Room 14 Canine Careers Unit @ A	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1024-2	Room 14 Canine Careers Unit @ B	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1024-3	Room 14 Canine Careers Unit @ C	SK	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1025-1	Room 13 sink	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1026-1	Hallway by Room 13	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1026-2	Hallway by Room 13	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1027-1	Women's Bathroom by Room 13 @ A	SK	App	5.26	2/20/2020	-	-	-	None	-	-	-
1027-2	Women's Bathroom by Room 13 @ B	SK	App	4.96	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1028-1	Men's Bathroom by Nurse's Office	SK	N/A	49.1	2/20/2020				None	SIGN		
1029-1	Nurse's Office @ A	SK	App	33.3	2/20/2020				Additional Sampling Required	Aerator flushed	9.32	10/9/2020
1029-2	Nurse's Office @ B	SK	App	16.8	10/9/2020				Additional Sampling Required			
1030-1	Faculty Room	WF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1030-2	Faculty Room	BF	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1030-3	Faculty Room	SK	App	5.33	2/20/2020	-	-	-	None	-	-	-
1030-4	Faculty Room	SKY	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1031-1	Room 11	SK	App	30.6	2/20/2020				Additional Sampling Required	Aerator flushed	8.98	10/9/2020
1031-2	Room 11	WF	N/A		2/20/2020	-	-	-	None	CAPPED	-	-
1032-1	Room 12 Retail Center	SK	App	9.76	2/20/2020	-	-	-	None	-	-	-
1032-2	Room 12 Retail Center-hot water dispenser	OS	N/A		2/20/2020	-	-	-	None		-	-
1032-3	Room 12 - Back Sink	SK	App	13.8	2/20/2020	-	-	-	None	-	-	-
1033-1	Room 9 Counter	SK	App	6.52	2/20/2020	-	-	-	None	-	-	-
1033-2	Room 9 Vanity @ A	SK	App	47.7	2/20/2020				Additional Sampling Required	Aerator flushed	6.53	10/9/2020
1033-3	Room 9 Vanity @ B	SK	App	17.8	2/20/2020				Additional Sampling Required	Aerator flushed	8.98	10/9/2020
1034-1	Kitchen Handwash	SK	App	12.7	2/20/2020	-	-	-	None	-	-	-
1034-2	Kitchen Opposite Stove	SK	App	11.5	2/20/2020	-	-	-	None	-	-	-
1034-3	Kitchen Dishwash @ A	SK	App	13.8	2/20/2020	-	-	-	None	-	-	-
1034-4	Kitchen Dishwash @ B	SK	App	23	2/20/2020				Additional Sampling Required		7.93	10/9/2020
1034-5	Kitchen Dishwash	SPY	App	<1.0	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1035-1	Room 10 Cosmetology	WF	N/A		2/20/2020	-	-	-	None	CAPPED	-	-
1035-2	Room 10 Cosmetology	SK	App	27	2/20/2020				Additional Sampling Required		13.9	10/9/2020
1035-3	Room 10 Hair wash Station @ A	SPY	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1035-4	Room 10 Hair wash Station @ B	SPY	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1035-5	Room 10 Hair wash Station @ C	SPY	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1035-6	Room 10 by Hair wash Station	WF	N/A	20.8	2/20/2020				None	CAPPED		
1036-1	Room 7	WF	N/A		2/20/2020	-	-	-	None	CAPPED	-	-
1036-2	Room 7- sink by water fountain	SK	App	15.7	10/9/2020				Additional Sampling Required			
1036-3	Room 7- 3 Compartment sink	SK	App	7.74	2/20/2020	-	-	-	None	-	-	-
1036-4	Room 7 - Counter 1	SK	App	22.2	2/20/2020				Additional Sampling Required	Aerator flushed	1/4/00	10/9/2020
1036-5	Room 7 - Counter 2 by dishwasher	SK	App	5.39	2/20/2020	-	-	-	None	-	-	-
1037-1	Room 8	WF	App	11.1	2/20/2020	-	-	-	None	-	-	-
1037-2	Room 8	SK	App	13.2	2/20/2020	-	-	-	None	-	-	-
1038-1	Room 5	WF	App	43.6	2/20/2020				None	CAPPED		
1038-2	Room 5	SK	App	32.6	2/20/2020				Additional Sampling Required	Aerator flushed	9.08	10/9/2020
1039-1	Room 6	WF	App	44.3	2/20/2020				None	CAPPED		
1039-2	Room 6 - by water fountain	SK	App	61.5	2/20/2020				Additional Sampling Required	Aerator flushed	12.4	10/9/2020
1039-3	Room 6 Counter @ A	SK	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1039-4	Room 6 Counter @ B	SK	App	1.41	2/20/2020	-	-	-	None	-	-	-
1039-5	Room 6 Dishwash @ A	SK	App	4.18	2/20/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1039-6	Room 6 Dishwash @ B	SPY	App	<1.0	2/20/2020	-	-	-	None	-	-	-
1039-7	Room 6 closet	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1040-1	Custodial Closet by Room 6	SS	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1041-1	Room 3	WF	N/A		2/20/2020	-	-	-	None	CAPPED	-	-
1041-2	Room 3	SK	App	9.07	2/20/2020	-	-	-	None	-	-	-
1042-1	Room 4	SK	App	25	2/20/2020				Additional Sampling Required	Aerator flushed	8.51	10/9/2020
1043-1	Room 2	SK	App	5.55	2/20/2020	-	-	-	None	-	-	-
1043-2	Room 2 Hair wash Station	SPY	N/A		2/20/2020	-	-	-	None	SIGN	-	-
1044-1	Room 1 Counter 1- left	SK	App	3.78	2/20/2020	-	-	-	None	-	-	-
1044-2	Room 1 Counter 2- right	SK	App	1.55	2/20/2020	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2200873-14037

February 26, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Islip Career Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 24, 2020. New York Environmental analyzed the samples on February 25, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	20 Feb 2020
Date Received:	24 Feb 2020
Date Analyzed:	25 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200224P158	1	Hallway by IOC Faculty Room - WF; Initial	1.00	<1.00	µg/L	
200224P159	2	Hallway by IOC Faculty Room - BF; Initial	1.00	<1.00	µg/L	
200224P160	3	Girl's Bathroom by Room 4 @ A - SK; Initial	1.00	3.61	µg/L	
200224P161	4	Girl's Bathroom by Room 4 @ B - SK; Initial	1.00	11.3	µg/L	
200224P162	5	Girl's Bathroom by Room 4 @ C - SK; Initial	1.00	13.5	µg/L	
200224P163	6	Boy's Bathroom by Room 4 - SK; Initial	1.00	2.20	µg/L	
200224P164	7	Men's Bathroom by Room 4 @ A - SK; Initial	1.00	4.04	µg/L	
200224P165	8	Men's Bathroom by Room 4 @ B - SK; Initial	1.00	3.82	µg/L	
200224P166	9	Women's Bathroom by Room 4 - SK; Initial	1.00	1.16	µg/L	
200224P167	10	Women's Bathroom ADA by Room 4 - SK; Initial	1.00	<1.00	µg/L	
200224P168	11	Room 2 - SK; Initial	1.00	5.43	µg/L	
200224P169	12	Room 1 - SK; Initial	1.00	1.32	µg/L	
200224P170	13	Room1 Bathroom - SK; Initial	1.00	<1.00	µg/L	
200224P171	14	ICC Cafeteria - WF; Initial	1.00	<1.00	µg/L	
200224P172	15	ICC Cafeteria - BF; Initial	1.00	<1.00	µg/L	
200224P173	16	ICC Cafeteria - SK; Initial	1.00	23.3	µg/L	H
200224P174	17	Computer Lab/Lunch Room - SK; Initial	1.00	1.42	µg/L	
200224P175	18	Room 23 Horticulture Unit @ A - SK; Initial	1.00	6.18	µg/L	
200224P176	19	Room 23 Horticulture Unit @ B - SK; Initial	1.00	4.57	µg/L	
200224P177	20	Room 20 Auto Mechanics - WF; Initial	1.00	7.73	µg/L	
200224P178	21	Room 19 Weight Room - SK; Initial	1.00	<1.00	µg/L	
200224P179	22	Room 15 - WF; Initial	1.00	7.00	µg/L	
200224P180	23	Room 18 - WF; Initial	1.00	34.4	µg/L	H
200224P181	24	Hallway by Room 13 - WF; Initial	1.00	<1.00	µg/L	
200224P182	25	Hallway by Room 13 - BF; Initial	1.00	<1.00	µg/L	
200224P183	26	Women's Bathroom by Room 13 @ A - SK; Initial	1.00	5.26	µg/L	



Date Collected:	20 Feb 2020
Date Received:	24 Feb 2020
Date Analyzed:	25 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200224P184	27	Women's Bathroom by Room 13 @ B - SK; Initial	1.00	4.96	µg/L	
200224P185	28	Men's Bathroom by Nurse's Office - SK; Initial	1.00	49.1	µg/L	H
200224P186	29	Nurse's Office @ A - SK; Initial	1.00	33.3	µg/L	H
200224P187	30	Nurse's Office @ B - SK; Initial	1.00	86.2	µg/L	E,H
200224P188	31	Faculty Room - WF; Initial	1.00	<1.00	µg/L	
200224P189	32	Faculty Room - BF; Initial	1.00	<1.00	µg/L	
200224P190	33	Faculty Room - SK; Initial	1.00	5.33	µg/L	
200224P191	34	Faculty Room - SKY; Initial	1.00	<1.00	µg/L	
200224P192	35	Room 11 - SK; Initial	1.00	30.6	µg/L	H
200224P193	36	Room 12 Retail Center - SK; Initial	1.00	9.76	µg/L	
200224P194	37	Room 12 - Back Sink - SK; Initial	1.00	13.8	µg/L	
200224P195	38	Room 9 Counter - SK; Initial	1.00	6.52	µg/L	
200224P196	39	Room 9 Vanity @ A - SK; Initial	1.00	47.7	µg/L	H
200224P197	40	Room 9 Vanity @ B - SK; Initial	1.00	17.8	µg/L	H
200224P198	41	Kitchen Handwash - SK; Initial	1.00	12.7	µg/L	
200224P199	42	Kitchen Opposite Stove - SK; Initial	1.00	11.5	µg/L	
200224P200	43	Kitchen Dishwash @ A - SK; Initial	1.00	13.8	µg/L	
200224P201	44	Kitchen Dishwash @ B - SK; Initial	1.00	23.0	µg/L	H
200224P202	45	Kitchen Dishwash - SPY; Initial	1.00	<1.00	µg/L	
200224P203	46	Room 10 Cosmetology - SK; Initial	1.00	27.0	µg/L	H
200224P204	47	Room 10 by Hair wash Station - WF; Initial	1.00	20.8	µg/L	H
200224P205	48	Room 7- sink by water fountain - SK; Initial	1.00	19.5	µg/L	H
200224P206	49	Room 7- 3 Compartment sink - SK; Initial	1.00	7.74	µg/L	
200224P207	50	Room 7 - Counter 1 - SK; Initial	1.00	22.2	µg/L	H
200224P208	51	Room 7 - Counter 2 by dishwasher - SK; Initial	1.00	5.39	µg/L	
200224P209	52	Room 8 - WF; Initial	1.00	11.1	µg/L	
200224P210	53	Room 8 - SK; Initial	1.00	13.2	µg/L	



Date Collected:	20 Feb 2020
Date Received:	24 Feb 2020
Date Analyzed:	25 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200224P211	54	Room 5 - WF; Initial	1.00	43.6	µg/L	H
200224P212	55	Room 5 - SK; Initial	1.00	32.6	µg/L	H
200224P213	56	Room 6 - WF; Initial	1.00	44.3	µg/L	H
200224P214	57	Room 6 - by water fountain - SK; Initial	1.00	61.5	µg/L	E,H
200224P215	58	Room 6 Counter @ A - SK; Initial	1.00	<1.00	µg/L	
200224P216	59	Room 6 Counter @ B - SK; Initial	1.00	1.41	µg/L	
200224P217	60	Room 6 Dishwash @ A - SK; Initial	1.00	4.18	µg/L	
200224P218	61	Room 6 Dishwash @ B - SPY; Initial	1.00	<1.00	µg/L	
200224P219	62	Room 3 - SK; Initial	1.00	9.07	µg/L	
200224P220	63	Room 4 - SK; Initial	1.00	25.0	µg/L	H
200224P221	64	Room 2 - SK; Initial	1.00	5.55	µg/L	
200224P222	65	Room 1 Counter 1- left - SK; Initial	1.00	3.78	µg/L	
200224P223	66	Room 1 Counter 2- right - SK; Initial	1.00	1.55	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2204094-15832

October 12, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Islip Career Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on October 09, 2020. New York Environmental analyzed the samples on October 10, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	09 Oct 2020
Date Received:	09 Oct 2020
Date Analyzed:	10 Oct 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
201009P003	1	Room 4-SK; Initial	1.00	8.51	µg/L	
201009P004	2	Room 6 by Water Fountain-SK; Initial	1.00	12.4	µg/L	
201009P005	3	Room 5-SK; Initial	1.00	9.08	µg/L	
201009P006	4	Room 7, Sink by Water Fountain-SK; Initial	1.00	15.7	µg/L	H
201009P007	5	Room 7, Counter 1-SK; Initial	1.00	4.41	µg/L	
201009P008	6	Room 10 Cosmetology-SK; Initial	1.00	13.9	µg/L	
201009P009	7	Room 9 Vanity @ A-SK; Initial	1.00	6.53	µg/L	
201009P010	8	Room 9 Vanity @ B-SK; Initial	1.00	1.77	µg/L	
201009P011	9	Room 11-SK; Initial	1.00	8.98	µg/L	
201009P012	10	Nurse's Office @ A-SK; Initial	1.00	9.32	µg/L	
201009P013	11	Nurse's Office @ B-SK; Initial	1.00	16.8	µg/L	H
201009P014	12	Kitchen Dishwash @ B-SK; Initial	1.00	7.93	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2204451-16122

November 9, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Islip Career Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on November 06, 2020. New York Environmental analyzed the samples on November 07, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	06 Nov 2020
Date Received:	06 Nov 2020
Date Analyzed:	07 Nov 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
201106M179	1	Room 18-SK; Initial	1.00	8.53	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix K

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
0001-1	Faculty Lounge B-01	SK	APP	1.13	2/13/2020	-	-	-	None	-	-	-
0001-2	Faculty Lounge B-01	SPY	N/A	<1.0	2/13/2020	-	-	-	None	SIGN	-	-
0001-3	Faculty Lounge B-01	IM	APP	<1.0	2/13/2020	-	-	-	None	-	-	-
0001-4	Faculty Lounge B-01 Coffee Maker	CF	APP	<1.0	2/13/2020	-	-	-	None	-	-	-
0002-1	File Room B-35	SS	N/A		2/13/2020	-	-	-	None	SIGN	-	-
0003-1	Mens Bathroom by B-02	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
0004-1	Womens Bathroom B-03 @ A	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
0004-2	Womens Bathroom B-03 @ B	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
0004-3	Womens Bathroom B-03 @ C	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
0005-1	Boiler Room B-31	SS	N/A		2/13/2020	-	-	-	None	SIGN	-	-
0006-1	Hall by Elevator	BF	APP	<1.0	2/13/2020	-	-	-	None	-	-	-
0006-2	Hall by Elevator	WF	APP	<1.0	2/13/2020	-	-	-	None	-	-	-
1001-1	Julie's Kitchenette	SK	APP	<1.0	2/13/2020	-	-	-	None	-	-	-
1001-2	Julie's Kitchenette	SP	N/A		2/13/2020	-	-	-	None	Removed from Service	-	-
1002-1	Julie's Bathroom	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1003-1	Womens Bathroom 79 @ A	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1003-2	Womens Bathroom 79 @ B	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1003-3	Womens Bathroom 79 @ C	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1004-1	Hall by Room 56	BF	APP	<1.0	2/13/2020	-	-	-	None	-	-	-
1004-2	Hall by Room 56	WF	APP	<1.0	2/13/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1005-1	Mens Bathroom 78 @ A	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1005-1	Mens Bathroom 78 @ B	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1006-1	Boiler Room 61	SS	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1007-1	Room 73	SK	APP	8.54	2/13/2020	-	-	-	None	-	-	-
1007-2	Room 73	SPY	APP	9.13	2/13/2020	-	-	-	None	-	-	-
1007-3	Room 73 Coffee Maker	CF	APP	<1.0	2/13/2020	-	-	-	None	-	-	-
1007-4	Room 73	IM	APP	<1.0	2/13/2020	-	-	-	None	-	-	-
1008-1	Unisex Bathroom 65	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1009-1	Hall by Room 66	WF	APP	<1.0	2/13/2020	-	-	-	None	-	-	-
1010-1	Unisex Bathroom 64	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1011-1	Ryan's Bathroom	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1012-1	Womens Bathroom in Room 32 @ A	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1012-1	Womens Bathroom in Room 32 @ B	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1013-1	Mens Bathroom in Room 32 @ A	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1013-1	Mens Bathroom in Room 32 @ B	SK	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1014-1	Receiving Room	SS	N/A		2/13/2020	-	-	-	None	SIGN	-	-
1014-1	Receiving Room Coffee Maker	CF	APP	<1.0	2/13/2020	-	-	-	None	-	-	-
1015-1	Hall by Receiving Room	BF	APP	<1.0	2/13/2020	-	-	-	None	-	-	-
1015-2	Hall by Receiving Room	WF	APP	<1.0	2/13/2020	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2200870-14034

February 26, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: James Hines Admin Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 24, 2020. New York Environmental analyzed the samples on February 25, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	20 Feb 2020
Date Received:	24 Feb 2020
Date Analyzed:	25 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200224P001	1	Faculty Lounge B-01 - SK; Initial	1.00	1.13	µg/L	
200224P002	2	Faculty Lounge B-01 - IM; Initial	1.00	<1.00	µg/L	
200224P003	3	Faculty Lounge B-01 Coffee Maker - CF; Initial	1.00	<1.00	µg/L	
200224P004	4	Hall by Elevator - BF; Initial	1.00	<1.00	µg/L	
200224P005	5	Hall by Elevator - WF; Initial	1.00	<1.00	µg/L	
200224P006	6	Julie's Kitchenette - SK; Initial	1.00	<1.00	µg/L	
200224P007	7	Hall by Room 56 - BF; Initial	1.00	<1.00	µg/L	
200224P008	8	Hall by Room 56 - WF; Initial	1.00	<1.00	µg/L	
200224P009	9	Room 73 - SK; Initial	1.00	8.54	µg/L	
200224P010	10	Room 73 - SPY; Initial	1.00	9.13	µg/L	
200224P011	11	Room 73 Coffee Maker - CF; Initial	1.00	<1.00	µg/L	
200224P012	12	Room 73 - IM; Initial	1.00	<1.00	µg/L	
200224P013	13	Hall by Room 66 - WF; Initial	1.00	<1.00	µg/L	
200224P014	14	Receiving Room Coffee Maker - CF; Initial	1.00	<1.00	µg/L	
200224P015	15	Hall by Receiving Room - BF; Initial	1.00	<1.00	µg/L	
200224P016	16	Hall by Receiving Room - WF; Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix L

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
0001-1	100 Wing Men's Bathroom @ A	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
0001-2	100 Wing Men's Bathroom @ B	SK	App	1.23	2/29/2020	-	-	-	None	-	-	-
0001-3	100 Wing Men's Bathroom @ C	SK	App	2.52	2/29/2020	-	-	-	None	-	-	-
0001-4	100 Wing Men's Bathroom @ D	SK	App	1.36	2/29/2020	-	-	-	None	-	-	-
0002-1	Custodial Office	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
0003-1	Room 106	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
0004-1	Hallway by Room 108	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
0005-1	100 Wing Women's Bathroom @ A	SK	App	1.94	2/29/2020	-	-	-	None	-	-	-
0005-2	100 Wing Women's Bathroom @ B	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
0005-3	100 Wing Women's Bathroom @ C	SK	App	4.64	2/29/2020	-	-	-	None	-	-	-
0005-4	100 Wing Women's Bathroom @ D	SK	App	11.2	2/29/2020	-	-	-	None	-	-	-
0006-1	Girl's Locker Room Bathroom @ A	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
0006-2	Girl's Locker Room Bathroom @ B	SK	App	3.49	2/29/2020	-	-	-	None	-	-	-
0006-3	Girl's Locker Room Bathroom @ C	SK	App		2/29/2020	-	-	-	None	Removed from Service	-	-
0006-4	Girl's Locker Room Bathroom @ D	SK	App	5.99	2/29/2020	-	-	-	None	-	-	-
0007-1	100 Wing Custodial Closet	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
0008-1	Hallway by 100 Wing Custodial Closet	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
0008-2	Hallway by 100 Wing Custodial Closet	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
0009-1	Gym Custodial Closet	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
0010-1	Boy's Locker Room Bathroom @ A	SK	App		2/29/2020	-	-	-	None	Removed from Service	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
0010-2	Boy's Locker Room Bathroom @ B	SK	App	9.19	2/29/2020	-	-	-	None	-	-	-
0010-3	Boy's Locker Room Bathroom @ C	SK	App	10.2	2/29/2020	-	-	-	None	-	-	-
1001-1	Room 112 @ A	SK	App	1.25	2/29/2020	-	-	-	None	-	-	-
1001-2	Room 112 @ A	SPY	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1001-3	Room 112 @ B	SK	App	1.66	2/29/2020	-	-	-	None	-	-	-
1001-4	Room 112 @ B	SPY	App	1.49	2/29/2020	-	-	-	None	-	-	-
1002-1	Faculty Room	SK	App	3.31	2/29/2020	-	-	-	None	-	-	-
1003-1	200 Wing Women's Faculty Bathroom	SK	App	3	2/29/2020	-	-	-	None	-	-	-
1004-1	200 Wing Men's Faculty Bathroom	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1005-1	Hallway by Room 227	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1005-2	Hallway by Room 227	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1006-1	Room 226	SK	App	4.86	2/29/2020	-	-	-	None	-	-	-
1007-1	Fan Room	SS	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1008-1	Hallway by Room 233	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1008-2	Hallway by Room 233	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
1009-1	Room 233 Bathroom-Principal	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
1010-1	Room 232 Nurse's Office	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
2001-1	Custodial Closet by Room 341	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
2002-1	300 Wing Men's Bathroom @ A	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
2002-2	300 Wing Men's Bathroom @ B	SK	App	1.2	2/29/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
2003-1	Room 343	SK	App	8.2	2/29/2020	-	-	-	None	-	-	-
2004-1	Room 345	SK	App	2.58	2/29/2020	-	-	-	None	-	-	-
2005-1	Hallway by Room 350	WF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
2005-2	Hallway by Room 350	BF	App	<1.0	2/29/2020	-	-	-	None	-	-	-
2006-1	300 Wing Women's Bathroom @ A	SK	App	1.92	2/29/2020	-	-	-	None	-	-	-
2006-2	300 Wing Women's Bathroom @ B	SK	App	2.41	2/29/2020	-	-	-	None	-	-	-
2006-3	300 Wing Women's Bathroom @ C	SK	App	1.11	2/29/2020	-	-	-	None	-	-	-
0011-1	Kitchen Handwash @ A	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-
0011-2	Kitchen 3 Bay Sink	SK	App	<1.0	2/29/2020	-	-	-	None	-	-	-
0011-3	Kitchen 3 Bay Sink	SPY	App	13.4	2/29/2020	-	-	-	None	-	-	-
0011-4	Kitchen Handwash @ B	SK	N/A		2/29/2020	-	-	-	None	SIGN	-	-

Laboratory Report

NYE Report #: 2201049-14116

March 4, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Jefferson Academic Center 19373

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on March 02, 2020. New York Environmental analyzed the samples on March 03, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	02 Mar 2020
Date Received:	02 Mar 2020
Date Analyzed:	03 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200302Q002	1	Basement Boy's Bathroom @A-SK; Initial	1.00	<1.00	µg/L	
200302Q003	2	Basement Boy's Bathroom @B-SK; Initial	1.00	1.23	µg/L	
200302Q004	3	Basement Boy's Bathroom @C-SK; Initial	1.00	2.52	µg/L	
200302Q005	4	Basement Boy's Bathroom @D-SK; Initial	1.00	1.36	µg/L	
200302Q006	5	Hallway by Room 108-WF; Initial	1.00	<1.00	µg/L	
200302Q007	6	Girl's Bathroom by Room 107 @ A-SK; Initial	1.00	1.94	µg/L	
200302Q008	7	Girl's Bathroom by Room 107 @ B-SK; Initial	1.00	<1.00	µg/L	
200302Q009	8	Girl's Bathroom by Room 107 @ C-SK; Initial	1.00	4.64	µg/L	
200302Q010	9	Girl's Bathroom by Room 107 @ D -SK; Initial	1.00	11.2	µg/L	
200302Q011	10	100 Wing Women's Bathroom @ A-SK; Initial	1.00	<1.00	µg/L	
200302Q012	11	100 Wing Women's Bathroom @ B-SK; Initial	1.00	3.49	µg/L	
200302Q013	12	100 Wing Women's Bathroom @ D-SK; Initial	1.00	5.99	µg/L	
200302Q014	13	Hallway by 100 Wing Custodial Closet-WF; Initial	1.00	<1.00	µg/L	
200302Q015	14	Hallway by 100 Wing Custodial Closet-BF; Initial	1.00	<1.00	µg/L	
200302Q016	15	Men's Locker Room Bathroom @ B-SK; Initial	1.00	9.19	µg/L	
200302Q017	16	Men's Locker Room Bathroom @ C-SK; Initial	1.00	10.2	µg/L	
200302Q018	17	Room 13 @ A-SK; Initial	1.00	1.25	µg/L	
200302Q019	18	Room 13 @ A-SPY; Initial	1.00	<1.00	µg/L	
200302Q020	19	Room 13 @ B-SK; Initial	1.00	1.66	µg/L	
200302Q021	20	Room 13 @ B-SPY; Initial	1.00	1.49	µg/L	
200302Q022	21	Faculty Room-SK; Initial	1.00	3.31	µg/L	
200302Q023	22	Women's Bathroom by Faculty Room-SK; Initial	1.00	3.00	µg/L	
200302Q024	23	Men's Bathoroomb by Faculty Room-SK; Initial	1.00	<1.00	µg/L	
200302Q025	24	Hallway by Room 227-WF; Initial	1.00	<1.00	µg/L	
200302Q026	25	Hallway by Room 227-BF; Initial	1.00	<1.00	µg/L	
200302Q027	26	Room 226-SK; Initial	1.00	4.86	µg/L	



Date Collected:	02 Mar 2020
Date Received:	02 Mar 2020
Date Analyzed:	03 Mar 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
200302Q028	27	Hallway by Room 233-WF; Initial	1.00	<1.00	µg/L	
200302Q029	28	Hallway by Room 233-BF; Initial	1.00	<1.00	µg/L	
200302Q030	29	Room 232 Nurse's Office-SK; Initial	1.00	<1.00	µg/L	
200302Q031	30	Boy's Bathroom by Room 342 @ A-SK; Initial	1.00	<1.00	µg/L	
200302Q032	31	Boy's Bathroom by Room 342 @ B-SK; Initial	1.00	1.20	µg/L	
200302Q033	32	Room 343-SK; Initial	1.00	8.20	µg/L	
200302Q034	33	Room 345-SK; Initial	1.00	2.58	µg/L	
200302Q035	34	Hallway by Room 350-WF; Initial	1.00	<1.00	µg/L	
200302Q036	35	Hallway by Room 350-BF; Initial	1.00	<1.00	µg/L	
200302Q037	36	Women's Bathroom by Room 350 @A-SK; Initial	1.00	1.92	µg/L	
200302Q038	37	Women's Bathroom by Room 350 @B-SK; Initial	1.00	2.41	µg/L	
200302Q039	38	Women's Bathroom by Room 350 @C-SK; Initial	1.00	1.11	µg/L	
200302Q040	39	Kitchen 3 Bay Sink-SK; Initial	1.00	<1.00	µg/L	
200302Q041	40	Kitchen 3 Bay Sink-SPY; Initial	1.00	13.4	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix M

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
0001-1	Boiler Room Bathroom	SK	N/A		2/19/2020	-	-	-	None	SIGN	-	-
0002-1	Hallway by Boiler Room	WF	App	35.1	2/19/2020				None	Removed from Service		
0003-1	Mens Bathroom by Room 614 @ A	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
0003-2	Mens Bathroom by Room 614 @ B	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
0003-3	Mens Bathroom by Room 614	SS	N/A		2/19/2020	-	-	-	None	SIGN	-	-
0004-1	Cafeteria	WF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
0004-2	Cafeteria	BF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
0005-1	Girls Bathroom by Cafeteria	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
0006-1	Womens Faculty Bathroom by Cafeteria @ A	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
0006-2	Womens Faculty Bathroom by Cafeteria @ B	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
0006-3	Womens Faculty Bathroom by Cafeteria @ C	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
0006-4	Womens Faculty Bathroom by Cafeteria	SP	N/A		2/19/2020	-	-	-	None	Locked Door	-	-
0007-1	Kitchen Island	SK	App	4.25	2/19/2020	-	-	-	None	-	-	-
0007-2	Kitchen Dishwash 3 Bay	SPY	App	1.13	2/19/2020	-	-	-	None	-	-	-
0007-3	Kitchen Dishwash 3 Bay	SK	App	2.61	2/19/2020	-	-	-	None	-	-	-
0008-1	Faculty Room	SK	App	2.01	2/19/2020	-	-	-	None	-	-	-
1001-1	Room 117 Bathroom	SK	App	6.96	2/19/2020	-	-	-	None	-	-	-
1002-1	Girls Bathroom by Room 112 @ A	SK	N/A		2/19/2020	-	-	-	None	SIGN	-	-
1002-2	Girls Bathroom by Room 112 @ B	SK	N/A		2/19/2020	-	-	-	None	SIGN	-	-
1002-3	Girls Bathroom by Room 112 @ C	SK	N/A		2/19/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1002-4	Girls Bathroom by Room 112 @ D	SK	N/A		2/19/2020	-	-	-	None	SIGN	-	-
1003-1	Hallway by Room 112	WF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1003-2	Hallway by Room 112	BF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1004-1	Nurses's Office	SK	App	8.21	2/19/2020	-	-	-	None	-	-	-
1004-2	Nurses's Office Bathroom	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1005-1	Custodial Closet by Nurses Office	SS	N/A		2/19/2020	-	-	-	None	SIGN	-	-
1006-1	Boys Bathroom by Nurses Office @ A	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1006-2	Boys Bathroom by Nurses Office @ B	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1006-3	Boys Bathroom by Nurses Office @ C	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1006-4	Boys Bathroom by Nurses Office @ D	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1006-5	Boys Bathroom by Nurses Office	SP	N/A		2/19/2020	-	-	-	None	Locked Door	-	-
1007-1	Hallway by Room 103	WF	App	7.62	2/19/2020	-	-	-	None	-	-	-
1008-1	Room 103 Bathroom @ A	SK	App	195	2/19/2020				Additional Sampling Required	Aerator Flushed	10.1	11/6/2020
1008-2	Room 103 Bathroom @ B	SK	App	55.7	2/19/2020				Additional Sampling Required	Aerator Flushed	4.71	11/6/2020
1009-1	Room 101 Bathroom @ A	SK	App	51.2	2/19/2020				Additional Sampling Required	Aerator Flushed	7.87	11/6/2020
1009-2	Room 101 Bathroom @ B	SK	App	25.4	2/19/2020				Additional Sampling Required	Aerator Flushed	9.9	11/6/2020
1010-1	Room 100	WF	App	38.6	2/19/2020				None	Removed from Service		11/6/2020
1010-2	Room 100 Bathroom @ A	SK	App	334	2/19/2020				Additional Sampling Required	Aerator Flushed	7.01	11/6/2020
1010-3	Room 100 Bathroom @ B	SK	App	248	2/19/2020				Additional Sampling Required	Aerator Flushed	12.8	11/6/2020
2001-1	Room 200 Art Closet	SK	N/A		2/19/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
2002-1	Hallway by Room 207	WF	App		2/19/2020	-	-	-	None	Removed from Service	-	-
2003-1	Custodial Closet by Room 207	SS	N/A		2/19/2020	-	-	-	None	SIGN	-	-
2004-1	Boys Bathroom by Room 207 @ A	SK	App	12.7	2/19/2020	-	-	-	None	-	-	-
2004-2	Boys Bathroom by Room 207 @ B	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2004-3	Boys Bathroom by Room 207 @ C	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2004-4	Boys Bathroom by Room 207 @ D	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2004-5	Boys Bathroom by Room 207	SP	N/A		2/19/2020	-	-	-	None	Locked Door	-	-
2005-1	Faculty Bathroom	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2006-1	Hallway by Room 208	WF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
2006-2	Hallway by Room 208	BF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
2007-1	Girls Bathroom by Room 210 @ A	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2007-2	Girls Bathroom by Room 210 @ B	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2007-3	Girls Bathroom by Room 210 @ C	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2007-4	Girls Bathroom by Room 210 @ D	SK	N/A		2/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2007-5	Girls Bathroom by Room 210	SP	N/A		2/19/2020	-	-	-	None	Locked Door	-	-
2008-1	Gym Upstairs Bathroom	SK	N/A		2/19/2020	-	-	-	None	SIGN	-	-

Laboratory Report

NYE Report #: 2200803-14006

February 21, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Sayville Elementary, Sayville, NY

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 20, 2020. New York Environmental analyzed the samples on February 21, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	19 Feb 2020
Date Received:	20 Feb 2020
Date Analyzed:	21 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200220L001	1	Hallway by Boiler Room - WF; Initial	1.00	35.1	µg/L	H
200220L002	2	Cafeteria - WF; Initial	1.00	<1.00	µg/L	
200220L003	3	Cafeteria - BF; Initial	1.00	<1.00	µg/L	
200220L004	4	Kitchen Island - SK; Initial	1.00	4.25	µg/L	
200220L005	5	Kitchen Dishwash 3 Bay - SPY; Initial	1.00	1.13	µg/L	
200220L006	6	Kitchen Dishwash 3 Bay - SK; Initial	1.00	2.61	µg/L	
200220L007	7	Faculty Room - SK; Initial	1.00	2.01	µg/L	
200220L008	8	Room 117 Bathroom - SK; Initial	1.00	6.96	µg/L	
200220L009	9	Hallway by Room 112 - WF; Initial	1.00	<1.00	µg/L	
200220L010	10	Hallway by Room 112 - BF; Initial	1.00	<1.00	µg/L	
200220L011	11	Nurses's Office - SK; Initial	1.00	8.21	µg/L	
200220L012	12	Hallway by Room 103 - WF; Initial	1.00	7.62	µg/L	
200220L013	13	Room 103 Bathroom @ A - SK; Initial	1.00	195	µg/L	E,H
200220L014	14	Room 103 Bathroom @ B - SK; Initial	1.00	55.7	µg/L	E,H
200220L015	15	Room 101 Bathroom @ A - SK; Initial	1.00	51.2	µg/L	E,H
200220L016	16	Room 101 Bathroom @ B - SK; Initial	1.00	25.4	µg/L	H
200220L017	17	Room 100 - WF; Initial	1.00	38.6	µg/L	H
200220L018	18	Room 100 Bathroom @ A - SK; Initial	1.00	334	µg/L	E,H
200220L019	19	Room 100 Bathroom @ B - SK; Initial	1.00	248	µg/L	E,H
200220L020	20	Boys Bathroom by Room 207 @ A - SK; Initial	1.00	12.7	µg/L	
200220L021	21	Hallway by Room 208 - WF; Initial	1.00	<1.00	µg/L	
200220L022	22	Hallway by Room 208 - BF; Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.



Laboratory Report

NYE Report #: 2204449-16120

November 9, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Sayville Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on November 06, 2020. New York Environmental analyzed the samples on November 07, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

Li Tsang, Laboratory Director

Date Collected:	06 Nov 2020
Date Received:	06 Nov 2020
Date Analyzed:	07 Nov 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
201106M172	1	Room 100 Bathroom @ A	1.00	7.01	µg/L	
201106M173	2	Room 100 Bathroom @ B	1.00	12.8	µg/L	
201106M174	3	Room 101 Bathroom @ A	1.00	7.87	µg/L	
201106M175	4	Room 101 Bathroom @ B	1.00	9.90	µg/L	
201106M176	5	Room 103 Bathroom @ A	1.00	10.1	µg/L	
201106M177	6	Room 103 Bathroom @ B	1.00	4.71	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix N

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Building 2 Men's Bathroom 58	SK	App	9.54	2/19/2020	-	-	-	None	-	-	-
1002-1	Building 2 Hallway by Men's Bathroom 58	WF	N/A		2/19/2020	-	-	-	None	CAPPED	-	-
1003-1	Building 2 Women's Bathroom 57	SK	App	6.19	2/19/2020	-	-	-	None	-	-	-
1004-1	Building 2 Copy Room 11	SK	App	55.7	10/9/2020				Additional Sampling Required	Permanent Sign Posted		
1005-1	Building 2 Bathroom 15	SK	App	12	2/19/2020	-	-	-	None	-	-	-
1006-1	Building 2 Textbook Office Bathroom	SK	App	18	2/19/2020				None	SIGN		
1007-1	Building 2 Custodial Closet 21	SS	N/A		2/19/2020	-	-	-	None	SIGN	-	-
1008-1	Building 2 Hallway by Custodial Closet 21	WF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1008-2	Building 2 Hallway by Custodial Closet 21	BF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1009-1	Building 2 Women's Bathroom 23 @ A	SK	App	10.1	2/19/2020	-	-	-	None	-	-	-
1009-2	Building 2 Women's Bathroom 23 @ B	SK	App	11.2	2/19/2020	-	-	-	None	-	-	-
1010-1	Building 2 Conference Room 27	SK	App	42.5	10/9/2020				Additional Sampling Required	Aerator Flushed	8.61	11/6/2020
1011-1	Building 2 Faculty Kitchen	SK	App	2.03	2/19/2020	-	-	-	None	-	-	-
1012-1	Building 2 Room 24 Bathroom	SK	App	76.4	2/19/2020				None	SIGN		
1013-1	Building 3 Boy's Bathroom by Gym	SK	App	2.75	2/19/2020	-	-	-	None	-	-	-
1014-1	Building 3 Hallway by Gym/Front Office	WF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1014-2	Building 3 Hallway by Gym/Front Office	BF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1015-1	Building 3 Women's Bathroom by Front Office	SK	App	8.63	2/19/2020	-	-	-	None	-	-	-
1016-1	Building 3 Men's Bathroom by Front Office	SK	App	14.2	2/19/2020	-	-	-	None	-	-	-
1017-1	Building 3 Small Kitchen @ A	SK	App	2.85	2/19/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1017-2	Building 3 Small Kitchen @ B	SK	App	11	2/19/2020	-	-	-	None	-	-	-
1017-3	Building 3 Small Kitchen @ C	SK	App	2.68	2/19/2020	-	-	-	None	-	-	-
1018-1	Building 3 Women's Bathroom by Room 307 @ A	SK	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1018-2	Building 3 Women's Bathroom by Room 307 @ B	SK	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1019-1	Building 3 Custodial Closet by Room 307	SS	N/A		2/19/2020	-	-	-	None	SIGN	-	-
1020-1	Building 3 Men's Bathroom by Room 307 @ A	SK	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1020-2	Building 3 Men's Bathroom by Room 307 @ B	SK	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1021-1	Building 3 Women's Staff Bathroom by Room 305	SK	App	4.15	2/19/2020	-	-	-	None	-	-	-
1022-1	Building 3 Common Area	SK	App	5.47	2/19/2020	-	-	-	None	-	-	-
1023-1	Building 3 Room 306D	SK	App	24.2	10/9/2020				Additional Sampling Required	Permanent Sign Posted		
1024-1	Building 3 Room 305	SK	App	7.28	2/19/2020	-	-	-	None	-	-	-
1025-1	Building 3 Room 304	SK	App	5.79	2/19/2020	-	-	-	None	-	-	-
1026-1	Building 3 Room 303	SK	App	3.51	2/19/2020	-	-	-	None	-	-	-
1027-1	Building 3 Common Area Kitchen @ A	SK	App	22.7	2/19/2020				Additional Sampling Required	Aerator Flushed	2.63	10/9/2020
1027-2	Building 3 Common Area Kitchen @ B	SK	App	21	2/19/2020				Additional Sampling Required	Aerator Flushed	6.78	10/9/2020
1027-3	Building 3 Common Area Kitchen @ C	SK	App	97.3	2/19/2020				Additional Sampling Required	Aerator Flushed	3.61	10/9/2020
1027-4	Building 3 Common Area Kitchen @ D	SK	App	50.1	2/19/2020				Additional Sampling Required	Aerator Flushed	3.67	10/9/2020
1028-1	Building 3 Room 302	SK	App	4.99	2/19/2020	-	-	-	None	-	-	-
1029-1	Building 3 Room 301	SK	App	2.43	2/19/2020	-	-	-	None	-	-	-
1030-1	Building 3 Custodial Closet by Nurse's Office	SS	N/A		2/19/2020	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1031-1	Building 3 Women's Bathroom by Room 218	SK	App	1.08	2/19/2020	-	-	-	None	-	-	-
1032-1	Building 3 Men's Bathroom by Room 218	SK	App	4.59	2/19/2020	-	-	-	None	-	-	-
1033-1	Building 3 Main Kitchen Handwash	SK	App	10.5	2/19/2020	-	-	-	None	-	-	-
1033-2	Building 3 Main Kitchen Dishwash	SPY	App	1.86	2/19/2020	-	-	-	None	-	-	-
1033-3	Building 3 Main Kitchen Dishwash	SK	App	7.28	2/19/2020	-	-	-	None	-	-	-
1034-1	Building 3 Custodial Closet by Main Kitchen	SS	N/A		2/19/2020	-	-	-	None	SIGN	-	-
1035-1	Building 3 Room 217	SK	App	1.67	2/19/2020	-	-	-	None	-	-	-
1036-1	Building 3 Room 209	SK	App	1.85	2/19/2020	-	-	-	None	-	-	-
1036-2	Building 3 Room 209 Changing Area	SK	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1037-1	Building 3 Room 208	SK	N/A		2/19/2020	-	-	-		SIGN	-	-
1038-1	Building 3 Room 207	SK	App	9.59	2/19/2020	-	-	-	None	-	-	-
1039-1	Building 3 Room 206	SK	App	2.91	2/19/2020	-	-	-	None	-	-	-
1040-1	Building 3 Room 205	SK	App	2.91	2/19/2020	-	-	-	None	-	-	-
1041-1	Building 3 Room 204	SK	App	10.5	2/19/2020	-	-	-	None	-	-	-
1042-1	Building 3 Room 202	SK	App	2.05	2/19/2020	-	-	-	None	-	-	-
1043-1	Building 3 Room 201	SK	App	4.94	2/19/2020	-	-	-	None	-	-	-
1044-1	Building 3 200 Wing Kitchen	SK	App	86.2	2/19/2020				Additional Sampling Required	Aerator Flushed	6.22	10/9/2020
1045-1	Building 3 200 Wing Girl's Bathroom	SK	App	3.52	2/19/2020	-	-	-	None	-	-	-
1046-1	Building 3 200 Wing Boy's Bathroom	SK	App	3.53	2/19/2020	-	-	-	None	-	-	-
1047-1	Building 3 Hallway by 200 Wing Boy's Bathroom	WF	App	<1.0	2/19/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1047-2	Building 3 Hallway by 200 Wing Boy's Bathroom	BF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1048-1	Building 3 B Faculty Room	SK	App	4.21	2/19/2020	-	-	-	None	-	-	-
1049-1	Building 3 Nurse's Office	SK	App	1.9	2/19/2020	-	-	-	None	-	-	-
1050-1	Building 4 Cafeteria	SK	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1051-1	Building 4 Women's Faculty Bathroom by Room 21	SK	App	3.9	2/19/2020	-	-	-	None	-	-	-
1052-1	Building 4 Men's Faculty Bathroom by Room 21	SK	App	11.5	2/19/2020	-	-	-	None	-	-	-
1053-1	Building 4 Faculty Lounge	SK	App	3.21	2/19/2020	-	-	-	None	-	-	-
1054-1	Building 4 Custodial Closet by Room 8	SS	N/A		2/19/2020	-	-	-	None	SIGN	-	-
1055-1	Building 4 Women's Bathroom by Room 8 @ A	SK	App	1.07	2/19/2020	-	-	-	None	-	-	-
1055-2	Building 4 Women's Bathroom by Room 8 @ B	SK	App	1.09	2/19/2020	-	-	-	None	-	-	-
1055-3	Building 4 Women's Bathroom by Room 8 @ C	S	App	3	2/19/2020	-	-	-	None	-	-	-
1056-1	Building 4 Hallway by Room 8	WF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1056-2	Building 4 Hallway by Room 8	BF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1057-1	Building 4 Men's Bathroom by Room 8 @ A	SK	App	1.33	2/19/2020	-	-	-	None	-	-	-
1057-2	Building 4 Men's Bathroom by Room 8 @ B	SK	N/A		2/19/2020	-	-	-	None	CAPPED	-	-
1057-3	Building 4 Men's Bathroom by Room 8 @ C	SK	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1058-1	Building 1 Hallway by Room 19	WF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1058-2	Building 1 Hallway by Room 19	BF	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1059-1	Building 1 Girl's Bathroom 18	SK	App	1.19	2/19/2020	-	-	-	None	-	-	-
1060-1	Building 1 Staff Bathroom	SK	App	<1.0	2/19/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1061-1	Building 1 Boy's Bathroom 17	SK	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1062-1	Building 1 Room 10	SK	App	6.85	2/19/2020	-	-	-	None	-	-	-
1063-1	Building 1 Custodial Closet by Room 10	SK	N/A		2/19/2020	-	-	-	None	SIGN	-	-
1064-1	Building 1 Kitchen	SK	App	1.26	2/19/2020	-	-	-	None	-	-	-
1064-2	Building 1 Kitchen	SPY	App	<1.0	2/19/2020	-	-	-	None	-	-	-
1065-1	Building 1 Room 11	SK	App	3.99	2/19/2020	-	-	-	None	-	-	-
1066-1	Building 1 Room 12	SK	App	4.7	2/19/2020	-	-	-	None	-	-	-
1067-1	Building 1 Room 1 Bathroom	SK	App	2.37	2/19/2020	-	-	-	None	-	-	-
1068-1	Building 1 Room 2 Bathroom	SK	App	1.64	2/19/2020	-	-	-	None	-	-	-
1069-1	Building 1 Faculty Room	SK	App	7.38	2/19/2020	-	-	-	None	-	-	-
1069-2	Building 1 Faculty Room Bathroom	SK	App	1.42	2/19/2020	-	-	-	None	-	-	-
1070-1	Building 1 Nurse's Office	SK	App	9.22	2/19/2020	-	-	-	None	-	-	-
1070-2	Building 1 Nurse's Office Bathroom	SK	App	<1.0	2/19/2020	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2200807-14010

February 24, 2020

Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Westhampton Beach Learning Center, Westhampton, NY

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 20, 2020. New York Environmental analyzed the samples on February 21, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

Li Tsang, Laboratory Director

Date Collected:	19 Feb 2020
Date Received:	20 Feb 2020
Date Analyzed:	21 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200220L030	1	Building 2 Men's Bathroom 58 - SK; Initial	1.00	9.54	µg/L	
200220L031	2	Building 2 Women's Bathroom 57 - SK; Initial	1.00	6.19	µg/L	
200220L032	3	Building 2 Copy Room 11 - SK; Initial	1.00	54.4	µg/L	E,H
200220L033	4	Building 2 Bathroom 15 - SK; Initial	1.00	12.0	µg/L	
200220L034	5	Building 2 Textbook Office Bathroom - SK; Initial	1.00	18.0	µg/L	H
200220L035	7	Building 2 Hallway by Custodial Closet 21 - WF; Initial	1.00	<1.00	µg/L	
200220L036	8	Building 2 Hallway by Custodial Closet 21 - BF; Initial	1.00	<1.00	µg/L	
200220L037	9	Building 2 Women's Bathroom 23 @ A - SK; Initial	1.00	10.1	µg/L	
200220L038	10	Building 2 Women's Bathroom 23 @ B - SK; Initial	1.00	11.2	µg/L	
200220L039	11	Building 2 Conference Room 27 - SK; Initial	1.00	66.5	µg/L	E,H
200220L040	12	Building 2 Faculty Kitchen - SK; Initial	1.00	2.03	µg/L	
200220L041	13	Building 2 Room 24 Bathroom - SK; Initial	1.00	76.4	µg/L	E,H
200220L042	14	Building 3 Boy's Bathroom by Gym - SK; Initial	1.00	2.75	µg/L	
200220L043	15	Building 3 Hallway by Gym/Front Office - WF; Initial	1.00	<1.00	µg/L	
200220L044	16	Building 3 Hallway by Gym/Front Office - BF; Initial	1.00	<1.00	µg/L	
200220L045	17	Building 3 Women's Bathroom by Front Office - SK; Initial	1.00	8.63	µg/L	
200220L046	18	Building 3 Men's Bathroom by Front Office - SK; Initial	1.00	14.2	µg/L	
200220L047	19	Building 3 Small Kitchen @ A - SK; Initial	1.00	2.85	µg/L	
200220L048	20	Building 3 Small Kitchen @ B - SK; Initial	1.00	11.0	µg/L	
200220L049	21	Building 3 Small Kitchen @ C - SK; Initial	1.00	2.68	µg/L	
200220L050	22	Building 3 Women's Bathroom by Room 307 @ A - SK; Initial	1.00	<1.00	µg/L	
200220L051	23	Building 3 Women's Bathroom by Room 307 @ B - SK; Initial	1.00	<1.00	µg/L	
200220L052	25	Building 3 Men's Bathroom by Room 307 @ A - SK; Initial	1.00	<1.00	µg/L	
200220L053	26	Building 3 Men's Bathroom by Room 307 @ B - SK; Initial	1.00	<1.00	µg/L	
200220L054	27	Building 3 Women's Staff Bathroom by Room 305 - SK; Initial	1.00	4.15	µg/L	
200220L055	28	Building 3 Common Area - SK; Initial	1.00	5.47	µg/L	



Date Collected:	19 Feb 2020
Date Received:	20 Feb 2020
Date Analyzed:	21 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200220L056	29	Building 3 Room 306D - SK; Initial	1.00	143	µg/L	E,H
200220L057	30	Building 3 Room 305 - SK; Initial	1.00	7.28	µg/L	
200220L058	31	Building 3 Room 304 - SK; Initial	1.00	5.79	µg/L	
200220L059	32	Building 3 Room 303 - SK; Initial	1.00	3.51	µg/L	
200220L060	33	Building 3 Common Area Kitchen @ A - SK; Initial	1.00	22.7	µg/L	H
200220L061	34	Building 3 Common Area Kitchen @ B - SK; Initial	1.00	21.0	µg/L	H
200220L062	35	Building 3 Common Area Kitchen @ C - SK; Initial	1.00	97.3	µg/L	E,H
200220L063	36	Building 3 Common Area Kitchen @ D - SK; Initial	1.00	50.1	µg/L	E,H
200220L064	37	Building 3 Room 302 - SK; Initial	1.00	4.99	µg/L	
200220L065	38	Building 3 Room 301 - SK; Initial	1.00	2.43	µg/L	
200220L066	39	Building 3 Women's Bathroom by Room 218 - SK; Initial	1.00	1.08	µg/L	
200220L067	40	Building 3 Men's Bathroom by Room 218 - SK; Initial	1.00	4.59	µg/L	
200220L068	41	Building 3 Main Kitchen Handwash - SK; Initial	1.00	10.5	µg/L	
200220L069	42	Building 3 Main Kitchen Dishwash - SPY; Initial	1.00	1.86	µg/L	
200220L070	43	Building 3 Main Kitchen Dishwash - SK; Initial	1.00	7.28	µg/L	
200220L071	45	Building 3 Room 217 - SK; Initial	1.00	1.67	µg/L	
200220L072	46	Building 3 Room 209 - SK; Initial	1.00	1.85	µg/L	
200220L073	47	Building 3 Room 209 Changing Area - SK; Initial	1.00	<1.00	µg/L	
200220L074	48	Building 3 Room 207 - SK; Initial	1.00	9.59	µg/L	
200220L075	49	Building 3 Room 206 - SK; Initial	1.00	2.91	µg/L	
200220L076	50	Building 3 Room 205 - SK; Initial	1.00	2.91	µg/L	
200220L077	51	Building 3 Room 204 - SK; Initial	1.00	10.5	µg/L	
200220L078	52	Building 3 Room 202 - SK; Initial	1.00	2.05	µg/L	
200220L079	53	Building 3 Room 201 - SK; Initial	1.00	4.94	µg/L	
200220L080	54	Building 3 200 Wing Kitchen - SK; Initial	1.00	86.2	µg/L	E,H
200220L081	55	Building 3 200 Wing Girl's Bathroom - SK; Initial	1.00	3.52	µg/L	
200220L082	56	Building 3 200 Wing Boy's Bathroom - SK; Initial	1.00	3.53	µg/L	



Date Collected:	19 Feb 2020
Date Received:	20 Feb 2020
Date Analyzed:	21 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200220L083	57	Building 3 Hallway by 200 Wing Boy's Bathroom - WF; Initial	1.00	<1.00	µg/L	
200220L084	58	Building 3 Hallway by 200 Wing Boy's Bathroom - BF; Initial	1.00	<1.00	µg/L	
200220L085	59	Building 3 B Faculty Room - SK; Initial	1.00	4.21	µg/L	
200220L086	60	Building 3 Nurse's Office - SK; Initial	1.00	1.90	µg/L	
200220L087	61	Building 4 Cafeteria - SK; Initial	1.00	<1.00	µg/L	
200220L088	62	Building 4 Women's Faculty Bathroom by Room 21 - SK; Initial	1.00	3.90	µg/L	
200220L089	63	Building 4 Men's Faculty Bathroom by Room 21 - SK; Initial	1.00	11.5	µg/L	
200220L090	64	Building 4 Faculty Lounge - SK; Initial	1.00	3.21	µg/L	
200220L091	66	Building 4 Women's Bathroom by Room 8 @ A - SK; Initial	1.00	1.07	µg/L	
200220L092	67	Building 4 Women's Bathroom by Room 8 @ B - SK; Initial	1.00	1.09	µg/L	
200220L093	68	Building 4 Women's Bathroom by Room 8 @ C - S; Initial	1.00	3.00	µg/L	
200220L094	69	Building 4 Hallway by Room 8 - WF; Initial	1.00	<1.00	µg/L	
200220L095	70	Building 4 Hallway by Room 8 - BF; Initial	1.00	<1.00	µg/L	
200220L096	71	Building 4 Men's Bathroom by Room 8 @ A - SK; Initial	1.00	1.33	µg/L	
200220L097	72	Building 4 Men's Bathroom by Room 8 @ C - SK; Initial	1.00	<1.00	µg/L	
200220L098	73	Building 1 Hallway by Room 19 - WF; Initial	1.00	<1.00	µg/L	
200220L099	74	Building 1 Hallway by Room 19 - BF; Initial	1.00	<1.00	µg/L	
200220L100	75	Building 1 Girl's Bathroom 18 - SK; Initial	1.00	1.19	µg/L	
200220L101	76	Building 1 Staff Bathroom - SK; Initial	1.00	<1.00	µg/L	
200220L102	77	Building 1 Boy's Bathroom 17 - SK; Initial	1.00	<1.00	µg/L	
200220L103	78	Building 1 Room 10 - SK; Initial	1.00	6.85	µg/L	
200220L104	79	Building 1 Custodial Closet by Room 10 - SK; Initial	1.00	4.39	µg/L	
200220L105	80	Building 1 Kitchen - SK; Initial	1.00	1.26	µg/L	
200220L106	81	Building 1 Kitchen - SPY; Initial	1.00	<1.00	µg/L	
200220L107	82	Building 1 Room 11 - SK; Initial	1.00	3.99	µg/L	
200220L108	83	Building 1 Room 12 - SK; Initial	1.00	4.70	µg/L	
200220L109	84	Building 1 Room 1 Bathroom - SK; Initial	1.00	2.37	µg/L	



Date Collected:	19 Feb 2020
Date Received:	20 Feb 2020
Date Analyzed:	21 Feb 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
200220L110	85	Building 1 Room 2 Bathroom - SK; Initial	1.00	1.64	µg/L	
200220L111	86	Building 1 Faculty Room - SK; Initial	1.00	7.38	µg/L	
200220L112	87	Building 1 Faculty Room Bathroom - SK; Initial	1.00	1.42	µg/L	
200220L113	88	Building 1 Nurse's Office - SK; Initial	1.00	9.22	µg/L	
200220L114	89	Building 1 Nurse's Office Bathroom - SK; Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2204104-15842

October 12, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Westhampton Beach Learning Center

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on October 09, 2020. New York Environmental analyzed the samples on October 12, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	09 Oct 2020
Date Received:	09 Oct 2020
Date Analyzed:	12 Oct 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
201009Q001	1	Building 2 Copy Room 11-SK, Initial	1.00	55.7	µg/L	E,H
201009Q002	2	Building 2 Conference Room 27-SK, Initial	1.00	42.5	µg/L	H
201009Q003	3	Building 3 200 Wing Kitchen-SK, Initial	1.00	6.22	µg/L	
201009Q004	4	Building 3 Common Area Kitchen @ A-SK, Initial	1.00	2.63	µg/L	
201009Q005	5	Building 3 Common Area Kitchen @ B-SK, Initial	1.00	6.78	µg/L	
201009Q006	6	Building 3 Common Area Kitchen @ C-SK, Initial	1.00	3.61	µg/L	
201009Q007	7	Building 3 Common Area Kitchen @ D-SK, Initial	1.00	3.67	µg/L	
201009Q008	8	Building 3 Room 306D-SK, Initial	1.00	24.2	µg/L	H

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2204453-16124

November 9, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Westhampton Beach Learning Center

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on November 06, 2020. New York Environmental analyzed the samples on November 07, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

Li Tsang, Laboratory Director

Date Collected:	06 Nov 2020
Date Received:	06 Nov 2020
Date Analyzed:	07 Nov 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
201106M181	1	Building 2 Conference Room 27-SK; Initial	1.00	8.61	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix O

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	First Floor Faculty Room	SK	App	1.03	12/19/2020	-	-	-	None	-	-	-
1002-1	Coffee Room 2-Bay	SK	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1002-2	Coffee Room Handwash	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1003-1	Kitchen Prep	SK	App	2.09	12/19/2020	-	-	-	None	-	-	-
1003-2	Kitchen Handwash @A	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1003-3	Kitchen 2 Bay	SK	App	20.1	1/6/2021	<1.0	<1.0	1/12/21	FR	Aerator Flushed	10.8	1/12/2021
1003-4	Kitchen Pot Filler-Right	PF	App	5.49	12/19/2020	-	-	-	None	-	-	-
1003-5	Kitchen Pot Filler-Middle	PF	App	2.66	12/19/2020	-	-	-	None	-	-	-
1003-6	Kitchen Pot Filler-Left	PF	App	41.4	1/6/2021	<1.0	<1.0	1/12/21	FR	Fixture Flushed	2.47	1/12/2021
1003-7	Kitchen Handwash @B	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1003-8	Kitchen Handwash @C	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1003-9	Kitchen Ice Machine	IM	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1004-1	Kitchen Dishwash Room @A	SPY	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1004-2	Kitchen Dishwash Room @A	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1004-3	Kitchen Dishwash Room @B	SPY	App		12/19/2020	-	-	-	Sign Required	-	-	-
1005-1	Men's Bathroom by Kitchen	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1006-1	Women's Bathroom by Kitchen	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1007-1	Conference Room 5/8 Coffee Room	SK	App	4.38	12/19/2020	-	-	-	None	-	-	-
1008-1	Hall by Conference Room 8	WF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1008-2	Hall by Conference Room 8	BF	App	<1.0	12/19/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1009-1	Men's Bathroom by Auditorium @ A	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1009-2	Men's Bathroom by Auditorium @ B	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1009-3	Men's Bathroom by Auditorium @ C	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1010-1	Women's Bathroom by Auditorium @ A	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1010-2	Women's Bathroom by Auditorium @ B	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1010-3	Women's Bathroom by Auditorium @ C	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1011-1	Women's Bathroom-East by Auditorium @ A	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1011-2	Women's Bathroom-East by Auditorium @ B	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1011-3	Women's Bathroom-East by Auditorium @ C	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1011-4	Women's Bathroom-East by Auditorium @ D	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1011-5	Women's Bathroom-East by Auditorium @ E	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1012-1	Hall by Auditorium	WF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1012-2	Hall by Auditorium	BF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1013-1	Hall by Bathroom 148	WF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1013-2	Hall by Bathroom 148	BF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1014-1	Men's Bathroom 148 @A	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1014-2	Men's Bathroom 148 @B	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1014-3	Men's Bathroom 148 @C	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1014-4	Men's Bathroom 148 @D	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1015-1	Women's Bathroom 149 @A	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1015-2	Women's Bathroom 149 @B	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1015-3	Women's Bathroom 149 @C	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1015-4	Women's Bathroom 149 @D	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1016-1	Hall by Bathroom 158	WF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1016-2	Hall by Bathroom 158	BF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1017-1	Men's Bathroom 160 @A	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1017-2	Men's Bathroom 160 @B	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1017-3	Men's Bathroom 160 @C	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1017-4	Men's Bathroom 160 @D	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1018-1	Women's Bathroom 159 @ A	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1018-2	Women's Bathroom 159 @ B	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1018-3	Women's Bathroom 159 @ C	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1018-4	Women's Bathroom 159 @ D	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1019-1	Hall by Cafeteria	WF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1019-2	Hall by Cafeteria	BF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1020-1	Women's Room by Cafeteria	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1021-1	Men's Room by Cafeteria	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
1022-1	Cafeteria (left-by clock)	SK	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1022-2	Cafeteria (right- rear wall)	SK	App	1.09	12/19/2020	-	-	-	None	-	-	-
1023-1	Nurse's Office	SK	App	<1.0	12/19/2020	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1023-2	Nurse's Office Bathroom	SK	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1024-1	Hall by Nurse's Office	WF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1024-2	Hall by Nurse's Office	BF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1025-1	Room 121	SK	App	<1.0	12/19/2020	-	-	-	None	-	-	-
1026-1	Room 145	SK	App	5.59	12/19/2020	-	-	-	None	-	-	-
2001-1	Hall by Bathroom 215	WF	App		12/19/2020	-	-	-	None	Removed from Service	-	-
2001-2	Hall by Bathroom 215	BF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
2002-1	Men's Bathroom 215 @A	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2002-2	Men's Bathroom 215 @B	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2002-3	Men's Bathroom 215 @C	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
2003-1	Women's Bathroom 214 @A	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2003-1	Women's Bathroom 214 @B	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2003-1	Women's Bathroom 214 @C	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2004-1	Second Floor Faculty Room	SK	App	2.97	12/19/2020	-	-	-	None	-	-	-
2005-1	Hall by Bathroom 232	WF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
2005-2	Hall by Bathroom 232	BF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
2006-1	Women's Bathroom 232 @A	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2006-2	Women's Bathroom 232 @B	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2006-3	Women's Bathroom 232 @C	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2006-4	Women's Bathroom 232 @D	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
2007-1	Men's Bathroom 233 @A	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2007-2	Men's Bathroom 233 @B	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2007-3	Men's Bathroom 233 @C	SK	N/A		12/19/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2007-4	Men's Bathroom 233 @D	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
2008-1	Women's Bathroom 244	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
2009-1	Men's Bathroom 245	SK	N/A		12/19/2020	-	-	-	Sign Required	-	-	-
2010-1	Hall by Bathroom 245	WF	App	<1.0	12/19/2020	-	-	-	None	-	-	-
2010-2	Hall by Bathroom 245	BF	App	<1.0	12/19/2020	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2205085-16507

December 22, 2020

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Sequoia High School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on December 21, 2020. New York Environmental analyzed the samples on December 22, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	19 Dec 2020
Date Received:	21 Dec 2020
Date Analyzed:	22 Dec 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
201221P003	1	First Floor Faculty Room-SK; Initial	1.00	1.03	µg/L	
201221P004	2	Coffee Room 2-Bay-SK; Initial	1.00	<1.00	µg/L	
201221P005	3	Kitchen Prep-SK; Initial	1.00	2.09	µg/L	
201221P006	4	Kitchen 2 Bay-SK; Initial	1.00	19.5	µg/L	H
201221P007	5	Kitchen Pot Filler-Right-PF; Initial	1.00	5.49	µg/L	
201221P008	6	Kitchen Pot Filler-Middle-PF; Initial	1.00	2.66	µg/L	
201221P009	7	Kitchen Pot Filler-Left-PF; Initial	1.00	18.1	µg/L	H
201221P010	8	Kitchen Ice Machine- IM; Initial	1.00	<1.00	µg/L	
201221P011	9	Conference Room 5/8 Coffee Room-SK; Initial	1.00	4.38	µg/L	
201221P012	10	Hall by Conference Room 8-WF; Initial	1.00	<1.00	µg/L	
201221P013	11	Hall by Conference Room 8-BF; Initial	1.00	<1.00	µg/L	
201221P014	12	Hall by Auditorium-WF; Initial	1.00	<1.00	µg/L	
201221P015	13	Hall by Auditorium-BF; Initial	1.00	<1.00	µg/L	
201221P016	14	Hall by Bathroom 148-WF; Initial	1.00	<1.00	µg/L	
201221P017	15	Hall by Bathroom 148-BF; Initial	1.00	<1.00	µg/L	
201221P018	16	Hall by Bathroom 158-WF; Initial	1.00	<1.00	µg/L	
201221P019	17	Hall by Bathroom 158-BF; Initial	1.00	<1.00	µg/L	
201221P020	18	Hall by Cafeteria-WF; Initial	1.00	<1.00	µg/L	
201221P021	19	Hall by Cafeteria-BF; Initial	1.00	<1.00	µg/L	
201221P022	20	Cafeteria (left-by clock)-SK; Initial	1.00	<1.00	µg/L	
201221P023	21	Cafeteria (right- rear wall)-SK; Initial	1.00	1.09	µg/L	
201221P024	22	Nurse's Office-SK; Initial	1.00	<1.00	µg/L	
201221P025	23	Nurse's Office Bathroom-SK; Initial	1.00	<1.00	µg/L	
201221P026	24	Hall by Nurse's Office-WF; Initial	1.00	<1.00	µg/L	
201221P027	25	Hall by Nurse's Office-BF; Initial	1.00	<1.00	µg/L	
201221P028	26	Room 121-SK; Initial	1.00	<1.00	µg/L	



Date Collected:	19 Dec 2020
Date Received:	21 Dec 2020
Date Analyzed:	22 Dec 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
201221P029	27	Hall by Bathroom 215-BF; Initial	1.00	<1.00	µg/L	
201221P030	28	Second Floor Faculty Room-SK; Initial	1.00	2.97	µg/L	
201221P031	29	Hall by Bathroom 232-WF; Initial	1.00	<1.00	µg/L	
201221P032	30	Hall by Bathroom 232-BF; Initial	1.00	<1.00	µg/L	
201221P033	31	Hall by Bathroom 245-WF; Initial	1.00	<1.00	µg/L	
201221P034	32	Hall by Bathroom 245-BF; Initial	1.00	<1.00	µg/L	
201221P035	33	Room 145-SK; Initial	1.00	5.59	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Laboratory Report

NYE Report #: 2210081-16631

January 7, 2021

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Sequoya High School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on January 06, 2021. New York Environmental analyzed the samples on January 07, 2021 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	06 Jan 2021
Date Received:	06 Jan 2021
Date Analyzed:	07 Jan 2021

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
210106P001	1	Kitchen 2-Bay-SK; Initial	1.00	20.1	µg/L	H
210106P002	2	Kitchen Pot Filler-Left-PF; Initial	1.00	41.4	µg/L	H

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2210208-16696

January 14, 2021

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Sequoya High School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on January 13, 2021. New York Environmental analyzed the samples on January 14, 2021 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	12 Jan 2021
Date Received:	13 Jan 2021
Date Analyzed:	14 Jan 2021

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
210113Q196	1	Kitchen 2-Bay-SK; Initial	1.00	10.8	µg/L	
210113Q197	2	Kitchen 2-Bay-SK; 15 Sec Flush	1.00	<1.00	µg/L	
210113Q198	3	Kitchen 2-Bay-SK; 60 Sec Flush	1.00	<1.00	µg/L	
210113Q199	4	Kitchen Pot filler Left-PF; Initial	1.00	2.47	µg/L	
210113Q200	5	Kitchen Pot filler Left-PF; 15 Sec Flush	1.00	<1.00	µg/L	
210113Q201	6	Kitchen Pot filler Left-PF; 60 Sec Flush	1.00	<1.00	µg/L	

Cor Comment:

CID CID: Client ID LOQ: Limit of Quantitation

Appendix P

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1000-1	Kitchen 1 Bay Handwash by Bathroom	SK	App	12	1/12/2021	-	-	-	None	-	-	-
1000-2	Kitchen 2 Bay (Left)	SK	App	<1.0	1/12/2021	-	-	-	None	-	-	-
1000-3	Kitchen 2 Bay (Right)	SK	App	9.82	1/12/2021	-	-	-	None	-	-	-
1000-4	Kitchen 1 Bay Handwash by Dishwashing Station	SK	App	15.1	1/29/2021	1.34	1.69	1/29/2021	FR	Aerator Flushed Permanent Sign Posted	-	-
1000-5	Kitchen Dishwashing Station	SPY	App	4.96	1/12/2021	-	-	-	None	-	-	-
1000-6	Kitchen Pot Filler	PF	App	28.7	1/12/2021				Additional Sampling Required	Aerator Flushed	10.2	1/29/2021
1000-7	Kitchen Island	SK	App	10.2	1/12/2021	-	-	-	None	-	-	-
1000-8	Kitchen Bathroom	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1000-9	Kitchen Can Wash Room 50C	SP	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1001-1	Hall by Boiler Room 48	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1002-1	Custodian Office 47	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1002-2	Custodian Office 47	SS	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1003-1	Cafeterium	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1004-1	Girls Locker Room Bathroom	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1005-1	Main Office	SK	App	3.27	1/12/2021	-	-	-	None	-	-	-
1006-1	Nurses Office	SK	App	2.01	1/12/2021	-	-	-	None	-	-	-
1006-2	Nurses Office Bathroom	SK	App	<1.0	1/12/2021	-	-	-	None	-	-	-
1007-1	Mens Bathroom by Gym @ A	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1007-2	Mens Bathroom by Gym @ B	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1008-1	Hall by Gym	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1008-2	Hall by Gym Bottle Filler	BF	App	<1.0	1/12/2021	-	-	-	None	-	-	-
1009-1	Custodial Closet by Room 23	SS	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1010-1	Womens Bathroom by Room 23 @ A	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1010-2	Womens Bathroom by Room 23 @ B	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1011-1	Room 23	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1011-2	Room 23	SK	App	17.9	1/12/2021				Additional Sampling Required	Aerator Flushed	9.04	1/21/2021
1012-1	Room 22	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1012-2	Room 22	SK	App	3.67	1/12/2021	-	-	-	None	-	-	-
1013-1	Faculty Room 9	WF	App	5.44	1/12/2021	-	-	-	None	-	-	-
1013-2	Faculty Room 9	SK	App	4.42	1/12/2021	-	-	-	None	-	-	-
1014-1	Room 21	WF	App	2.49	1/12/2021	-	-	-	None	-	-	-
1014-2	Room 21	SK	App	23.9	1/12/2021				Additional Sampling Required	Aerator Flushed	6.19	1/21/2021
1015-1	Room 10	WF	App	16	1/12/2021				Additional Sampling Required	LineFlushed	9.43	1/29/2021
1015-2	Room 10	SK	App	26.5	1/29/2021	<1.0	<1.0	1/29/2021	FR	Aerator Flushed Permanent Sign Posted	-	-
1016-1	Hall by Room 10	WF	App	1.26	1/12/2021	-	-	-	None	-	-	-
1017-1	Room 20	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1017-2	Room 20	SK	App	9.89	1/12/2021	-	-	-	None	-	-	-
1018-1	Room 11	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1018-2	Room 11	SK	App	1.06	1/12/2021	-	-	-	None	-	-	-
1019-1	Room 19	WF	App	3.33	1/12/2021	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1019-2	Room 19	SK	App	19.4	1/29/2021	6.77	<1.0	1/29/2021	FR	Aerator Flushed Permanent Sign Posted	-	-
1020-1	Room 12 Multi Purpose Room	WF	App	<1.0	1/12/2021	-	-	-	None	-	-	-
1020-2	Room 12 Multi Purpose Room	SK	App	<1.0	1/12/2021	-	-	-	None	-	-	-
1021-1	Room 18	WF	App	<1.0	1/12/2021	-	-	-	None	-	-	-
1021-2	Room 18	SK	App	1.75	1/12/2021	-	-	-	None	-	-	-
1022-1	Art Room 17	WF	App	7.89	1/12/2021	-	-	-	None	-	-	-
1022-2	Art Room 17	SK	App	53.3	1/12/2021				Additional Sampling Required	Aerator Flushed	5.26	1/21/2021
1023-1	Room 16	WF	App	1.83	1/12/2021	-	-	-	None	-	-	-
1023-2	Room 16	SK	App	200	1/12/2021				Additional Sampling Required	Aerator Flushed	13.5	1/21/2021
1023-3	Room 16 Bathroom	SK	App	28.2	1/12/2021				Additional Sampling Required	Aerator Flushed	11.7	1/21/2021
1024-1	Room 15	WF	App	7.06	1/12/2021	-	-	-	None	-	-	-
1024-2	Room 15	SK	App	14.9	1/12/2021	-	-	-	None	-	-	-
1024-3	Room 15 Bathroom	SK	App	20.3	1/12/2021				Additional Sampling Required	Aerator Flushed	13.6	1/21/2021
1025-1	Room 14	WF	App	1.61	1/12/2021	-	-	-	None	-	-	-
1025-2	Room 14 @ A (Right)	SK	App	21.3	1/12/2021				Additional Sampling Required	Aerator Flushed	9.14	1/21/2021
1025-3	Room 14 @ B (Left)	SK	App	2.59	1/12/2021	-	-	-	None	-	-	-
1026-1	Room 13	WF	App	<1.0	1/12/2021	-	-	-	None	-	-	-
1026-2	Room 13 @ A (Left)	SK	App	11.7	1/12/2021	-	-	-	None	-	-	-
1026-3	Room 13 @ B (Right)	SK	App	2.57	1/12/2021	-	-	-	None	-	-	-
1027-1	Boys Locker Room Bathroom	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1028-1	Room 25	WF	App	8.86	1/12/2021	-	-	-	None	-	-	-
1028-2	Room 25	SK	App	27.5	1/12/2021				Additional Sampling Required	Aerator Flushed	8.03	1/21/2021
1029-1	Room 26	WF	App	3.3	1/12/2021	-	-	-	None	-	-	-
1029-2	Room 26	SK	App	14	1/12/2021	-	-	-	None	-	-	-
1030-1	Room 27	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1030-2	Room 27	SK	App	4.92	1/12/2021	-	-	-	None	-	-	-
1031-1	Room 28	WF	App	1.97	1/12/2021	-	-	-	None	-	-	-
1031-2	Room 28	SK	App	5.32	1/12/2021	-	-	-	None	-	-	-
1032-1	Room 29	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1032-2	Room 29	SK	App	6.78	1/12/2021	-	-	-	None	-	-	-
1033-1	Room 30	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1033-2	Room 30	SK	App	13.4	1/12/2021	-	-	-	None	-	-	-
1034-1	Room 31	WF	App	4.86	1/12/2021	-	-	-	None	-	-	-
1034-2	Room 31	SK	App	7.35	1/12/2021	-	-	-	None	-	-	-
1035-1	Room 32	WF	App	19.6	1/29/2021	12.2	3.77		FR	Removed from Service		
1035-2	Room 32	SK	App	27.3	1/29/2021	4.12	1.83		FR	Aerator Flushed Permanent Sign Posted		
1036-1	Room 33 OT/PT	WF	App	4.3	1/12/2021	-	-	-	None	-	-	-
1036-2	Room 33 OT/PT	SK	App	26.9	1/29/2021	<1.0	<1.0		FR	Aerator Flushed Permanent Sign Posted		
1037-1	Room 34	WF	App	2.1	1/12/2021	-	-	-	None	-	-	-
1037-2	Room 34	SK	App	<1.0	1/12/2021	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1038-1	Room 35	WF	App	4.19	1/12/2021	-	-	-	None	-	-	-
1038-2	Room 35	SK	App	10.5	1/12/2021	-	-	-	None	-	-	-
1039-1	Boys Bathroom by Room 35 @ A	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1039-2	Boys Bathroom by Room 35 @ B	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1039-3	Boys Bathroom by Room 35 @ C	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1039-4	Boys Bathroom by Room 35 @ D	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1040-1	Custodial Closet by Room 35	SS	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1041-1	Hall by Room 35	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1041-2	Hall by Room 35 Bottle Filler	BF	App	<1.0	1/12/2021	-	-	-	None	-	-	-
1042-1	Girls Bathroom by Room 35 @ A	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1042-2	Girls Bathroom by Room 35 @ B	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1042-3	Girls Bathroom by Room 35 @ C	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1042-4	Girls Bathroom by Room 35 @ D	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1043-1	Room 38	WF	App	3.01	1/12/2021	-	-	-	None	-	-	-
1043-2	Room 38	SK	App	8.08	1/12/2021	-	-	-	None	-	-	-
1044-1	Room 39	WF	App	5.75	1/12/2021	-	-	-	None	-	-	-
1044-2	Room 39	SK	App	116	1/29/2021	2.59	<1.0		FR	Aerator Flushed Permanent Sign Posted		
1045-1	Boys Bathroom by Room 60 @ A	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1045-2	Boys Bathroom by Room 60 @ B	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1046-1	Custodial Closet by Room 60	SS	N/A		1/12/2021	-	-	-	None	SIGN	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1047-1	Girls Bathroom by Room 60 @ A	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1047-2	Girls Bathroom by Room 60 @ B	SK	N/A		1/12/2021	-	-	-	None	SIGN	-	-
1048-1	Hall by Room 60 (Right)	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1048-2	Hall by Room 60 Bottle Filler (Right)	BF	App	1.36	1/12/2021	-	-	-	None	-	-	-
1048-3	Hall by Room 60 (Left)	WF	App		1/12/2021	-	-	-	None	Removed from Service	-	-
1049-1	Room 60	WF	App	7.02	1/12/2021	-	-	-	None	-	-	-
1049-2	Room 60	SK	App	7.62	1/12/2021	-	-	-	None	-	-	-
1050-1	Room 59	WF	App	5.73	1/12/2021	-	-	-	None	-	-	-
1050-2	Room 59	SK	App	3.9	1/12/2021	-	-	-	None	-	-	-
1051-1	Room 58	WF	App	3.53	1/12/2021	-	-	-	None	-	-	-
1051-2	Room 58	SK	App	3.04	1/12/2021	-	-	-	None	-	-	-
1052-1	Room 57	WF	App	3.04	1/12/2021	-	-	-	None	-	-	-
1052-2	Room 57	SK	App	3.68	1/12/2021	-	-	-	None	-	-	-
1053-1	Room 56	WF	App	5.08	1/12/2021	-	-	-	None	-	-	-
1053-2	Room 56	SK	App	14	1/12/2021	-	-	-	None	-	-	-
1054-1	Room 55	WF	App	3.09	1/12/2021	-	-	-	None	-	-	-
1054-2	Room 55	SK	App	10.2	1/12/2021	-	-	-	None	-	-	-
1055-1	Room 54	WF	App	4.32	1/12/2021	-	-	-	None	-	-	-
1055-2	Room 54	SK	App	15.4	1/12/2021				Additional Sampling Required	Aerator Flushed	6.82	1/21/2021
1056-1	Room 53	WF	App	5.62	1/12/2021	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1056-2	Room 53	SK	App	3.15	1/12/2021	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2210205-16693

January 15, 2021

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Tecumseh Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on January 13, 2021. New York Environmental analyzed the samples on January 14, 2021 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	12 Jan 2021
Date Received:	13 Jan 2021
Date Analyzed:	14 Jan 2021

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
210113Q001	1	Kitchen 1 Bay Handwash by Bathroom-SK; Initial	1.00	12.0	µg/L	
210113Q002	2	Kitchen 2 Bay (Left)-SK; Initial	1.00	<1.00	µg/L	
210113Q003	3	Kitchen 2 Bay (Right)-SK; Initial	1.00	9.82	µg/L	
210113Q004	4	Kitchen 1 Bay Handwash by Dishwashing Station-SK; Initial	1.00	17.0	µg/L	H
210113Q005	5	Kitchen Dishwashing Station-SPY; Initial	1.00	4.96	µg/L	
210113Q006	6	Kitchen Pot Filler-SP; Initial	1.00	28.7	µg/L	H
210113Q007	7	Kitchen Island -SK; Initial	1.00	10.2	µg/L	
210113Q008	8	Main Office-SK; Initial	1.00	3.27	µg/L	
210113Q009	9	Nurses Office-SK; Initial	1.00	2.01	µg/L	
210113Q010	10	Nurses Office Bathroom-SK; Initial	1.00	<1.00	µg/L	
210113Q011	11	Hall by Gym Bottle Filler-BF; Initial	1.00	<1.00	µg/L	
210113Q012	12	Room 23-SK; Initial	1.00	17.9	µg/L	H
210113Q013	13	Room 22-SK; Initial	1.00	3.67	µg/L	
210113Q014	14	Faculty Room 9-WF; Initial	1.00	5.44	µg/L	
210113Q015	15	Faculty Room 9-SK; Initial	1.00	4.42	µg/L	
210113Q016	16	Room 21-WF; Initial	1.00	2.49	µg/L	
210113Q017	17	Room 21-SK; Initial	1.00	23.9	µg/L	H
210113Q018	18	Room 10-WF; Initial	1.00	16.0	µg/L	H
210113Q019	19	Room 10-SK; Initial	1.00	40.2	µg/L	H
210113Q020	20	Room 20-WF; Initial	1.00	1.26	µg/L	
210113Q021	21	Room 20-SK; Initial	1.00	9.89	µg/L	
210113Q022	22	Room 11-SK; Initial	1.00	1.06	µg/L	
210113Q023	23	Room 19-WF; Initial	1.00	3.33	µg/L	
210113Q024	24	Room 19-SK; Initial	1.00	36.4	µg/L	H
210113Q025	25	Room 12 Multi Purpose Room-WF; Initial	1.00	<1.00	µg/L	
210113Q026	26	Room 12 Multi Purpose Room-SK; Initial	1.00	<1.00	µg/L	



Date Collected:	12 Jan 2021
Date Received:	13 Jan 2021
Date Analyzed:	14 Jan 2021

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
210113Q027	27	Room 18-WF; Initial	1.00	<1.00	µg/L	
210113Q028	28	Room 18-SK; Initial	1.00	1.75	µg/L	
210113Q029	29	Art Room 17-WF; Initial	1.00	7.89	µg/L	
210113Q030	30	Art Room 17-SK; Initial	1.00	53.3	µg/L	E,H
210113Q031	31	Room 16-WF; Initial	1.00	1.83	µg/L	
210113Q032	32	Room 16-SK; Initial	1.00	200	µg/L	E,H
210113Q033	33	Room 16 Bathroom-SK; Initial	1.00	28.2	µg/L	H
210113Q034	34	Room 15-WF; Initial	1.00	7.06	µg/L	
210113Q035	35	Room 15-SK; Initial	1.00	14.9	µg/L	
210113Q036	36	Room 15 Bathroom-SK; Initial	1.00	20.3	µg/L	H
210113Q037	37	Room 14-WF; Initial	1.00	1.61	µg/L	
210113Q038	38	Room 14 @ A (Right)-SK; Initial	1.00	21.3	µg/L	H
210113Q039	39	Room 14 @ B (Left)-SK; Initial	1.00	2.59	µg/L	
210113Q040	40	Room 13-WF; Initial	1.00	<1.00	µg/L	
210113Q041	41	Room 13 @ A (Left)-SK; Initial	1.00	11.7	µg/L	
210113Q042	42	Room 13 @ B (Right)-SK; Initial	1.00	2.57	µg/L	
210113Q043	43	Room 25-WF; Initial	1.00	8.86	µg/L	
210113Q044	44	Room 25-SK; Initial	1.00	27.5	µg/L	H
210113Q045	45	Room 26-WF; Initial	1.00	3.30	µg/L	
210113Q046	46	Room 26-SK; Initial	1.00	14.0	µg/L	
210113Q047	47	Room 27-SK; Initial	1.00	4.92	µg/L	
210113Q048	48	Room 28-WF; Initial	1.00	1.97	µg/L	
210113Q049	49	Room 28-SK; Initial	1.00	5.32	µg/L	
210113Q050	50	Room 29-SK; Initial	1.00	6.78	µg/L	
210113Q051	51	Room 30-SK; Initial	1.00	13.4	µg/L	
210113Q052	52	Room 31-WF; Initial	1.00	4.86	µg/L	
210113Q053	53	Room 31-SK; Initial	1.00	7.35	µg/L	

Date Collected:	12 Jan 2021
Date Received:	13 Jan 2021
Date Analyzed:	14 Jan 2021

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
210113Q054	54	Room 32-WF; Initial	1.00	26.3	µg/L	H
210113Q055	55	Room 32-SK; Initial	1.00	30.3	µg/L	H
210113Q056	56	Room 33 OT/PT-WF; Initial	1.00	4.30	µg/L	
210113Q057	57	Room 33 OT/PT-SK; Initial	1.00	26.9	µg/L	H
210113Q058	58	Room 34-WF; Initial	1.00	2.10	µg/L	
210113Q059	59	Room 34-SK; Initial	1.00	<1.00	µg/L	
210113Q060	60	Room 35-WF; Initial	1.00	4.19	µg/L	
210113Q061	61	Room 35-SK; Initial	1.00	10.5	µg/L	
210113Q062	62	Hall by Room 35 Bottle Filler-BF; Initial	1.00	<1.00	µg/L	
210113Q063	63	Room 38-WF; Initial	1.00	3.01	µg/L	
210113Q064	64	Room 38-SK; Initial	1.00	8.08	µg/L	
210113Q065	65	Room 39-WF; Initial	1.00	5.75	µg/L	
210113Q066	66	Room 39-SK; Initial	1.00	52.8	µg/L	E,H
210113Q067	67	Hall by Room 60 Bottle Filler (Right)-BF; Initial	1.00	1.36	µg/L	
210113Q068	68	Room 60-WF; Initial	1.00	7.02	µg/L	
210113Q069	69	Room 60-SK; Initial	1.00	7.62	µg/L	
210113Q070	70	Room 59-WF; Initial	1.00	5.73	µg/L	
210113Q071	71	Room 59-SK; Initial	1.00	3.90	µg/L	
210113Q072	72	Room 58-WF; Initial	1.00	3.53	µg/L	
210113Q073	73	Room 58-SK; Initial	1.00	3.04	µg/L	
210113Q074	74	Room 57-WF; Initial	1.00	3.04	µg/L	
210113Q075	75	Room 57-SK; Initial	1.00	3.68	µg/L	
210113Q076	76	Room 56-WF; Initial	1.00	5.08	µg/L	
210113Q077	77	Room 56-SK; Initial	1.00	14.0	µg/L	
210113Q078	78	Room 55-WF; Initial	1.00	3.09	µg/L	
210113Q079	79	Room 55-SK; Initial	1.00	10.2	µg/L	
210113Q080	80	Room 54-WF; Initial	1.00	4.32	µg/L	



Date Collected:	12 Jan 2021
Date Received:	13 Jan 2021
Date Analyzed:	14 Jan 2021

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
210113Q081	81	Room 54-SK; Initial	1.00	15.4	µg/L	H
210113Q082	82	Room 53-WF; Initial	1.00	5.62	µg/L	
210113Q083	83	Room 53-SK; Initial	1.00	3.15	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2210309-16760

January 22, 2021

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Tecumseh Elementary School; 179 Granny Road, Farmingville, NY

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on January 21, 2021. New York Environmental analyzed the samples on January 22, 2021 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	21 Jan 2021
Date Received:	21 Jan 2021
Date Analyzed:	22 Jan 2021

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
210121N003	1	Kitchen 1 Bay Handwash by Dishwash Station-SK; Initial	1.00	19.5	µg/L	H
210121N004	2	Kitchen Pot Filler-PF; Initial	1.00	19.8	µg/L	H
210121N005	3	Room 23-SK; Initial	1.00	9.04	µg/L	
210121N006	4	Room 21-SK; Initial	1.00	46.6	µg/L	H
210121N007	5	Room 10-WF; Initial	1.00	21.1	µg/L	H
210121N008	6	Room 10-SK; Initial	1.00	87.2	µg/L	E,H
210121N009	7	Room 19-SK; Initial	1.00	42.8	µg/L	H
210121N010	8	Art Room 17-SK; Initial	1.00	5.26	µg/L	
210121N011	9	Room 16-SK; Initial	1.00	95.5	µg/L	E,H
210121N012	10	Room 15-SK; Initial	1.00	38.8	µg/L	H
210121N013	11	Room 15 Bathroom-SK; Initial	1.00	271	µg/L	E,H
210121N014	12	Room 14 @A-SK; Initial	1.00	9.14	µg/L	
210121N015	13	Room 25-SK; Initial	1.00	26.0	µg/L	H
210121N016	14	Room 32-WF; Initial	1.00	20.9	µg/L	H
210121N017	15	Room 32-SK; Initial	1.00	78.2	µg/L	E,H
210121N018	16	Room 33 CT/PT-SK; Initial	1.00	17.6	µg/L	H
210121N019	17	Room 39-SK; Initial	1.00	16.8	µg/L	H
210121N020	18	Room 54-SK; Initial	1.00	6.82	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2210415-16820

February 3, 2021

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Tecumseh Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on January 29, 2021. New York Environmental analyzed the samples on February 02, 2021 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	29 Jan 2021
Date Received:	29 Jan 2021
Date Analyzed:	02 Feb 2021

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
210129K028	1	Kitchen 1 Bay Handwash by Dishwashing Station - SK, Initial	1.00	15.1	µg/L	H
210129K029	2	Kitchen 1 Bay Handwash by Dishwashing Station - SK, 15 Sec Follow-up	1.00	1.34	µg/L	
210129K030	3	Kitchen 1 Bay Handwash by Dishwashing Station - SK, 60 Sec Follow-up	1.00	1.69	µg/L	
210129K031	4	Kitchen Pot Filler - PF, Initial	1.00	10.2	µg/L	
210129K032	5	Kitchen Pot Filler - PF, 15 Sec Follow-up	1.00	NA	µg/L	
210129K033	6	Kitchen Pot Filler - PF, 60 Sec Follow-up	1.00	NA	µg/L	
210129K034	7	Room 21 - SK, Initial	1.00	6.19	µg/L	
210129K035	8	Room 21 - SK, 15 Sec Follow-up	1.00	NA	µg/L	
210129K036	9	Room 21 - SK, 60 Sec Follow-up	1.00	NA	µg/L	
210129K037	10	Room 10 - WF, Initial	1.00	9.43	µg/L	
210129K038	11	Room 10 - WF, 15 Sec Follow-up	1.00	NA	µg/L	
210129K039	12	Room 10 - WF, 60 Sec Follow-up	1.00	NA	µg/L	
210129K040	13	Room 10 - SK, Initial	1.00	26.5	µg/L	H
210129K041	14	Room 10 - SK, 15 Sec Follow-up	1.00	<1.00	µg/L	
210129K042	15	Room 10 - SK, 60 Sec Follow-up	1.00	<1.00	µg/L	
210129K043	16	Room 19 - SK, Initial	1.00	19.4	µg/L	H
210129K044	17	Room 19 - SK, 15 Sec Follow-up	1.00	6.77	µg/L	
210129K045	18	Room 19 - SK, 60 Sec Follow-up	1.00	<1.00	µg/L	
210129K046	19	Room 16 - SK, Initial	1.00	13.5	µg/L	
210129K047	20	Room 16 - SK, 15 Sec Follow-up	1.00	NA	µg/L	
210129K048	21	Room 16 - SK, 60 Sec Follow-up	1.00	NA	µg/L	
210129K049	22	Room 16 Bathroom - SK, Initial	1.00	11.7	µg/L	
210129K050	23	Room 16 Bathroom - SK, 15 Sec Follow-up	1.00	NA	µg/L	
210129K051	24	Room 16 Bathroom - SK, 60 Sec Follow-up	1.00	NA	µg/L	
210129K052	25	Room 15 Bathroom - SK, Initial	1.00	13.6	µg/L	
210129K053	26	Room 15 Bathroom - SK, 15 Sec Follow-up	1.00	NA	µg/L	



Date Collected:	29 Jan 2021
Date Received:	29 Jan 2021
Date Analyzed:	02 Feb 2021

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
210129K054	27	Room 15 Bathroom - SK, 60 Sec Follow-up	1.00	NA	µg/L	
210129K055	28	Room 25 - SK, Initial	1.00	8.03	µg/L	
210129K056	29	Room 25 - SK, 15 Sec Follow-up	1.00	NA	µg/L	
210129K057	30	Room 25 - SK, 60 Sec Follow-up	1.00	NA	µg/L	
210129K058	31	Room 32 - WF, Initial	1.00	19.6	µg/L	H
210129K059	32	Room 32 - WF, 15 Sec Follow-up	1.00	12.2	µg/L	
210129K060	33	Room 32 - WF, 60 Sec Follow-up	1.00	3.77	µg/L	
210129K061	34	Room 32 - SK, Initial	1.00	27.3	µg/L	H
210129K062	35	Room 32 - SK, 15 Sec Follow-up	1.00	4.12	µg/L	
210129K063	36	Room 32 - SK, 60 Sec Follow-up	1.00	1.83	µg/L	
210129K064	37	Room 33 OT/PT - SK, Initial	1.00	16.8	µg/L	H
210129K065	38	Room 33 OT/PT - SK, 15 Sec Follow-up	1.00	<1.00	µg/L	
210129K066	39	Room 33 OT/PT - SK, 60 Sec Follow-up	1.00	<1.00	µg/L	
210129K067	40	Room 39 - SK, Initial	1.00	116	µg/L	E,H
210129K068	41	Room 39 - SK, 15 Sec Follow-up	1.00	2.59	µg/L	
210129K069	42	Room 39 - SK, 60 Sec Follow-up	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

NA: Sample not analyzed per customer request.

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.