

Radon Testing Results - Springfield School District

The EPS's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting

Six spike tests were conducted to ensure the integrity of the testing process and all spike test passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Academy of Arts & Academics	Room 108/109	RK107897	2/18/2022	Detector Kit	2.7 ± 0.7
Academy of Arts & Academics	Room 112	RK107926	2/18/2022	Detector Kit	1.2 ± 0.5
Academy of Arts & Academics	Room 113/114	RK107380	2/18/2022	Detector Kit	0.8 ± 0.3
Academy of Arts & Academics	Room 106	RK107414	2/18/2022	Detector Kit	< 0.7
Academy of Arts & Academics	Room 116	RK107416	2/18/2022	Detector Kit	< 0.6
Academy of Arts & Academics	Room 117	RK107408	2/18/2022	Detector Kit	< 0.6
Academy of Arts & Academics	Room 118	RK108297	2/18/2022	Detector Kit	< 0.6
Academy of Arts & Academics	Room 119	RK107399	2/18/2022	Detector Kit	< 0.9
Academy of Arts & Academics	Room 103	RK108298	2/18/2022	Detector Kit	2.1 ± 0.4
Academy of Arts & Academics	Room 127	RK108287	2/18/2022	Detector Kit	1.3 ± 0.4
Academy of Arts & Academics	Room 126	RK108288	2/18/2022	Detector Kit	0.6 ± 0.3
Academy of Arts & Academics	Room 126	RK108291	2/18/2022	Duplicate	< 0.6
Academy of Arts & Academics	Studio 1	RK107762	2/18/2022	Detector Kit	< 0.7
Academy of Arts & Academics	Studio 1	RK107390	2/18/2022	Duplicate	< 0.6
Academy of Arts & Academics	Principal Office	RK107935	2/18/2022	Detector Kit	1.0 ± 0.5
Academy of Arts & Academics	Health Office	RK108296	2/18/2022	Detector Kit	0.9 ± 0.5
Academy of Arts & Academics	Studio 2	RK108295	2/18/2022	Detector Kit	< 0.7
Academy of Arts & Academics	Conference Room	RK108293	2/18/2022	Detector Kit	1.4 ± 0.5
Academy of Arts & Academics	Staff Room A	RK107822	2/18/2022	Detector Kit	1.0 ± 0.4
Academy of Arts & Academics	Staff Room B	RK107839	2/18/2022	Detector Kit	< 0.6
Academy of Arts & Academics	Staff Room C	RK107752	2/18/2022	Detector Kit	1.1 ± 0.5
Academy of Arts & Academics	Studio 3	RK104628	2/18/2022	Detector Kit	< 0.8
Academy of Arts & Academics	Studio P	RK107753	2/18/2022	Detector Kit	< 0.6
Academy of Arts & Academics	Studio 6	RK107837	2/18/2022	Detector Kit	< 0.8
Academy of Arts & Academics	Studio 5	RK107821	2/18/2022	Detector Kit	< 0.6
Academy of Arts & Academics	Studio 5	RK107764	2/18/2022	Duplicate	< 0.7
Academy of Arts & Academics	Studio 4	RK107773	2/18/2022	Detector Kit	< 0.6