

## Radon Testing Results - Springfield School District

The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.

Six spike tests were conducted to ensure the integrity of the testing process and all spike test passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Agnes Stewart Middle School	Family Center 129	RK108256	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Main Office 100	RK108257	2/17/2022	Detector Kit	< 0.5
Agnes Stewart Middle School	Office Workroom	RK108260	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Office Workroom	RK108283	2/17/2022	Duplicate	< 0.4
Agnes Stewart Middle School	Office 104	RK108266	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Office 102	RK108259	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Room 110	RK108299	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Office 108	RK108325	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Health Room 106	RK108284	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Pass Room	RK107895	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	SRC 105	RK107942	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Art 111	RK107894	2/17/2022	Detector Kit	< 0.5
Agnes Stewart Middle School	Computer Lab 112	RK107918	2/17/2022	Detector Kit	< 0.5
Agnes Stewart Middle School	Industrial Tech 113	RK107849	2/17/2022	Detector Kit	< 0.6
Agnes Stewart Middle School	Band 114	RK107910	2/17/2022	Detector Kit	-
Agnes Stewart Middle School	Band 114	RK107886	2/17/2022	Detector Kit	-
Agnes Stewart Middle School	Music 115	RK107902	2/17/2022	Detector Kit	1.2 ± 0.3
Agnes Stewart Middle School	Cafeteria	RK107896	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Cafeteria	RK107347	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Kitchen	RK107359	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Stage	RK107367	2/17/2022	Detector Kit	0.8 ± 0.2
Agnes Stewart Middle School	A117	RK107375	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	A118	RK107382	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	A118	RK107438	2/17/2022	Duplicate	< 0.4
Agnes Stewart Middle School	A101	RK107440	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	A110	RK107439	2/17/2022	Detector Kit	0.7 ± 0.3
Agnes Stewart Middle School	A102	RK107432	2/17/2022	Detector Kit	< 0.3

Agnes Stewart Middle School	A103	RK107424	2/17/2022	Detector Kit	< 0.3
Agnes Stewart Middle School	A104	RK107784	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	A105	RK107754	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	A106	RK107785	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	A107	RK107792	2/17/2022	Detector Kit	< 0.5
Agnes Stewart Middle School	A108	RK107818	2/17/2022	Detector Kit	< 0.3
Agnes Stewart Middle School	A109	RK107761	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Media Center	RK107823	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Media Center	RK107815	2/17/2022	Detector Kit	< 0.6
Agnes Stewart Middle School	Conference 127	RK107814	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Media Center – Ms. Nancy	RK107766	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Media Center – Ms. Nancy	RK107838	2/17/2022	Duplicate	< 0.5
Agnes Stewart Middle School	E Gymnasium 124	RK107940	2/17/2022	Detector Kit	< 0.5
Agnes Stewart Middle School	E Gymnasium 124	RK108317	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Main Gym 123	RK108292	2/17/2022	Detector Kit	< 0.4
Agnes Stewart Middle School	Main Gym 123	RK108258	2/17/2022	Detector Kit	0.6 ± 0.3
Agnes Stewart Middle School	Main Gym 123	RK108253	2/17/2022	Detector Kit	0.4 ± 0.3