

Radon Testing Results - Springfield School District

The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.

Six spike tests were conducted to ensure the integrity of the testing process and all spike test passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Brattain Campus	Room 6	RK108271	2/18/2022	Detector Kit	< 0.6
Brattain Campus	Room 5	RK107844	2/18/2022	Detector Kit	< 0.5
Brattain Campus	Room 5	RK108321	2/18/2022	Duplicate	< 0.6
Brattain Campus	Room 7	RK107939	2/18/2022	Detector Kit	< 0.8
Brattain Campus	Resource Center	RK107882	2/18/2022	Detector Kit	< 0.6
Brattain Campus	Hall of Justice	RK104717	2/18/2022	Detector Kit	< 0.8
Brattain Campus	Room 19	RK107866	2/18/2022	Detector Kit	< 0.6
Brattain Campus	Room 4	RK107947	2/18/2022	Detector Kit	< 0.5
Brattain Campus	Room 20	RK107879	2/18/2022	Detector Kit	< 0.6
Brattain Campus	Room 3	RK107873	2/18/2022	Detector Kit	< 0.5
Brattain Campus	Room 2	RK107395	2/18/2022	Detector Kit	< 0.4
Brattain Campus	Room 2	RK107435	2/18/2022	Duplicate	< 0.5
Brattain Campus	Room 1	RK107938	2/18/2022	Detector Kit	< 0.5
Brattain Campus	Custodian Office	RK107923	2/18/2022	Detector Kit	1.8
Brattain Campus	Cafeteria	RK107865	2/18/2022	Detector Kit	< 0.7
Brattain Campus	Cafeteria	RK107854	2/18/2022	Detector Kit	< 0.6
Brattain Campus	Alternative Education Office	RK107906	2/18/2022	Detector Kit	0.8
Brattain Campus	Stage Office	RK107888	2/18/2022	Detector Kit	1
Brattain Campus	Gym	RK108307	2/18/2022	Detector Kit	< 0.6
Brattain Campus	Gym	RK107904	2/18/2022	Detector Kit	< 0.8
Brattain Campus	Principal Office	RK107887	2/18/2022	Detector Kit	1.6
Brattain Campus	Main Office	RK107878	2/18/2022	Detector Kit	1
Brattain Campus	Health Room	RK107427	2/18/2022	Detector Kit	0.8
Brattain Campus	Staff Room	RK107870	2/18/2022	Detector Kit	1.3
Brattain Campus	Staff Room	RK107890	2/18/2022	Duplicate	0.9
Brattain Campus	Nurse Room	RK107426	2/18/2022	Detector Kit	2.9
Brattain Campus	Room 9	RK107930	2/18/2022	Detector Kit	< 0.5

Brattain Campus	Room 9	RK107442	2/18/2022	Duplicate	0.8
Brattain Campus	Room 10	RK107383	2/18/2022	Detector Kit	0.6
Brattain Campus	Room 11	RK107756	2/18/2022	Detector Kit	0.7
Brattain Campus	Room 12	RK107434	2/18/2022	Detector Kit	< 0.5
Brattain Campus	Room 13	RK107443	2/18/2022	Detector Kit	< 0.5
Brattain Campus	Room 14	RK107757	2/18/2022	Detector Kit	0.4