

Radon Testing Results - Springfield School District

The EPS's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting

Six spike tests were conducted to ensure the integrity of the testing process and all spike test passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Douglas Gardens	Principal Office	RK107877	2/17/2022	Detector Kit	0.8 ± 0.3
Douglas Gardens	Main Office	RK107893	2/17/2022	Detector Kit	0.8 ± 0.4
Douglas Gardens	Faculty Room	RK108285	2/17/2022	Detector Kit	< 0.6
Douglas Gardens	Office Work Room	RK107929	2/17/2022	Detector Kit	0.4 ± 0.3
Douglas Gardens	Library	RK107905	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Library	RK107921	2/17/2022	Duplicate	< 0.4
Douglas Gardens	D Pod Laundry Room	RK108305	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 19	RK108312	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 20	RK107913	2/17/2022	Detector Kit	< 0.5
Douglas Gardens	Room 20	RK107924	2/17/2022	Duplicate	< 0.5
Douglas Gardens	Room 21	RK107931	2/17/2022	Detector Kit	< 0.6
Douglas Gardens	Room 22	RK108311	2/17/2022	Detector Kit	< 0.5
Douglas Gardens	Cafeteria	RK108304	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Kitchen	RK108303	2/17/2022	Detector Kit	< 0.5
Douglas Gardens	Gymnasium	RK107916	2/17/2022	Detector Kit	< 0.5
Douglas Gardens	Gymnasium	RK107943	2/17/2022	Detector Kit	< 0.5
Douglas Gardens	Family Center	RK107861	2/17/2022	Detector Kit	< 0.5
Douglas Gardens	Custodial Office	RK107920	2/17/2022	Detector Kit	< 0.6
Douglas Gardens	Room 17	RK107917	2/17/2022	Detector Kit	< 0.5
Douglas Gardens	F-Pod Center Room	RK107932	2/17/2022	Detector Kit	< 0.5
Douglas Gardens	F-Pod Center Room	RK107344	2/17/2022	Duplicate	< 0.4
Douglas Gardens	Room 16	RK107387	2/17/2022	Detector Kit	< 0.5
Douglas Gardens	Room 15	RK107384	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 14	RK107366	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 13	RK107372	2/17/2022	Detector Kit	< 0.5
Douglas Gardens	Room 18	RK107365	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	E-Pod Center Room	RK107358	2/17/2022	Detector Kit	< 0.4

Douglas Gardens	Room 8	RK107351	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 9	RK107377	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 10	RK107378	2/17/2022	Detector Kit	< 0.3
Douglas Gardens	Room 11	RK107831	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 12	RK107783	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Office/Room 7	RK107775	2/17/2022	Detector Kit	< 0.3
Douglas Gardens	A-Pod Center Room	RK107903	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 1	RK107767	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 2	RK107759	2/17/2022	Detector Kit	< 0.3
Douglas Gardens	Room 3	RK107816	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 4	RK107832	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 5	RK107824	2/17/2022	Detector Kit	< 0.4
Douglas Gardens	Room 6	RK107808	2/17/2022	Detector Kit	< 0.3
Douglas Gardens	Room 6	RK107799	2/17/2022	Duplicate	< 0.4
Douglas Gardens	Music Portable	RK108265	2/17/2022	Detector Kit	< 0.4