

## Radon Testing Results - Springfield School District

The EPS's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting

Six spike tests were conducted to ensure the integrity of the testing process and all spike test passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Thurston Middle School	Main Office	RK108199	2/25/2022	Detector Kit	< 0.4
Thurston Middle School	Principal's Office	RK108166	2/25/2022	Detector Kit	1.6
Thurston Middle School	Mrs. Beattie	RK108193	2/25/2022	Detector Kit	1.2
Thurston Middle School	Student Services Office	RK108233	2/25/2022	Detector Kit	0.6
Thurston Middle School	Student Services	RK108169	2/25/2022	Detector Kit	0.6
Thurston Middle School	Room 2	RK108168	2/25/2022	Detector Kit	0.8
Thurston Middle School	Room 3	RK108181	2/25/2022	Detector Kit	0.9
Thurston Middle School	Room 4	RK108198	2/25/2022	Detector Kit	1.2
Thurston Middle School	Room 5	RK108205	2/25/2022	Detector Kit	<b>4.5</b>
Thurston Middle School	Room 5	RK108172	2/25/2022	Duplicate	3.6
Thurston Middle School	Room 7	RK108178	2/25/2022	Detector Kit	1.4
Thurston Middle School	Room 8	RK108184	2/25/2022	Detector Kit	0.7
Thurston Middle School	Room 8	RK108221	2/25/2022	Duplicate	0.9
Thurston Middle School	Room 9	RK108793	2/25/2022	Detector Kit	< 0.4
Thurston Middle School	Cafetorium 13	RK104644	2/25/2022	Detector Kit	1.5
Thurston Middle School	Cafetorium 13	RK108200	2/25/2022	Detector Kit	DNR
Thurston Middle School	Room 14	RK108821	2/25/2022	Detector Kit	0.6
Thurston Middle School	Room 14	RK108822	2/25/2022	Duplicate	< 0.3
Thurston Middle School	Room 12	RK108794	2/25/2022	Detector Kit	0.4
Thurston Middle School	Room 11	RK108209	2/25/2022	Detector Kit	< 0.3
Thurston Middle School	Room 11	RK108786	2/25/2022	Duplicate	< 0.4
Thurston Middle School	Room 15	RK108789	2/25/2022	Detector Kit	0.4
Thurston Middle School	Room 17	RK108827	2/25/2022	Detector Kit	0.6
Thurston Middle School	Room 17	RK108828	2/25/2022	Duplicate	< 0.4
Thurston Middle School	Room 16	RK104624	2/25/2022	Detector Kit	1.0
Thurston Middle School	Room 19	RK104655	2/25/2022	Detector Kit	1.3
Thurston Middle School	Room 18	RK104715	2/25/2022	Detector Kit	2.1

Thurston Middle School	Room 18	RK104640	2/25/2022	Duplicate	2.5
Thurston Middle School	Library	RK104656	2/25/2022	Detector Kit	1.7
Thurston Middle School	Library	RK104618	2/25/2022	Detector Kit	2.5
Thurston Middle School	Room 21	RK104632	2/25/2022	Detector Kit	DNR
Thurston Middle School	Room 22	RK104627	2/25/2022	Detector Kit	0.8
Thurston Middle School	Room 23	RK104635	2/25/2022	Detector Kit	1.0
Thurston Middle School	Room 24	RK104642	2/25/2022	Detector Kit	1.1
Thurston Middle School	Room 25	RK108163	2/25/2022	Detector Kit	1.7
Thurston Middle School	Main Gym	RK108251	2/25/2022	Detector Kit	1.3
Thurston Middle School	Main Gym	RK108145	2/25/2022	Detector Kit	DNR
Thurston Middle School	Room 26	RK108185	2/25/2022	Detector Kit	1.2
Thurston Middle School	Room 28	RK108228	2/25/2022	Detector Kit	1.4
Thurston Middle School	Room 31	RK108820	2/25/2022	Detector Kit	< 0.4
Thurston Middle School	Room 32	RK108192	2/25/2022	Detector Kit	< 0.4
Thurston Middle School	Room 33	RK108213	2/25/2022	Detector Kit	< 0.5
Thurston Middle School	Room 29	RK104696	2/25/2022	Detector Kit	< 0.5
Thurston Middle School	Room 30	RK108182	2/25/2022	Detector Kit	< 0.3
Thurston Middle School	Industrial Tech 10 Cust. Room	RK104617	2/25/2022	Detector Kit	0.5
Thurston Middle School	Industrial Tech 10 Shop	RK104664	2/25/2022	Detector Kit	0.9