

Radon Testing Results - Springfield School District

The EPS's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting

Six spike tests were conducted to ensure the integrity of the testing process and all spike test passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Thurston High School	Main Office	RK107872	2/23/2022	Detector Kit	< 0.6
Thurston High School	Lisa McDaniel Office	RK107856	2/23/2022	Detector Kit	< 0.7
Thurston High School	Kim Pelster Office	RK107410	2/23/2022	Detector Kit	< 0.5
Thurston High School	S. Office	RK107360	2/23/2022	Detector Kit	< 0.6
Thurston High School	Health Room	RK107362	2/23/2022	Detector Kit	< 0.4
Thurston High School	Conference Room	RK107368	2/23/2022	Detector Kit	< 0.4
Thurston High School	Student Services	RK107864	2/23/2022	Detector Kit	< 0.7
Thurston High School	Jared Taylor Office	RK107852	2/23/2022	Detector Kit	< 0.7
Thurston High School	Room 73	RK107883	2/23/2022	Detector Kit	0.8 ± 0.5
Thurston High School	Family Resource Center	RK107867	2/23/2022	Detector Kit	< 0.6
Thurston High School	Room 71	RK107915	2/23/2022	Detector Kit	2.3 ± 0.5
Thurston High School	Room 70	RK107402	2/23/2022	Detector Kit	1.9 ± 0.4
Thurston High School	Room 76	RK107418	2/23/2022	Detector Kit	3.0 ± 0.4
Thurston High School	Room 75	RK107899	2/23/2022	Detector Kit	2.8 ± 0.4
Thurston High School	Room 74	RK107417	2/23/2022	Detector Kit	2.2 ± 0.3
Thurston High School	"IDF"	RK107436	2/23/2022	Detector Kit	1.0 ± 0.3
Thurston High School	Staff Room	RK108268	2/23/2022	Detector Kit	2.2 ± 0.4
Thurston High School	Room 77	RK107891	2/23/2022	Detector Kit	1.0 ± 0.4
Thurston High School	Room 87	RK107881	2/23/2022	Detector Kit	< 0.6
Thurston High School	Room 86	RK107892	2/23/2022	Detector Kit	2.3 ± 0.4
Thurston High School	Room 85	RK107396	2/23/2022	Detector Kit	0.8 ± 0.3
Thurston High School	Room 84	RK107354	2/23/2022	Detector Kit	< 0.6
Thurston High School	Room 83	RK107350	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 82	RK107369	2/23/2022	Detector Kit	1.4 ± 0.3
Thurston High School	Room 93	RK107355	2/23/2022	Detector Kit	< 0.4
Thurston High School	Room 94	RK108261	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 95	RK107376	2/23/2022	Detector Kit	1.2 ± 0.4

Thurston High School	Room 96	RK107828	2/23/2022	Detector Kit	1.2 ± 0.4
Thurston High School	Room 97	RK108281	2/23/2022	Detector Kit	1.2 ± 0.4
Thurston High School	Room 98	RK107349	2/23/2022	Detector Kit	1.1 ± 0.3
Thurston High School	Room 106	RK107908	2/23/2022	Detector Kit	< 0.8
Thurston High School	Room 105	RK107361	2/23/2022	Detector Kit	0.8 ± 0.3
Thurston High School	Room 104	RK108274	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 103	RK108275	2/23/2022	Detector Kit	< 0.6
Thurston High School	Room 102	RK108273	2/23/2022	Detector Kit	< 0.7
Thurston High School	Room 101	RK108280	2/23/2022	Detector Kit	0.6 ± 0.3
Thurston High School	Room 48	RK107411	2/23/2022	Detector Kit	< 0.7
Thurston High School	Room 49	RK108276	2/23/2022	Detector Kit	< 0.6
Thurston High School	Room 50	RK107937	2/23/2022	Detector Kit	< 0.6
Thurston High School	Room 51	RK107385	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 47	RK107409	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 46	RK107374	2/23/2022	Detector Kit	< 0.6
Thurston High School	Room 45	RK108272	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 44	RK108278	2/23/2022	Detector Kit	< 0.7
Thurston High School	Room 42	RK107373	2/23/2022	Detector Kit	< 0.4
Thurston High School	Room 43	RK107875	2/23/2022	Detector Kit	< 0.6
Thurston High School	College/Career Center	RK107953	2/23/2022	Detector Kit	DNR
Thurston High School	Library Tutor Center	RK108269	2/23/2022	Detector Kit	< 0.5
Thurston High School	Library Main Desk	RK107419	2/23/2022	Detector Kit	< 0.5
Thurston High School	Library Conference Room	RK107370	2/23/2022	Detector Kit	< 0.5
Thurston High School	Library Staff Room	RK107345	2/23/2022	Detector Kit	0.5 ± 0.3
Thurston High School	Amy Sfranieri Office	RK107346	2/23/2022	Detector Kit	0.5 ± 0.3
Thurston High School	No name Office	RK108282	2/23/2022	Detector Kit	< 0.6
Thurston High School	Hennessy Office	RK107356	2/23/2022	Detector Kit	0.6 ± 0.3
Thurston High School	Workroom	RK107364	2/23/2022	Detector Kit	< 0.5
Thurston High School	Tindall Office	RK107357	2/23/2022	Detector Kit	< 0.7
Thurston High School	Counseling Center	RK107425	2/23/2022	Detector Kit	< 0.6
Thurston High School	Counseling Center File Storage	RK107403	2/23/2022	Detector Kit	0.8 ± 0.4
Thurston High School	Room 140	RK107388	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 141	RK107412	2/23/2022	Detector Kit	0.9 ± 0.4
Thurston High School	Room 142	RK107392	2/23/2022	Detector Kit	DNR

Thurston High School	Room 143	RK107835	2/23/2022	Detector Kit	< 0.4
Thurston High School	Room 144	RK107758	2/23/2022	Detector Kit	< 0.4
Thurston High School	Room 145	RK107352	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 146	RK107428	2/23/2022	Detector Kit	1.5 ± 0.4
Thurston High School	Room 133A	RK107836	2/23/2022	Detector Kit	0.6 ± 0.3
Thurston High School	Room 133	RK107420	2/23/2022	Detector Kit	0.7 ± 0.4
Thurston High School	Room 134	RK108277	2/23/2022	Detector Kit	0.9 ± 0.3
Thurston High School	Science Classroom 135	RK107809	2/23/2022	Detector Kit	0.8 ± 0.4
Thurston High School	Room 132	RK107827	2/23/2022	Detector Kit	< 0.6
Thurston High School	Room 131	RK107843	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 130	RK107798	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 120	RK107782	2/23/2022	Detector Kit	< 0.6
Thurston High School	Room 120	RK107751	2/23/2022	Duplicate	< 0.6
Thurston High School	Room 121	RK107793	2/23/2022	Detector Kit	0.7 ± 0.4
Thurston High School	Room 122	RK107776	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 122	RK107791	2/23/2022	Duplicate	< 0.7
Thurston High School	Room 123	RK107842	2/23/2022	Detector Kit	4.2 ± 0.4
Thurston High School	Room 123	RK107826	2/23/2022	Duplicate	4.6 ± 0.4
Thurston High School	Room 124	RK107769	2/23/2022	Detector Kit	0.9 ± 0.4
Thurston High School	Room 125	RK107786	2/23/2022	Detector Kit	0.6 ± 0.4
Thurston High School	Room 125	RK107397	2/23/2022	Duplicate	1.1 ± 0.4
Thurston High School	Room 114	RK107413	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 113	RK107386	2/23/2022	Detector Kit	2.3 ± 0.3
Thurston High School	Room 113	RK107353	2/23/2022	Duplicate	2.2 ± 0.4
Thurston High School	Room 112	RK107804	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 111	RK107819	2/23/2022	Detector Kit	2.5 ± 0.4
Thurston High School	Room 111	RK107812	2/23/2022	Duplicate	1.5 ± 0.3
Thurston High School	Main Gym North Wall	RK107833	2/23/2022	Detector Kit	1.2 ± 0.5
Thurston High School	Main Gym Northeast Corner	RK107848	2/23/2022	Detector Kit	0.8 ± 0.4
Thurston High School	Concession	RK107795	2/23/2022	Detector Kit	3.7 ± 0.4
Thurston High School	Concession	RK108267	2/23/2022	Duplicate	4.1 ± 0.4
Thurston High School	Fitness Room	RK108290	2/23/2022	Detector Kit	< 0.5
Thurston High School	Aux Gym	RK107348	2/23/2022	Detector Kit	0.8 ± 0.3
Thurston High School	Aux Gym	RK107840	2/23/2022	Detector Kit	0.8 ± 0.3

Thurston High School	Aux Gym	RK108286	2/23/2022	Detector Kit	1.0 ± 0.3
Thurston High School	Choir 150	RK107829	2/23/2022	Detector Kit	< 0.6
Thurston High School	Choir 150	RK107760	2/23/2022	Detector Kit	< 0.5
Thurston High School	Music 151	RK107800	2/23/2022	Detector Kit	< 0.4
Thurston High School	Music 151 Practice Room	RK107794	2/23/2022	Detector Kit	< 0.6
Thurston High School	Cafeteria	RK107841	2/23/2022	Detector Kit	< 0.5
Thurston High School	Cafeteria	RK107811	2/23/2022	Detector Kit	< 0.5
Thurston High School	Lounge	RK108332	2/23/2022	Detector Kit	< 0.6
Thurston High School	Student Lounge 171	RK108345	2/23/2022	Detector Kit	< 0.5
Thurston High School	Auditorium Lobby	RK108350	2/23/2022	Detector Kit	< 0.5
Thurston High School	Auditorium South End	RK108334	2/23/2022	Detector Kit	0.9 ± 0.5
Thurston High School	Auditorium North End	RK108351	2/23/2022	Detector Kit	< 0.6
Thurston High School	Stage	RK108328	2/23/2022	Detector Kit	< 0.5
Thurston High School	Green Room	RK108335	2/23/2022	Detector Kit	< 0.6
Thurston High School	Green Room	RK108336	2/23/2022	Duplicate	< 0.5
Thurston High School	Theater Office	RK108342	2/23/2022	Detector Kit	< 0.6
Thurston High School	Drafting 161	RK108343	2/23/2022	Detector Kit	< 0.6
Thurston High School	Drafting 161	RK108320	2/23/2022	Duplicate	< 0.5
Thurston High School	Room 166	RK108339	2/23/2022	Detector Kit	< 0.5
Thurston High School	Woodshop	RK108340	2/23/2022	Detector Kit	0.6 ± 0.4
Thurston High School	Woodshop Classroom 160	RK108150	2/23/2022	Detector Kit	< 0.6
Thurston High School	Woodshop West	RK108344	2/23/2022	Detector Kit	0.7 ± 0.4
Thurston High School	Metalshop Office	RK108149	2/23/2022	Detector Kit	< 0.8
Thurston High School	Metalshop	RK108133	2/23/2022	Detector Kit	0.6 ± 0.4
Thurston High School	Metalshop Classroom	RK108146	2/23/2022	Detector Kit	0.8 ± 0.3
Thurston High School	Metalshop Classroom	RK108134	2/23/2022	Duplicate	0.7 ± 0.4
Thurston High School	Room 164	RK108093	2/23/2022	Detector Kit	< 0.5
Thurston High School	Room 165	RK108094	2/23/2022	Detector Kit	< 0.8
Thurston High School	Room 167	RK108082	2/23/2022	Detector Kit	< 0.7
Thurston High School	Room 167	RK108088	2/23/2022	Detector Kit	1.2 ± 0.5
Thurston High School	Room 168	RK108104	2/23/2022	Detector Kit	0.7 ± 0.4
Thurston High School	Robotics	RK108112	2/23/2022	Detector Kit	0.8 ± 0.4
Thurston High School	Room 169	RK108063	2/23/2022	Detector Kit	< 0.6
Thurston High School	Room 169	RK108075	2/23/2022	Duplicate	0.8 ± 0.4