

# Radon Testing Results - Springfield School District

The EPS's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting

Six spike tests were conducted to ensure the integrity of the testing process and all spike test passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Springfield High School	Room 152	RK108353	2/24/2022	Detector Kit	< 0.4
Springfield High School	Room 157 (Green)	RK108306	2/24/2022	Detector Kit	< 0.4
Springfield High School	Room 151	RK108116	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 150	RK108118	2/24/2022	Detector Kit	< 0.6
Springfield High School	Room 158	RK108136	2/24/2022	Detector Kit	< 0.6
Springfield High School	Room 158 Northwest	RK108143	2/24/2022	Detector Kit	< 0.6
Springfield High School	Room 158 Northwest	RK108120	2/24/2022	Duplicate	< 0.5
Springfield High School	Room 159	RK108313	2/24/2022	Detector Kit	< 0.5
Springfield High School	Library College & Career Center	RK108110	2/24/2022	Detector Kit	< 0.6
Springfield High School	Library	RK108090	2/24/2022	Detector Kit	0.8 ± 0.4
Springfield High School	Library Learning Lab	RK108089	2/24/2022	Detector Kit	< 0.5
Springfield High School	Library 356	RK108130	2/24/2022	Detector Kit	< 0.6
Springfield High School	Library Breakroom	RK108138	2/24/2022	Detector Kit	0.5 ± 0.3
Springfield High School	Library 352	RK108053	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 557	RK108052	2/24/2022	Detector Kit	< 0.6
Springfield High School	Room 551	RK108061	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 550	RK108067	2/24/2022	Detector Kit	0.6 ± 0.3
Springfield High School	Room 550	RK108114	2/24/2022	Duplicate	< 0.5
Springfield High School	Room 511	RK108128	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 507	RK108056	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 508	RK108127	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 506	RK108132	2/24/2022	Detector Kit	0.7 ± 0.4
Springfield High School	Room 503	RK108123	2/24/2022	Detector Kit	< 0.6
Springfield High School	Miller Mart Store	RK108119	2/24/2022	Detector Kit	0.6 ± 0.3
Springfield High School	Room 330	RK108330	2/24/2022	Detector Kit	0.8 ± 0.4
Springfield High School	Room 332	RK108111	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 331	RK108126	2/24/2022	Detector Kit	< 0.5

Springfield High School	ELD Office	RK108139	2/24/2022	Detector Kit	0.7 ± 0.4
Springfield High School	Counseling Lobby	RK108331	2/24/2022	Detector Kit	< 0.4
Springfield High School	Counseling Lobby	RK108322	2/24/2022	Duplicate	< 0.4
Springfield High School	Room 305	RK108327	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 304	RK108122	2/24/2022	Detector Kit	0.7 ± 0.3
Springfield High School	Room 307	RK108085	2/24/2022	Detector Kit	< 0.6
Springfield High School	Room 320	RK108326	2/24/2022	Detector Kit	0.6 ± 0.3
Springfield High School	Room 320	RK108333	2/24/2022	Duplicate	0.5 ± 0.3
Springfield High School	Room 312	RK108109	2/24/2022	Detector Kit	< 0.7
Springfield High School	Room 319	RK108310	2/24/2022	Detector Kit	< 0.7
Springfield High School	Room 313	RK108318	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 315	RK108142	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 364	RK108103	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 363	RK108135	2/24/2022	Detector Kit	< 0.6
Springfield High School	Room 363	RK108323	2/24/2022	Duplicate	< 0.5
Springfield High School	Room 362	RK108106	2/24/2022	Detector Kit	< 0.6
Springfield High School	Dean of Students	RK108059	2/24/2022	Detector Kit	< 0.6
Springfield High School	Room 112	RK108060	2/24/2022	Detector Kit	0.9 ± 0.4
Springfield High School	Office 101	RK108054	2/24/2022	Detector Kit	< 0.6
Springfield High School	Room 103	RK108144	2/24/2022	Detector Kit	0.4 ± 0.3
Springfield High School	Attendance	RK108137	2/24/2022	Detector Kit	< 0.7
Springfield High School	Room 106	RK108083	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 116	RK108124	2/24/2022	Detector Kit	< 0.6
Springfield High School	Room 116	RK108051	2/24/2022	Duplicate	< 0.6
Springfield High School	Commons-East	RK108117	2/24/2022	Detector Kit	< 0.6
Springfield High School	Commons-South	RK108105	2/24/2022	Detector Kit	DNR
Springfield High School	Room 703	RK108102	2/24/2022	Detector Kit	< 0.5
Springfield High School	Kitchen Lounge	RK108086	2/24/2022	Detector Kit	< 0.5
Springfield High School	Kitchen Office 707	RK108095	2/24/2022	Detector Kit	0.6 ± 0.4
Springfield High School	Auditorium Center Balcony	RK108121	2/24/2022	Detector Kit	< 0.5
Springfield High School	Auditorium Northeast Stage	RK108173	2/24/2022	Detector Kit	< 0.5
Springfield High School	Auditorium Northwest Stage	RK108180	2/24/2022	Detector Kit	DNR
Springfield High School	Backstage Area	RK108129	2/24/2022	Detector Kit	DNR
Springfield High School	Custodian Office	RK108079	2/24/2022	Detector Kit	< 0.5

Springfield High School	Office 751	RK108055	2/24/2022	Detector Kit	< 0.5
Springfield High School	Office 755	RK108068	2/24/2022	Detector Kit	< 0.7
Springfield High School	Office 771	RK108157	2/24/2022	Detector Kit	< 0.5
Springfield High School	Choir 773	RK108069	2/24/2022	Detector Kit	< 0.7
Springfield High School	Drama 757	RK108125	2/24/2022	Detector Kit	< 0.5
Springfield High School	Office 776	RK108148	2/24/2022	Detector Kit	< 0.5
Springfield High School	Band 778 South	RK108098	2/24/2022	Detector Kit	< 0.5
Springfield High School	Band 778 North	RK108107	2/24/2022	Detector Kit	< 0.6
Springfield High School	Office 784	RK108188	2/24/2022	Detector Kit	< 0.4
Springfield High School	Office 794	RK108064	2/24/2022	Detector Kit	< 0.5
Springfield High School	Orchestra 786	RK108158	2/24/2022	Detector Kit	< 0.4
Springfield High School	Room 935	RK108232	2/24/2022	Detector Kit	0.6 ± 0.3
Springfield High School	Ceramics 936	RK108346	2/24/2022	Detector Kit	0.5 ± 0.3
Springfield High School	Office 936A	RK108337	2/24/2022	Detector Kit	0.5 ± 0.3
Springfield High School	Office 936A	RK108062	2/24/2022	Duplicate	0.5 ± 0.3
Springfield High School	Room 960	RK108140	2/24/2022	Detector Kit	< 0.5
Springfield High School	Drafting 934	RK108349	2/24/2022	Detector Kit	0.5 ± 0.3
Springfield High School	Room 934A	RK108341	2/24/2022	Detector Kit	0.6 ± 0.3
Springfield High School	Room 940	RK108324	2/24/2022	Detector Kit	0.9 ± 0.4
Springfield High School	Room 940	RK108338	2/24/2022	Duplicate	0.8 ± 0.4
Springfield High School	Room 920	RK108071	2/24/2022	Detector Kit	< 0.4
Springfield High School	Office 921	RK108151	2/24/2022	Detector Kit	< 0.5
Springfield High School	Auto Shop	RK108099	2/24/2022	Detector Kit	< 0.6
Springfield High School	Auto Shop	RK108108	2/24/2022	Detector Kit	< 0.5
Springfield High School	Room 932	RK108226	2/24/2022	Detector Kit	1.8 ± 0.4
Springfield High School	Room 933	RK108194	2/24/2022	Detector Kit	1.2 ± 0.3
Springfield High School	Room 927	RK108078	2/24/2022	Detector Kit	1.4 ± 0.4
Springfield High School	Woodshop	RK108218	2/24/2022	Detector Kit	< 0.6
Springfield High School	Woodshop	RK108219	2/24/2022	Detector Kit	0.6 ± 0.4
Springfield High School	Woodshop	RK108186	2/24/2022	Detector Kit	< 0.4
Springfield High School	824 Concessions	RK108096	2/24/2022	Detector Kit	0.9 ± 0.4
Springfield High School	Main Gym West	RK108097	2/24/2022	Detector Kit	DNR
Springfield High School	Main Gym East	RK108081	2/24/2022	Detector Kit	< 0.5
Springfield High School	Main Gym East	RK108348	2/24/2022	Duplicate	DNR

Springfield High School	East Auxiliary Gym-North	RK108314	2/24/2022	Detector Kit	< 0.7
Springfield High School	East Auxiliary Gym-South	RK108302	2/24/2022	Detector Kit	< 0.4
Springfield High School	West Auxiliary Gym-North	RK108100	2/24/2022	Detector Kit	< 0.5
Springfield High School	West Auxiliary Gym-South	RK108141	2/24/2022	Detector Kit	< 0.6
Springfield High School	P-5	RK108070	2/24/2022	Detector Kit	< 0.6
Springfield High School	P-2	RK108087	2/24/2022	Detector Kit	< 0.7
Springfield High School	P-3	RK108092	2/24/2022	Detector Kit	< 0.5
Springfield High School	P-3	RK108065	2/24/2022	Duplicate	< 0.5
Springfield High School	P-4	RK108115	2/24/2022	Detector Kit	< 0.5
Springfield High School	Teen Center Building-Health	RK108076	2/24/2022	Detector Kit	< 0.6
Springfield High School	Health Center Office	RK108225	2/24/2022	Detector Kit	< 0.5
Springfield High School	Health Center Nurse's Room	RK108113	2/24/2022	Detector Kit	< 0.5
Springfield High School	Health Center Break Room	RK108091	2/24/2022	Detector Kit	< 0.5
Springfield High School	Belinda's Office	RK108084	2/24/2022	Detector Kit	< 0.6
Springfield High School	Nursery	RK108066	2/24/2022	Detector Kit	< 0.6
Springfield High School	Child Development Office	RK108080	2/24/2022	Detector Kit	< 0.6
Springfield High School	Room 951	RK108212	2/24/2022	Detector Kit	< 0.4
Springfield High School	Metals Building-North	RK108077	2/24/2022	Detector Kit	< 0.6
Springfield High School	Metals Building Lockers	RK108214	2/24/2022	Detector Kit	1.0 ± 0.3
Springfield High School	Metals Building South Shop	RK108242	2/24/2022	Detector Kit	0.9 ± 0.3
Springfield High School	Metals Building Classroom	RK108167	2/24/2022	Detector Kit	< 0.5
Springfield High School	Metals Building Computer Lab	RK108058	2/24/2022	Detector Kit	< 0.6
Springfield High School	Metals Shop Teacher Office	RK108074	2/24/2022	Detector Kit	< 0.7