

Radon Testing Results - Springfield School District

The EPS's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting

Six spike tests were conducted to ensure the integrity of the testing process and all spike test passed satisfactorily.

Site Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Ridgeview Elementary	Main Office	RK108771	3/3/2022	Detector Kit	0.8 ± 0.3
Ridgeview Elementary	Workroom	RK108774	3/3/2022	Detector Kit	1.9 ± 0.4
Ridgeview Elementary	Health Room	RK108766	3/3/2022	Detector Kit	1.4 ± 0.3
Ridgeview Elementary	Staff Room	RK108758	3/3/2022	Detector Kit	2.8 ± 0.3
Ridgeview Elementary	Cafeteria	RK108853	3/3/2022	Detector Kit	0.7 ± 0.4
Ridgeview Elementary	Cafeteria	RK108191	3/3/2022	Detector Kit	DNR
Ridgeview Elementary	Cafeteria	RK108217	3/3/2022	Duplicate	1.0 ± 0.3
Ridgeview Elementary	Room 1	RK108237	3/3/2022	Detector Kit	2.2 ± 0.3
Ridgeview Elementary	Room 2	RK108851	3/3/2022	Detector Kit	2.9 ± 0.5
Ridgeview Elementary	Counselor Office	RK108782	3/3/2022	Detector Kit	3.3 ± 0.3
Ridgeview Elementary	Counselor Office	RK108784	3/3/2022	Duplicate	1.6 ± 0.3
Ridgeview Elementary	Room 3	RK108833	3/3/2022	Detector Kit	1.7 ± 0.4
Ridgeview Elementary	Room 4	RK108808	3/3/2022	Detector Kit	2.9 ± 0.4
Ridgeview Elementary	Room 5	RK108841	3/3/2022	Detector Kit	3.3 ± 0.4
Ridgeview Elementary	Room 6	RK108831	3/3/2022	Detector Kit	< 0.4
Ridgeview Elementary	Room 7	RK108856	3/3/2022	Detector Kit	2.6 ± 0.3
Ridgeview Elementary	Room 7	RK108846	3/3/2022	Duplicate	3.2 ± 0.3
Ridgeview Elementary	Room 8	RK108811	3/3/2022	Detector Kit	3.1 ± 0.4
Ridgeview Elementary	Room 9	RK108829	3/3/2022	Detector Kit	4.7 ± 0.5
Ridgeview Elementary	Room 10	RK108847	3/3/2022	Detector Kit	1.7 ± 0.4
Ridgeview Elementary	Room 11	RK108843	3/3/2022	Detector Kit	2.2 ± 0.4
Ridgeview Elementary	Room 12	RK108835	3/3/2022	Detector Kit	6.0 ± 0.5
Ridgeview Elementary	Room 13	RK108839	3/3/2022	Detector Kit	6.0 ± 0.5
Ridgeview Elementary	Room 14	RK108780	3/3/2022	Detector Kit	3.3 ± 0.5
Ridgeview Elementary	Room 15	RK108837	3/3/2022	Detector Kit	2.6 ± 0.6
Ridgeview Elementary	Room 16	RK108832	3/3/2022	Detector Kit	3.5 ± 0.5
Ridgeview Elementary	Room 17	RK108815	3/3/2022	Detector Kit	1.5 ± 0.3

Ridgeview Elementary	Room 18	RK108812	3/3/2022	Detector Kit	2.4 ± 0.4
Ridgeview Elementary	Room 19	RK108222	3/3/2022	Detector Kit	3.8 ± 0.5
Ridgeview Elementary	Room 20	RK108223	3/3/2022	Detector Kit	1.1 ± 0.4
Ridgeview Elementary	Office D	RK108161	3/3/2022	Detector Kit	3.3 ± 0.4
Ridgeview Elementary	Speech A	RK108813	3/3/2022	Detector Kit	4.5 ± 0.4
Ridgeview Elementary	ELD B	RK108818	3/3/2022	Detector Kit	0.7 ± 0.3
Ridgeview Elementary	Office C	RK108817	3/3/2022	Detector Kit	2.4 ± 0.3
Ridgeview Elementary	Room F	RK108768	3/3/2022	Detector Kit	2.3 ± 0.4
Ridgeview Elementary	Library	RK108790	3/3/2022	Detector Kit	1.7 ± 0.3
Ridgeview Elementary	Library	RK108799	3/3/2022	Detector Kit	1.8 ± 0.4
Ridgeview Elementary	Library Office	RK108759	3/3/2022	Detector Kit	1.9 ± 0.4
Ridgeview Elementary	Gym	RK108798	3/3/2022	Detector Kit	< 0.6
Ridgeview Elementary	Gym	RK108800	3/3/2022	Detector Kit	< 0.7
Ridgeview Elementary	Music Room	RK108803	3/3/2022	Detector Kit	0.9 ± 0.4