

Radon test result report for:

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9176769	25	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	0.6 ± 0.4	2019-02-23
9176746	CAFETERIA	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	1.2 ± 0.4	2019-02-23
9176767	21	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	0.9 ± 0.4	2019-02-23
9176772	24	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	1.1 ± 0.4	2019-02-23
9176750	18	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	1.2 ± 0.4	2019-02-23
9176765	19	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	1.0 ± 0.4	2019-02-23
9176770	LIBRARY	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.9 ± 0.4	2019-02-23
9176747	CAFETERIA	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	0.9 ± 0.4	2019-02-23
9176768	LIBRARY	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	1.4 ± 0.4	2019-02-23
9176744	16	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	1.0 ± 0.5	2019-02-23
9176751	17	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	0.8 ± 0.5	2019-02-23
9176756	22	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	0.9 ± 0.4	2019-02-23
9176766	STAFF	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	1.7 ± 0.5	2019-02-23
9176771	20	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	1.2 ± 0.4	2019-02-23
9176742	16 BLANK	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	< 0.3	2019-02-23
9176748	14	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	1.6 ± 0.5	2019-02-23
9176754	23	2019-02-15 @ 8:00 am	2019-02-18 @ 11:00 am	1.3 ± 0.4	2019-02-23

Radon test result report for:
204

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9176774	6	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	0.8 ± 0.4	2019-02-23
9176752	10	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.8 ± 0.5	2019-02-23
9176757	13	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.1 ± 0.5	2019-02-23
9176762	OFFICE	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.7 ± 0.5	2019-02-23
9176777	13	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.2 ± 0.5	2019-02-23
9176743	7	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	< 0.3	2019-02-23
9176755	7	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.2 ± 0.4	2019-02-23
9176760	1	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.7 ± 0.4	2019-02-23
9176775	2	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.5 ± 0.4	2019-02-23
9176753	11	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.6 ± 0.5	2019-02-23
9176758	9	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.1 ± 0.4	2019-02-23
9176763	5	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.2 ± 0.4	2019-02-23
9176773	8	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.2 ± 0.5	2019-02-23
9176778	1	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.0 ± 0.5	2019-02-23
9176761	MUSIC	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	< 0.3	2019-02-23
9176776	3	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	0.9 ± 0.4	2019-02-23
9176759	12	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	1.6 ± 0.5	2019-02-23
9176764	4	2019-02-15 @ 7:00 am	2019-02-18 @ 11:00 am	0.8 ± 0.4	2019-02-23

November 20, 2019

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
205

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9176714	PRINCIPAL	2019-02-15 @ 11:00 am	2019-02-18 @ 11:00 am	32.4 ± 1.9	2019-02-23

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498