

LODI UNIFIED SCHOOL DISTRICT



Heating Ventilation Air Conditioning Installation: #2023-07

ADDENDUM NO. 1

September 22, 2023

Owner: Lodi Unified School District
880 N. Guild Ave.
Lodi, CA 95240

This Addendum has been prepared to clarify, modify, delete, or add to the drawings and/or specifications for the above referenced project, and revisions to items listed here shall supersede description thereof prior to the above stated date. All conditions not specifically referenced here shall remain the same. It is the obligation of the Prime Contractor to make subcontractors aware of any items herein that may affect submitted bids.

Acknowledge receipt of this addendum by inserting its number and date in the bidding documents. Failure to do so may subject bidder to disqualification.

All addenda items refer to the plans and specifications unless specifically noted otherwise.

REQUEST FOR PROPOSAL #2023-07

Cover Page Indicates: Proposals must be received in Technology Services

Please refer to 1.4 Submission and REPLACE with below:

The address for submission of the proposals is:

Lodi Unified School District

Maintenance and Operations

ATTN: Joe Patty

880 N. Guild Ave.

Lodi, CA 95240

QUESTIONS:

1. In the RFP part 3.6 calls for a 2-year warranty and exhibit A note 28 calls for 1 year warranty. Which warranty applies?

PART 3 – Scope of Services

3.6 Warranty

The Two (2) Year Warranty is Correct. Replace Exhibit A, Note 28. WARRANTY/QUALITY: minimum period of one (1) year, with “minimum period of two (2) years.”

2. At walk it was stated adapter curbs provided by the district, however part 2.1 of the RFP stats adapter curb provided by installing contractor. Which applies?

The curbs will be provided by Lennox.

3. We would assume the warranty would be only on material provided and labor as units and adapters are provided by the district. Is this correct?

Only the material you are provided.

4. Is it contractors' responsibility to measure and verify which locations curb adapters are required?

Yes, based on verifying the Lennox adapter curb being provided for that School.

5. Will structural review and upgrades be required by the contractor if new units and curb adapters increase weight by 5 percent?

No-we did the calculations they do not increase the weight.

6. Is contractor responsible for permits and inspections or is district proving IOR?

The district is providing an IOR.

7. Please provide all school schedules and breaks. Is summer school going to be in session while work is to be performed?

This work will need to be performed -Nights, Weekends, Holiday's, Spring Break, Summer Break.

8. In the RFP part 1.9 has insurance requirements and exhibit A note 27 calls for different insurance requirements. Which insurance requirement applies?

Note 27 is the correct insurance requirements.

9. RFP states classroom ductwork needs to be done by the installation contractor. Please provide scope or plans showing ducting needed.

There will be a few cases where the installing contractor will need to run new ducting. We will address this on a case-by-case basis-Noting this would be a Change Order.

10. Need site maps of units to be replaced as well as spreadsheet of all units to be changed out.

Maps attached.

11. Which specific sites currently have Pelican?

Pelican information worksheet attached.

12. Which specific sites will be converted to Pelican before starting the installation of the new equipment?

Information worksheet attached.

13. Which specific sites will require gateways and repeaters, if any?

No Gateways-there will need to be repeaters added to ensure the systems working properly-for Bidding purposes put 15 in the bid. Any additional will be added as a change order.

14. Are new smoke detectors to be provided and installed by contractor or reuse existing?

Re-use existing smoke detectors if possible.

15. Who is responsible for fire/life safety after units are installed?

Installing contractor to test if needed.

16. Are we to assume existing breakers, conduit, and/or wire are adequate for new unit loads?

Yes

17. Are we to assume disconnects to be fused style?

Yes

18. Are we to assume existing gas lines are adequate for new unit loads?

Yes

19. For disconnect and reconnect of gas lines and condensate lines will new traps, sediment traps, flex hoses, and valves be required?

Yes

20. Is pre/post air balance required?

Post-needed to configure the pelican.

21. Is commissioning and training required?

No

22. Are title 24 documents required?

Yes, as needed by ESSER

23. If there are delays on receiving units, will the October 31, 2024 liquidated damages date be extended?

Yes, As needed.

24. Will contractor have to be present for delivery of equipment at the M and O site or responsibility by the district?

No

25. How long can equipment be stored at M and O site?

As needed-

26. Will factory startup be provided on district provided equipment?

No

27. Will you be providing site maps for each school indicating which units to be replaced.

Yes

28. Please clarify which schools need Pelican controls.

Yes

29 Will you be providing the bid form and bid docs for this project? Also, is this project requiring a Bid Bond?


Yes, documents will be addressed in Addendum #2 on Monday, September 22, 2023.

**30 We would like to confirm that the EXHIBIT A included in the RFP packet which refers to (small projects) is the correct agreement for this bid/project.
We would also like to confirm that there is no bid bond required on this bid?**

Yes, bid bond is required.

There will be an Addendum #2 on Monday, September 25, 2023 to address bid documents.













—West Lane



— Ronald E. McNair Way

POINTS

Prepare Unit to be Discovered





	NVR
	Display
	Camera (12)

1st Floor



2nd Floor




	NVR
	Display
	Camera (25)









Site Overview



1670 - Westwood







Parking Lot

Grass Area

	NVR
	Display
	Camera (28)

15 Package Units

4 ton
208 v/c 33RD




Done

4/20/2023

023
Baza 1/10/75 to the Bundara

Document Unit to be Replaced

RF-DI-MOL 41 UNIT






NVR
Display
Camera (21)



Pelican
Don







4 TON
208 10




4 TON
110 208



4 TON
208 30




4 TON
208 30




5 TON
208 10



4 TON
208 10



4 TON
208 10





4 TON
10


2
PRESERVE
UNITS

PERMIT
2022

23
PRESERVE
UNITS









Site Overview

3035 - Plaza Robles

← Thornton Rd →



	NVR
	Display
	Camera (18)




16 parking units

3000 units to be demolished

3000 units to be replaced

ALL units







4000 units





4 rows
200 10



17
primary
units





4 rows
200 30





14
primary
units

Tam O Shanter Dr



Track/Baseball/Football Field





	NVR
	Display
	Camera (22)













3 PARTIALS

Site Overview

3040 - Tokay



Legend	
	Access Control
	Paxton Addition
	AccuGuardian Current



CLAIRMONT						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>	<u>Model #</u>	
Head Start	Bard	208 1 Phase	5	N	replaced 6/2022	
Healthy Start	Bard	208 1 Phase	5	N		
Multi Purpose						
Kitchen						
Lounge	Package Unit	460 volt 3 phase	4	Y	LGAO48H4BS	Lennox
Office2						
Office 3						
Office 4						
Storage						
Work Room						
Lobby						
K1	Package Unit	460 volt 3 phase	5	Y	LGAO6OH4BS	Lennox
K2	Package Unit	460 volt 3 phase	5	Y	LGAO6OH4BS	Lennox
3	Bard	208 3PH	4	N		
4	Bard	208 3PH	4	N		
5	Bard	208 3PH	4	N		
6	Bard	208 3PH	4	N		
7	Bard	208 3PH	4	N		
8	Bard	208 3PH	4	N		
9	Bard	208 3PH				
10	Bard	208 3PH	4	N		
11	Bard	208 1 Phase	4	N		
12	Bard	208 1 Phase	4	N		

13	Bard	208 1 Phase	4	N		
14	Bard	208 1 Phase	4	N		
15	Bard	208 1 Phase	4	N		
16	Bard	208 1 Phase	4	N		
17	Bard	208 1 Phase	4	N		
18	Bard	208 1 Phase	4	N		
19A Conference	Package Unit	460 volt 3 phase	4	Y	LGAO48H4BS	Lennox
19B Lab	Package Unit	460 volt 3 phase	4	Y	LGAO48H4BS	Lennox
Custodial						
20						
21						
22						
23						
24						
25						
26						
27						
L1						
L2						
L3						
L4						
Library						
30	Bard	208 1 Phase	4	N		
31	Bard	208 1 Phase	4	N		
32	Bard	208 1 Phase	4	N		
33A	Bard	208 1 Phase	4	N		

33B	Bard	208 v 1 Phase	4	N		
<u>Summary</u>						
	Package Units	5	Total			
	Vertical package units	21	Total			

CREEKSIDE						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>	<u>Model #</u>	
1	Bard	208 V 3 PHASE	4	N		
2	Bard	208 V 3 PHASE	4	N		
3	Bard	208 V 3 PHASE	4	N		
4	Bard	208 V 3 PHASE	4	N		
5	Bard	208 V 3 PHASE	4	N		
6	Bard	208 V 3 PHASE	4	N		
7	Bard	208 V 3 PHASE	4	N		
8 Lab	Bard	208 V 3 PHASE	4	N		
9	Bard	208 V 3 PHASE	4	N		
10	Bard	208 V 3 PHASE	4	N		
11	Bard	208 V 3 PHASE	4	N		
12	Bard	208 V 3 PHASE	4	N		
13	Bard	208 V 3 PHASE	4	N		
14	Bard	208 V 3 PHASE	4	N		
15	Bard	208 V 3 PHASE	4	N		
16						
17						
Custodial Room						
18						
19						
20						
21						

22						
23						
24						
25						
Work Room						
PE						
Counseling						
Library						
27	Bard	208 V 1 PHASE	4	N		
Head Start	Bard	208 V 1 PHASE	4	N		
28	Bard	208 V 1 PHASE	4	N		
29	Bard	208 V 1 PHASE	4	N		
30	Bard	208 V 1 PHASE	5	N		
31	Package Unit					
32	Package Unit					
Office						
Work Room						
VP						
Principal						
33	Package Unit	480 Volt 3 Phase	4	Y	YHCO48A4RLAIJO2C	Trane
34	Package Unit	480 Volt 3 Phase	4	Y	YHCO48A4RLAIJO2C	Trane
35	Package Unit	480 Volt 3 Phase	4	Y	YHCO48A4RLAIJO2C	Trane
36	Package Unit	480 Volt 3 Phase	4	Y	YHCO48A4RLAIJO2C	Trane
37	Package Unit	480 Volt 3 Phase	4	Y	YHCO48A4RLAIJO2	Trane

38	Package Unit	480 Volt 3 Phase	4	Y	YHCO48A4RLAIJO2	Trane
39	Package Unit	480 Volt 3 Phase	4	Y	YHCO48A4RLAIJO2C	Trane
40	Package Unit	480 Volt 3 Phase	4	Y	YHCO48A4RLAIJO2C	Trane
41	Package Unit	480 Volt 3 Phase	4	Y	YHCO48A4RLAIJO2C	Trane
42	Package Unit	480 Volt 3 Phase	4	Y	YHCO48A4RLAIJO2C	Trane
47	Package Unit	480 Volt 3 Phase	4	Y		Trane
Work room	Package Unit	208 Volt 1 Phase	2	Y	YCPO24F1LBB	Trane
Multi Purpose						
Kitchen						
Counseling Office						
Storage						
Staff Lounge	Package Unit					
<u>Summary</u>						
	Package Units	12	Total			
	Vertical package units	20	Total			

DELTA SIERRA (portables only)						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>		
22	Bard	208 3 ph	4	N		
23	Bard	208 3 ph	4	N		
24	Bard	208 3 ph	4	N		
25	Bard	208 3 ph	4	N		
26	Bard	208 3 ph	4	N		
27	Bard	208 3 ph	4	N		
28	Bard	208 3 ph	4	N	EMS TO REPLACE 6/2023	
29	Bard	208 3 ph	4	N	EMS TO REPLACE 6/2023	
30	Bard	208 3 ph	4	N		
31	Bard	208 1 PH	4	N		
32	Bard	208 1 PH	4	N		
33	Bard	208 1 PH	4	N		
21	Bard	208 1 PH	4	N		
34	Bard	208 1 PH	4	N		
<u>Summary</u>						
	Package Units	0	Total			
	Vertical package units	12	Total			

HERITAGE						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>		
Head Start	Bard	208 1 PHASE	4	N		
K1	Package Unit				New York Unit	
K2	Package Unit	480 Volt 3 Phase	4	Y	Trane	YHC048AHELA1GD/426100637L
3						
4						
5						
6						
7						
8						
A1						
A2						
A3						
1						
2						
3						
4						
Library	Package Unit	480 Volt 3 phase	5	Y	Trane	YHC060A4BMA14/311100391L
Vice Principal						
Principal/Office	Package Unit	208 volt 1 phase	3	Y	York	D3NZ030N5606NXA
Kitchen						
Storage						
Office						
Multi Purpose						
Staff Lounge	Package Unit	208 volt 3 phase	4	Y	York	D3NZ048N090NXA
Storage						

9 Lab						
10						
11						
12						
13						
14						
15						
16						
17						
18						
PE						
Work Room						
P1	Bard	208 1 PHASE	4	N		
P2	Bard	208 1 PHASE	4	N		
P3	Bard	208 1 PHASE	4	N		
Work Room	Bard	208 1 PHASE	5	N		
Office						
Kitchen						
P4	Bard	208 1 PHASE	4	N		
P5	Bard	208 1 PHASE	4	N		
P6	Bard	208 1 PHASE	4	N		
Office Portable	Bard	208 1 PHASE	4	N		
Head Start Portable	Bard	208 1 PHASE	4	N		
<u>Summary</u>						
	Package Units	4	Total			
	Vertical package units	9	Total			

LIVE OAK						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>	<u>Model #</u>	<u>Make</u>
Office	Package unit	208 volt 3 phase	4	N	PHE4B363IA	York
VP						
Principal	Package unit	208 volt 3 phase	3	N	B3HPO42A25A	York
Work Room						
1	Bard	208 v 3 Phase	4	N		
2	Bard	208 v 3 Phase	4	N		
3	Bard	208 v 3 Phase	4	N		
4	Bard	208 v 3 Phase	4	N		
5	Bard	208 v 3 Phase	4	N		
6	Bard	208 v 3 Phase	4	N		
7	Bard	208 v 3 Phase	4	N		
8	Bard	208 v 3 Phase	4	N		
9	Bard	208 v 3 Phase	4	N		
10	Bard	208 v 3 Phase	4	N		
11	Bard	208 v 3 Phase	4	N		
12 Head Start	Bard	208 1 ph	5	N		
13 Head Start	Bard	208 1 ph	4	N		
14						
Custodial Room						
15	Bard	208 1 ph	4	N		
16	Bard	208 1 ph	4	N		
17	Bard	208 1 ph	4	N		
18	Bard	208 1 ph	4	N		
19	Bard	208 1 ph	4	N		
20	Bard	208 1 ph	4	N		

21	Bard	208 1 ph	4	N		
22	Bard	208 1 Ph	4	N		
23	Bard	208 1 ph	4	N		
24	Bard	208 1 ph	4	N		
Staff Lounge						
Kitchen						
Storage						
Multi Purpose						
<u>Summary</u>						
	Package Units	2	Total			
	Vertical package units	23	Total			

Lodi High						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>	<u>Make</u>	<u>Model</u>
S Admin	Package Unit	208 Volt 1 Phase	3	Y	Lennox	GCS16H-311-75-1P
S Admin	Package Unit	208 Volt 1 Phase	3	Y	Lennox	GCS16H-311-75-1P
S Admin	Package Unit	208 Volt 1 Phase	3	Y	Lennox	GCS16H-311-75-1P
Staff Center	Package Unit	208 Volt 1 Phase	3	Y	Lennox	GCS16H-311-75-1P
Staff Center	Package Unit	208 Volt 1 Phase	3	Y	Lennox	GCS16H-311-75-1P
12C	Package Unit	480 Volt 3 Phase	4	Y	Lennox	GCS16H-413-100-1G
				Y	Lennox	
S Gym Coach office J4-54	Package Unit	208 Volt 3 phase	5	Y	Lennox	GCS16-513-125-1Y
S Gym Athletic office J4-5	Package Unit	208 Volt 3 phase	4	Y	Lennox	GCS16-261-50-1P
Library E3-86	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-513-125-1G
Library E2-85	Package Unit	480 Volt 3 phase	4	Y	Lennox	GCS16-413-100-1G
Library E9-88	Package Unit	208 Volt 1 Phase	3	Y	Lennox	GCS16H-311-75-1P
Library E4-87	Package Unit	208 Volt 1 Phase	3	y	Lennox	GCS16H-311-75-1P
51	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-653-75-3G
52	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-653-75-1G
53	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-413-100-1G
54	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-413-100-1G
55	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-413-100-1G
56	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-513-125-1G
50's wing hallway F7-61	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-513-125-1G
60	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-653-75-1G
61	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-653-75-1G
62	Package Unit	208 Volt 1 Phase	2	Y	Lennox	GCS16H-261-50-1P
80	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-653-75-1G
83	Package Unit	208 Volt 1 Phase	2	Y	Lennox	GCS16-261-50-1P
81	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-513-125-1G
82	Package Unit	480 Volt 3 phase	4	Y	York	DIHO48NO6O46BOB

84	Package Unit	480 Volt 3 phase	5	Y	Lennox	GCS16-513-125-1G
70's Hallway	Package Unit	480 Volt 3 phase	4	Y	York	ZFO48NO6N4AAA1A
<u>Summary</u>						
	Package Units	28	Total			
	Vertical package units	0	Total			

McAULIFFE						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>	<u>Model #</u>	<u>Make</u>
Kitchen		Q				
Office	Package Unit	480 volt 3 phase	4	Y	YSC048A4EMA10DOB	Trane
Storage						
Office						
Storage						
Multi-Purpose						
Stage	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
Music						
1st Floor						
103	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
104						
105	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
106	Package Unit	480 volt 3 phase	4	Y	YSC048A4EMA10DOB	Trane
107						
108						
109						
110	Package Unit	480 volt 3 phase	4	Y		Trane
111						
112						
113	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
114						
115	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
116	Package Unit	480 volt 3 phase	4	Y	YSC048A4EMA10DOB	Trane
119						
120						
121	Package Unit	480 volt 3 phase	4	Y	YSC048A4EMA10DOB	Trane
123	Package Unit	480 volt 3 phase	4	Y	YSC048A4EMA10DOB	Trane
145						
126		480 volt 3 phase	4	Y	YSC048A4EMA10DOB	Trane

127						
128	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
129						
130	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
132	Package Unit	480 volt 3 phase	3	Y	YSC036A4EMA04DOB	Trane
133						
140						
141						
142						
143						
145						
146						
147						
148						
149						
150						
153						
154						
155						
156						
157						
158	Package Unit	480 volt 3 phase	4	Y	YSC048A4EMA10DOB	Trane
159						
160						
MDF						
2nd Floor						
203	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
204						
205		480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
206		480 volt 3 phase	4	Y	YSC048A4EMA10DOB	Trane
208		480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane

209						
210	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
211						
212						
213	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
214						
215	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
216	Package Unit	480 volt 3 phase	4	Y	YSC048A4EMA10DOB	Trane
217						
218	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
219						
220						
221	Package Unit	480 volt 3 phase	4	Y	YSC060A4EMA14DOB	Trane
222						
223	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
224	Package Unit	480 volt 3 phase	4	Y	YSC048A4EMA10DOB	Trane
226	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
227						
228	Package Unit	480 volt 3 phase	5	Y	YSC060A4EMA14DOB	Trane
229	Package Unit	480 volt 3 phase	4	Y	YSC048A4EMA10DOB	Trane
231						
234						
237						
238						
239						
240	Package Unit	480 volt 3 phase	3	Y	YSC036A4EMA04DOB	Trane
Library						
Portables						
P1	Bard	208 1 phase	4	N		
P2	Bard	208 1 phase	4	N		
P3	Bard	208 1 phase	4	N		

P4	Bard	208 1 phase	4	N		
P5	Bard	208 1 phase	4	N		
P6	Bard	208 1 phase	4	N		
<u>Summary</u>						
	Package Units	32	Total			
	Vertical package units	6	Total			

McNAIR (portables, culinary arts)							
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>	<u>Model #</u>	<u>Make</u>	
<i>culinary arts</i>							
E101	Package Unit	480 Volt 3 phase	4	y	YHCO48A4ELA1LO2C	Trane	
E102	Package Unit	480 Volt 3 phase	4	y	YHCO48A4ELA1LO2C	Trane	
E103	Package Unit	480 Volt 3 phase	4	y	YHCO48A4ELA1LO2C	Trane	
E104	Package Unit	480 Volt 3 phase	4	y	YHCO48A4ELA1LO2C	Trane	
E105							
<i>portables</i>							
P1	Bard	208 V 1 PH	4	N	PWYO42KAVXA	Wall King	
P2	Bard	208 V 1 PH	4	N	PWYO42KAVXA	Wall King	
P3	Bard	208 V 1 PH	4	N	PWYO42KAVXA	Wall King	
P4	Bard	208 V 1 PH	4	N	WH421LAO8	Wall King	
P5	Bard	208 V 1 PH	4	N	PWYO42KAVXA	Wall King	
P6	Bard	208 V 1 PH	4	N	PWYO42KAVXA	Wall King	
P7	Bard	208 V 1 PH	4	N	PWYO42KAVXA	Wall King	
P8	Bard	208 V 1 PH	4	N	PWYO42KAVXA	Wall King	
P9	Bard	208 V 1 PH	4	N	PWYO42KAVXA	Wall King	
P10	Bard	208 V 1 PH	4	N	Replaced 8/2022	may Need economizer	
<u>Summary</u>							
	Package Units	4	Total				
	Vertical package units	10	Total				

MILLSWOOD						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>	<u>Model</u>	<u>Make</u>
Music Room						
Stage	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA02UH	Trane
Storage						
Kitchen						
Office						
Pe Office	Package Unit	480volt 3 phase	4	Y	YSC048A4EMA12DOB	Trane
Multi Purpose						
1st Floor						
103	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
104						
105	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
106	Package Unit	480volt 3 Phase	4	Y	YSC048A4EMA12DOB	Trane
108	Package Unit	480volt 3 Phase	5	Y	ZF0ADO0DH000CX	Aaon
110	Package Unit	480volt 3 Phase	4	Y	YSC048A4EMA12DOB	
112						
113	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
114	Package Unit	480volt 3 Phase	4	Y		
115	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
116	Package Unit	480volt 3 phase	4		YSC048A4EMA12DOB	Trane
119						
121	Package Unit	480volt 3 Phase	5	Y	YSC048A4EMA12DOB	Trane
123	Package Unit	480volt 3 Phase	4	Y	YSC048A4EMA12DOB	Trane
125						
126	Package Unit	480volt 3 Phase	4	Y	YSC048A4EMA12DOB	Trane
127						
128	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	
129						
130	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
132	Package Unit	480volt 3 Phase	3	Y	YSC036A4EMA10DOB	Trane
145						

146						
147						
148	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
150						
153						
154						
155						
156						
157						
158	Package Unit	480volt 3 Phase	3	Y		
159						
160						
161						
Lobby						
Attendance Office						
2nd Floor						
203	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
204						
205	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
206	Package Unit	480volt 3 Phase	4	Y	YSC048A4EMA12DOB	Trane
208	Package Unit	480volt 3 Phase	5		YSC060A4EMA16DOB	Trane
210	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
212						
213	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
214	Package Unit	480volt 3 Phase	5			
215	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
216	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
217						
218	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
219						
221		480volt 3 Phase	5		YSC060A4EMA16DOB	Trane

222						
223	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
224	Package Unit	480volt 3 Phase	4	Y	YSC048A4EMA12DOB	Trane
226	Package Unit	480volt 3 Phase	5	Y	YSC060A4EMA16DOB	Trane
227	Package Unit	480volt 3 Phase	4	Y	Replaced 3 2023	
228						
229	Package Unit	480volt 3 Phase	4	Y	YSC048A4EMA12DOB	Trane
234						
238						
239						
240	Package Unit	480volt 3 Phase	3	Y	YSC036A4EMA10DOB	Trane
Portables						
301	Bard	208 1Ph	4	N		
302	Bard	208 1Ph	4	N		
303	Bard	208 1Ph	4	N		
<u>Summary</u>						
	Package Units	35	Total			
	Vertical package units	3	Total			

MORADA MIDDLE						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>	<u>Model #</u>	
1	N/A					
2	N/A					
3	N/A					
4	N/A					
5	N/A					
Dark Room	N/A					
6	N/A					
7	N/A					
8	N/A					
9	N/A					
10	N/A					
Work Room	N/A					
11	N/A					
12	N/A					
VP	N/A					
Principal	N/A					
14A	N/A					
14B	N/A					
15 Lobby	N/A					
25	Bard	208 1 PHASE	4	N		
26	Bard	208 1 PHASE	4	N		
27	Bard	208 1 PHASE	4	N		
28	N/A					
29	N/A					
Library	N/A					
30	N/A					

31	N/A					
32	N/A					
33	N/A					
Multipurpose	N/A					
Kitchen	N/A					
Office	N/A					
Stage	N/A					
39	Bard	208 1 PHASE	4	N		
40	Bard	208 1 PHASE	4	N		
41	Bard	208 1 PHASE	4	N		
43	Package Unit	208 volts 3 phase	4	Y	YHCO48A3RLAZO2AI	Trane
44	Package Unit	208 volts 3 phase	4	Y	YSCO48G3RLAO1DAI	Trane
45	Package Unit	208 volts 3 phase	4	Y	YHCO48A3RLAZO2AI	Trane
46	Package Unit	208 volts 3 phase	4	Y	YHCO48A3RLAZO2AI	Trane
47	Package Unit	208 volts 3 phase	4	Y	YHCO48A3RLAZO2AI	Trane
48						
49						
50	Package Unit	208 volts 3 phase	4	Y	YHCO48A3RLAZO2AI	Trane
51	Package Unit	208 volts 3 phase	4	Y	YCDO48A3RLAOZO2AI	Trane
52	Package Unit	208 volts 3 phase	4	Y	YHCO48A3RLAZO2AI	Trane
Teacher work room 50's						
53	Package Unit	208 volts 3 phase	4	Y	48XPN048090511	Carrier
54	Package Unit	208 volts 3 phase	4	Y	48XPN048090511	Carrier
55	Package Unit	208 volts 3 phase	4	Y	48XPN048090511	Carrier
56	Package Unit	208 volts 3 phase	4	Y	48XPN048090511	Carrier
<u>Summary</u>						

	Package Units	12	Total			
	Vertical package units	6	Total			

OAKWOOD						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>	<u>Model #</u>	
K1	Package unit	480 volt 3 phase	4	Y	PGDB048FO751M2XS	McQuay
K2	Package unit	480 volt 3 phase	4	Y	PGDB048FO751M2XS	McQuay
Admin						
Office	Package unit	480 volt 3 phase	4	Y	PGDB048FO751M2XS	McQuay
Office						
Office						
Copy/Work Room	Package unit	480 volt 3 phase	4	Y	PGDBO48FO751M2XS	McQuay
3	Package unit	480 volt 3 phase	4	Y	PGDBO48FO751M2XS	McQuay
4	Package unit	480 volt 3 phase	4	Y	PGDBO48FO751M2XS	McQuay
5	Package unit	480 volt 3 phase	4	Y	PGDBO48FO751M2XS	McQuay
6	Package unit	480 volt 3 phase	4	Y	PGDBO48FO751M2XS	McQuay
7	Package unit	480 volt 3 phase	4	Y	PGDBO48FO751M2XS	McQuay
8	Package unit	480 volt 3 phase	4	Y	PGDBO48FO751M2XS	McQuay
9	Package unit	480 volt 3 phase	4	Y	PGDBO48FO751M2XS	McQuay
10	Package unit	480 volt 3 phase	4	Y	PGDBO48FO751M2XS	McQuay
11	Bard	208 V 3 Phase	4	N		
12	Bard	208 V 3 Phase	4	N		
13	Bard	208 V 3 Phase	4	N		
14	Bard	208 V 3 Phase	4	N		
15	Package unit	480 volt 3 phase	4	Y	PGDBO48FO751N2X	McQuay
Library	Package unit	480 volt 3 phase	5	Y	PGDBO60FO751N2X	McQuay
Custodial Room	Package unit	480 volt 3 phase	3	Y	PGDBO36FO501M2XS	McQuay
Office						
PE						
16	Package unit	480 volt 3 phase	4	Y		McQuay
Stage						

Multipurpose						
Kitchen						
Lounge						
Office						
Storage						
17	Package unit	208 volt 3 phase	4	Y	YHC048A3RLA0Z02AI	Trane
18	Package unit	208 volt 3 phase	4	Y	YHC048A3RLA0Z02AI	Trane
19	Package unit	208 volt 3 phase	4	Y	YHC048A3RLA0Z02AI	Trane
20	Package unit	208 volt 3 phase	4	Y	YHC048A3RLA0Z02AI	Trane
21	Package unit	208 volt 3 phase	4	Y	YHC048A3RLA0Z02AI	Trane
22	Package unit	208 volt 3 phase	4	Y	YHC048A3RLA0Z02AI	Trane
23	Package unit	208 volt 3 phase	4	Y	YHC048A3RLA0Z02AI	Trane
24	Package unit	208 volt 3 phase	4	Y	YHC048A3RLA0Z02AI	Trane
25	Package unit	208 volt 3 phase	4	Y	YHC048A3RLA0Z02AI	Trane
26	Package unit	208 volt 3 phase	4	Y	YHC048A3RLA0Z02AI	Trane
Work Room	Package unit	208 volt 1 phase	2	Y	YCP024FILOAB/232114T2H	Trane
28						
31	Bard	208 1 PH	4	N		
32	Bard	208 1 PH	4	N		
33	Bard	208 1 PH	4	N	Replaced 1/2023	
34	Bard	208 1 PH	4	N		
35	Bard	208 1 PH	4	N		
36	Bard	208 1 PH	4	N	Replaced 1/2023	
37	Bard	208 1 PH	4	N		
39	Bard	208 1 PH	4	N		

40	Bard	208 1 PH	4	N		
41	Bard	208 1 PH	4	N		
42	Bard	208 1 PH	4	N		
43	Bard	208 1 PH	4	N		
Head Start	Bard	208 1 PH	5	N		
<u>Summary</u>						
	Package Units	27	Total			
	Vertical package units	15	Total			

PARKLANE						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>	<u>Make</u>	<u>Model #</u>
K1	Split					
Office	Combo unit			Y		Being Engineered
Office	Combo unit			Y		Being Engineered
Nurse	Combo unit			Y		Being Engineered
Office	Combo unit			Y		Being Engineered
VP	Combo unit			Y		Being Engineered
Principal	Combo unit			Y		Being Engineered
Work Room	Combo unit			Y		Being Engineered
Storage	Combo unit			Y		Being Engineered
K2	Split			Y		
3	Combo unit			Y		Being Engineered
4	Combo unit			Y		Being Engineered
5	Combo unit			Y		Being Engineered
6	Combo unit			Y		Being Engineered
7	Combo unit			Y		Being Engineered
8	Combo unit			Y		Being Engineered
9	Combo unit			Y		Being Engineered
10	Combo unit			Y		Being Engineered
Counseling	Combo unit			Y		Being Engineered
Speech	Combo unit			Y		Being Engineered
Library	Combo unit			Y		Being Engineered
14	Bard	208 V 1 PHASE	4	N		
15	Bard	208 V 1 PHASE	4	N		
16	Bard	208 V 1 PHASE	4	N		
17	Bard	208 V 1 PHASE	4	N		
18	Bard	208 V 1 PHASE	4	N		

19	Bard	208 V 1 PHASE	4	N		
20	Bard	208 V 1 PHASE	4	N		
21	Bard	208 V 1 PHASE	4	N		
22	Bard	208 V 3 PHASE	4	N		
23	Bard	208 V 3 PHASE	4	N		
24	Bard	208 V 3 PHASE	4	N		
25	Package Unit	208 Volt 3 Phase	3	Y	Snyder General	PGDBO36FO75INZX
26	Package Unit	208 Volt 3 Phase	3	Y	Snyder General	PGDBO36FO75INZX
27	Package Unit	208 Volt 3 Phase	3	Y	Snyder General	PGDBO36FO75INZX
28	Package Unit	208 Volt 3 Phase	3	Y	Snyder General	PGDBO36FO75INZX
29	Package Unit	208 Volt 3 Phase	3	Y	Snyder General	PGDBO36FO75INZX
Custodial Room						
30	Package Unit	208 Volt 3 Phase	5	Y	Snyder General	PGDBO48FO75INZX5
Stage						
Staff Lounge	Package Unit	208 Volt 3 Phase	5	Y	Snyder General	PGDBO36FO50INZX
Kitchen						
Storage						
MPR						
32	Bard	208 V 1 PHASE	5	N		
33	Bard	208 V 1 PHASE	4	N		
35	Package Unit	208 Volt 3 Phase	4	Y	Trane	YHCO48A3RLAOZO2AI
36	Package Unit	208 Volt 3 Phase	4	Y	Trane	YHCO48A3RLAOZO2AI
37	Package Unit	208 Volt 3 Phase	4	Y	Trane	YHCO48A3RLAOZO2AI
38	Package Unit	208 Volt 3 Phase	4	Y	Trane	YHCO48A3RLAOZO2AI

39	Package Unit	208 Volt 3 Phase	4	Y	Trane	YHCO48A3RLAOZO2AI
40	Package Unit	208 Volt 3 Phase	4	Y	Trane	YHCO48A3RLAOZO2AI
41	Package Unit	208 Volt 3 Phase	4	Y	Trane	YHCO48A3RLAOZO2AI
42	Package Unit	208 Volt 3 Phase	4	Y	Trane	YHCO48A3RLAOZO2AI
43	Package Unit	208 Volt 3 Phase	4	Y	Trane	YHCO48A3RLAOZO2AI
44	Package Unit	208 Volt 3 Phase	4	Y	Trane	YHCO48A3RLAOZO2AI
Work Room	Package Unit	208 Volt 1 Phase	2	Y	Trane	YCPO24FILOAB
Custodial Room						
45	Bard	208 V 1 PHASE	5	N		
<u>Summary</u>						
	Package Units	18	Total			
	Vertical package units	14	Total			

PLAZA ROBLES						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>		
1	Package unit	208 volt 3 phase	4	Y	Day and Night	580CVP048074/3292G51020
2	Package unit	208 volt 3 phase	4	Y	Day and Night	580CVP048074/3292G51020
3	Package unit	208 volt 3 phase	4	Y	Day and Night	580CVP048074/3292G51020
4	Package unit	208 volt 3 phase	4	Y	Day and Night	580CVP048074/3292G51020
5	Package unit	208 volt 3 phase	4	Y	Day and Night	580CVP048074/3292G51020
6	Package unit	208 volt 3 phase	4	Y	Day and Night	580CVP048074/3292G51020
7	Package unit	208 volt 3 phase	4	Y	Day and Night	580CVP048074/3292G51020
8	Package unit	208 volt 3 phase	4	Y	Day and Night	580CVP048074/3292G51020
9	Package unit	208 volt 3 phase	4	Y	Day and Night	580CVP048074/3292G51020
Custodial Room	N/A					
Snack Bar	N/A					
Mult-Purpose						
10	Package unit	208 volt 3 phase	3	Y	Day and Night	580CPV036074/3292050091
11	Package unit	208 volt 3 phase	4	Y	Carrier	48HCLA04A2A5A0A0A0/3111G20145
Office	N/A					
Office	N/A					
Office	N/A					
Office	N/A					
Office	N/A					
12	Package unit	208 volt 3 phase	4	Y	Day and Night	580CPV048074/3292G51016
13	Package unit	208 volt 3 phase	4	Y	Day and Night	580CPV048074/3292G51022
Nursery	N/A					
Nursery	N/A					
14	Bard	208 V 1 PH	4	N		
15	Bard	208 V 1 PH	4	N		
16	Bard	208 V 1 PH	4	N		
17A	Bard	208 V 1 Phase	4	N		

17B	Bard	208 V 1 PH	4	N		
Office	N/A					
Office	N/A					
Office	N/A					
Laundry	N/A					
Kitchen	N/A					
VP	N/A					
Principal	N/A					
Counselor	N/A					
Meeting Room	N/A					
Office						
Storage	N/A					
Lobby	N/A					
Lounge						
Work Room	N/A					
Custodial Room	N/A					
<u>Summary</u>						
	Package Units	13	Total			
	Vertical package units	6	Total			

REESE (office, MP, Portables)								
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>				
Kindergarten								
VP								
Staff Workroom								
Storage								
Principal								
Office								
Multipurpose	Package Unit	208 V 3 Phase	25 TONN	Y	Carrie Model #	48NODOITATA5A6BOGO		Newer Unit
Kitchen	Package Unit	208 v						Newer Unit
Storage								
portables								
18	Bard	208 V 1 Phase	4	N				
19	Bard	208 V 1 Phase	4	N				
20	Bard	208 V 1 Phase	4	N				
21	Bard	208 V 1 Phase	4	N				
22	Bard	208 V 1 Phase	5	N				
23	Bard	208 V 1 Phase	4	N	Replaced 8/2022			
24	Bard	208 V 1 Phase	4	N	Replaced 10/2022	Needs Economizer		
25	Bard	208 V 1 Phase	4	N				
26	Bard	208 V 1 Phase	4	N				
27	Bard	208 V 1 Phase	4	N				
28	Bard	208 V 1 Phase	4	N				
29	Bard	208 V 1 Phase	4	N				
30	Bard	208 V 1 Phase	4	N				
31	Bard	208 V 1 Phase	4	N				
<u>Summary</u>								
	Package Units	0	Total					
	Vertical package units	12	Total					

SCHOOL READINESS & PRESCHOOL							
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>			
Work Room							
Secretary							
Office	Package Unit	208 Volt 1 Phase	3	Y	PGD36C072E/0009111409	Amana	
Storage							
Kitchen							
School readiness Rm 1	Package Unit	208 Volt 1 Phase	5	Y	PGD60C0902E/0011137374	Amana	2001
School readiness Rm 2	Package Unit	208 Volt 1 Phase	5	Y	PGD60C0902E/0012150206	Amana	2001
Annex Staff lounge	Package Unit	208 Volt 1 Phase	2.5	Y	PGAD30D1K5/L973425368	Heil	
<u>Summary</u>							
	Package Units	4	Total				
	Vertical package units	0	Total				

Tokay High						
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>		
Office						
A/C 2	Package Unit	480 Volt 3 phase		Y	D2EG036N7946A	York
A/C 3	Package Unit	480 Volt 3 phase		Y	D1H060N07946B	York
Library						
A/C L2	Package Unit	480 Volt 3 phase		Y	D1HS060N07946B0B	York
A/C L1	Package Unit	480 Volt 3 phase		Y	D1HS060N07946B0B	York
I.A. Building						
IA -14	Package Unit	480 Volt 3 phase		Y	D2EG36N0446D	York
IA-14	Package Unit	480 Volt 3 phase		Y	D2EG03GN41408	York
IA-1	Package Unit	480 Volt 3 phase		Y	D1EH036A25B	York
IA-13	Package Unit	480 Volt 3 phase		Y	PSB036D1LA	Heil
IA 13	Package Unit	480 Volt 3 phase		Y	PSB036D1LA	Heil
IA 12	Package Unit	480 Volt 3 phase		Y	DIEG0G0N08246B	York
IA 12	Package Unit	480 Volt 3 phase		Y	DIE060N08246B	York
IA 9	Package Unit	480 Volt 3 phase		Y	DIHGOGON07946B0B	York
IA 8	Package Unit	480 Volt 3 phase		Y	D1HGO48N06046RUA	York
IA 7	Package Unit	480 Volt 3 phase		Y	D1HG048N05646A	York
IA 13	Package Unit	480 Volt 3 phase		Y	D1EH4242A46B	York
IA 10	Package Unit	480 Volt 3 phase		Y	DIEHO42A46B	York
IA 10	Package Unit	480 Volt 3 phase		Y	D1NH036N07246C	York
IA 11	Package Unit	208 volt 1 phase		Y	DINH024N05606C	York
IA 49	Package Unit	208 volt 1 phase		Y	DIEH024A06B	York
IA32	Package Unit	208 volt 1 phase		Y	D1EHO24A06B	York
IA 5	Package Unit	480 Volt 3 phase		Y	D1H042N0646A	York
Cafe						
Custodial	Package Unit	208 volt 1 phase		Y	D1NH042NO6506C	York
AC 1M	Package Unit	480 Volt 3 phase		Y	YCDO49C4LABF	Trane

AC 2M	Package Unit	480 Volt 3 phase		Y	YCDO49C4LABF	Trane
AC 3M	Package Unit	480 Volt 3 phase		Y	YCDO49C4LABF	Trane
AC 4M	Package Unit	480 Volt 3 phase		Y	YCDO49C4LABF	Trane
AC 5M	Package Unit	480 Volt 3 phase		Y	YCD037C4LABE	Trane
AC 6M	Package Unit	480 Volt 3 phase		Y	YCDO49C4LABF	Trane
AC 7M	Package Unit	480 Volt 3 phase		Y	YCD061C4LABF	Trane
Staff Lunch rm	Package Unit	480 Volt 3 phase		Y	D1H9060N07946BUA	York
<u>Summary</u>						
	Package Units	30	Total			
	Vertical package units	0	Total			

WESTWOOD							
<u>Location</u>	<u>Model</u>	<u>Voltage</u>	<u>Ton</u>	<u>Gas (Y or N)</u>	<u>Notes</u>	<u>Model #</u>	
K1	Package Unit	480 Volt 3 phase	4		New Unit Lennox		
K2	Package Unit	480 Volt 3 phase	4		New Unit Lennox		
Office							
Storage							
Work Room							
Principal							
Vice Principal							
P1	Bard	208 V 1 phase	4	N			
Headstart	Bard	208 V 1 phase	4	N			
2	Bard	208 V 1 phase	5	N			
3	Bard	208 V 3 Phase	4	N			
4	Bard	208 V 3 Phase	4	N			
5	Bard	208 V 3 Phase	4	N			
6	Bard	208 V 3 Phase	4	N			
7	Bard	208 V 3 Phase	4	N			
8	Bard	208 V 3 Phase	4	N			
9	Bard	208 V 3 Phase	4	N			
10							
10A	Package Unit	480 Volt 3 phase		Y	new unit		
10B	Package Unit	480 Volt 3 phase		Y	new unit		
11	Package Unit	480 Volt 3 phase		Y	new unit		
12	Package Unit	480 Volt 3 phase		Y	new unit		
13	Package Unit	480 Volt 3 phase		Y	new unit		
14	Package Unit	480 Volt 3 phase		Y	new unit		
Custodial Room							
15	Package Unit	480 Volt 3 phase	4	Y		PGDBO48FO75IM2	McQuay
16	Package Unit	480 Volt 3 phase	4	Y		PGDBO48FO75IM2	McQuay
Music	Package Unit	480 Volt 3 phase	4	Y		PGDBO48FO75IM2	McQuay
17	Package Unit	480 Volt 3 phase	4	Y		PGDBO48FO75IM2	McQuay
18	Package Unit	480 Volt 3 phase	3	Y		PGDBO36FO5OIM2	McQuay

19	Package Unit	480 Volt 3 phase	4	Y		PGDBO48FO75IM2	McQuay
20	Package Unit	480 Volt 3 phase	4	Y		PGDBO48FO5OLM1	McQuay
PE							McQuay
21	Package Unit	480 Volt 3 phase	4	Y		PGDBO48FO75IM2	McQuay
22	Package Unit	480 Volt 3 phase	4	Y		PGDBO24GO5OIM1	McQuay
Library	Package Unit	480 Volt 3 phase	4	Y		PGDBO36FO5OIM2	McQuay
Library	Package Unit	480 Volt 3 phase	4	Y		PGDBO48FO75IM2	McQuay
23	Package Unit	480 Volt 3 phase	4	Y		YHCO4BA4RLAIKO2C	Trane
24	Package Unit	480 Volt 3 phase	4	Y		YHCO4BA4RLAIKO2C	Trane
25	Package Unit	480 Volt 3 phase	4	Y		YHCO4BA4RLAIKO2C	Trane
26	Package Unit	480 Volt 3 phase	4	Y		YHCO4BA4RLAIKO2C	Trane
27	Package Unit	480 Volt 3 phase	4	Y		YHCO4BA4RLAIKO2C	Trane
28	Package Unit	480 Volt 3 phase	4	Y		YHCO4BA4RLAIKO2C	Trane
29	Package Unit	480 Volt 3 phase	4	Y		YHCO4BA4RLAIKO2C	Trane
30	Package Unit	480 Volt 3 phase	4	Y		YHCO4BA4RLAIKO2C	Trane
31	Package Unit	480 Volt 3 phase	4	y		YHCO4BA4RLAIKO2C	Trane
32	Package Unit	480 Volt 3 phase	4	Y		YHCO4BA4RLAIKO2C	Trane
47	Package Unit	208 Volt 1 phase	2	Y		YCP024F1LOBB	Trane
Phyc Office/Cust	Package Unit	480 Volt 3 phase	4	Y			
Music	Package Unit	480 Volt 3 phase	4	Y		PGDBO4BFO75IM2	Lennox
Stage							
Storage							
Custodial Room							
Kitchen							
Staff Lounge	Package Unit	480 Volt 3 phase	4	Y		PGDBO48FO75IM2	Lennox
<u>Summary</u>							
	Package Units	25	Total				
	Vertical package units	10	Total				