

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

CLIENT INFORMATION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy NY 12182
Client Rep:	Bob Schongar

Date of Sampling:	4/15/2021	6/16/2021
Samples Taken By:	Tim LeVan	Jack Thomas
Samples Taken By:	Jack Thomas	Ken Retell

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Rensselaer Park Elementary School
BLDG ADDRESS:	70 110th St. Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1972				

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead test Results ug/L from 4/15/2021	Lead test Results ug/L from 6/16/21	Remediation
226	RPES-01-BF-P-226	Faculty men's room	Sink faucet			X	5:35	1.5		
227	RPES-01-DW-P-227	Corridor 153	Water fountain			X	5:36	1.3		
228	RPES-01-BF-P-228	Faculty women's room	Sink faucet			X	5:36	2.1		
229	RPES-01-FS-P-229	107 Faculty room	Sink faucet			X	5:38	1.4		
230	RPES-01-CF-P-230	108	Sink faucet			X	5:39	5.1		
231	RPES-01-DW-P-231	108	Water fountain			X	5:39	3.5		
232	RPES-01-CF-P-232	109	Sink faucet			X	5:41	4.6		
233	RPES-01-DW-P-233	1	Water fountain			X	5:41	7.4		
234	RPES-01-CF-P-234	110	Sink faucet			X	5:43	2.9		
235	RPES-01-DW-P-235	110	Water fountain			X	5:43	2.5		
236	RPES-01-NS1-P-236	112 Nurses office	Sink faucet 1			X	5:45	14.4		
237	RPES-01-NS2-P-237	112 Nurses office	Sink faucet 2			X	5:45	3		
238	RPES-01-NS3-P-238	112 Nurses office	Sink faucet 3			X	5:45	2.1		
239	RPES-01-CF-P-239	116	Sink faucet			X	5:47	3.9		
240	RPES-01-DW-P-240	116	Water fountain			X	5:47	20.3	4.3	
241	RPES-01-CF-P-241	117	Sink faucet			X	5:49	2.2		
242	RPES-01-DW-P-242	117	Water fountain			X	5:49	1.3		
243	RPES-01-CF-P-243	118	Sink faucet			X	5:50	3		
244	RPES-01-DW-P-244	118	Water fountain			X	5:50	4.2		
245	RPES-01-CF-P-245	119	Sink faucet			X	5:52	3.6		
246	RPES-01-DW-P-246	119	Water fountain			X	5:52	2.6		
247	RPES-01-CF-P-247	120	Sink faucet			X	5:53	2.6		
248	RPES-01-DW-P-248	120	Water fountain			X	5:53	2.1		
249	RPES-01-CF-P-249	121	Sink faucet			X	5:55	4.5		
250	RPES-01-DW-P-250	121	Water fountain			X	5:55	1.5		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	PACE Analytical
------	-----------------

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMANTION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy Ny 12182
Client Rep:	Bob Schongar

Date of Sampling:	4/15/2021	6/16/2021
Samples Taken By:	Tim LeVan	Jack Thomas
Samples Taken By:	Jack Thomas	Ken Retell

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Rensselaer Park Elementary School
BLDG ADDRESS:	70 110th St. Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1972				

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead test Results ug/L from 4/15/2021	Lead test Results ug/L from	Remediation
251	RPES-01-CF-P-251	125	Sink faucet			X	5:57	2.7		
252	RPES-01-DW-P-252	125	Water fountain			X	5:57	3.1		
253	RPES-01-DW-P-253	Corridor near 131	Water fountain			X	5:59	4.3		
254	RPES-01-CF-P-254	126	Sink faucet			X	5:59	4.8		
255	RPES-01-DW-P-255	126	Water fountain			X	5:59	6.9		
256	RPES-01-ADA1-P-256	Boys ADA Sink Faucet	Sink Faucet			X	6:01	10.8		
257	RPES-01-ADA2-P-257	Girls ADA Sink Faucet	Sink Faucet			X	6:01	8.5		
258	RPES-01-CF1-P-258	128 Art room	Sink faucet 1			X	6:03	1.7		
259	RPES-01-CF2-P-259	128 Art room	Sink faucet 2			X	6:03	7.2		
260	RPES-01-DW-P-260	Cafeteria	Water Fountain			X	6:05	<1.0		
261	RPES-01-KF1-P-261	Kitchen	Sink faucet 1			X	6:08	3.6		
262	RPES-01-KF2-P-262	Kitchen	Sink faucet 2			X	6:08	1.5		
264	RPES-01-DW-P-264	Corridor by girls locker Room	Water fountain			X	6:11	1		
265	RPES-01-BF-P-265	Girls locker room	Sink faucet			X	6:13	3.7		
266	RPES-01-BF-P-266	Girls gym coach bathroom	Sink faucet			X	6:13	12.1		
267	RPES-01-DW-P-267	Gym girls side	Water fountain			X	6:15	13.9		
268	RPES-01-DW-P-268	Gym boys side	Water fountain			X	6:17	43.2	6.9	
269	RPES-01-BF-P-269	Boys locker room	Sink faucet			X	6:19	4.5		
270	RPES-01-BF-P-270	Boys gym coach bathroom	Sink faucet			X	6:19	1.9		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	PACE Analytical
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMATION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy Ny 12182
Client Rep:	Bob Schongar

Date of Sampling:	4/15/2021	6/16/2021
Samples Taken By:	Tim LeVan	Jack Thomas
Samples Taken By:	Jack Thomas	Ken Retell

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Rensselaer Park Elementary School
BLDG ADDRESS:	70 110th St. Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1972				

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead test Results ug/L from 4/15/2021	Lead test Results ug/L from	Remediation
271	RPES-01-DW-P-271	Corridor by boys locker Room	Water fountain			X	6:20	1.5		
272	RPES-01-BF-P-272	Receiving room bathroom	Sink faucet			X	6:21	8.1		
273	RPES-02-DW-P-273	Corridor next to bathrooms	Water fountain			X	5:38	6		
274	RPES-02-CF-P-274	231	Sink faucet			X	5:40	2.2		
275	RPES-02-DW-P-275	231	Water fountain			X	5:40	3.4		
276	RPES-02-CF-P-276	234	Sink faucet			X	5:42	6.1		
277	RPES-02-DW-P-277	234	Water fountain			X	5:43	6.7		
278	RPES-02-CF-P-278	230	Sink faucet			X	5:44	5.2		
279	RPES-02-DW-P-279	230	Water fountain			X	5:45	43.7	18.5	Turned off for repair
280	RPES-02-CF-P-280	229	Sink faucet			X	5:47	3.5		
281	RPES-02-DW-P-281	229	Water fountain			X	5:47	6.8		
282	RPES-02-DW-P-282	Corridor outside 223	Water fountain			X	5:49	4.8		
283	RPES-02-CF-P-283	223	Sink faucet			X	5:51	10.3		
284	RPES-02-DW-P-284	223	Water fountain			X	5:52	6.4		
285	RPES-02-CF-P-285	228	Sink faucet			X	5:53	3.5		
286	RPES-02-DW-P-286	228	Water fountain			X	5:54	20.7	18.3	Turned off for repair
287	RPES-02-CF-P-287	227	Sink faucet			X	5:55	5.8		
288	RPES-02-DW-P-288	227	Water fountain			X	5:56	5.3		
289	RPES-02-CF-P-289	224	Sink faucet			X	5:57	6		
290	RPES-02-DW-P-290	224	Water fountain			X	5:58	6.6		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO₃@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	PACE Analytical
Contact:	
Comments:	Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name:	Lansingburgh Central School District
Address:	576 Fifth Ave Troy Ny 12182
Client Rep:	Bob Schongar

Date of Sampling:	4/15/2021	6/16/2021
Samples Taken By:	Tim LeVan	Jack Thomas
Samples Taken By:	Jack Thomas	Ken Retell

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Rensselaer Park Elementary School
BLDG ADDRESS:	70 110th St. Troy NY 12182
CONTACT NAME & NUMBERS:	Bob Schongar 518-858-5580

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1972				

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead test Results ug/L from 4/15/2021	Lead test Results ug/L from 6/16/2021	Remediation
291	RPES-02-CF-P-291	226	Sink faucet			X	6:00	8.9		
292	RPES-02-DW-P-292	226	Water fountain			X	6:01	5.5		
293	RPES-02-ADA2-P-293	Girls ADA Faucet	Sink Faucet			X	6:02	3.8		
294	RPES-02-ADA1-P-294	Boys ADA Faucet	Sink Faucet			X	6:03	7.2		
295	RPES-02-BF-P-295	212 women's room	Sink faucet			X	6:05	2.7		
296	RPES-02-BF-P-296	212 men's room	Sink faucet			X	6:06	6.1		
297	RPES-02-CF-P-297	222	Sink faucet			X	6:09	8.3		
298	RPES-02-DW-P-298	222	Water fountain			X	6:09	5.7		
299	RPES-02-CF-P-299	218	Sink faucet			X	6:11	6.9		
300	RPES-02-DW-P-300	218	Water fountain			X	6:11	2.6		
301	RPES-02-CF-P-301	221	Sink faucet			X	6:13	6		
302	RPES-02-DW-P-302	221	Water fountain			X	6:13	25.9	6.9	
303	RPES-02-CF-P-303	220	Sink faucet			X	6:15	15.6	21.1	Turned off for repair
304	RPES-02-DW-P-304	220	Water fountain			X	6:15	29	17.5	Turned off for repair
305	RPES-02-DW-P-305	Corridor outside 219	Water fountain			X	6:17	2.9		
306	RPES-02-DW-P-306	Corridor near center stairwell	Water fountain			X	6:18	46.5	<1.0	
307	RPES-02-CF-P-307	201	Sink faucet			X	6:20	5		
308	RPES-02-DW-P-308	201	Water fountain			X	6:21	2.1		
309	RPES-02-CF-P-309	207	Sink faucet			X	6:22	7.2		
310	RPES-02-DW-P-310	207	Water fountain			X	6:23	9.7		
311	RPES-02-CF-P-311	202	Sink faucet			X	6:24	9.4		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	PACE Analytical
Contact:	
Comments:	Provide Laboratory Data Report (LDR) and Chain of Custody

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
RPES-01-DW-P-240	6/16/2021 06:11	7/1/2021 17:45	70177294001	Lead	4.3	15	ug/L
RPES-01-DW-P-268	6/16/2021 06:40	7/1/2021 17:46	70177294002	Lead	6.9	15	ug/L
RPES-02-DW-P-279	6/16/2021 06:35	7/1/2021 17:49	70177294003	Lead	18.5	15	ug/L
RPES-02-DW-P-286	6/16/2021 06:30	7/1/2021 17:50	70177294004	Lead	18.3	15	ug/L
RPES-02-DW-P-302	6/16/2021 06:26	7/1/2021 17:51	70177294005	Lead	6.9	15	ug/L
RPES-02-CF-P-303	6/16/2021 06:19	7/1/2021 17:52	70177294006	Lead	21.1	15	ug/L
RPES-02-DW-P-304	6/16/2021 06:20	7/1/2021 17:55	70177294007	Lead	17.5	15	ug/L
RPES-02-GS1-P-306	6/16/2021 06:16	7/1/2021 17:55	70177294008	Lead	<1.0	15	ug/L

NYSDOH Action Level for Lead of 15 ppb