

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

CLIENT INFORMANTION

| | |
|-------------|--------------------------------------|
| Name: | Lansingburgh Central School District |
| Address: | 576 Fifth Ave Troy NY 12182 |
| Client Rep: | Bob Schongar |

| | | |
|-------------------------------|-------------|--|
| Date of Sampling: 4/22/21 | 5/25/2021 | |
| Samples Taken By: Tim LeVan | Jack Thomas | |
| Samples Taken By: Jack Thomas | Ken Retell | |

SCHOOL/PROJECT INFORMATION

| | |
|-------------------------|-------------------------------|
| BLDG NO./NAME: | Knickerbacker middle school |
| BLDG ADDRESS: | 320 Seventh Ave Troy NY 12182 |
| CONTACT NAME & NUMBERS: | Bob Schongar 518-858-5580 |

| | | | | |
|---------------|-----------------|-----------------|-----------------|------------------|
| (1) Yr. Built | (2) Yr 1st Add: | (3) Yr 2nd Add: | (4) Yr 1st Mod: | (5) Yr. 2nd Mod: |
| 1935 | | | | |

SAMPLE DATA

| Sample Description ID (ID must match container label) | | | | Outlet Information | | | Lead test Results | Lead test Results | | |
|---|------------------|-------------------------|--------------------|---------------------|-----------------|------------|---------------------------|---------------------|-------------------|-------------------------|
| Lab Sample # | BOCES Sample # | Location | Outlet Description | Outlet Make & Model | Construct. Date | First Draw | Time of Collection (24hr) | ug/L from 4/22/2021 | ug/L from 5/15/21 | Remediation |
| 1 | KMS-BM-BF1-P-01 | Boys locker room | Sink faucet | Chicago | | X | 4:55 | 6.9 | | |
| 2 | KMS-BM-BF2-P-02 | Boys locker room | Sink faucet | Chicago | | X | 4:56 | 8.1 | | |
| 3 | KMS-BM-LF1-P-03 | Laundry Room | Sink Faucet | | | X | 4:57 | 44.9 | | Hot water only, no test |
| 4 | KMS-BM-LF2-P-04 | Laundry room | Sink Faucet | | | X | 4:58 | 6.1 | | |
| 5 | KMS-BM-IM-P-05 | Track office | Ice machine | Manitowoc | | X | 7:56 | 4.8 | | |
| 6 | KMS-BM-BF-P-06 | Track office | Sink Faucet | | | X | 5:01 | 32.8 | <1.0 | |
| 7 | KMS-BM-BF-P-07 | Men's room | Sink Faucet | | | X | 5:02 | 348 | 45.6 | Turned off for repair |
| 8 | KMS-BM- BF1-P-08 | Girls locker room | Sink faucet | | | X | 5:07 | 134 | 8.4 | |
| 9 | KMS-BM-BF2-P-09 | Girls locker room | Sink faucet | Chicago | | X | 5:08 | 6.8 | | |
| 10 | KMS-BM-BF3-P-10 | Girls locker room | Sink faucet | Chicago | | X | 5:08 | 8.2 | | |
| 11 | KMS-BM-BF-P-11 | Women's room | Sink Faucet | | | X | 5:09 | 32.1 | 13.4 | |
| 12 | KMS-BM-SF-P-12 | Maintenance shop | Sink faucet | Delta | | X | 5:11 | 3.0 | | |
| 13 | KMS-BM-FS-P-13 | Faculty room | Sink faucet | | | X | 5:13 | 9.1 | | |
| 14 | KMS-BM-BF-P-14 | Faculty room bathroom | Sink faucet | | | X | 5:17 | 7.3 | | |
| 15 | KMS-BM-COF-P-15 | Custodian office | Sink faucet | | | X | 5:19 | 3.7 | | |
| 16 | KMS-01-DW-P-16 | Corridor outside 112 | Water fountain | Elkay | | X | 5:20 | <1.0 | | |
| 17 | KMS-01-DW-P-17 | GYM south east side | Water fountain | Elkay | | X | 5:25 | 3.6 | | |
| 18 | KMS-01-BF-P-18 | Coaches office bathroom | Sink faucet | | | X | 5:24 | 16.3 | 16.8 | Turned off for repair |
| 19 | KMS-01-BF-P-19 | Nurses office bathroom | Sink faucet | Chicago | | X | 5:27 | 1.5 | | |
| 20 | KMS-01-NF1-P-20 | Nurses office | Sink faucet #1 | | | X | 5:28 | 6.7 | | |
| 21 | KMS-01-NF2-P-21 | Nurses office | Sink faucet #2 | | | X | 5:28 | 6.0 | | |
| 22 | KMS-01-CF-P-22 | Wood shop | Sink faucet | Central | | X | 5:29 | 21.6 | 31.2 | Turned off for repair |
| 23 | KMS-01-CF1-P-23 | Metal shop 113 | Sink Faucet #1 | | | X | 5:32 | 192 | 23.5 | Turned off for repair |
| 24 | KMS-01-CF2-P-24 | Metal shop 113 | Sink faucet #2 | Speakman | | X | 5:33 | 125 | 46.9 | Turned off for repair |

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

| | | | |
|------------------|--------------|-------|-------|
| Relinquished By: | Received By: | Time: | Date: |
| | | | |

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead and (Pb)

| | |
|---|--|
| Lab: PACE Analytical | |
| Contact: | |
| Comments: Provide Laboratory Data Report (LDR) and Chain of Custody | |

CLIENT INFORMATION

| | |
|-------------|--------------------------------------|
| Name: | Lansingburgh Central School District |
| Address: | 576 Fifth Ave Troy Ny 12182 |
| Client Rep: | Bob Schongar |

| | | |
|-------------------|-------------|-------------|
| Date of Sampling: | 4/22/21 | 5/15/2021 |
| Samples Taken By: | Tim LeVan | Jack Thomas |
| Samples Taken By: | Jack Thomas | Ken Retell |

SCHOOL/PROJECT INFORMATION

| | |
|-------------------------|-------------------------------|
| BLDG NO./NAME: | Knickerbacker Middle School |
| BLDG ADDRESS: | 320 Seventh Ave Troy NY 12182 |
| CONTACT NAME & NUMBERS: | Bob Schongar 518-858-5580 |

| | | | | |
|---------------|-----------------|-----------------|-----------------|------------------|
| (1) Yr. Built | (2) Yr 1st Add: | (3) Yr 2nd Add: | (4) Yr 1st Mod: | (5) Yr. 2nd Mod: |
| 1935 | | | | |

SAMPLE DATA

| Sample Description ID (ID must match container label) | | | | Outlet Information | | | | | | |
|---|-----------------|---|--------------------|---------------------|-----------------|------------|---------------------------|---------------------------------------|-------------------------------------|-----------------------|
| Lab Sample # | BOCES Sample # | Location | Outlet Description | Outlet Make & Model | Construct. Date | First Draw | Time of Collection (24hr) | Lead test Results ug/L from 4/22/2021 | Lead test Results ug/L from 5/15/21 | Remediation |
| 25 | KMS-01-HC-P-25 | Court yard | Hose connection | | | X | 5:36 | 33.1 | 15.4 | Turned off for repair |
| 26 | KMS-01-CF-P-26 | Rm 115 | Sink faucet | | 2016 | X | 5:37 | <1.0 | | |
| 27 | KMS-01-DW-P-27 | 1st floor Corridor outside boys room | Water fountain | Elkay | | X | 5:40 | 3.3 | | |
| 28 | KMS-01-DW-P-28 | Corridor outside 112 | Bottle filler | Elkay | | X | 5:39 | <1.0 | | |
| 29 | KMS-01-DW-P-29 | Northwest Stairwell off gym | Water fountain | Halsey Taylor | | X | 5:24 | 4.3 | | |
| 30 | KMS-01-BF1-P-30 | Boys room | Sink faucet #1 | Chicago | | X | 5:41 | 6.6 | | |
| 31 | KMS-01-BF2-P-31 | Boys room | Sink faucet #2 | Chicago | | X | 5:41 | 9.4 | | |
| 32 | KMS-01-BF3-P-32 | Boys room | Sink faucet #3 | Chicago | | X | 5:42 | 6.8 | | |
| 33 | KMS-01-BF-P-33 | Principals bathroom | Sink faucet | | | X | 5:44 | 24.5 | 18.9 | Turned off for repair |
| 34 | KMS-01-DW-P-34 | 1 st floor corridor outside girls room | Water fountain | Elkay | | X | 5:45 | 3.1 | | |
| 35 | KMS-01-BF1-P-35 | 1 ST Floor girls room | Sink faucet #1 | Chicago | | X | 5:46 | 6.6 | | |
| 36 | KMS-01-BF2-P-36 | 1 ST Floor girls room | Sink faucet #2 | Chicago | | X | 5:46 | 10.6 | | |
| 37 | KMS-01-CF-P-37 | Rm 126 | Sink faucet | | 2016 | X | 5:47 | 30.9 | 8.3 | |
| 38 | KMS-01-CF-P-38 | Rm 134, storage Rm | Sink faucet | | | X | 5:49 | 12.3 | | |
| 39A | KMS-02-CF-P-39A | Rm 210 | Back sink | | | X | 7:53 | 2.7 | | |
| 39 | KMS-02-CF-P-39 | Rm 210 | Sink faucet | | | X | 5:56 | 3.2 | | |
| 40 | KMS-02-CF1-P-40 | Rm 211 | Sink faucet #1 | Delta | | X | 5:56 | 1.5 | | |
| 41 | KMS-02-CF2-P-41 | Rm 211 | Sink faucet #2 | Kohler | | X | 5:56 | 1.9 | | |
| 42 | KMS-02-DW-P-42 | 2 nd floor Corridor outside Rm 212 | Water fountain | Elkay | | X | 5:58 | 8.2 | | |
| 43 | KMS-02-DW-P-43 | 2 nd floor corridor outside boys room | Water fountain | Elkay | | X | 5:59 | <1.0 | | |
| 44 | KMS-02-DW-P-44 | 2 nd floor corridor outside boys room | Bottle filler | Elkay | | X | 6:00 | <1.0 | | |
| 45 | KMS-02-BF1-P-45 | 2 ND floor boys room | Sink faucet #1 | Chicago | | X | 6:00 | 15.4 | 11.3 | |
| 46 | KMS-02-BF2-P-46 | 2 ND floor boys room | Sink faucet #2 | Chicago | | X | 6:01 | 14.8 | | |
| 47 | KMS-02-CF2-P-47 | Rm 224C | Sink faucet | | 2016 | X | 6:02 | 2.0 | | |
| 48 | KMS-02-DW-P-48 | 2 ND floor corridor outside girls room | Water fountain | Elkay | | X | 6:03 | 6.7 | | |
| 49 | KMS-02-BF1-P-49 | 2 nd floor girls room | Sink faucet #1 | Chicago | | X | 6:05 | 9.4 | | |
| 50 | KMS-02-BF2-P-50 | 2 nd floor girls room | Sink faucet #2 | Chicago | | X | 6:05 | 12.7 | | |
| 51 | KMS-02-BF3-P-51 | 2 nd floor girls room | Sink faucet #3 | Chicago | | X | 6:06 | 13.6 | | |

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

| | | | |
|------------------|--------------|-------|-------|
| Relinquished By: | Received By: | Time: | Date: |
| | | | |
| | | | |

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

| | |
|-----------|---|
| Lab: | PACE Analytical |
| Contact: | |
| Comments: | Provide Laboratory Data Report (LDR) and Chain of Custody |

CLIENT INFORMATION

| | |
|-------------|--------------------------------------|
| Name: | Lansingburgh Central School District |
| Address: | 576 Fifth Ave Troy Ny 12182 |
| Client Rep: | Bob Schongar |

| | | |
|-------------------|-------------|-------------|
| Date of Sampling: | 4/22/21 | 5/15/2021 |
| Samples Taken By: | Tim LeVan | Jack Thomas |
| Samples Taken By: | Jack Thomas | Ken Retell |

SCHOOL/PROJECT INFORMATION

| | |
|-------------------------|-------------------------------|
| BLDG NO./NAME: | Knickerbacker middle school |
| BLDG ADDRESS: | 320 Seventh Ave Troy NY 12182 |
| CONTACT NAME & NUMBERS: | Bob Schongar 518-858-5580 |

| | | | | |
|---------------|-----------------|-----------------|-----------------|------------------|
| (1) Yr. Built | (2) Yr 1st Add: | (3) Yr 2nd Add: | (4) Yr 1st Mod: | (5) Yr. 2nd Mod: |
| | | | | |

SAMPLE DATA

| Sample Description ID (ID must match container label) | | | | Outlet Information | | | | | | |
|---|-----------------|---|--------------------|---------------------|-----------------|------------|---------------------------|---------------------------------------|-------------------------------------|-----------------------|
| Lab Sample # | BOCES Sample # | Location | Outlet Description | Outlet Make & Model | Construct. Date | First Draw | Time of Collection (24hr) | Lead test Results ug/L from 4/22/2021 | Lead test Results ug/L from 5/15/21 | Remediation |
| 52 | KMS-02-BF-P-52 | Rm 230 bathroom | Sink faucet | | | X | 6:07 | 8.2 | | |
| 53 | KMS-02-BF-P-53 | Rm 236 bathroom | Sink faucet | | | X | 6:08 | 14.8 | | |
| 54 | KMS-03-CF1-P-54 | Rm 334 | Sink faucet | Chicago | | X | 6:12 | 26.2 | 17.7 | Turned off for repair |
| 55 | KMS-03-CF2-P-55 | Rm 332 | Sink faucet | Royal | | X | 6:14 | 167 | 28.2 | Turned off for repair |
| 56 | KMS-03-DW-P-56 | 3 RD floor corridor outside girls room | Water fountain | Elkay | | X | 6:16 | 5.9 | | |
| 57 | KMS-03-BF1-P-57 | 3 rd floor girls room | Sink faucet #1 | Chicago | | X | 6:17 | 20.3 | 15.3 | Turned off for repair |
| 58 | KMS-03-BF2-P-58 | 3 rd floor girls room | Sink faucet #2 | Chicago | | X | 6:17 | 20.5 | 15.6 | Turned off for repair |
| 59 | KMS-03-BF3-P-59 | 3 rd floor girls room | Sink faucet #3 | Chicago | | X | 6:18 | 21.3 | 21.1 | Turned off for repair |
| 60 | KMS-03-DW-P-60 | 3 RD floor corridor outside boys room | Water fountain | Elkay | | X | 6:19 | <1.0 | | |
| 61 | KMS-03-DW-P-61 | 3 RD floor corridor outside boys room | Bottle filler | Elkay | | X | 6:19 | <1.0 | | |
| 62 | KMS-03-BF1-P-62 | 3 RD floor boys room | Sink faucet #1 | Chicago | | X | 6:20 | 11.8 | | |
| 63 | KMS-03-BF2-P-63 | 3 RD floor boys room | Sink faucet #2 | Chicago | | X | 6:20 | 11.9 | | |
| 64 | KMS-03-DW-P-64 | Cafeteria | Water fountain | Halsey Taylor | | X | 6:22 | <1.0 | | |
| 65 | KMS-03-CF-P-65 | Rm 317A | Sink faucet #1 | | | X | 6:21 | 12.0 | | |
| 66 | KMS-03-CF-P-66 | Rm 317A | Sink faucet #2 | | | X | 6:23 | 17.5 | 36.8 | Turned off for repair |
| 67 | KMS-03-CF1-P-67 | Rm 317A | Sink faucet #3 | | | X | 6:23 | 14.0 | | |
| 68 | KMS-03-CF2-P-68 | Rm 317A | Sink faucet #4 | | | X | 6:24 | 22.0 | 197 | Turned off for repair |
| 69 | KMS-03-DW-P-69 | 3 rd floor corridor outside 312 | Water fountain | Elkay | | X | 6:25 | 6.1 | | |
| 70 | KMS-03-CF-P-70 | 311 | Sink faucet | Central | | X | 6:26 | 9.7 | | |
| 71 | KMS-03-BF-P-71 | 311B | Sink faucet | | | X | 6:27 | 13.7 | | |
| 72 | KMS-03-CF-P-72 | 310 | Sink faucet | Standard | | X | 6:27 | 35.4 | 26.9 | Turned off for repair |
| 73 | KMS-03-CF-P-73 | 310 | Sink faucet | Standard | | X | 6:27 | 23.6 | 21 | Turned off for repair |
| 74 | KMS-03-BF-P-74 | 310A | Sink faucet | Standard | | X | Not working No Sample | | | Removed |

Remediation

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

| Relinquished By: | Received By: | Time: | Date: |
|------------------|--------------|-------|-------|
| | | | |
| | | | |

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

| | |
|-----------|---|
| Lab: | PACE Analytical |
| Contact: | |
| Comments: | Provide Laboratory Data Report (LDR) and Chain of Custody |