



Addendum 3

Project: **BID NO. 2304-01 BOULAN PARK AND LARSON MIDDLE SCHOOLS
COOLER REPLACEMENT FOOD SERVICE EQUIPMENT**

Bid Due date: 11:00 AM Local Time, Tuesday, September 26, 2023 (UNCHANGED)

This Addendum is issued as modifications to the RFP previously issued to provide clarifications to the scope of work. This Addendum supersedes the original RFP. This along with the RFP becomes the bid documents.

I. General Information

1. For questions email purchasingoffice@troy.k12.mi.us or through Buildingconnected.com.
2. Invitation to Bid. Page 1. Revise Project Title. "Bid No. 2324-01 Boulan Park & Larson Middle School Cooler Replacement Food Service Equipment".

Questions and Answers.

- Q1. Please confirm if this bid category is responsible for final mechanical, plumbing, and electrical connections.
- A1. This bidder per the drawings is not responsible for the actual final mechanical, plumbing, and electrical connections to the food service equipment but is responsible to have qualified personnel on site while these final connections to confirm proper installation.

END