

MEETING RECORD

hord | coplan | macht

Date:	August 23, 2023
Project:	BVSD Centaurus HS Renovation
Project No:	223089.10
Prepared by:	A.Willson

DISTRIBUTION LIST

Name	Organization	Email
Nick Cady	Engineering Teacher, Centaurus HS	Nicholas.cady@bvsd.org
Catherine Barnes	Engineering Teacher, Centaurus HS	Catherine.barnes@bvsd.org
Ann Root	Teacher, Centaurus HS	Ann.root@bvsd.org
Wren Roberts	Special Education Teacher, Centaurus HS	Wren.roberts@bvsd.org
Katharine Thomas	Special Education Teacher, Centaurus HS	Katharine.thomas@bvsd.org
Daniel Ryan	Principal, Centaurus HS	Daniel.Ryan@bvsd.org
Tom Blahak	Project Manager BVSD	Tom.blahak@bvsd.org
Kris Stoppenhagen	Executive Director Bond Planning and Construction BVSD	Kris.Stoppenhagen@bvsd.org
Adele Willson	Project Principal, HCM	awillson@hcm2.com
Christoph Konradi	Project Architect, HCM	ckonradi@hcm2.com

CTE Program Discussion - Addition

No.	Item
1	HCM reviewed the current layout that was developed based on the comments from the previous meeting.
2	The following comments/suggestions were discussed. <ol style="list-style-type: none">1. The Fabrication Room was discussed. This room will have some equipment that will produce dust. Even with limited equipment, a dust collection system will likely be required.2. The teachers will provide an equipment list to Tom Blahak. The equipment will need to have a UL label. Exterior outlets and a hosebib are desirable. A sink is not needed on this room.3. Add double doors from existing classroom to Fabrication room.4. Add door between classroom and Fabrication room.5. Wall between Fabrication lab and new classroom should have higher STC for acoustical isolation.
3	Modify door location and add window into Mechanical classroom. The Mechanical classroom will need power/data to 32 workstations.
4	Makerspace room need 8 locations for overhead power. No sink is needed. A single door to the exterior is adequate.

Special Education Discussion

No. Item

- 1 The new classroom can be smaller to allow for a Chrome Book storage room to remain. There will be furniture partition areas to break up the room to work with individual student.
- 2 The storage room should be changed to a shared office with carpet. Add a door for access to the Autism classroom.
- 3 Add a door between the ILC classroom and Special Ed room.

Additional Toilet Rooms

No. Item

- 1 Daniel is concerned about the delivery access and location. The current hallway is used for many deliveries. If the delivery location moves inside custodial storage should be moved away from the stair with a new hallway.
- 2 Four individual's toilet rooms would be desirable.
- 3 The lockers in the hallway can be removed to allow for a location for the floor sink and washer/dryer.

Next Steps

No. Item

- 1 Marked up floor plans are attached for reference.
- 2 HCM will make the modifications and send them back to Tom Blahak for distribution.

These meeting notes were prepared by Hord Coplan Macht, Inc for the purpose of recording the information covered during this meeting. Should anyone object to any statement or interpretation contained herein, please inform Hord Coplan Macht, Inc. within seven days or the meeting notes shall stand as written.

Issued by,
Hord Coplan Macht, Inc.