

MEETING RECORD

hord | coplan | macht

Date:	September 7, 2023
Project:	BVSD Centaurus HS Renovation
Project No:	223089.10
Prepared by:	K. Aylesworth

DISTRIBUTION LIST

Name	Organization	Email
Karl Buck	Athletic Director, Centaurus HS	karl.buck@bvsd.org
Terry Gillach	POSA, BVSD	terry.gillach@bvsd.org
Jay Kinsel	Theatrical Director, Centaurus HS	jay.kinsel@bvsd.org
Daniel Ryan	Principal, Centaurus HS	daniel.ryan@bvsd.org
Tom Blahak	Project Manager, BVSD	tom.blahak@bvsd.org
Kris Stoppenhagen	Executive Director Bond Planning and Construction, BVSD	kris.stoppenhagen@bvsd.org
Kara Aylesworth	Project Manager, HCM	kaylesworth@hcm2.com
Christoph Konradi	Project Architect, HCM	ckonradi@hcm2.com
Eric Stoerger	Project Executive, IMEG	Eric.J.Stoerger@imegcorp.com

Auditorium Improvements – SD Review Focus Group

No.	Item
1	<p>The design team described the current scope of the improvements to the Auditorium as indicated on the Schematic Design drawings. That scope included new carpet, paint at the brick in the space, a new projector, a new podium, aisle lighting and improvements for ADA compliance.</p>
2	<p>Jay K. requested that the team share colors with him when they are selected for the Auditorium.</p> <p>All stagecraft occurs on the stage. A solids interceptor will be added to the existing sink that is at the side of the stage.</p>
3	<p>Houselights were replaced with LED lighting. The lights run at 1/3 power because they are too bright at full power. Lights need to be repaired as they blink at full power. Emergency lighting is always on at the stage. Fluorescent bulbs are removed for performances. Tom B. will talk with maintenance about both lighting issues.</p> <p>There are ongoing roof leaks at the Auditorium north and south walls and stage that appear to be at the junction of the sloped standing seam roofs and the precast parapet walls. Leaks appear to be at the wings of the stage. Tom will talk with maintenance to investigate the history of the leaks and locations.</p> <p>The school would like to have new LED performance lighting. They would like to keep the incandescent lights that they have and add LED lighting. They would like to change one twist lock outlet on both ends of each light bar with an Edison connection. None of the lights are motorized. Jay has provided a list of lights that he would like to add to the space. The team will price lights and installation. The dimmer/ lighting controls will need to be replaced along with adding lighting. The school will need to prioritize a list of lighting from most to least desired.</p> <p>The sound system is 40 years old and needs to be replaced. Romeo Lighting and Sound helped with a</p>

list of equipment and a budget for equipment. The sound board will need to be replaced with the sound system. The existing mikes are in good condition. Sound and HDMI connections should be located at the pedestal and front offstage. All speakers and wiring should be replaced as well as the amplifier.

The school has assistive listening devices.

Floor boxes at stage have exposed wiring and should be replaced for safety.

The projector will be placed close to the balcony. The projector should serve the projection screen and Cyc curtain at the back of the stage. The projection screen needs to be replaced. There is a hole in the middle of the screen. The team will replace with a similar size/model.

The main stage curtain and valance were replaced a few years ago. All the curtains behind the main curtain, legs, border bars and the cyclorama are older and should be replaced. Per Tom B. this item will be moved to maintenance.

4

The school would like a shed to store power tools and stagecraft equipment. Because of the number of items that are requested under the Auditorium scope the district will not likely be able to fund a shed.

Next Steps:

5

- The design team is working towards our next milestone for drawings, Design Development. Those documents will be issued on September 15th and our general contractor, Adolfson and Petersen will begin pricing for the scope that was identified today. After pricing is complete, we will meet with this group again to discuss and prioritize scope.

These meeting notes were prepared by Hord Coplan Macht, Inc for the purpose of recording the information covered during this meeting. Should anyone object to any statement or interpretation contained herein, please inform Hord Coplan Macht, Inc. within seven days or the meeting notes shall stand as written.

Issued by,
Hord Coplan Macht, Inc.