


**Addendum No. 1**  
**Date: March 8, 2023**



Project:  
**HVAC Replacement at Valley  
Grande Elementary School &  
Martin Middle School for the  
Dallas County Board of Education  
Selma, Alabama**

**MCKEE PROJECT NO. 22.140**  
**ALABAMA DIVISION OF CONSTRUCTION MANAGEMENT NO. 2022598**

The following changes and/or substitutions to the plans and specifications are hereby made a part of same and are incorporated in full force as part of the contract.

Bidders shall acknowledge receipt of this Addendum in writing on his Proposal Form.

**A1.1 GENERAL MODIFICATIONS:**

- A. Refer to the **Advertisement for Bids**, **Change** as follows:
1. Sealed proposals as described above shall be received by Mr. Anthony Sampson, Superintendent at The Dallas County Schools Office, 429 Lauderdale St., Selma, Alabama 36701, Phone: 334-875-3440, **until 2:00 PM Central Time, on Tuesday, March 28, 2023**, then opened and read aloud.

**A1.2 SPECIFICATION MODIFICATIONS:**

- A. NONE.

**A1.3 DRAWING MODIFICATIONS:**

- A. NONE.

**A1.4 CLARIFICATIONS & RESPONSES:**

- A. See the following responses to RFI questions received from Contractor's:

**Question:** NONE

**Answer:**

- B. See the following clarifications as follows:

1. Contractor's Option: Wall Mounted Dehumidifiers DH-1 to be replaced with Outdoor Wall Mounted Packaged Heat Pumps WPHP-1 thru WPHP-25 selected with Hot Gas Re-Heat Provided in Wall Pack Equipment for Dehumidification.

**END OF ADDENDUM**