

Q. Are the (12) convex mirrors district provided, or contractor provided?

A. Contractor provided.

Q. EDU-2, number 3) States, install filler pieces in each locker room at Fischer MS and Sheppard MS. Please clarify the quantity and location of these filler pieces.

A. Contractor must field verify for quantity and locations. Please note install fillers at locations where any locker meets the wall. Cover any blank space for a finished look.

Q. The attached proposal on page D-6 does not appear to contain additional lockers in it. Can a proposal and/or more information be provided on the remaining lockers that the contractor will be responsible for purchasing?

A. Invoice for additional locker columns attached to the end of this addendum. Please note there are now two proposals to be included by the contractor in its bid (the original scope sheets contain the proposal for additional parts/pieces and attached to this addendum is the proposal for additional locker columns)

Q. Is the expanded metal to be painted?

A. Expanded metal to be ordered in color of Chrome or Black. Lead time and cost will be the determining factor for color selection between Chrome and Black colors.

Q. Re -paint walls to match (approximately 900 sqft surface area. Is this referring to painting over the existing green only?

A. Repaint all walls and ceiling.

Q. Are we responsible for repairing and patching the Island tile?

A. Yes

Q. Is the Sierra estimate all the district requests us to procure, or is there additional?

A. The Sierra estimate (including the estimate attached here), along with procurement of any other materials and parts to successfully complete installation.

Q. ALTERNATE 3: Replacement of plexi glass window at equipment rooms; replace like in-kind. What is the approximate size and number of locations and a picture if you have one.

Hilaria Bauer, Ph.D., Superintendent

Board of Trustees: Minh Pham, President · Corina Herrera-Loera, Vice-President ·
Andrés Quintero, Clerk · Andrea Flores Shelton, Member · Linda Chavez, Member

A. Contractor to field verify. One location in each locker room (total of 2 approximate 10' x 3' openings to have plexi glass window replacement.



SCOPE CHANGES / ADDITIONAL ALTERNATIVES:

All references to Sheppard MS has been deleted/excluded from this project in its entirety.

Change to Base Scope: Repair one (1) locker room bench pedestal with tile to match. See picture below:



Changes to ALTERNATIVE 2: should include painting of all walls and ceilings within the locker rooms.

ALTERNATE 3: Replacement of plexi glass window at equipment rooms; replace like in-kind.

ALTERNATE 4: Final cleaning (power washing) at shower/storage areas and restrooms.

Hilaria Bauer, Ph.D., Superintendent

Board of Trustees: Minh Pham, President · Corina Herrera-Loera, Vice-President ·
Andrés Quintero, Clerk · Andrea Flores Shelton, Member · Linda Chavez, Member

Please submit a signed copy of this addendum with your RFQ/P response.

Company Name: _____

Signature: _____

Hilaria Bauer, Ph.D., Superintendent

Board of Trustees: Minh Pham, President · Corina Herrera-Loera, Vice-President ·
Andrés Quintero, Clerk · Andrea Flores Shelton, Member · Linda Chavez, Member