Lead in School Drinking Water Report

Monroe High School Post-remediation

Date(s) collected: 2023-09-30, 2023-06-07
Date(s) analyzed: 2023-10-13, 2023-06-27

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374230	Main Building	Sink - Multi-Compartment	Kitchen	Largest 3 tier sink across from dish washer	Tap	1
374096	Main Building	Sink - Multi-Compartment	Concession Stand	1 of 1	Tap	<1
374097	Main Building	Sink - Multi-Compartment	Concession Stand	1 of 1	Sprayer	<1
374098	Main Building	Fountain	Weight Room	Closest to maximum occupancy sign	Water Fountain	<1
374099	Main Building	Fountain	Weight Room	Closest to white board	Water Fountain	<1
374231	Main Building	Sink - Multi-Compartment	Kitchen	Largest 3 tier sink across from dishwasher	Tap	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**