

ATTACHMENT B

**Bernard Campbell Middle School
Field Forms**

Lee's Summit DW

Date Purged

7/25

Date Sampled

7/26

School

Bernard ~~High~~ Campbell Middle School

Team

OKK

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
1	1	X			nurses sink	12:24	8:21
2	1	X			work room sink	12:24	8:24
3	1		X		corridor 172 (L) fountain	12:29	8:26
4	1		X		corridor 172 (R) fountain	12:29	8:26
5	1		X		corridor 129 (L) fountain	12:36	8:28
6	1		X		corridor 129 (R) fountain	12:36	8:28
7	1	X			Kitchen prep sink	12:38	8:29
8	1	X			Kitchen prep sink by mixer	12:38	8:30
9	1	X			Kitchen prep sink on wall	12:38	8:32
10	1			X	Kitchen ice machine	12:38	8:33
11	1	X			Kitchen dish sink w/sprayer	12:39	8:34
12	1	X			dish sink (middle)	12:39	8:34
13	1	X			dish sink left	12:39	8:34
14	1			X	Kitchen dishwasher	12:40	8:35
15	1			X	post dishwasher sprayer	12:40	8:35
16	1	X			dish sink (R)	12:40	8:37
17	1	X			dish sink (L)	12:40	8:37
18	1			X	Steam oven	12:42	8:38
19	1			X	batch mixer	12:47	8:38
20	1	X			faculty dining sink	12:53	8:40
21	1		X		commons 184 (L) fountain	12:55	8:41
22	1		X		commons 184 (R) fountain	12:55	8:42
23	1	X			copy room 137 sink	13:00	8:43
24	1		X		hall by copy room fountain	13:00	8:44

Lee's Summit DW

Date Purged

Date Sampled

7/25
7/26

School

Bernard Campbell Middle
CBM

Team

A+K

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
25	1	X			teacher's room 127 sink	13:00	8:44
26	1	X			art studio 125 right sink	13:07	8:46
27	1	X			art studio 125 middle sink	13:07	8:46
28	1	X			art studio 125 left sink	13:07	8:47
29	1	X			art studio 124 single sink on wall	13:07	8:48
30	1	X			art studio 124 left sink	13:07	8:48
31	1	X			art studio 124 right sink	13:07	8:49
32	1	X			art studio 123 right sink	13:07	8:50
33	1	X			art studio 123 middle sink	13:07	8:50
34	1	X			art studio 123 left sink	13:07	8:50
35	1	X			193 band room sink	13:15	8:52
36	1			X	193 band room bubbler	13:15	8:52
37	1	X			191 sink	13:17	8:53
38	1			X	191 bubbler	13:17	8:53
39	1		X		corridor 118/136 cross fountain	13:22	8:55
40	1		X		corridor 115 fountain	13:23	8:56
41	1		X		114 a (left) fountain	13:30	8:58
42	1		X		114 a (right) fountain	13:30	8:59
43	1		X		fountain (i) outside boys locker	13:31	9:00
44	1		X		fountain (r) outside boys locker	13:31	9:00
45	1		X		boys locker room fountain	13:36	9:01
46	1		X		girls locker room fountain	13:38	9:02
47	1		X		fountain by concessions	13:44	9:03
48	1		X		library fountain	13:50	9:05

Lee's Summit DW

Date Purged 7/25
Date Sampled 7/26

School Bernard Campbell Middle School Team AK

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
49	U		X		corridor 245 fountain (1)	13:56	9:10
50	U		X		corridor 245 fountain (1)	13:56	9:10
51	U	X			science prep 234 sink	13:57	9:12
52	U	X			science prep 237 sink	13:57	9:13
53	U	X			231 sink	13:58	9:15
54	U	X			231 sink	13:58	9:15
55	U	X			231 sink	13:58	9:15
56	U	X			231 sink	13:58	9:16
57	U	X			231 sink	13:58	9:16
58	U	X			231 sink	13:58	9:17
59	U	X			231 sink	13:58	9:17
60	U	X			230 sink	13:59	9:20
61	U	X			230 sink	13:59	9:20
62	U	X			230 sink	13:59	9:21
63	U	X			230 sink	13:59	9:21
64	U	X			230 sink	13:59	9:21
65	U	X			230 sink	13:59	9:21
66	U	X			230 sink	13:59	9:21
67	U	X			230 sink	13:59	9:22
68	U	X			230 sink	13:59	9:22
69	U			X	science prep 237 dishwasher	14:00	9:27
70	U	X			229 sink	14:01	9:30
71	U	X			229 sink	14:01	9:30
72	U	X			229 sink	14:01	9:30

Lee's Summit DW

Date Purged 7/25
Date Sampled 7/26

School Bernard Campbell Middle (BCM)
Team ARK

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
73	U	X			229 sink	14:01	9:31
74	U	X			229 sink	14:01	9:31
75	U	X			229 sink	14:01	9:31
76	U	X			229 sink	14:01	9:31
77	U	X			229 sink	14:01	9:32
78	U	X			240 sink	14:10	9:36
79	U	X			240 sink	14:10	9:36
80	U	X			240 sink	14:10	9:36
81	U	X			240 sink	14:10	9:37
82	U	X			240 sink	14:10	9:37
83	U	X			240 sink	14:10	9:37
84	U	X			240 sink	14:10	9:37
85	U	X			240 sink	14:10	9:38
86	U	X			239 sink	14:12	9:41
87	U	X			239 sink	14:12	9:42
88	U	X			239 sink	14:12	9:42
89	U	X			239 sink	14:12	9:42
90	U	X			239 sink	14:12	9:43
91	U	X			239 sink	14:12	9:43
92	U	X			239 sink	14:12	9:43
93	U	X			239 sink	14:12	9:44
94	U	X			238 sink	14:14	9:47
95	U	X			238 sink	14:14	9:48
96	U	X			238 sink	14:14	9:48

Lee's Summit DW

Date Purged 7/25
Date Sampled 7/26

School

Bernard Campbell M2
(BCE)

Team

ARK

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
97	U	X			238 sink	14:14	9:48
98	U	X			238 sink	14:14	9:49
99	U	X			238 sink	14:14	9:49
100	U	X			238 sink	14:14	9:49
101	U	X			236 sink	14:16	9:53
102	U	X			236 sink	14:16	9:53
103	U	X			236 sink	14:16	9:54
104	U	X			236 sink	14:16	9:54
105	U	X			236 sink	14:16	9:54
106	U	X			236 sink	14:16	9:54
107	U	X			236 sink	14:16	9:55
108	U	X			236 sink	14:16	9:55
109	U	X			223 sink	14:09	10:04
110	U	X			223 sink	14:09	10:04
111	U	X			223 sink	14:09	10:05
112	U	X			223 sink	14:09	10:05
113	U	X			223 sink	14:09	10:05
114	U	X			223 sink	14:09	10:06
115	U	X			223 sink	14:09	10:06
116	U	X			223 sink	14:09	10:06
117	U	X			biology prep sink	14:07	10:07
118	U	X			221 sink	14:07	10:08
119	U	X			221 sink	14:07	10:08
120	U	X			221 sink	14:07	10:08

Lee's Summit DW

Date Purged 7/25
Date Sampled 7/26

School

Bernard Campbell Mid
(103 cm)

Team

AK

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
121	U	X			221 sink	14:07	10:09
122	U	X			221 sink	14:07	10:09
123	U	X			221 sink	14:07	10:09
124	U	X			221 sink	14:07	10:09
125	U	X			221 sink	14:07	10:10
126	U	X			live room 220 sink	14:04	10:15
127	U	X		X	live room 220 sink dishwasher	14:04	10:17
128	U	X			217 sink	14:20	10:19
129	U	X			217 sink	14:20	10:19
130	U	X			217 sink	14:20	10:19
131	U	X			217 sink	14:20	10:19
132	U	X			217 sink	14:20	10:20
133	U	X			217 sink	14:20	10:20
134	U	X			217 sink	14:20	10:20
135	U	X			217 sink	14:20	10:20
136	U	X			217 sink	14:20	10:21
137	0	X			concession stand sink	15:09	10:37
138	L	X			food prep 35 sink	15:15	10:34
139	L	X			35 sink	15:15	10:35
140	L	X			35 sink	15:15	10:35
141	L	X			32 35 sink	15:15	10:36
142	L	X			32 35 sink	15:15	10:36
143	L	X			33 sink	15:16	10:37
144	L	X			32 sink	15:15	10:37

Date Purged
Date Sampled

$$\frac{7/25}{7/26}$$

School

Bernard Campbell m.2
(Bcm)

Team

Q.22

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

[illegible]

ATTACHMENT C

Bernard Campbell Middle School Summary Table

Summary Table
Bernard Campbell MS

Sample ID	Date	Analyte	Result	Unit	Reporting Limit
BCMI-S1	7/26/2023	Lead	ND	µg/L	1
BCMI-S2	7/26/2023	Lead	3.6	µg/L	1
BCMI-DF3	7/26/2023	Lead	ND	µg/L	1
BCMI-DF4	7/26/2023	Lead	ND	µg/L	1
BCMI-DF5	7/26/2023	Lead	ND	µg/L	1
BCMI-DF6	7/26/2023	Lead	ND	µg/L	1
BCMI-S7	7/26/2023	Lead	ND	µg/L	1
BCMI-S8	7/26/2023	Lead	6.3	µg/L	1
BCMI-S9	7/26/2023	Lead	ND	µg/L	1
BCMI-O10	7/26/2023	Lead	ND	µg/L	1
BCMI-S11	7/26/2023	Lead	ND	µg/L	1
BCMI-S12	7/26/2023	Lead	ND	µg/L	1
BCMI-S13	7/26/2023	Lead	ND	µg/L	1
BCMI-O14	7/26/2023	Lead	ND	µg/L	1
BCMI-O15	7/26/2023	Lead	23.4	µg/L	1
BCMI-S16	7/26/2023	Lead	1.9	µg/L	1
BCMI-S17	7/26/2023	Lead	3.4	µg/L	1
BCMI-O18	7/26/2023	Lead	5.4	µg/L	1
BCMI-O19	7/26/2023	Lead	ND	µg/L	1
BCMI-S20	7/26/2023	Lead	ND	µg/L	1
BCMI-DF21	7/26/2023	Lead	ND	µg/L	1
BCMI-DF22	7/26/2023	Lead	ND	µg/L	1
BCMI-S23	7/26/2023	Lead	ND	µg/L	1
BCMI-DF24	7/26/2023	Lead	ND	µg/L	1
BCMI-S25	7/26/2023	Lead	2.9	µg/L	1
BCMI-S26	7/26/2023	Lead	1.5	µg/L	1
BCMI-S27	7/26/2023	Lead	ND	µg/L	1
BCMI-S28	7/26/2023	Lead	ND	µg/L	1
BCMI-S29	7/26/2023	Lead	ND	µg/L	1
BCMI-S30	7/26/2023	Lead	1.6	µg/L	1
BCMI-S31	7/26/2023	Lead	ND	µg/L	1
BCMI-S32	7/26/2023	Lead	2.4	µg/L	1
BCMI-S33	7/26/2023	Lead	2.9	µg/L	1
BCMI-S34	7/26/2023	Lead	2.0	µg/L	1
BCMI-S35	7/26/2023	Lead	ND	µg/L	1
BCMI-O36	7/26/2023	Lead	ND	µg/L	1
BCMI-S37	7/26/2023	Lead	1.3	µg/L	1
BCMI-O38	7/26/2023	Lead	ND	µg/L	1
BCMI-DF39	7/26/2023	Lead	ND	µg/L	1
BCMI-DF40	7/26/2023	Lead	ND	µg/L	1
BCMI-DF41	7/26/2023	Lead	ND	µg/L	1
BCMI-DF42	7/26/2023	Lead	ND	µg/L	1
BCMI-DF43	7/26/2023	Lead	ND	µg/L	1

BCMI-DF44	7/26/2023	Lead	ND	µg/L	1
BCMI-DF45	7/26/2023	Lead	ND	µg/L	1
BCMI-DF46	7/26/2023	Lead	ND	µg/L	1
BCMI-DF47	7/26/2023	Lead	ND	µg/L	1
BCMI-DF48	7/26/2023	Lead	ND	µg/L	1
BCMU-DF49	7/26/2023	Lead	ND	µg/L	1
BCMU-DF50	7/26/2023	Lead	ND	µg/L	1
BCMU-S51	7/26/2023	Lead	3.3	µg/L	1
BCMU-S52	7/26/2023	Lead	2.7	µg/L	1
BCMU-S53	7/26/2023	Lead	10.6	µg/L	1
BCMU-S54	7/26/2023	Lead	10.8	µg/L	1
BCMU-S55	7/26/2023	Lead	ND	µg/L	1
BCMU-S56	7/26/2023	Lead	ND	µg/L	1
BCMU-S57	7/26/2023	Lead	8.9	µg/L	1
BCMU-S58	7/26/2023	Lead	6.5	µg/L	1
BCMU-S59	7/26/2023	Lead	9.5	µg/L	1
BCMU-S60	7/26/2023	Lead	12.5	µg/L	1
BCMU-S61	7/26/2023	Lead	8.9	µg/L	1
BCMU-S62	7/26/2023	Lead	ND	µg/L	1
BCMU-S63	7/26/2023	Lead	8.9	µg/L	1
BCMU-S64	7/26/2023	Lead	7.6	µg/L	1
BCMU-S65	7/26/2023	Lead	8.2	µg/L	1
BCMU-S66	7/26/2023	Lead	ND	µg/L	1
BCMU-S67	7/26/2023	Lead	ND	µg/L	1
BCMU-S68	7/26/2023	Lead	2.4	µg/L	1
BCMU-O69	7/26/2023	Lead	123	µg/L	1
BCMU-S70	7/26/2023	Lead	ND	µg/L	1
BCMU-S71	7/26/2023	Lead	ND	µg/L	1
BCMU-S72	7/26/2023	Lead	1.3	µg/L	1
BCMU-S73	7/26/2023	Lead	1.3	µg/L	1
BCMU-S74	7/26/2023	Lead	1.3	µg/L	1
BCMU-S75	7/26/2023	Lead	ND	µg/L	1
BCMU-S76	7/26/2023	Lead	8.6	µg/L	1
BCMU-S77	7/26/2023	Lead	ND	µg/L	1
BCMU-S78	7/26/2023	Lead	ND	µg/L	1
BCMU-S79	7/26/2023	Lead	1.6	µg/L	1
BCMU-S80	7/26/2023	Lead	ND	µg/L	1
BCMU-S81	7/26/2023	Lead	12.8	µg/L	1
BCMU-S82	7/26/2023	Lead	10.7	µg/L	1
BCMU-S83	7/26/2023	Lead	2.1	µg/L	1
BCMU-S84	7/26/2023	Lead	ND	µg/L	1
BCMU-S85	7/26/2023	Lead	1.3	µg/L	1
BCMU-S86	7/26/2023	Lead	2.6	µg/L	1
BCMU-S87	7/26/2023	Lead	11.4	µg/L	1
BCMU-S88	7/26/2023	Lead	ND	µg/L	1
BCMU-S89	7/26/2023	Lead	2.3	µg/L	1
BCMU-S90	7/26/2023	Lead	1.4	µg/L	1
BCMU-S91	7/26/2023	Lead	11.8	µg/L	1

BCMU-S92	7/26/2023	Lead	6.1	µg/L	1
BCMU-S93	7/26/2023	Lead	11.6	µg/L	1
BCMU-S94	7/26/2023	Lead	10.6	µg/L	1
BCMU-S95	7/26/2023	Lead	11.6	µg/L	1
BCMU-S96	7/26/2023	Lead	8.2	µg/L	1
BCMU-S97	7/26/2023	Lead	ND	µg/L	1
BCMU-S98	7/26/2023	Lead	10.8	µg/L	1
BCMU-S99	7/26/2023	Lead	17.0	µg/L	1
BCMU-S100	7/26/2023	Lead	29.5	µg/L	1
BCMU-S101	7/26/2023	Lead	1.4	µg/L	1
BCMU-S102	7/26/2023	Lead	2.2	µg/L	1
BCMU-S103	7/26/2023	Lead	10.9	µg/L	1
BCMU-S104	7/26/2023	Lead	20.1	µg/L	1
BCMU-S105	7/26/2023	Lead	12.8	µg/L	1
BCMU-S106	7/26/2023	Lead	7.7	µg/L	1
BCMU-S107	7/26/2023	Lead	1.8	µg/L	1
BCMU-S108	7/26/2023	Lead	2.6	µg/L	1
BCMU-S109	7/26/2023	Lead	2.1	µg/L	1
BCMU-S110	7/26/2023	Lead	2.1	µg/L	1
BCMU-S111	7/26/2023	Lead	14.7	µg/L	1
BCMU-S112	7/26/2023	Lead	12.1	µg/L	1
BCMU-S113	7/26/2023	Lead	9.4	µg/L	1
BCMU-S114	7/26/2023	Lead	11.8	µg/L	1
BCMU-S115	7/26/2023	Lead	1.5	µg/L	1
BCMU-S116	7/26/2023	Lead	51.7	µg/L	1
BCMU-S117	7/26/2023	Lead	6.0	µg/L	1
BCMU-S118	7/26/2023	Lead	10.5	µg/L	1
BCMU-S119	7/26/2023	Lead	ND	µg/L	1
BCMU-S120	7/26/2023	Lead	10.3	µg/L	1
BCMU-S121	7/26/2023	Lead	10.4	µg/L	1
BCMU-S122	7/26/2023	Lead	ND	µg/L	1
BCMU-S123	7/26/2023	Lead	ND	µg/L	1
BCMU-S124	7/26/2023	Lead	ND	µg/L	1
BCMU-S125	7/26/2023	Lead	6.9	µg/L	1
BCMU-S126	7/26/2023	Lead	1.0	µg/L	1
BCMU-O127	7/26/2023	Lead	ND	µg/L	1
BCMU-S128	7/26/2023	Lead	31.9	µg/L	1
BCMU-S129	7/26/2023	Lead	18.7	µg/L	1
BCMU-S130	7/26/2023	Lead	17.1	µg/L	1
BCMU-S131	7/26/2023	Lead	11.2	µg/L	1
BCMU-S132	7/26/2023	Lead	11.1	µg/L	1
BCMU-S133	7/26/2023	Lead	2.4	µg/L	1
BCMU-S134	7/26/2023	Lead	ND	µg/L	1
BCMU-S135	7/26/2023	Lead	10.7	µg/L	1
BCMU-S136	7/26/2023	Lead	21.4	µg/L	1
BCMO-S137	7/26/2023	Lead	2.5	µg/L	1
BCML-S138	7/26/2023	Lead	1.4	µg/L	1
BCML-S139	7/26/2023	Lead	1.9	µg/L	1

BCML-S140	7/26/2023	Lead	1.3	µg/L	1
BCML-S141	7/26/2023	Lead	ND	µg/L	1
BCML-S142	7/26/2023	Lead	1.3	µg/L	1
BCML-S143	7/26/2023	Lead	1.7	µg/L	1
BCML-S144	7/26/2023	Lead	ND	µg/L	1
BCML-S145	7/26/2023	Lead	1.1	µg/L	1
BCML-S146	7/26/2023	Lead	2.4	µg/L	1
BCML-S147	7/26/2023	Lead	7.2	µg/L	1
BCML-DF148	7/26/2023	Lead	5.7	µg/L	1
BCML-S149	7/26/2023	Lead	ND	µg/L	1
BCML-DF150	7/26/2023	Lead	ND	µg/L	1
BCML-DF151	7/26/2023	Lead	ND	µg/L	1

µg/L: micrograms per liter

Bolded results indicate detections above reporting limit

ATTACHMENT D

Bernard Campbell Middle School Laboratory Analytical Report

September 14, 2023

Lindsay E. James
Blackstone Environmental, Inc.
16200 Foster Street
Overland Park, KS 66085
TEL: (913) 956-4160
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: Lees Summit School Dist DW/Bernard Campbell
Middle

WorkOrder: 23071993

Dear Lindsay E. James:

TEKLAB, INC received 151 samples on 7/28/2023 11:30:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley
Project Manager
(618)344-1004 ex 44
patrickriley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	158
Chain of Custody	Appended

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCS D Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Cooler Receipt Temp: NA °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: Blackstone Environmental, Inc.**Work Order:** 23071993**Client Project:** Lees Summit School Dist DW/Bernard Campbell Middle**Report Date:** 14-Sep-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2023	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-001

Client Sample ID: BCMI-S1

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:21

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/05/2023 22:53	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-002

Client Sample ID: BCMI-S2

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.6	µg/L	1	09/05/2023 22:57	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-003

Client Sample ID: BCMI-DF3

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/05/2023 23:12	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-004

Client Sample ID: BCMI-DF4

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/05/2023 23:15	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-005

Client Sample ID: BCMI-DF5

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/05/2023 23:26	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-006

Client Sample ID: BCMI-DF6

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/05/2023 23:30	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-007

Client Sample ID: BCMI-S7

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/05/2023 23:34	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-008

Client Sample ID: BCMI-S8

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.3	µg/L	5	09/13/2023 10:46	210837



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-009

Client Sample ID: BCMI-S9

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/05/2023 23:37	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-010

Client Sample ID: BCMI-O10

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:33

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/05/2023 23:41	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-011

Client Sample ID: BCMI-S11

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/05/2023 23:45	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-012

Client Sample ID: BCMI-S12

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/05/2023 23:59	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-013

Client Sample ID: BCMI-S13

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 0:03	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-014

Client Sample ID: BCMI-O14

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 0:07	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-015

Client Sample ID: BCMI-O15

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		23.4	µg/L	5	09/13/2023 11:00	210837



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-016

Client Sample ID: BCMI-S16

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.9	µg/L	1	09/06/2023 0:10	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-017

Client Sample ID: BCMI-S17

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.4	µg/L	5	09/13/2023 11:04	210837



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-018

Client Sample ID: BCMI-O18

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		5.4	µg/L	1	09/06/2023 0:21	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-019

Client Sample ID: BCMI-O19

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 0:25	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-020

Client Sample ID: BCMI-S20

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 0:28	210684



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-021

Client Sample ID: BCMI-DF21

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:41

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 0:32	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-022

Client Sample ID: BCMI-DF22

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 0:47	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-023

Client Sample ID: BCMI-S23

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 0:50	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-024

Client Sample ID: BCMI-DF24

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 0:54	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-025

Client Sample ID: BCMI-S25

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.9	µg/L	1	09/06/2023 1:05	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-026

Client Sample ID: BCMI-S26

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.5	µg/L	1	09/06/2023 1:09	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-027

Client Sample ID: BCMI-S27

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 1:12	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-028

Client Sample ID: BCMI-S28

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 1:16	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-029

Client Sample ID: BCMI-S29

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 1:20	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-030

Client Sample ID: BCMI-S30

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.6	µg/L	1	09/06/2023 1:34	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-031

Client Sample ID: BCMI-S31

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 1:38	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-032

Client Sample ID: BCMI-S32

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.4	µg/L	1	09/06/2023 1:42	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-033

Client Sample ID: BCMI-S33

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.9	µg/L	1	09/06/2023 1:45	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-034

Client Sample ID: BCMI-S34

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.0	µg/L	1	09/06/2023 1:49	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-035

Client Sample ID: BCMI-S35

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 1:53	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-036

Client Sample ID: BCMI-O36

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 1:56	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-037

Client Sample ID: BCMI-S37

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/06/2023 2:07	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-038

Client Sample ID: BCMI-O38

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 2:22	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-039

Client Sample ID: BCMI-DF39

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 2:26	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-040

Client Sample ID: BCMI-DF40

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:56

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/06/2023 2:29	210685



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-041

Client Sample ID: BCMI-DF41

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 15:46	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-042

Client Sample ID: BCMI-DF42

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:59

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 15:50	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-043

Client Sample ID: BCMI-DF43

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 15:54	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-044

Client Sample ID: BCMI-DF44

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 16:05	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-045

Client Sample ID: BCMI-DF45

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:01

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 16:08	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-046

Client Sample ID: BCMI-DF46

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:02

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 16:12	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-047

Client Sample ID: BCMI-DF47

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 16:27	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-048

Client Sample ID: BCMI-DF48

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 16:30	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-049

Client Sample ID: BCMU-DF49

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 16:34	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-050

Client Sample ID: BCMU-DF50

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 16:38	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-051

Client Sample ID: BCMU-S51

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.3	µg/L	1	09/07/2023 16:41	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-052

Client Sample ID: BCMU-S52

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:13

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.7	µg/L	1	09/07/2023 16:45	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-053

Client Sample ID: BCMU-S53

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.6	µg/L	1	09/07/2023 16:49	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-054

Client Sample ID: BCMU-S54

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.8	µg/L	1	09/07/2023 16:52	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-055

Client Sample ID: BCMU-S55

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 17:14	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-056

Client Sample ID: BCMU-S56

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 17:18	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-057

Client Sample ID: BCMU-S57

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.9	µg/L	1	09/07/2023 17:22	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-058

Client Sample ID: BCMU-S58

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.5	µg/L	1	09/07/2023 17:25	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-059

Client Sample ID: BCMU-S59

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		9.5	µg/L	1	09/07/2023 17:29	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-060

Client Sample ID: BCMU-S60

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.5	µg/L	1	09/07/2023 17:33	210687



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-061

Client Sample ID: BCMU-S61

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.9	µg/L	1	09/07/2023 17:36	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-062

Client Sample ID: BCMU-S62

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 17:40	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-063

Client Sample ID: BCMU-S63

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:21

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.9	µg/L	1	09/07/2023 18:02	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-064

Client Sample ID: BCMU-S64

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:21

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		7.6	µg/L	1	09/07/2023 18:06	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-065

Client Sample ID: BCMU-S65

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:21

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.2	µg/L	1	09/07/2023 18:09	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-066

Client Sample ID: BCMU-S66

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:21

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 18:13	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-067

Client Sample ID: BCMU-S67

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 18:17	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-068

Client Sample ID: BCMU-S68

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.4	µg/L	1	09/07/2023 18:20	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-069

Client Sample ID: BCMU-O69

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		123	µg/L	5	09/13/2023 11:08	210837



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-070

Client Sample ID: BCMU-S70

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 18:24	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-071

Client Sample ID: BCMU-S71

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 18:28	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-072

Client Sample ID: BCMU-S72

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/07/2023 18:31	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-073

Client Sample ID: BCMU-S73

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/07/2023 18:35	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-074

Client Sample ID: BCMU-S74

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/07/2023 18:50	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-075

Client Sample ID: BCMU-S75

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 18:53	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-076

Client Sample ID: BCMU-S76

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.6	µg/L	1	09/07/2023 19:04	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-077

Client Sample ID: BCMU-S77

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 19:08	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-078

Client Sample ID: BCMU-S78

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 19:11	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-079

Client Sample ID: BCMU-S79

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.6	µg/L	1	09/07/2023 19:15	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-080

Client Sample ID: BCMU-S80

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 19:19	210688



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-081

Client Sample ID: BCMU-S81

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.8	µg/L	1	09/07/2023 19:22	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-082

Client Sample ID: BCMU-S82

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.7	µg/L	1	09/07/2023 19:37	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-083

Client Sample ID: BCMU-S83

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.1	µg/L	1	09/07/2023 19:41	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-084

Client Sample ID: BCMU-S84

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 19:44	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-085

Client Sample ID: BCMU-S85

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/07/2023 19:48	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-086

Client Sample ID: BCMU-S86

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:41

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.6	µg/L	1	09/07/2023 19:59	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-087

Client Sample ID: BCMU-S87

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.4	µg/L	1	09/07/2023 20:03	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-088

Client Sample ID: BCMU-S88

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/07/2023 20:06	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-089

Client Sample ID: BCMU-S89

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.3	µg/L	1	09/07/2023 20:10	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-090

Client Sample ID: BCMU-S90

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	1	09/12/2023 14:09	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-091

Client Sample ID: BCMU-S91

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.8	µg/L	1	09/12/2023 14:24	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-092

Client Sample ID: BCMU-S92

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.1	µg/L	1	09/12/2023 14:28	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-093

Client Sample ID: BCMU-S93

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.6	µg/L	1	09/12/2023 14:31	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-094

Client Sample ID: BCMU-S94

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.6	µg/L	1	09/12/2023 14:35	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-095

Client Sample ID: BCMU-S95

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.6	µg/L	1	09/12/2023 14:39	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-096

Client Sample ID: BCMU-S96

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.2	µg/L	1	09/12/2023 14:42	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-097

Client Sample ID: BCMU-S97

Matrix: DRINKING WATER

Collection Date: 07/26/2023 0:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 14:53	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-098

Client Sample ID: BCMU-S98

Matrix: DRINKING WATER

Collection Date: 07/26/2023 0:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.8	µg/L	1	09/12/2023 14:57	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-099

Client Sample ID: BCMU-S99

Matrix: DRINKING WATER

Collection Date: 07/26/2023 0:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		17.0	µg/L	1	09/12/2023 15:12	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-100

Client Sample ID: BCMU-S100

Matrix: DRINKING WATER

Collection Date: 07/26/2023 0:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		29.5	µg/L	1	09/12/2023 15:15	210690



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-101

Client Sample ID: BCMU-S101

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	1	09/11/2023 13:18	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-102

Client Sample ID: BCMU-S102

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.2	µg/L	1	09/11/2023 13:21	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-103

Client Sample ID: BCMU-S103

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.9	µg/L	1	09/11/2023 13:25	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-104

Client Sample ID: BCMU-S104

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		20.1	µg/L	1	09/11/2023 13:36	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-105

Client Sample ID: BCMU-S105

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.8	µg/L	1	09/11/2023 13:40	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-106

Client Sample ID: BCMU-S106

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		7.7	µg/L	1	09/11/2023 13:43	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-107

Client Sample ID: BCMU-S107

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.8	µg/L	1	09/11/2023 13:47	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-108

Client Sample ID: BCMU-S108

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.6	µg/L	1	09/11/2023 13:51	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-109

Client Sample ID: BCMU-S109

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.1	µg/L	1	09/12/2023 17:01	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-110

Client Sample ID: BCMU-S110

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.1	µg/L	1	09/12/2023 17:05	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-111

Client Sample ID: BCMU-S111

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		14.7	µg/L	1	09/12/2023 17:09	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-112

Client Sample ID: BCMU-S112

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.1	µg/L	1	09/12/2023 17:12	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-113

Client Sample ID: BCMU-S113

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		9.4	µg/L	1	09/12/2023 17:16	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-114

Client Sample ID: BCMU-S114

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:06

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.8	µg/L	1	09/12/2023 17:20	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-115

Client Sample ID: BCMU-S115

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:06

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.5	µg/L	1	09/12/2023 17:34	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-116

Client Sample ID: BCMU-S116

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:06

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		51.7	µg/L	5	09/13/2023 11:19	210837



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-117

Client Sample ID: BCMU-S117

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:07

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.0	µg/L	1	09/12/2023 17:45	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-118

Client Sample ID: BCMU-S118

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.5	µg/L	1	09/12/2023 17:49	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-119

Client Sample ID: BCMU-S119

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 17:53	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-120

Client Sample ID: BCMU-S120

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.3	µg/L	1	09/12/2023 17:56	210732



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-121

Client Sample ID: BCMU-S121

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.4	µg/L	1	09/12/2023 18:00	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-122

Client Sample ID: BCMU-S122

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 18:04	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-123

Client Sample ID: BCMU-S123

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 18:07	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-124

Client Sample ID: BCMU-S124

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 10:20	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-125

Client Sample ID: BCMU-S125

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.9	µg/L	1	09/13/2023 10:31	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-126

Client Sample ID: BCMU-S126

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.0	µg/L	1	09/11/2023 15:40	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-127

Client Sample ID: BCMU-O127

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 15:44	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-128

Client Sample ID: BCMU-S128

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		31.9	µg/L	1	09/11/2023 15:48	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-129

Client Sample ID: BCMU-S129

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		18.7	µg/L	1	09/11/2023 15:51	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-130

Client Sample ID: BCMU-S130

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		17.1	µg/L	1	09/11/2023 15:55	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-131

Client Sample ID: BCMU-S131

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.2	µg/L	1	09/11/2023 15:59	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-132

Client Sample ID: BCMU-S132

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.1	µg/L	1	09/11/2023 16:02	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-133

Client Sample ID: BCMU-S133

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.4	µg/L	1	09/11/2023 16:06	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-134

Client Sample ID: BCMU-S134

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 16:10	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-135

Client Sample ID: BCMU-S135

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.7	µg/L	1	09/11/2023 16:13	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-136

Client Sample ID: BCMU-S136

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:21

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		21.4	µg/L	5	09/13/2023 11:22	210837



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-137

Client Sample ID: BCMO-S137

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.5	µg/L	1	09/11/2023 16:28	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-138

Client Sample ID: BCML-S138

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	1	09/11/2023 16:32	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-139

Client Sample ID: BCML-S139

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.9	µg/L	1	09/11/2023 16:43	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-140

Client Sample ID: BCML-S140

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/11/2023 16:46	210735



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-141

Client Sample ID: BCML-S141

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 16:50	210736



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-142

Client Sample ID: BCML-S142

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/11/2023 16:54	210736



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-143

Client Sample ID: BCML-S143

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.7	µg/L	1	09/11/2023 16:57	210736



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-144

Client Sample ID: BCML-S144

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 17:19	210736



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-145

Client Sample ID: BCML-S145

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.1	µg/L	1	09/11/2023 17:23	210736



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-146

Client Sample ID: BCML-S146

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:39

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.4	µg/L	1	09/11/2023 17:26	210736



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-147

Client Sample ID: BCML-S147

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		7.2	µg/L	1	09/11/2023 17:30	210736



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-148

Client Sample ID: BCML-DF148

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		5.7	µg/L	1	09/11/2023 17:34	210736



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-149

Client Sample ID: BCML-S149

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 17:37	210736



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-150

Client Sample ID: BCML-DF150

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 17:41	210736



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Lab ID: 23071993-151

Client Sample ID: BCML-DF151

Matrix: DRINKING WATER

Collection Date: 07/26/2023 10:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 17:45	210736



Receiving Check List

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071993

Client Project: Lees Summit School Dist DW/Bernard Campbell Middle

Report Date: 14-Sep-23

Carrier: Crossroads

Received By: CET

Completed by:

On:

01-Aug-23

Allison Colin

Reviewed by:

On:

01-Aug-23

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

Shipping container/cooler in good condition?	Yes ☒	No ☐	Not Present ☐	Temp °C NA
Type of thermal preservation?	None ☒	Ice ☐	Blue Ice ☐	Dry Ice ☐
Chain of custody present?	Yes ☒	No ☐		
Chain of custody signed when relinquished and received?	Yes ☒	No ☐		
Chain of custody agrees with sample labels?	Yes ☒	No ☐		
Samples in proper container/bottle?	Yes ☒	No ☐		
Sample containers intact?	Yes ☒	No ☐		
Sufficient sample volume for indicated test?	Yes ☒	No ☐		
All samples received within holding time?	Yes ☒	No ☐		
Reported field parameters measured:	Field ☐	Lab ☐	NA ☒	
Container/Temp Blank temperature in compliance?	Yes ☒	No ☐		

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?	Yes ☐	No ☐	No VOA vials ☒
Water - TOX containers have zero headspace?	Yes ☐	No ☐	No TOX containers ☒
Water - pH acceptable upon receipt?	Yes ☒	No ☐	NA ☐
NPDES/CWA TCN interferences checked/treated in the field?	Yes ☐	No ☐	NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

pg. 1 of 16 Work order # 23071993

pg. 1 of 16 Work order # 23071993

Client:	Blackstone Environmental, Inc.	Samples on:	☐ ICE	☐ BLUE ICE	☒ NO ICE	°C	LTG#
Address:	16200 Foster Street	Preserved in:	☐ LAB	☐ FIELD	FOR LAB USE ONLY		
City / State / Zip	Overland Park, KS 66085	Lab Notes					
Contact:	Lindsay E. James	Client Comments:					
E-Mail:	ljames@blackstone-env.com						
Phone:	(913) 495-9990						
Fax:							

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

[illegible]

Relinquished By	Date/Time	Received By	Date/Time
Kalena Minin	7/26/23 @ 1600	K. Minin	7/27/23 1400
K. Minin	7/27/23 1600	K. Minin	7/28/23 1132

BottleOrder: 82000



CHAIN OF CUSTODY

pg. 2 of 16 Work order # 23071993

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc. Address: 16200 Foster Street City / State / Zip: Overland Park, KS 66085 Contact: Lindsay E. James (913) 495-9990 E-Mail: ljames@blackstone-env.com	Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG# Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY Lab Notes Client Comments: Bernard Campbell Middle School
---	---

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED	
Lee's Summit School Dist. DW		Kaylee Muir			
Results Requested		Billing Instructions		# and Type of Containers	
☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)				OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES	
Lab Use Only	Sample Identification	Date/Time Sampled			
23071993 011	BCMI-S11	7/26/23 8:34	X		
012	BCMI-S12	8:34	X		
013	BCMI-S13	8:34	X		
014	BCMI-S14	8:35	X		
015	BCMI-S15	8:35	X		
016	BCMI-S16	8:37	X		
017	BCMI-S17	8:37	X		
018	BCMI-S18	8:38	X		
019	BCMI-S19	8:38	X		
020	BCMI-S20	8:40	X		

Relinquished By		Received By		Date/Time	
Kaylee Muir		W. D. [Signature]		7/27/23 1400	
W. D. [Signature]		[Signature]		7/27/23 1432	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 5 of 16 Work order # 23071993

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Address: 16200 Foster Street	Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes:
Contact: Lindsay E. James (913) 495-9990	
E-Mail: ljames@blackstone-env.com	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No
 Are these samples known to be hazardous? ☐ Yes ☒ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Client Comments:
 Bernard ~~Ward~~ Campbell Middle School

Project Name/Number		Sample Collector's Name		Matrix		INDICATE ANALYSIS REQUESTED											
Lee's Summit School Dist. DW		KM															
Lab Use Only	Results Requested ☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)	Billing Instructions		# and Type of Containers													
		Date/Time Sampled		UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER						
23071993 021	BCM1-DF21	7/24/23	8:41	X													
022	BCM1-DF22		8:42	X													
023	BCM1-S23		8:43	X													
024	BCM1-DF24		8:44	X													
025	BCM1-S25		8:44	X													
026	BCM1-S26		8:46	X													
027	BCM1-S27		8:46	X													
028	BCM1-S28		8:47	X													
029	BCM1-S29		8:48	X													
030	BCM1-S30		8:48	X													

Relinquished By		Date/Time		Received By		Date/Time	
Kagay mmm		7/26/23 @ 1600		W. Ward		7/27/23 1400	
W. Ward		7/27/23 1600		C. Ward		7/28/23 1120	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 5 of 5

Work order # 23071993

Work order # 23071993

Work order # 23071993

Work order # 23071993

Work order # 23071993



TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client:
Blackstone Environmental, Inc.
16200 Foster Street
Overland Park, KS 66085
Contact: Lindsay E. James
E-Mail: ljames@blackstone-env.com
Phone: (913) 495-9990
Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#

Preserved in: ☐ LAB ☐ FIELD ☐ FOR LAB USE ONLY

Lab Notes

Client Comments:
Bernard Campbell Middle School

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No
Are these samples known to be hazardous? ☐ Yes ☒ No
Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED									
Lee's Summit School Dist. DW		Haylee Muir											
Results Requested		Billing Instructions		MATRIX									
☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)		# and Type of Containers											
Lab Use Only		Date/Time Sampled											
23071993 041	BCM1-DF41	7/26/23	8:58	X									
042	BCM1-DF42		8:59										
043	BCM1-DF43		9:00										
044	BCM1-DF44		9:00										
045	BCM1-DF45		9:01										
046	BCM1-DF46		9:02										
047	BCM1-DF47		9:03										
048	BCM1-DF48		9:05										
049	BCM1-DF49		9:10										
050	BCM1-DF50		9:10										
Relinquished By		Date/Time		Received By									
Haylee Muir		7/26/23 @ 1600		Z. [Signature]									
				7/27/23 1600									
				7/28/23 1132									

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc. Address: 16200 Foster Street City / State / Zip: Overland Park, KS 66085 Contact: Lindsay E. James (913) 495-9990 E-Mail: ljames@blackstone-env.com	Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG# Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY Lab Notes Client Comments: Bernard Campbell Middle School	Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No Are these samples known to be hazardous? ☐ Yes ☒ No Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No
---	--	--

Project Name/Number		Sample Collector's Name	INDICATE ANALYSIS REQUESTED													
Lee's Summit School Dist. DW		Kaylee Muir	Matrix													
Results Requested		Billing Instructions	# and Type of Containers													
☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)			OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead
Lab Use Only	Sample Identification	Date/Time Sampled														
23071493	051 BCMU - S51	7/26/23 9:12	X								X					
052	- S52	9:13														
053	- S53	9:15														
054	- S54	9:15														
055	- S55	9:15														
056	- S56	9:16														
057	- S57	9:16														
058	- S58	9:16														
059	- S59	9:17														
060	- S60	9:17														
Relinquished By			Date/Time			Received By			Date/Time							
Kaylee Muir			7/26/23 1600			[Signature]			7/27/23 1400							
[Signature]			7/27/23 1600			[Signature]			7/28/23 1332							

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

CHAIN OF CUSTODY

pg. 7 of 10 Work order # 23071993

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Address: 16200 Foster Street	Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes:
Contact: Lindsay E. James (913) 495-9990	Client Comments:
E-Mail: ljames@blackstone-env.com	Bernard Campbell Middle School

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No
 Are these samples known to be hazardous? ☐ Yes ☒ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED	
Lee's Summit School Dist. DW		Kaylee Muir			
Results Requested ☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)	Sample Identification	Billing Instructions	Date/Time Sampled	MATRIX	
				Drinking Water	Aqueous
23071993 0101	BCMU-S101		7/26/23 9:20	X	
0102	- S102		9:20		
0103	- S103		9:21		
0104	- S104		9:21		
0105	- S105		9:21		
0106	- S106		9:21		
0107	- S107		9:22		
0108	- S108		9:22		
0109	- S109		9:27		
0110	- S110		9:30		

Relinquished By	Date/Time	Received By	Date/Time
Kaylee Muir	7/26/23 @ 1600	W. Campbell	7/27/23 1400
W. Campbell	7/27/23 1600	W. Campbell	7-28-23 1600

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 8 of 10 Work order # 23071493

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Address: 16200 Foster Street	Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes:
Contact: Lindsay E. James (913) 495-9990	
E-Mail: ljames@blackstone-env.com	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No
 Are these samples known to be hazardous? ☐ Yes ☒ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Client Comments:

Bernard Campbell Middle School

Project Name/Number		Sample Collector's Name	INDICATE ANALYSIS REQUESTED														
Lee's Summit School Dist. DW		Kaylee Muir	MATRIX														
Results Requested		Billing Instructions	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead									
Lab Use Only	Sample Identification	Date/Time Sampled															
23071493	0711 BC MU - S71	7/24/23 9:30	X					X									
072	- S72	9:30															
073	- S73	9:31															
074	- S74	9:31															
075	- S75	9:31															
076	- S76	9:31															
077	- S77	9:32															
078	- S78	9:36															
079	- S79	9:36															
080	- S80	9:36															

Relinquished By	Date/Time	Received By	Date/Time
Kaylee Muir	7/26/23 @ 10:00	L. E. James	7/27/23 19:00
			7/27/23 16:00

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 1 of 10 Work order # 23071443

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Address: 16200 Foster Street	Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes:
Contact: Lindsay E. James (913) 495-9990	
E-Mail: ljames@blackstone-env.com	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED	
Lee's Summit School Dist. DW		Kaylee Muir			
Results Requested		Billing Instructions		MATRIX	
☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ 3 Day (50% Surcharge)				Drinking Water ☒ Aqueous ☐ Groundwater ☐ Special Waste ☐ Sludge ☐ Soil ☐	
Lab Use Only	Sample Identification	Date/Time Sampled	# and Type of Containers	DW Lead	
23071443 081	BCMU - S81	7/26/23 9:37	X	X	
082	- S82	9:37			
083	- S83	9:37			
084	- S84	9:37			
085	- S85	9:38			
086	- S86	9:41			
087	- S87	9:42			
088	- S88	9:42			
089	- S89	9:42			
090	- S90	9:43			

Relinquished By	Date/Time	Received By	Date/Time
Kaylee Muir	7/26/23 @ 1600	[Signature]	7/27/23 1400
[Signature]	7/27/23 1600	[Signature]	7/28/23 1122

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 10 of 10 Work order # 13071493

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James (913) 495-9990
 E-Mail: ljames@blackstone-env.com
 Phone:
 Fax:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No
 Are these samples known to be hazardous? ☐ Yes ☒ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C LTG#
 Preserved in: ☐ LAB ☐ FIELD
 Lab Notes
 FOR LAB USE ONLY

Client Comments:

Bernard Campbell Middle School

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED													
Lee's Summit School Dist. DW		Kaylee Muir		Matrix				Matrix									
Results Requested	Billing Instructions	Date/Time Sampled	# and Type of Containers	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead								
Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)																	
091	RCMU - S91	7/26/23 9:43	X	X					X								
092	- S92	9:43															
093	- S93	9:44															
094	- S94	9:47															
095	- S95	9:48															
096	- S96	9:49															
097	- S97																
098	- S98																
099	- S99																
100	- S100																

Relinquished By	Date/Time	Received By	Date/Time
Kaylee Muir	7/26/23 @ 1600	[Signature]	7/27/23 1400
[Signature]	7/27/23 1600	[Signature]	7/28/23 1132

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 11 of 16 Work order # 23071943

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc. Address: 16200 Foster Street City / State / Zip: Overland Park, KS 66085 Contact: Lindsay E. James E-Mail: ljames@blackstone-env.com		Phone: (913) 495-9980 Fax:	
Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No Are these samples known to be hazardous? ☐ Yes ☒ No Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No		Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG# Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY Lab Notes Client Comments: Bernard Campbell ms	

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED	
Lee's Summit School Dist. DW		KSM			
Results Requested		Billing Instructions			
☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)					
Lab Use Only	Sample Identification	Date/Time Sampled	# and Type of Containers	MATRIX	
23071943 101	BSMA-S101	7/26/23 @ 953	OTHER	Drinking Water	X
102	-S102	@ 953	NaHSO4	Groundwater	
103	-S103	@ 954	MeOH	Special Waste	
104	-S104	@ 954	HCL	Sludge	
105	-S105	@ 954	H2SO4	Soil	
106	-S106	@ 954	NaOH	Aqueous	
107	-S107	@ 955	HNO3		
108	-S108	@ 955	UNPRES		
109	-S109	@ 1004			
110	-S110	@ 1004			
Relinquished By			Date/Time	Received By	Date/Time
Kaley M...			7/26/23 @ 1600	[Signature]	7/27/23 1400
S. [Signature]			7/27/23 1600	[Signature]	7/28/23 1132

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 12 of 16 Work order # 23071493

pg. 12 of 16 Work order # 235pg. 12 of 16 Work order # 235

Bottle Order: 82000



CHAIN OF CUSTODY

nd - Collinsville, IL 62234 - PR

3) 495-9990	Samples on: ☐ Preserved in: ☐ Lab Notes	Client Comments
------------------------	--	----------------------------

Client Comments:
Bernard Campbell
Middle School

☐ Yes ☒ No

[illegible]

Time	Room
1600	1600
1600	1600

The individual signing this agreement on behalf of the client, acknowledges that he/she is signing this agreement on behalf of the client, and that he/she has the authority to sign on behalf of the client. See www.irs.gov for more information.

Bottle Order: 82000



pg. 14 of 16 Work order # 23071993

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client:	Blackstone Environmental, Inc.		
Address:	16200 Foster Street		
City / State / Zip	Overland Park, KS	66085	
Contact:	Lindsay E. James		
E-Mail:	ljames@blackstone-env.com		
Phone:	(913) 495-9990		
Fax:			

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name <i>KSM</i>		INDICATE ANALYSIS REQUESTED																				
				MATRIX																				
				Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead															
☒ Standard	☐ 1-2 Day (100% Surcharge)	Billing Instructions		# and Type of Containers	OTHER	NaHSO ₄	MeOH	HCL	H ₂ SO ₄	NaOH	HNO ₃	UNPRES												
☐ Other	☐ 3 Day (50% Surcharge)			Date/Time Sampled																				
Lab Use Only	Sample Identification																							
23071903	131 BGMV - S131			7/26/23 @ 10:19 AM	X																			
132	- S132			@ 1020																				
133	- S133			@ 1020																				
134	- S134			@ 1020																				
135	- S135			@ 1020																				
136	↓ - S136			@ 1021																				
137	BCMO - S137			@ 1037																				
138	BCM L - S138			@ 1034																				
139	↓ - S139			@ 1035																				
140	↓ - S140			@ 1035																				

Relinquished By	Date/Time	Received By	Date/Time
Kalany Munn	7/26/23 @ 1600	<i>[Signature]</i>	7/27/23 1700
<i>[Signature]</i>	7/27/23 1600	<i>[Signature]</i>	7/28/23 1130

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.tektabinc.com for terms and conditions.

Bottle Order: 82000



pg. 15 of 16 Work order # 13071993

x: (618) 344-1005

	Samples on:	☐ ICE	☐ BLUE ICE	☐ NO ICE	°C	LTG#
	Preserved in:	☐ LAB	☐ FIELD	FOR LAB USE ONLY		
	Lab Notes					
Client Comments:						

Blackstone Environmental, Inc.	
18200 Foster Street	
Overland Park, KS 66085	
Lindsay E. James	(913) 495-9990
james@blackstone-env.com	

Bernard Campbell
MS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

[illegible]

Relinquished By	Date/Time	Received By	Date/Time
Randy Munn	7/26/23 @ 1600	[Signature]	7/27/23 1400
[Signature]	7/27/23 1600	[Signature]	7/28/23 1132

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 16 of 16 Work order # 23071003

pg. 16 of 16 Work order # 23071003

pg. 16 of 16 Work order # 23071003

BottleOrder: 82000

