

ATTACHMENT B

**East Trails Middle School
Field Forms**

Lee's Summit DW

Date Purged
8/1

Date Sampled
8/2

School

East Trails Middle School
(ETM)

Team

A-K+T

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	D Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
1	1		X		corridor 6100 a fountain (l)	12:37	8:18
2	1		X		corridor 6100 a fountain (r)	12:37	8:18
3	1		X		band 6103 sink	12:44	8:20
4	1		X		girls locker F111 fountain (l)	12:50	8:22
5	1		X		girls locker F111 fountain (r)	12:50	8:22
6	1		X		fountain (l) F113 by gym	12:51	8:23
7	1		X		fountain (r) F113 by gym	12:51	8:23
8	1		X		boys locker F112 fountain (l)	12:50	8:24
9	1		X		boys locker F112 fountain (r)	12:50	8:24
10	1		X		aux gym F114 fountain (l)	12:56	8:25
11	1		X		aux gym F114 fountain (r)	12:56	8:25
12	1	X			Kitchen prep sink	13:04	8:27
13	1	X			Kitchen prep sink	13:04	8:27
14	1	X			Kitchen prep sink	13:04	8:28
15	1	X			Kitchen prep sink	13:04	8:28
16	1	X			Kitchen prep sink w/sprayer	13:04	8:29
17	1	X			Kitchen dish sink (r)	13:04	8:29
18	1	X			Kitchen dish sink (m)	13:04	8:30
19	1	X			Kitchen dish sink (l)	13:04	8:30
20	1			X	Kitchen dishwasher	13:04	8:31
21	1	X			Kitchen serving sink	13:05	8:32
22	1	X			Kitchen serving sink	13:05	8:32
23	1			X	steam oven (r)	13:08	8:34
24	1			X	steam oven (m)	13:08	8:34

Lee's Summit DW

Date Purged 8/1
Date Sampled 8/2

School

East Trails Middle School
(ETM)

Team

AK+T

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	ID Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
25	1			X	Steam oven (1)	13:08	8:35
26	1	X			staff dining ell sink	13:15	8:36
27	1			X	staff dining ell ice machine	13:15	8:37
28	1		X		commons ell 100 fountain	13:17	8:37
29	1	X			workroom ell 101A in media center	13:19	8:38
30	1	X			B104 sink	13:24	8:40
31	1	X			B104 sink	13:24	8:41
32	1	X			B104 sink	13:24	8:42
33	1	X			B104 sink	13:24	8:42
34	1	X			B104 sink	13:24	8:42
35	1	X			B104 sink	13:24	8:42
36	1	X			B104 sink	13:25	8:43
37	1	X			B104 sink	13:25	8:44
38	1	X			B104 sink	13:26	8:45
39	1	X			B102 sink	13:26	8:48
40	1	X			B102 sink	13:26	8:48
41	1	X			B102 sink	13:26	8:48
42	1	X			B102 sink	13:26	8:49
43	1	X			B102 sink	13:27	8:49
44	1	X			B102 sink	13:27	8:49
45	1	X			B102 sink	13:27	8:50
46	1	X			B102 sink	13:27	8:50
47	1	X			B102 sink	13:27	8:50
48	1	X			B103 sink	13:27	8:51

Lee's Summit DW

Date Purged 8/1
Date Sampled 8/2

School East Trails Middle School
(ETM)

Team A+K+T

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	D Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
49	1	X			B103 sink	13:27	8:51
50	1	X			B103 sink	13:28	8:51
51	1	X			B103 sink	13:28	8:52
52	1	X			B103 sink	13:28	8:52
53	1	X			B103 sink	13:28	8:52
54	1	X			B103 sink	13:28	8:53
55	1	X			B103 sink	13:29	8:53
56	1	X		X	B103a prep ice maker	13:29	8:55
57	1	X		X	B103a prep ice maker B118 sink	13:31	8:57
58	1	X	X		B103a prep ice maker B118 sink	13:39	8:57
59	1		X		corridor B100c fountain (1)	13:37	8:59
60	1		X		corridor B100c fountain (r)	13:37	8:59
61	1	X			C104 sink	13:43	9:00
62	1	X			C104 sink	13:43	9:00
63	1	X			C104 sink	13:43	9:01
64	1	X			C104 sink	13:43	9:01
65	1	X			C104 sink	13:43	9:01
66	1	X			C104 sink	13:43	9:02
67	1	X			C104 sink	13:44	9:02
68	1	X			C104 sink	13:44	9:03
69	1	X			C104 sink	13:44	9:03
70	1	X			C103a sink (prep)	13:45	9:04
71	1			X	C103a prep ice machine	13:45	9:04
72	1	X			C102 sink	13:45	9:08

Lee's Summit DW

Date Purged 8/1
Date Sampled 8/2

School East Trails Middle School
(ETM)

Team AK+T

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	D Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
73	1	X			C102 sink	13:45	9:08
74	1	X			C102 sink	13:46	9:08
75	1	X			C102 sink	13:46	9:09
76	1	X			C102 sink	13:46	9:09
77	1	X			C102 sink	13:46	9:09
78	1	X			C102 sink	13:46	9:10
79	1	X			C102 sink	13:47	9:10
80	1	X			C102 sink	13:47	9:10
81	1	X			C103 sink	13:47	9:11
82	1	X			C103 sink	13:47	9:11
83	1	X			C103 sink	13:47	9:11
84	1	X			C103 sink	13:48	9:12
85	1	X			C103 sink	13:48	9:12
86	1	X			C103 sink	13:48	9:12
87	1	X			C103 sink	13:48	9:13
88	1	X			C103 sink	13:48	9:13
89	1		X		commons c100 fountain (1)	13:55	9:17
90	1		X		commons c100 fountain (r)	13:55	9:17
91	1	X			D104 sink	13:57 13:57	9:24
92	1	X			D104 sink	13:57	9:25
93	1	X			D104 sink	13:57	9:25
94	1	X			D104 sink	13:57	9:25
95	1	X			D104 sink	13:57	9:26
96	1	X			D104 sink	13:57	9:26

Lee's Summit DW

Date Purged 8/1 School East Trails Middle School Team AK+T
 Date Sampled 8/2 (ETM)

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	D Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
97	1	X			D104 sink	13:57	9:26
98	1	X			D104 sink	13:57	9:27
99	1	X			D104 sink	13:57	9:27
100	1	X			D103A prep sink	13:58	9:28
101	1	X			D102 sink	13:58	9:30
102	1	X			D102 sink	13:58	9:30
103	1	X			D102 sink	13:59	9:30
104	1	X			D102 sink	13:59	9:31
105	1	X			D102 sink	13:59	9:31
106	1	X			D102 sink	13:59	9:31
107	1	X			D102 sink	13:59	9:32
108	1	X			D102 sink	13:59	9:32
109	1	X			D103 sink	14:00	9:33
110	1	X			D103 sink	14:00	9:33
111	1	X			D103 sink	14:00	9:33
112	1	X			D103 sink	14:00	9:34
113	1	X			D103 sink	14:00	9:34
114	1	X			D103 sink	14:00	9:34
115	1	X			D103 sink	14:00	9:34
116	1	X			D103 sink	14:00	9:34
117	1		X		commons D100 fountain (1)	14:13	9:36
118	1		X		commons D100 fountain (2)	14:13	9:36
119	1	X			A126 sink	14:15	9:39
120	1			X	A126 dishwasher - Same water line as 119	14:15	9:41

Date Purged

8/11

Date Sampled

8/12

School

East Trails Middle School
(ETM)

Team

AK+T

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	D Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
121	1	X			workroom A108 sink	14:20	9:43
122	1	X			break room A108 sink	14:21	9:45
123	1			X	break room A108 dishwasher	14:21	9:46
124	1			X	break room A108 water/ice machine	14:21	9:46
125	1			X	break room A108 fridge water/ice	14:21	9:47
126	2	X			A202 sink	14:29	9:52
127	2		X		corridor B200c fountain (1)	14:34	9:54
128	2		X		corridor B200c fountain (1)	14:34	9:56
129	2	X			A207 sink	14:34	9:56
130	2	X			A207 sink	14:34	9:57
131	2	X			A207 sink	14:34	9:57
132	2	X			A207 sink	14:34	9:58
133	2	X			A207 sink	14:34	9:58
134	2	X			A207 sink	14:34	10:01
135	2	X			A207 sink	14:34	10:01
136	2	X			A207A party sink	14:35	10:02
137	2	X			A208 sink	14:35	10:02
138	2	X			A209 sink	14:35	10:04
139	2			X	A207 dishwasher - Same water line ¹³⁹	14:35	10:04
140	2		X		corridor C200c fountain (1)	14:43	10:07
141	2		X		corridor C200c fountain (1)	14:43	10:07
142	2	X			A211 sink	14:44	10:10
143	2	X			A211 sink	14:44	10:10
144	2	X			A211 sink	14:44	10:10

Lee's Summit DW

Date Purged

Date Sampled _____

$$\frac{1}{8}$$
$$\frac{2}{8}$$

School

School

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Team

Team

[illegible]

ATTACHMENT C

East Trails Middle School Summary Table

Summary Table
East Trails Middle School

Sample ID	Date	Analyte	Result	Unit	Reporting Limit
ETM1-DF1	8/2/2023	Lead	ND	µg/L	1
ETM1-DF2	8/2/2023	Lead	ND	µg/L	1
ETM1-DF3	8/2/2023	Lead	ND	µg/L	1
ETM1-DF4	8/2/2023	Lead	ND	µg/L	1
ETM1-DF5	8/2/2023	Lead	ND	µg/L	1
ETM1-DF6	8/2/2023	Lead	ND	µg/L	1
ETM1-DF7	8/2/2023	Lead	ND	µg/L	1
ETM1-DF8	8/2/2023	Lead	ND	µg/L	1
ETM1-DF9	8/2/2023	Lead	ND	µg/L	1
ETM1-DF10	8/2/2023	Lead	ND	µg/L	1
ETM1-DF11	8/2/2023	Lead	ND	µg/L	1
ETM1-S12	8/2/2023	Lead	ND	µg/L	1
ETM1-S13	8/2/2023	Lead	ND	µg/L	1
ETM1-S14	8/2/2023	Lead	1.1	µg/L	1
ETM1-S15	8/2/2023	Lead	ND	µg/L	1
ETM1-S16	8/2/2023	Lead	ND	µg/L	1
ETM1-S17	8/2/2023	Lead	ND	µg/L	1
ETM1-S18	8/2/2023	Lead	ND	µg/L	1
ETM1-S19	8/2/2023	Lead	1.3	µg/L	1
ETM1-S20	8/2/2023	Lead	ND	µg/L	1
ETM1-S21	8/2/2023	Lead	ND	µg/L	1
ETM1-S22	8/2/2023	Lead	ND	µg/L	1
ETM1-O23	8/2/2023	Lead	4.9	µg/L	1
ETM1-O24	8/2/2023	Lead	2.0	µg/L	1
ETM1-O25	8/2/2023	Lead	1.8	µg/L	1
ETM1-S26	8/2/2023	Lead	ND	µg/L	1
ETM1-O27	8/2/2023	Lead	ND	µg/L	1
ETM1-DF28	8/2/2023	Lead	ND	µg/L	1
ETM1-S29	8/2/2023	Lead	ND	µg/L	1
ETM1-S30	8/2/2023	Lead	ND	µg/L	1
ETM1-S31	8/2/2023	Lead	3.4	µg/L	1
ETM1-S32	8/2/2023	Lead	ND	µg/L	1
ETM1-S33	8/2/2023	Lead	1.2	µg/L	1
ETM1-S34	8/2/2023	Lead	1.0	µg/L	1
ETM1-S35	8/2/2023	Lead	2.1	µg/L	1
ETM1-S36	8/2/2023	Lead	1.3	µg/L	1
ETM1-S37	8/2/2023	Lead	3.3	µg/L	1
ETM1-S38	8/2/2023	Lead	3.0	µg/L	1
ETM1-S39	8/2/2023	Lead	ND	µg/L	1
ETM1-S40	8/2/2023	Lead	ND	µg/L	1
ETM1-S41	8/2/2023	Lead	ND	µg/L	1
ETM1-S42	8/2/2023	Lead	ND	µg/L	1
ETM1-S43	8/2/2023	Lead	ND	µg/L	1

ETM1-S44	8/2/2023	Lead	ND	µg/L	1
ETM1-S45	8/2/2023	Lead	1.0	µg/L	1
ETM1-S46	8/2/2023	Lead	ND	µg/L	1
ETM1-S47	8/2/2023	Lead	1.2	µg/L	1
ETM1-S48	8/2/2023	Lead	ND	µg/L	1
ETM1-S49	8/2/2023	Lead	ND	µg/L	1
ETM1-S50	8/2/2023	Lead	1.4	µg/L	1
ETM1-S51	8/2/2023	Lead	1.9	µg/L	1
ETM1-S52	8/2/2023	Lead	2.8	µg/L	1
ETM1-S53	8/2/2023	Lead	2.9	µg/L	1
ETM1-S54	8/2/2023	Lead	1.3	µg/L	1
ETM1-S55	8/2/2023	Lead	ND	µg/L	1
ETM1-S56	8/2/2023	Lead	ND	µg/L	1
ETM1-S57	8/2/2023	Lead	1.4	µg/L	1
ETM1-S58	8/2/2023	Lead	ND	µg/L	1
ETM1-DF59	8/2/2023	Lead	ND	µg/L	1
ETM1-DF60	8/2/2023	Lead	ND	µg/L	1
ETM1-S61	8/2/2023	Lead	1.0	µg/L	1
ETM1-S62	8/2/2023	Lead	ND	µg/L	1
ETM1-S63	8/2/2023	Lead	ND	µg/L	1
ETM1-S64	8/2/2023	Lead	ND	µg/L	1
ETM1-S65	8/2/2023	Lead	ND	µg/L	1
ETM1-S66	8/2/2023	Lead	ND	µg/L	1
ETM1-S67	8/2/2023	Lead	2.1	µg/L	1
ETM1-S68	8/2/2023	Lead	ND	µg/L	1
ETM1-S69	8/2/2023	Lead	2.1	µg/L	1
ETM1-S70	8/2/2023	Lead	3.8	µg/L	1
ETM1-O71	8/2/2023	Lead	ND	µg/L	1
ETM1-S72	8/2/2023	Lead	2.2	µg/L	1
ETM1-S73	8/2/2023	Lead	ND	µg/L	1
ETM1-S74	8/2/2023	Lead	1.8	µg/L	1
ETM1-S75	8/2/2023	Lead	1.6	µg/L	1
ETM1-S76	8/2/2023	Lead	3.2	µg/L	1
ETM1-S77	8/2/2023	Lead	2.0	µg/L	1
ETM1-S78	8/2/2023	Lead	4.9	µg/L	1
ETM1-S79	8/2/2023	Lead	1.5	µg/L	1
ETM1-S80	8/2/2023	Lead	3.3	µg/L	1
ETM1-S81	8/2/2023	Lead	ND	µg/L	1
ETM1-S82	8/2/2023	Lead	ND	µg/L	1
ETM1-S83	8/2/2023	Lead	1.5	µg/L	1
ETM1-S84	8/2/2023	Lead	1.4	µg/L	1
ETM1-S85	8/2/2023	Lead	3.6	µg/L	1
ETM1-S86	8/2/2023	Lead	ND	µg/L	1
ETM1-S87	8/2/2023	Lead	2.4	µg/L	1
ETM1-S88	8/2/2023	Lead	1.4	µg/L	1
ETM1-DF89	8/2/2023	Lead	ND	µg/L	1
ETM1-DF90	8/2/2023	Lead	ND	µg/L	1
ETM1-S91	8/2/2023	Lead	7.3	µg/L	1

ETM1-S92	8/2/2023	Lead	1.1	µg/L	1
ETM1-S93	8/2/2023	Lead	2.6	µg/L	1
ETM1-S94	8/2/2023	Lead	8.1	µg/L	1
ETM1-S95	8/2/2023	Lead	2.9	µg/L	1
ETM1-S96	8/2/2023	Lead	ND	µg/L	1
ETM1-S97	8/2/2023	Lead	7.8	µg/L	1
ETM1-S98	8/2/2023	Lead	2.5	µg/L	1
ETM1-S99	8/2/2023	Lead	1.4	µg/L	1
ETM1-S100	8/2/2023	Lead	1.7	µg/L	1
ETM1-S101	8/2/2023	Lead	3.0	µg/L	1
ETM1-S102	8/2/2023	Lead	6.0	µg/L	1
ETM1-S103	8/2/2023	Lead	ND	µg/L	1
ETM1-S104	8/2/2023	Lead	2.0	µg/L	1
ETM1-S105	8/2/2023	Lead	ND	µg/L	1
ETM1-S106	8/2/2023	Lead	1.4	µg/L	1
ETM1-S107	8/2/2023	Lead	3.2	µg/L	1
ETM1-S108	8/2/2023	Lead	3.4	µg/L	1
ETM1-S109	8/2/2023	Lead	7.1	µg/L	1
ETM1-S110	8/2/2023	Lead	5.4	µg/L	1
ETM1-S111	8/2/2023	Lead	7.3	µg/L	1
ETM1-S112	8/2/2023	Lead	5.8	µg/L	1
ETM1-S113	8/2/2023	Lead	4.9	µg/L	1
ETM1-S114	8/2/2023	Lead	4.0	µg/L	1
ETM1-S115	8/2/2023	Lead	5.3	µg/L	1
ETM1-S116	8/2/2023	Lead	ND	µg/L	1
ETM1-DF117	8/2/2023	Lead	ND	µg/L	1
ETM1-DF118	8/2/2023	Lead	ND	µg/L	1
ETM1-S119	8/2/2023	Lead	ND	µg/L	1
ETM1-O120	8/2/2023	Lead	ND	µg/L	1
ETM1-S121	8/2/2023	Lead	ND	µg/L	1
ETM1-S122	8/2/2023	Lead	ND	µg/L	1
ETM1-O123	8/2/2023	Lead	ND	µg/L	1
ETM1-O124	8/2/2023	Lead	ND	µg/L	1
ETM1-O125	8/2/2023	Lead	ND	µg/L	1
ETM2-S126	8/2/2023	Lead	ND	µg/L	1
ETM2-DF127	8/2/2023	Lead	ND	µg/L	1
ETM2-DF128	8/2/2023	Lead	ND	µg/L	1
ETM2-S129	8/2/2023	Lead	ND	µg/L	1
ETM2-S130	8/2/2023	Lead	ND	µg/L	1
ETM2-S131	8/2/2023	Lead	ND	µg/L	1
ETM2-S132	8/2/2023	Lead	ND	µg/L	1
ETM2-S133	8/2/2023	Lead	ND	µg/L	1
ETM2-S134	8/2/2023	Lead	ND	µg/L	1
ETM2-S135	8/2/2023	Lead	ND	µg/L	1
ETM2-S136	8/2/2023	Lead	ND	µg/L	1
ETM2-S137	8/2/2023	Lead	1.2	µg/L	1
ETM2-S138	8/2/2023	Lead	ND	µg/L	1
ETM2-O139	8/2/2023	Lead	ND	µg/L	1

ETM2-DF140	8/2/2023	Lead	ND	µg/L	1
ETM2-DF141	8/2/2023	Lead	ND	µg/L	1
ETM2-S142	8/2/2023	Lead	2.4	µg/L	1
ETM2-S143	8/2/2023	Lead	ND	µg/L	1
ETM2-S144	8/2/2023	Lead	ND	µg/L	1
ETM2-S145	8/2/2023	Lead	3.6	µg/L	1
ETM2-S146	8/2/2023	Lead	ND	µg/L	1
ETM2-S147	8/2/2023	Lead	ND	µg/L	1
ETM2-S148	8/2/2023	Lead	ND	µg/L	1
ETM2-S149	8/2/2023	Lead	ND	µg/L	1
ETM2-S150	8/2/2023	Lead	ND	µg/L	1
ETM2-S151	8/2/2023	Lead	ND	µg/L	1
ETM2-S152	8/2/2023	Lead	ND	µg/L	1
ETM2-S153	8/2/2023	Lead	1.1	µg/L	1
ETM2-S154	8/2/2023	Lead	ND	µg/L	1
ETM2-DF155	8/2/2023	Lead	ND	µg/L	1
ETM2-DF156	8/2/2023	Lead	ND	µg/L	1

µg/L: micrograms per liter

Bolded results indicate results above reporting limits

ATTACHMENT D

East Trails Middle School Laboratory Analytical Report

September 25, 2023

Lindsay E. James
Blackstone Environmental, Inc.
16200 Foster Street
Overland Park, KS 66085
TEL: (913) 956-4160
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: Lees Summit School Dist DW East Trails Middle

WorkOrder: 23080304

Dear Lindsay E. James:

TEKLAB, INC received 156 samples on 8/3/2023 11:50:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley
Project Manager
(618)344-1004 ex 44
patrickriley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	163
Chain of Custody	Appended

Client: Blackstone Environmental, Inc.**Work Order:** 23080304**Client Project:** Lees Summit School Dist DW East Trails Middle**Report Date:** 25-Sep-23**Abbr Definition**

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Cooler Receipt Temp: N/A °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: Blackstone Environmental, Inc.**Work Order:** 23080304**Client Project:** Lees Summit School Dist DW East Trails Middle**Report Date:** 25-Sep-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-001

Client Sample ID: ETM1-DF1

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 12:39	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-002

Client Sample ID: ETM1-DF2

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 12:42	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-003

Client Sample ID: ETM1-DF3

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 12:46	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-004

Client Sample ID: ETM1-DF4

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 12:49	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-005

Client Sample ID: ETM1-DF5

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 12:52	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-006

Client Sample ID: ETM1-DF6

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:23

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 12:55	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-007

Client Sample ID: ETM1-DF7

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:23

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 12:59	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-008

Client Sample ID: ETM1-DF8

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 13:02	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-009

Client Sample ID: ETM1-DF9

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 13:38	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-010

Client Sample ID: ETM1-DF10

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 13:15	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-011

Client Sample ID: ETM1-DF11

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 13:18	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-012

Client Sample ID: ETM1-S12

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 13:22	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-013

Client Sample ID: ETM1-S13

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 13:25	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-014

Client Sample ID: ETM1-S14

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.1	µg/L	1	09/15/2023 13:28	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-015

Client Sample ID: ETM1-S15

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 13:32	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-016

Client Sample ID: ETM1-S16

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 13:35	211072



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-017

Client Sample ID: ETM1-S17

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 21:35	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-018

Client Sample ID: ETM1-S18

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 21:58	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-019

Client Sample ID: ETM1-S19

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/15/2023 21:38	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-020

Client Sample ID: ETM1-S20

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 1:29	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-021

Client Sample ID: ETM1-S21

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 22:02	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-022

Client Sample ID: ETM1-S22

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 22:05	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-023

Client Sample ID: ETM1-O23

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.9	µg/L	1	09/15/2023 22:08	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-024

Client Sample ID: ETM1-O24

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.0	µg/L	1	09/15/2023 22:12	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-025

Client Sample ID: ETM1-O25

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.8	µg/L	1	09/15/2023 22:15	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-026

Client Sample ID: ETM1-S26

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 22:18	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-027

Client Sample ID: ETM1-O27

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 22:21	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-028

Client Sample ID: ETM1-DF28

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 22:41	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-029

Client Sample ID: ETM1-S29

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 1:33	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-030

Client Sample ID: ETM1-S30

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 22:45	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-031

Client Sample ID: ETM1-S31

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:41

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.4	µg/L	5	09/23/2023 1:36	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-032

Client Sample ID: ETM1-S32

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 22:48	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-033

Client Sample ID: ETM1-S33

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.2	µg/L	5	09/23/2023 1:40	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-034

Client Sample ID: ETM1-S34

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.0	µg/L	1	09/15/2023 22:51	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-035

Client Sample ID: ETM1-S35

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.1	µg/L	1	09/15/2023 22:54	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-036

Client Sample ID: ETM1-S36

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/15/2023 22:58	211119



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-037

Client Sample ID: ETM1-S37

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.3	µg/L	5	09/23/2023 1:44	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-038

Client Sample ID: ETM1-S38

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.0	µg/L	5	09/23/2023 1:47	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-039

Client Sample ID: ETM1-S39

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 2:02	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-040

Client Sample ID: ETM1-S40

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 20:46	211121



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-041

Client Sample ID: ETM1-S41

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 20:56	211121



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-042

Client Sample ID: ETM1-S42

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 2:06	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-043

Client Sample ID: ETM1-S43

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 2:09	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-044

Client Sample ID: ETM1-S44

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 20:49	211121



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-045

Client Sample ID: ETM1-S45

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.0	µg/L	5	09/23/2023 2:13	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-046

Client Sample ID: ETM1-S46

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 2:17	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-047

Client Sample ID: ETM1-S47

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.2	µg/L	1	09/15/2023 20:52	211121



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-048

Client Sample ID: ETM1-S48

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:51

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 2:20	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-049

Client Sample ID: ETM1-S49

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:51

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 2:24	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-050

Client Sample ID: ETM1-S50

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:51

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	5	09/23/2023 2:28	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-051

Client Sample ID: ETM1-S51

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.9	µg/L	1	09/15/2023 21:15	211121



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-052

Client Sample ID: ETM1-S52

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.8	µg/L	5	09/23/2023 2:50	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-053

Client Sample ID: ETM1-S53

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.9	µg/L	5	09/23/2023 2:53	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-054

Client Sample ID: ETM1-S54

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	5	09/23/2023 2:57	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-055

Client Sample ID: ETM1-S55

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 3:01	211166



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-056

Client Sample ID: ETM1-S56

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 21:19	211121



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-057

Client Sample ID: ETM1-S57

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	5	09/23/2023 0:01	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-058

Client Sample ID: ETM1-S58

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 23:01	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-059

Client Sample ID: ETM1-DF59

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:59

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 23:04	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-060

Client Sample ID: ETM1-DF60

Matrix: DRINKING WATER

Collection Date: 08/02/2023 8:59

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 23:08	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-061

Client Sample ID: ETM1-S61

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.0	µg/L	5	09/23/2023 0:05	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-062

Client Sample ID: ETM1-S62

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 23:11	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-063

Client Sample ID: ETM1-S63

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:01

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 0:08	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-064

Client Sample ID: ETM1-S64

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:01

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 23:47	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-065

Client Sample ID: ETM1-S65

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:01

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 0:12	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-066

Client Sample ID: ETM1-S66

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:02

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 23:24	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-067

Client Sample ID: ETM1-S67

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:02

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.1	µg/L	1	09/15/2023 23:28	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-068

Client Sample ID: ETM1-S68

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 23:31	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-069

Client Sample ID: ETM1-S69

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.1	µg/L	1	09/15/2023 23:34	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-070

Client Sample ID: ETM1-S70

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.8	µg/L	1	09/15/2023 23:37	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-071

Client Sample ID: ETM1-071

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 23:41	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-072

Client Sample ID: ETM1-S72

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.2	µg/L	1	09/16/2023 0:30	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-073

Client Sample ID: ETM1-S73

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 23:44	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-074

Client Sample ID: ETM1-S74

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.8	µg/L	1	09/16/2023 0:07	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-075

Client Sample ID: ETM1-S75

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.6	µg/L	1	09/16/2023 0:11	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-076

Client Sample ID: ETM1-S76

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.2	µg/L	1	09/16/2023 0:14	211122



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-077

Client Sample ID: ETM1-S77

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.0	µg/L	1	09/16/2023 0:17	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-078

Client Sample ID: ETM1-S78

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.9	µg/L	1	09/16/2023 0:21	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-079

Client Sample ID: ETM1-S79

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.5	µg/L	1	09/16/2023 0:24	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-080

Client Sample ID: ETM1-S80

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.3	µg/L	1	09/16/2023 1:13	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-081

Client Sample ID: ETM1-S81

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 0:27	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-082

Client Sample ID: ETM1-S82

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 0:50	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-083

Client Sample ID: ETM1-S83

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.5	µg/L	1	09/16/2023 0:54	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-084

Client Sample ID: ETM1-S84

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	5	09/23/2023 0:34	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-085

Client Sample ID: ETM1-S85

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.6	µg/L	1	09/16/2023 0:57	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-086

Client Sample ID: ETM1-S86

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 1:00	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-087

Client Sample ID: ETM1-S87

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:13

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.4	µg/L	1	09/16/2023 1:04	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-088

Client Sample ID: ETM1-S88

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:13

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	5	09/23/2023 0:38	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-089

Client Sample ID: ETM1-DF89

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 1:07	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-090

Client Sample ID: ETM1-DF90

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 1:10	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-091

Client Sample ID: ETM1-S91

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		7.3	µg/L	1	09/16/2023 1:57	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-092

Client Sample ID: ETM1-S92

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.1	µg/L	1	09/16/2023 1:33	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-093

Client Sample ID: ETM1-S93

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.6	µg/L	1	09/16/2023 1:37	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-094

Client Sample ID: ETM1-S94

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.1	µg/L	1	09/16/2023 1:40	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-095

Client Sample ID: ETM1-S95

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.9	µg/L	1	09/16/2023 1:43	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-096

Client Sample ID: ETM1-S96

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 1:47	211123



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-097

Client Sample ID: ETM1-S97

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		7.8	µg/L	1	09/16/2023 1:50	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-098

Client Sample ID: ETM1-S98

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.5	µg/L	1	09/16/2023 1:53	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-099

Client Sample ID: ETM1-S99

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	1	09/16/2023 2:17	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-100

Client Sample ID: ETM1-S100

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.7	µg/L	1	09/16/2023 2:40	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-101

Client Sample ID: ETM1-S101

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.0	µg/L	1	09/16/2023 2:20	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-102

Client Sample ID: ETM1-S102

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.0	µg/L	1	09/16/2023 2:23	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-103

Client Sample ID: ETM1-S103

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 2:26	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-104

Client Sample ID: ETM1-S104

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.0	µg/L	1	09/16/2023 2:30	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-105

Client Sample ID: ETM1-S105

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 2:33	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-106

Client Sample ID: ETM1-S106

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	1	09/16/2023 2:36	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-107

Client Sample ID: ETM1-S107

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.2	µg/L	1	09/16/2023 3:00	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-108

Client Sample ID: ETM1-S108

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.4	µg/L	1	09/16/2023 3:03	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-109

Client Sample ID: ETM1-S109

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:33

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		7.1	µg/L	1	09/16/2023 3:06	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-110

Client Sample ID: ETM1-S110

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:33

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		5.4	µg/L	1	09/16/2023 3:10	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-111

Client Sample ID: ETM1-S111

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:33

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		7.3	µg/L	1	09/16/2023 3:13	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-112

Client Sample ID: ETM1-S112

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		5.8	µg/L	1	09/16/2023 3:23	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-113

Client Sample ID: ETM1-S113

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.9	µg/L	1	09/16/2023 3:16	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-114

Client Sample ID: ETM1-S114

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.0	µg/L	1	09/16/2023 3:20	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-115

Client Sample ID: ETM1-S115

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		5.3	µg/L	1	09/16/2023 3:43	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-116

Client Sample ID: ETM1-S116

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/16/2023 3:46	211136



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-117

Client Sample ID: ETM1-DF117

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 14:08	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-118

Client Sample ID: ETM1-DF118

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 14:12	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-119

Client Sample ID: ETM1-S119

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:39

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 14:16	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-120

Client Sample ID: ETM1-O120

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:41

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 14:19	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-121

Client Sample ID: ETM1-S121

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 14:23	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-122

Client Sample ID: ETM1-S122

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 14:27	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-123

Client Sample ID: ETM1-O123

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 14:30	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-124

Client Sample ID: ETM1-O124

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 14:34	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-125

Client Sample ID: ETM1-O125

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 14:38	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-126

Client Sample ID: ETM2-S126

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 7:59	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-127

Client Sample ID: ETM2-DF127

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 8:03	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-128

Client Sample ID: ETM2-DF128

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:56

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 8:14	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-129

Client Sample ID: ETM2-S129

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:56

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 8:18	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-130

Client Sample ID: ETM2-S130

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 8:29	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-131

Client Sample ID: ETM2-S131

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 8:43	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-132

Client Sample ID: ETM2-S132

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 8:47	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-133

Client Sample ID: ETM2-S133

Matrix: DRINKING WATER

Collection Date: 08/02/2023 9:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 8:51	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-134

Client Sample ID: ETM2-S134

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:01

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 8:54	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-135

Client Sample ID: ETM2-S135

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:01

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/23/2023 0:41	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-136

Client Sample ID: ETM2-S136

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:02

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 8:58	211138



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-137

Client Sample ID: ETM2-S137

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:02

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.2	µg/L	1	09/18/2023 9:02	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-138

Client Sample ID: ETM2-S138

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 9:05	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-139

Client Sample ID: ETM2-O139

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 9:09	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-140

Client Sample ID: ETM2-DF140

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:07

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 9:13	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-141

Client Sample ID: ETM2-DF141

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/18/2023 9:16	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-142

Client Sample ID: ETM2-S142

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.4	µg/L	1	09/18/2023 9:31	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-143

Client Sample ID: ETM2-S143

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 16:28	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-144

Client Sample ID: ETM2-S144

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 16:31	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-145

Client Sample ID: ETM2-S145

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.6	µg/L	1	09/15/2023 16:35	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-146

Client Sample ID: ETM2-S146

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 16:39	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-147

Client Sample ID: ETM2-S147

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 16:42	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-148

Client Sample ID: ETM2-S148

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:13

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 16:53	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-149

Client Sample ID: ETM2-S149

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:13

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 16:57	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-150

Client Sample ID: ETM2-S150

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:14

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 17:19	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-151

Client Sample ID: ETM2-S151

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:14

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 17:23	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-152

Client Sample ID: ETM2-S152

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:14

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 17:26	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-153

Client Sample ID: ETM2-S153

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.1	µg/L	5	09/23/2023 0:45	211167



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-154

Client Sample ID: ETM2-S154

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 17:30	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-155

Client Sample ID: ETM2-DF155

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 17:34	211140



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Lab ID: 23080304-156

Client Sample ID: ETM2-DF156

Matrix: DRINKING WATER

Collection Date: 08/02/2023 10:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 17:37	211140



Receiving Check List

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080304

Client Project: Lees Summit School Dist DW East Trails Middle

Report Date: 25-Sep-23

Carrier: Spee Dee

Received By: TWM

Completed by:

On:

03-Aug-23

Amber Dilallo

Reviewed by:

On:

04-Aug-23

Ellie Hopkins

Pages to follow:

Chain of custody

16

Extra pages included

0

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C N/A

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice ☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☒

No ☐

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory. - amberdilallo - 8/3/2023 1:41:14 PM

CHAIN OF CUSTODY

pg. 1 of 16 Work order # 23080304

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James (913) 495-9990
 E-Mail: ljames@blackstone-env.com

Phone: (913) 495-9990
 Fax:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Samples on: ☐ ICE ☐ BLUE ICE ☒ NO ICE ☐ LG#
 Preserved in: ☒ LAB ☐ FIELD
 Lab Notes

FOR LAB USE ONLY

Client Comments:

East Trails Middle School

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED													
Lee's Summit School Dist. DW		AR TB		MATRIX													
Results Requested		Billing Instructions		Date/Time Sampled		Groundwater		Special Waste		Sludge		Soil		Drinking Water		Aqueous	
Lab Use Only	Sample Identification	Sample Identification	Date/Time Sampled	UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER						
23080304	ETM1 - DF1	ETM1 - DF1	8/2/23 8:18	X													
002	- DF2	- DF2	8:18														
003	- DF3	- DF3	8:20														
004	- DF4	- DF4	8:22														
005	- DF5	- DF5	8:22														
006	- DF6	- DF6	8:23														
007	- DF7	- DF7	8:23														
008	- DF8	- DF8	8:24														
009	- DF9	- DF9	8:24														
010	- DF10	- DF10	8:25														

Relinquished By		Date/Time		Received By		Date/Time	
V. [Signature]		8/2/23 11:20		[Signature]		8/2/23 1200	
[Signature]		8/2/23 1600		[Signature]		8-3-23 1150 8-3-23	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 2 of 16 Work order # 2280304

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
Address: 16200 Foster Street
City / State / Zip: Overland Park, KS 66085
Contact: Lindsay E. James (913) 495-9990
E-Mail: ljames@blackstone-env.com

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Preserved in: ☐ LAB ☐ FIELD **FOR LAB USE ONLY**
Lab Notes

Client Comments:

East Trails Middle School

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED																															
Lee's Summit School Dist. DW		AR TB		Matrix				Groundwater								Special Waste				Sludge				Soil				Drinking Water				Aqueous			
Results Requested		Billing Instructions		# and Type of Containers																															
<input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)				OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES																															
Lab Use Only	Sample Identification	Date/Time Sampled																																	
23080304	ETM1 - DF11	8/2/23 8:25	X																																
012	-S12	8:27																																	
013	-S13	8:27																																	
014	-S14	8:28																																	
015	-S15	8:28																																	
016	-S16	8:29																																	
017	-S17	8:29																																	
018	-S18	8:30																																	
019	-S19	8:30																																	
020	-O20	8:31																																	
Relinquished By				Date/Time				Received By				Date/Time																							
V. Davis				8/2/23 11:20				W. Davis				8/2/23 1200																							
E. Davis				8/2/23 1600				E. Davis				8-3-23 1150																							

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 3 of 6 Work order # 23080301

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG#
Address: 16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes
Contact: Lindsay E. James (913) 495-9990	Client Comments: ETMS
E-Mail: ljames@blackstone-env.com	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED													
Lee's Summit School Dist. DW		AR TB		Billing Instructions				# and Type of Containers				MATRIX					
Lab Use Only	Results Requested	Sample Identification	Date/Time Sampled	OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead
23080301	Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) Other <input type="checkbox"/> 3 Day (50% Surcharge)	ETMS1-S21	8/2/23 8:32	X								X					
022		- S22	8:32														
023		- 023	8:34														
024		- 024	8:34														
025		- 025	8:35														
026		- S26	8:36														
027		- 027	8:37														
028		- DF28	8:37														
029		- S29	8:38														
030		- S30	8:40														
Relinquished By				Date/Time				Received By				Date/Time					
Vicki Parker				8/2/23 11:20				W. [Signature]				8/2/23 1200					
W. [Signature]				8/2/23 1600				W. [Signature]				8/3/23 1150					

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc. Address: 16200 Foster Street City / State / Zip: Overland Park, KS 66085 Contact: Lindsay E. James (913) 495-9990 E-Mail: ljames@blackstone-env.com		Preserved in: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG# FOR LAB USE ONLY Lab Notes	
Client Comments: ETMS			

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED													
Lee's Summit School Dist. DW		AR TB		MATRIX													
Results Requested		Billing Instructions		Aqueous						Groundwater							
<input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Date/Time Sampled		Drinking Water						Special Waste							
Sample Identification		Date/Time Sampled		Sludge						Soil							
Lab Use Only		Date/Time Sampled		DW Lead													
23080304	ETMS - S31	8/2/23	8:41	X													
032	-S32		8:42														
033	-S33		8:42														
034	-S34		8:42														
035	-S35		8:42														
036	-S36		8:43														
037	-S37		8:44														
038	-S38		8:45														
039	-S39		8:48														
040	-S40		8:48														
Relinquished By				Date/Time				Received By				Date/Time					
V. J. [Signature]				8/2/23 11:20				L. [Signature]				8/2/23 11:50					
L. [Signature]				8/2/23 1600				[Signature]				8/2/23 1600					

pg. 5 of 16 Work order # 23080304

pg. 5 of 16 Work order #

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C LTG# _____

Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY

Lab Notes

Client Comments:

Client Comments:

ETMS

BottleOrder: 82000



CHAIN OF CUSTODY

pg. 6 of 16 Work order # 23080304

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG#
Address: 16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes
Contact: Lindsay E. James (913) 495-9990	
E-Mail: ljames@blackstone-env.com	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Client Comments:

ETMS

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED															
Lee's Summit School Dist. DW		AR TB		Billing Instructions				Matrix				Indicate Analysis Requested							
Results Requested	Sample Identification	Date/Time Sampled	# and Type of Containers	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead										
Standard	1-2 Day (100% Surcharge)	3 Day (50% Surcharge)	OTHER																
23080304	ETMS1 - S51	8/2/23 8:52	X						X										
052	- S52	8:52																	
053	- S53	8:52																	
054	- S54	8:53																	
055	- S55	8:53																	
056	- S56	8:55																	
057	- S57	8:57																	
058	- S58	8:57																	
059	- DF59	8:59																	
060	- DF60	8:59																	

Relinquished By	Date/Time	Received By	Date/Time
V. J. Pak	8/2/23 11:20	W. J. Pak	8/2/23 1200
W. J. Pak	8/2/23 6:00	W. J. Pak	8/3/23 1150

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



CHAIN OF CUSTODY

pg. 7 of 16 Work order # 23080304

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG#
Address: 16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes
Contact: Lindsay E. James (913) 495-9990	Client Comments:
E-Mail: ljames@blackstone-env.com	ETMS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED															
Lee's Summit School Dist. DW		AR TB		Billing Instructions				Matrix				Indicate Analysis Requested							
Lab Use Only	Results Requested	Sample Identification	Date/Time Sampled	# and Type of Containers								Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead		
	Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) Other <input type="checkbox"/> 3 Day (50% Surcharge)			UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER								
23080304		ETMS1-S61	8/2/23 9:00	X															
062		-S62	9:00																
063		-S63	9:01																
064		-S64	9:01																
065		-S65	9:01																
066		-S66	9:02																
067		-S67	9:02																
068		-S68	9:03																
069		-S69	9:03																
070		-S70	9:04																
Relinquished By				Date/Time				Received By				Date/Time							
Vicki				8/2/23 11:20				[Signature]				8/2/23 1200							
L. E. James				8/2/23 1600				[Signature]				8-3-23 1600							

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



13080304




13080304

Client: _____	Blackstone Environmental, Inc.	_____	_____	_____	_____
Address: _____	16200 Foster Street	_____	_____	_____	_____
City / State / Zip _____	Overland Park, KS 66085	_____	_____	_____	_____
Contact: _____	Lindsay E. James	Phone: _____	(913) 495-9990	_____	_____
E-Mail: _____	ljames@blackstone-env.com	Fax: _____	_____	_____	_____

Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE	_____ °C	_____ LTG#
Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD	<u>FOR LAB USE ONLY</u>	
Lab Notes	_____	
Client Comments:	_____	

ETMS

[illegible]

Relinquished By	Date/Time	Received By	Date/Time
Vetric Mh	8/2/23 11:20		8/2/23 1200
	8/2/23 600		8-3-23 1150

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG#
Address: 16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes:
Contact: Lindsay E. James (913) 495-9990	Client Comments:
E-Mail: ljames@blackstone-env.com	ETMS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED																													
Lee's Summit School Dist. DW		AR TB		Billing Instructions				MATRIX																									
Results Requested		Sample Identification		Date/Time Sampled		# and Type of Containers				Groundwater				Special Waste				Sludge				Soil				Drinking Water				Aqueous			
Lab Use Only	Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) Other <input type="checkbox"/> 3 Day (50% Surcharge)																																
23080304		ETMS1-S81		8/12/23	9:11	X																											
082		-S82			9:11																												
083		-S83			9:11																												
084		-S84			9:12																												
085		-S85			9:12																												
086		-S86			9:12																												
087		-S87			9:13																												
088		-S88			9:13																												
089		-DF89			9:17																												
090		-DF90			9:17																												
Relinquished By				Date/Time				Received By				Date/Time																					
Vicki Pak				8/12/23 11:20				L. James				8/12/23 1200																					
L. James				8/12/23 1600				8/12/23 1600				8-3-23 1150																					

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



00369

FAX: (618) 344-1005

Client: _____ Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> _____ °C <input type="checkbox"/> LTG# _____
Address: _____ 16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u>
City / State / Zip _____ Overland Park, KS 66085	Lab Notes _____
Contact: _____ Lindsay E. James	
E-Mail: _____ ljames@blackstone-env.com	
Phone: _____ (913) 495-9990	
Fax: _____	
Client Comments: _____	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED						
Lee's Summit School Dist. DW										
<input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers						
Lab Use Only		Sample Identification	Date/Time Sampled							
ETM1 - S91		8/2/23 9:24	X							
- S92		9:25								
- S93		9:25								
- S94		9:25								
- S95		9:26								
- S96		9:26								
- S97		9:26								
- S98		9:27								
- S99		9:27								
- S100		9:28								
Relinquished By				Date/Time		Received By		Date/Time		
Vicki [Signature]				8/2/23 11:20		[Signature]		8/2/23 12:00		
C. [Signature]				8/2/23 1600		[Signature]		8.3.23 1150		



TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James Phone: (913) 495-9990
 E-Mail: ljames@blackstone-env.com Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
 Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY
 Lab Notes

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Client Comments:

ETMS

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED											
Lee's Summit School Dist. DW		AR TB													
Results Requested		Billing Instructions		MATRIX											
<input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)															
Lab Use Only	Sample Identification	Date/Time Sampled	# and Type of Containers												
			OTHER												
			NaHSO4												
			MeOH												
			HCL												
			H2SO4												
			NaOH												
			HNO3												
			UNPRES												
</															

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client:	Blackstone Environmental, Inc.	Samples on:	<input type="checkbox"/> ICE	<input type="checkbox"/> BLUE ICE	<input type="checkbox"/> NO ICE	<input type="checkbox"/> °C	<input type="checkbox"/> LTG#
Address:	16200 Foster Street	Preserved in:	<input type="checkbox"/> LAB	<input type="checkbox"/> FIELD	FOR LAB USE ONLY		
City / State / Zip	Overland Park, KS 66085	Lab Notes					
Contact:	Lindsay E. James (913) 495-9990	Client Comments:	ETMS				
E-Mail:	ljames@blackstone-env.com						

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED													
Lee's Summit School Dist. DW		AR TB		MATRIX													
Results Requested		Billing Instructions		# and Type of Containers				Groundwater				Special Waste					
Standard <input type="checkbox"/> 1-2 Day (100% Surcharge)		Date/Time Sampled		OTHER				Drinking Water				Sludge					
Other <input type="checkbox"/> 3 Day (50% Surcharge)				NaHSO4				Soil				Aqueous					
Lab Use Only	Sample Identification	Date/Time Sampled		H2SO4	NaOH	HNO3	UNPRES										
23080304	ETM1 - S111	8/12/23 9:33	X														
112	- S112	9:34															
113	- S113	9:34															
114	- S114	9:34															
115	- S115	9:34															
116	- S116	9:34															
117	- DF117	9:36															
118	- DF118	9:36															
119	- S119	9:39															
120	- O120	9:41															
Relinquished By		Date/Time		Received By				Date/Time									
Vicki Bink		8/12/23 11:20		[Signature]				8/12/23 1200									
[Signature]		8/12/23 1600		[Signature]				8/12/23 1150									

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



73080304

73080304

73080304

73080304

BottleOrder: 82000



TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG#
Address: 16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes
Contact: Lindsay E. James (913) 495-9990	Client Comments:
E-Mail: ljames@blackstone-env.com	ETMS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED															
Lee's Summit School Dist. DW		AR JB		Billing Instructions				MATRIX											
Results Requested		Sample Identification		Date/Time Sampled		# and Type of Containers				Groundwater				Special Waste					
Standard	1-2 Day (100% Surcharge)	Other	3 Day (50% Surcharge)					OTHER				Sludge				Soil			
								NaHSO4				Drinking Water				Aqueous			
								MeOH				X							
								HCL											
								H2SO4											
								NaOH											
								HNO3											
								UNPRES											
23080304	ETM2 - S131			8/12/23	9:57	X													
132	-S132				9:58														
133	-S133				9:58														
134	-S134				10:01														
135	-S135				10:01														
136	-S136				10:02														
137	-S137				10:02														
138	-S138				10:04														
139	-O139				10:04														
140	-DF140				10:07														
Relinquished By				Date/Time				Received By				Date/Time							
Viti B...				8/12/23 11:20				W. J...				8/12/23 1200							
C. B...				8/12/23 1600				S. J...				8/3/23 1650							

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG#
Address: 16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes
Contact: Lindsay E. James (913) 495-9990	Client Comments:
E-Mail: ljames@blackstone-env.com	ETMS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name AR TB		INDICATE ANALYSIS REQUESTED														
Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers		MATRIX												
Lab Use Only	Sample Identification	Date/Time Sampled		OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead	
23080304	ETM2 - DE141	8/12/23 10:10	X									X						
142	- S142	10:10																
143	- S143	10:10																
144	- S144	10:10																
145	- S145	10:11																
146	- S146	10:12																
147	- S147	10:12																
148	- S148	10:13																
149	- S149	10:13																
150	- S150	10:14																
Relinquished By		Date/Time		Received By					Date/Time									
VSA		8/12/23 11:20		C. J. [Signature]					8/12/23 1200									
L. [Signature]		8/12/23 1600		Y R					8/12/23 1150									

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



Work order # 723

fax: (618) 344-1005

Client: _____ Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE	°C _____	LTG# _____
Address: _____ 16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD	<u>FOR LAB USE ONLY</u>	
City / State / Zip _____ Overland Park, KS 66085	Lab Notes		
Contact: _____ Lindsay E. James			
E-Mail: _____ ljames@blackstone-env.com			
Phone: _____ (913) 495-9990			
Fax: _____			
Client Comments:			

ETMS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

[illegible]

Relinquished By	Date/Time	Received By	Date/Time
V. R. R. R.	8/2/23 11:20	V. R. R. R.	8/2/23 12:00
V. R. R. R.	8/2/23 16:00	V. R. R. R.	8-3-23 1150

