

ATTACHMENT B

**Lee's Summit North High School
Field Forms**

Lee's Summit DW

Date Purged 7/27/23
Date Sampled 7/28/23

School LSN HS

Team CS-BB

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
1	1	x			SINK ACCESS FROM SECRETARY	1300	919
2	1	x			SINK IN LOUNGE 1139	1307	921
3			x		DOF OUTSIDE BATHROOM 918	1310	923
4			x		L DOF OUTSIDE 917	1311	923
5			x		R DOF OUTSIDE 917	1311	923
6		x			SINK IN 1156	1312	925
7		x			SINK IN NUSS 1148 FRONT	1315	928
8		x			SINK IN NUSS 1148 BACK	1315	928
9		x			L SINK IN 1101	1318	930
10		x			R SINK IN 1101	1318	930
11		x			L SINK IN 1102	1318	930
12		x			R SINK IN 1102	1318	930
13		x			SINK IN GEFAN HOUSE 1099	1319	930
14		x			GR. SINK IN 1103	1322	935
15		x			CLOCKWISE FROM DOOR 1103	1322	935
16		x			" " 1103	1322	935
17		x			" " 1103	1322	935
18		x			" " 1103	1322	935
19		x			" " 1103	1322	935
20		x			" " 1103	1322	935
21		x			" " 1103	1322	935
22		x			SINK IN 1095	1324	940
23		x			SINK IN 1094	1324	940
24		x			GR. SINK IN 1104	1332	944

Lee's Summit DW

Date Purged 7/27/23 School LSW HS Team RS + SO

Date Sampled _____

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
25		X			CLOCKWISE FROM DOOR 1104	1332	944
26		X			" " 1104	1332	944
27		X			" " 1104	1332	944
28		X			" " 1104	1332	944
29		X			" " 1104	1332	944
30		X			" " 1104	1332	944
31		X			" " 1104	1332	944
32		X			SINK IN 1093	1336	948
33		X			SINK IN 1092	1336	948
34		X			CLOCKWISE FROM DOOR 1105	1339	950
35		X			CLOCKWISE FROM DOOR 1105	1339	950
36		X			" " 1105	1339	950
37		X			" " 1105	1339	950
38		X			" " 1105	1339	950
39		X			" " 1105	1339	950
40		X			" " 1105	1339	950
41		X			" " 1105	1339	950
42		X			CLOCKWISE FROM DOOR 1106	1340	958
43		X			CLOCKWISE FROM DOOR 1106	1340	958
44		X			" " 1106	1340	958
45		X			" " 1106 - NOT WORKING	---	---
46		X			" " 1106	1340	958
47		X			" " 1106	1340	958
48		X			" " 1106	1340	958

Lee's Summit DW

Team 25 & 28

School LSW HS

Date Purged 7/27/23

Date Sampled _____

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
49		X			CLOCKWISE FROM DOOR 1106	1340	958
50		X			CTR SINK IN 1301	1342	1000
51		X			CLOCKWISE FROM DOOR 1301	1342	1000
52		X			" " " 1301	1342	1000
53		X			" " " 1301	1342	1000
54		X			" " " 1301	1342	1000
55		X			" " " 1301	1342	1000
56		X			" " " 1301	1342	1000
57		X			" " " 1301	1342	1000
58		X			SINK IN 1089	1344	1008
59		X			SINK IN 1089	1344	1008
60		X			SINK IN 1089	1344	1008
61		X			CTR SINK IN 1302	1348	1012
62		X			CLOCKWISE FROM DOOR 1302	1348	1012
63		X			" " " 1302	1348	1012
64		X			" " " 1302	1348	1012
65		X			" " " 1302	1348	1012
66		X			" " " 1302	1348	1012
67		X			" " " 1302	1348	1012
68		X			" " " 1302	1348	1012
69		X			CTR SINK IN 1304	1352	1016
70		X			CLOCKWISE FROM DOOR 1304	1352	1016
71		X			" " " 1304	1352	1016
72		X			" " " 1304	1352	1016

Lee's Summit DW

Team LS-BB

School LS-MS

Date Purged 7/27/23

Date Sampled

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
73		X			CLOCKWISE FROM DOOR 1304	1352	1016
74		X			" " 1304	1352	1016
75		X			" " 1304	1352	1016
76		X			" " 1304	1352	1016
77		X			L SINK IN 1088	1400	1020
78		X			R SINK IN 1088	1400	1020
79		X			CTR SINK IN 1306	1405	1025
80		X			CLOCKWISE FROM DOOR 1306	1405	1025
81		X			" " 1306	1405	1025
82		X			" " 1306	1405	1025
83		X			" " 1306	1405	1025
84		X			" " 1306	1405	1025
85		X			" " 1306	1405	1025
86		X			" " 1306	1405	1025
87		X			CTR SINK IN 1107	1408	1030
88		X			CLOCKWISE FROM DOOR 1107	1408	1030
89		X			" " 1107	1408	1030
90		X			" " 1107	1408	1030
91		X			" " 1107	1408	1030
92		X			" " 1107	1408	1030
93		X			" " 1107	1408	1030
94		X			" " 1107	1408	1030
95		X			" " 1107	1408	1030
96		X			CTR SINK IN 1120	1411	1035

Lee's Summit DW

Team FS + RB

Date Purged 7/27/23

School LSN HS

Date Sampled _____

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
97		X			CLOCKWISE FROM DOOR 1120	1411	1035
98		X			" " 1120	1411	1035
99		X			" " 1120	1411	1035
100		X			" " 1120	1411	1035
101		X			" " 1120	1411	1035
102		X			" " 1120	1411	1035
103		X			" " 1120	1411	1035
104		X			" " 1120	1411	1035
105		X			SINK IN STORAGE 107-1120	1413	1035
106			X		L DWG E1309	1419	1040
107			X		R DWG E1309	1419	1040
108		X			SINK IN 1110	1420	1048
109		X			SINK IN 1124	1424	1050
110		X			SINK OFF 1125	1428	1050
111		X			SINK IN 967 GALLERY	1438	1055
112		X			SINK IN 968	1441	1055
113		X			SINK IN 1163	1442	1055
114		X			SINK IN 1165 CLOCKWISE FROM DOOR	1448	1100
115		X			" " "	1448	1100
116		X			" " "	1448	1100
117		X			" " "	1448	1100
118		X			" " "	1448	1100
119		X			" " "	1448	1100
120		X			" " "	1448	1100

Lee's Summit DW

Team RS & RB

Date Purged 7/27/23

School LSU HS

Date Sampled _____

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
121	1			X	DESKWASHEN IN 1165	1448	1100
122		X			SINK 1168 CLOCKWISE FROM DOOR	1450	1110
123		X			SINK 1168 "	1450	1110
124		X			SINK 1168 "	1450	1110
125		X			SINK 1168 "	1450	1110
126		X			SINK IN 1167 CLOCKWISE FROM DOOR	1500	1115
127		X			SINK IN 1167	1500	1115
128		X			SINK IN 1167	1500	1115
129			X		L DWF OUTSIDE BOYS	1504	1117
130			X		R DWF OUTSIDE BOYS	1504	1117
131			X		L DWF OUTSIDE GIRLS	1504	1117
132			X		R DWF OUTSIDE GIRLS	1504	1117
133		X			SINK IN ART OFFICE 1172	1513	1120
134		X			L SINK IN 1173	1514	1122
135		X			M SINK IN 1173	1514	1122
136		X			R SINK IN 1173	1514	1122
137		X			L SINK IN 1174	1515	1124
138		X			M SINK IN 1174	1515	1124
139		X			R SINK IN 1174	1515	1124
140		X			L SINK IN 1175	1518	1126
141		X			M SINK IN 1175	1518	1126
142		X			R SINK IN 1175	1518	1126
143		X			SINK IN 1178	1522	1130
144			X		DWF IN 1178	1522	1130

Lee's Summit DW

Team LS RB

Date Purged 7/27/23
Date Sampled 7/28/23

School LSN HS

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
145	1	X			SINK IN 1001 / MAKEUP	1523	1135
146	1	X			SINK IN 1183	1525	1135
147		X			SINK IN 1188	1530	1138
148			X		DWF IN 1188	1530	1138
149		X			SINK IN 1181	1536	1140
150		X			SINK IN 1179	1538	1140
151		X			SINK OUTSIDE 1195G	1543	1144
152		X			SINK OUTSIDE 1195D	1543	1144
153			X		DWF IN 1190 - NOT WORKING	-	-
154			X		DWF IN 1189	1545	1144
155			X		DWF IN COMMONS 1200	1548	1146
156		X			L SINK IN CONC - INACCESSIBLE TO SAMPLE	1548	-
157		X			TR SINK IN CONC - INACCESSIBLE TO SAMPLE	1548	-
158			X		L DWF OUTSIDE CONC	1550	1146
159			X		R DWF OUTSIDE CONC	1550	1146
160			X		DWF IN FN BY MEN VR	1550	1146
161			X		DWF IN FN BY MENUS VR - NOT WORKING	1551	-
162			X		DWF OUTSIDE WEIGHT ROOM	1553	1155
163			X		DWF IN WOMEN'S LOCKERS ROOM	1600	1155
164			X		DWF IN VAR WOMEN'S LOCKERS ROOM	1601	1155
165		X			SINK IN BOSS SUITS 1208	1604	1155
166		X			SINK IN KITCHEN	1610	1200
167		X			" "	1610	1200
168		X			" "	1610	1200

Lee's Summit DW

Team ES + BS

School LSN HS

Date Purged 7/27/23

Date Sampled _____

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
169	1	X			SINK IN KITCHEN	1610	1200
170	1	X			" "	1610	1200
171	1	X			" "	1610	1200
172	1	X			SINK IN KITCHEN	1612	1200
173	1	X			" "	1612	1200
174	1	X			" "	1612	1200
175	1			X	COMBI OVEN	1612	1200
176	1	X			SINK ACROSS FROM 175	1612	1200
177	1	X			SINK IN KITCHEN	1614	1200
178	1	X			SINK IN KITCHEN	1614	1200
179	1			X	COMBI OVEN	1614	1200
180	1			X	ICE MACHINE	1615	1200
181	1	X			L SINK IN DISH	1618	1205
182	1	X			M SINK IN DISH	1618	1205
183	1	X			R SINK IN DISH	1618	1205
184	1			X	DISHWASHER	1618	1205
185	2		X		L DWF NEAR STAIRS/ELE	1620	1200
186	2		X		R DWF NEAR STAIRS/ELE	1620	1220
187	2		X		L DWF NEAR 2101	1620	1225
188	2		X		R DWF NEAR 2101	1620	1225
189	2		X		L DWF NEAR 2308	1622	1225
190	2		X		R DWF NEAR 2308	1622	1225
191	2		X		DWF OUTSIDE 2315	1624	1230
197	2	X			SINK IN 2130 - NOT DRAINING	1628	1230

ATTACHMENT C

Lee's Summit North High School Summary Table

Summary Table
Lee's Summit North HS

Sample ID	Date	Analyte	Result	Unit	Reporting Limit
LSNISK1	7/28/2023	Lead	ND	µg/L	1
LSNISK2	7/28/2023	Lead	ND	µg/L	1
LSNIDF3	7/28/2023	Lead	ND	µg/L	1
LSNIDF4	7/28/2023	Lead	ND	µg/L	1
LSNIDF5	7/28/2023	Lead	ND	µg/L	1
LSNISK6	7/28/2023	Lead	ND	µg/L	1
LSNISK7	7/28/2023	Lead	2.1	µg/L	1
LSNISK8	7/28/2023	Lead	2.2	µg/L	1
LSNISK9	7/28/2023	Lead	6.7	µg/L	1
LSNISK10	7/28/2023	Lead	6.3	µg/L	1
LSNISK11	7/28/2023	Lead	4.0	µg/L	1
LSNISK12	7/28/2023	Lead	6.0	µg/L	1
LSNISK13	7/28/2023	Lead	4.0	µg/L	1
LSNISK14	7/28/2023	Lead	9.6	µg/L	1
LSNISK15	7/28/2023	Lead	10.6	µg/L	1
LSNISK16	7/28/2023	Lead	8.5	µg/L	1
LSNISK17	7/28/2023	Lead	19.4	µg/L	1
LSNISK18	7/28/2023	Lead	12.3	µg/L	1
LSNISK19	7/28/2023	Lead	12.5	µg/L	1
LSNISK20	7/28/2023	Lead	12.1	µg/L	1
LSNISK21	7/28/2023	Lead	10.1	µg/L	1
LSNISK22	7/28/2023	Lead	3.4	µg/L	1
LSNISK23	7/28/2023	Lead	8.8	µg/L	1
LSNISK24	7/28/2023	Lead	24.5	µg/L	1
LSNISK25	7/28/2023	Lead	8.0	µg/L	1
LSNISK26	7/28/2023	Lead	35.0	µg/L	1
LSNISK27	7/28/2023	Lead	13.1	µg/L	1
LSNISK28	7/28/2023	Lead	21.5	µg/L	1
LSNISK29	7/28/2023	Lead	18.9	µg/L	1
LSNISK30	7/28/2023	Lead	15.6	µg/L	1
LSNISK31	7/28/2023	Lead	30.7	µg/L	1
LSNISK32	7/28/2023	Lead	22.8	µg/L	1
LSNISK33	7/28/2023	Lead	7.7	µg/L	1
LSNISK34	7/28/2023	Lead	36.1	µg/L	1
LSNISK35	7/28/2023	Lead	8.4	µg/L	1
LSNISK36	7/28/2023	Lead	9.6	µg/L	1
LSNISK37	7/28/2023	Lead	7.6	µg/L	1
LSNISK38	7/28/2023	Lead	11.8	µg/L	1
LSNISK39	7/28/2023	Lead	9.5	µg/L	1
LSNISK40	7/28/2023	Lead	8.8	µg/L	1
LSNISK41	7/28/2023	Lead	8.4	µg/L	1
LSNISK42	7/28/2023	Lead	26.8	µg/L	1
LSNISK43	7/28/2023	Lead	12.1	µg/L	1

LSNISK44	7/28/2023	Lead	12.8	µg/L	1
LSNISK46	7/28/2023	Lead	10.2	µg/L	1
LSNISK47	7/28/2023	Lead	13.7	µg/L	1
LSNISK48	7/28/2023	Lead	7.8	µg/L	1
LSNISK49	7/28/2023	Lead	19.7	µg/L	1
LSNISK50	7/28/2023	Lead	27.7	µg/L	1
LSNISK51	7/28/2023	Lead	24.9	µg/L	1
LSNISK52	7/28/2023	Lead	14.4	µg/L	1
LSNISK53	7/28/2023	Lead	17.0	µg/L	1
LSNISK54	7/28/2023	Lead	83.9	µg/L	1
LSNISK55	7/28/2023	Lead	15.9	µg/L	1
LSNISK56	7/28/2023	Lead	15.5	µg/L	1
LSNISK57	7/28/2023	Lead	12.1	µg/L	1
LSNISK58	7/28/2023	Lead	43.3	µg/L	1
LSNISK59	7/28/2023	Lead	9.1	µg/L	1
LSNISK60	7/28/2023	Lead	17.4	µg/L	1
LSNISK61	7/28/2023	Lead	15.9	µg/L	1
LSNISK62	7/28/2023	Lead	17.9	µg/L	1
LSNISK63	7/28/2023	Lead	20.5	µg/L	1
LSNISK64	7/28/2023	Lead	15.9	µg/L	1
LSNISK65	7/28/2023	Lead	15.2	µg/L	1
LSNISK66	7/28/2023	Lead	15.0	µg/L	1
LSNISK67	7/28/2023	Lead	13.1	µg/L	1
LSNISK68	7/28/2023	Lead	12.1	µg/L	1
LSNISK69	7/28/2023	Lead	32.1	µg/L	1
LSNISK70	7/28/2023	Lead	14.1	µg/L	1
LSNISK71	7/28/2023	Lead	11.1	µg/L	1
LSNISK72	7/28/2023	Lead	11.6	µg/L	1
LSNISK73	7/28/2023	Lead	9.3	µg/L	1
LSNISK74	7/28/2023	Lead	12.3	µg/L	1
LSNISK75	7/28/2023	Lead	13.3	µg/L	1
LSNISK76	7/28/2023	Lead	12.8	µg/L	1
LSNISK77	7/28/2023	Lead	29.5	µg/L	1
LSNISK78	7/28/2023	Lead	17.6	µg/L	1
LSNISK79	7/28/2023	Lead	17.5	µg/L	1
LSNISK80	7/28/2023	Lead	20.5	µg/L	1
LSNISK81	7/28/2023	Lead	13.2	µg/L	1
LSNISK82	7/28/2023	Lead	16.5	µg/L	1
LSNISK83	7/28/2023	Lead	19.2	µg/L	1
LSNISK84	7/28/2023	Lead	12.4	µg/L	1
LSNISK85	7/28/2023	Lead	12.6	µg/L	1
LSNISK86	7/28/2023	Lead	14.2	µg/L	1
LSNISK87	7/28/2023	Lead	15.2	µg/L	1
LSNISK88	7/28/2023	Lead	16.1	µg/L	1
LSNISK89	7/28/2023	Lead	12.3	µg/L	1
LSNISK90	7/28/2023	Lead	10.9	µg/L	1
LSNISK91	7/28/2023	Lead	11.0	µg/L	1
LSNISK92	7/28/2023	Lead	12.5	µg/L	1

LSNISK93	7/28/2023	Lead	11.0	µg/L	1
LSNISK94	7/28/2023	Lead	53.0	µg/L	1
LSNISK95	7/28/2023	Lead	26.5	µg/L	10
LSNISK96	7/28/2023	Lead	29.7	µg/L	1
LSNISK97	7/28/2023	Lead	7.4	µg/L	1
LSNISK98	7/28/2023	Lead	14.7	µg/L	1
LSNISK99	7/28/2023	Lead	9.4	µg/L	1
LSNISK100	7/28/2023	Lead	19.7	µg/L	1
LSNISK101	7/28/2023	Lead	15.1	µg/L	1
LSNISK102	7/28/2023	Lead	37.0	µg/L	1
LSNISK103	7/28/2023	Lead	11.9	µg/L	1
LSNISK104	7/28/2023	Lead	175	µg/L	1
LSNISK105	7/28/2023	Lead	4.0	µg/L	1
LSNIDF106	7/28/2023	Lead	ND	µg/L	1
LSNIDF107	7/28/2023	Lead	ND	µg/L	1
LSNISK108	7/28/2023	Lead	4.0	µg/L	1
LSNISK109	7/28/2023	Lead	2.0	µg/L	1
LSNISK110	7/28/2023	Lead	8.1	µg/L	1
LSNISK111	7/28/2023	Lead	ND	µg/L	1
LSNISK112	7/28/2023	Lead	8.0	µg/L	1
LSNISK113	7/28/2023	Lead	1.5	µg/L	1
LSNISK114	7/28/2023	Lead	1.4	µg/L	1
LSNISK115	7/28/2023	Lead	ND	µg/L	1
LSNISK116	7/28/2023	Lead	ND	µg/L	1
LSNISK117	7/28/2023	Lead	1.1	µg/L	1
LSNISK118	7/28/2023	Lead	ND	µg/L	1
LSNISK119	7/28/2023	Lead	ND	µg/L	1
LSNISK120	7/28/2023	Lead	ND	µg/L	1
LSNISK121	7/28/2023	Lead	ND	µg/L	1
LSNISK122	7/28/2023	Lead	ND	µg/L	1
LSNISK123	7/28/2023	Lead	1.7	µg/L	1
LSNISK124	7/28/2023	Lead	1.2	µg/L	1
LSNISK125	7/28/2023	Lead	ND	µg/L	1
LSNISK126	7/28/2023	Lead	1.7	µg/L	1
LSNISK127	7/28/2023	Lead	4.9	µg/L	1
LSNISK128	7/28/2023	Lead	10.1	µg/L	1
LSNIDF129	7/28/2023	Lead	ND	µg/L	1
LSNIDF130	7/28/2023	Lead	ND	µg/L	1
LSNIDF131	7/28/2023	Lead	ND	µg/L	1
LSNIDF132	7/28/2023	Lead	ND	µg/L	1
LSNISK133	7/28/2023	Lead	3.4	µg/L	1
LSNISK134	7/28/2023	Lead	3.5	µg/L	1
LSNISK135	7/28/2023	Lead	2.6	µg/L	1
LSNISK136	7/28/2023	Lead	3.1	µg/L	1
LSNISK137	7/28/2023	Lead	ND	µg/L	1
LSNISK138	7/28/2023	Lead	ND	µg/L	1
LSNISK139	7/28/2023	Lead	ND	µg/L	1
LSNISK140	7/28/2023	Lead	ND	µg/L	1

LSNISK141	7/28/2023	Lead	ND	µg/L	1
LSNISK142	7/28/2023	Lead	1.2	µg/L	1
LSNISK143	7/28/2023	Lead	ND	µg/L	1
LSNIDF144	7/28/2023	Lead	ND	µg/L	1
LSNISK145	7/28/2023	Lead	4.3	µg/L	1
LSNISK146	7/28/2023	Lead	ND	µg/L	1
LSNISK147	7/28/2023	Lead	2.1	µg/L	1
LSNIDF148	7/28/2023	Lead	ND	µg/L	1
LSNISK149	7/28/2023	Lead	ND	µg/L	1
LSNISK150	7/28/2023	Lead	8.8	µg/L	1
LSNISK151	7/28/2023	Lead	6.2	µg/L	1
LSNISK152	7/28/2023	Lead	ND	µg/L	1
LSNIDF154	7/28/2023	Lead	ND	µg/L	1
LSNIDF155	7/28/2023	Lead	ND	µg/L	1
LSNIDF158	7/28/2023	Lead	ND	µg/L	1
LSNIDF159	7/28/2023	Lead	ND	µg/L	1
LSNIDF160	7/28/2023	Lead	ND	µg/L	1
LSNIDF162	7/28/2023	Lead	ND	µg/L	1
LSNIDF163	7/28/2023	Lead	ND	µg/L	1
LSNIDF164	7/28/2023	Lead	ND	µg/L	1
LSNISK165	7/28/2023	Lead	3.1	µg/L	1
LSNISK166	7/28/2023	Lead	ND	µg/L	1
LSNISK167	7/28/2023	Lead	8.6	µg/L	1
LSNISK168	7/28/2023	Lead	4.2	µg/L	1
LSNISK169	7/28/2023	Lead	14.9	µg/L	1
LSNISK170	7/28/2023	Lead	1.4	µg/L	1
LSNISK171	7/28/2023	Lead	4.1	µg/L	1
LSNISK172	7/28/2023	Lead	ND	µg/L	1
LSNISK173	7/28/2023	Lead	ND	µg/L	1
LSNISK174	7/28/2023	Lead	1.8	µg/L	1
LSNIO175	7/28/2023	Lead	4.7	µg/L	1
LSNISK176	7/28/2023	Lead	3.8	µg/L	1
LSNISK177	7/28/2023	Lead	13.9	µg/L	1
LSNISK178	7/28/2023	Lead	ND	µg/L	1
LSNIO179	7/28/2023	Lead	4.0	µg/L	1
LSNIO180	7/28/2023	Lead	1.2	µg/L	1
LSNISK181	7/28/2023	Lead	ND	µg/L	1
LSNISK182	7/28/2023	Lead	ND	µg/L	1
LSNISK183	7/28/2023	Lead	ND	µg/L	1
LSNIO184	7/28/2023	Lead	ND	µg/L	1
LSN2DF185	7/28/2023	Lead	ND	µg/L	1
LSN2DF186	7/28/2023	Lead	ND	µg/L	1
LSN2DF187	7/28/2023	Lead	ND	µg/L	1
LSN2DF188	7/28/2023	Lead	ND	µg/L	1
LSN2DF189	7/28/2023	Lead	ND	µg/L	1
LSN2DF190	7/28/2023	Lead	ND	µg/L	1
LSN2DF191	7/28/2023	Lead	ND	µg/L	1
LSN2SK192	7/28/2023	Lead	1.4	µg/L	1

LSN2SK193	7/28/2023	Lead	ND	µg/L	1
LSN2SK194	7/28/2023	Lead	6.2	µg/L	1
LSN2SK195	7/28/2023	Lead	2.9	µg/L	1
LSN2SK196	7/28/2023	Lead	6.9	µg/L	1
LSN2DF198	7/28/2023	Lead	1.1	µg/L	1
LSN2DF199	7/28/2023	Lead	ND	µg/L	1
LSN2DF200	7/28/2023	Lead	ND	µg/L	1
LSNISK201	7/28/2023	Lead	14.1	µg/L	10
LSNISK202	7/28/2023	Lead	ND	µg/L	1

µg/L: micrograms per liter

Bolded results indicate detection above reporting limits

ATTACHMENT D

Lee's Summit North High School Laboratory Analytical Report

September 19, 2023

Lindsay E. James
Blackstone Environmental, Inc.
16200 Foster Street
Overland Park, KS 66085
TEL: (913) 956-4160
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: Lees Summit School Dist DW/LSN HS

WorkOrder: 23080087

Dear Lindsay E. James:

TEKLAB, INC received 196 samples on 8/1/2023 2:20:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley
Project Manager
(618)344-1004 ex 44
patrickriley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	203
Chain of Custody	Appended

Client: Blackstone Environmental, Inc.**Work Order:** 23080087**Client Project:** Lees Summit School Dist DW/LSN HS**Report Date:** 19-Sep-23**Abbr Definition**

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Cooler Receipt Temp: NA °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: Blackstone Environmental, Inc.**Work Order:** 23080087**Client Project:** Lees Summit School Dist DW/LSN HS**Report Date:** 19-Sep-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2023	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-001

Client Sample ID: LSNISK1

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 15:13	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-002

Client Sample ID: LSNISK2

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:21

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 15:17	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-003

Client Sample ID: LSNIDF3

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:23

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 15:21	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-004

Client Sample ID: LSNIDF4

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:23

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 19:30	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-005

Client Sample ID: LSNIDF5

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:23

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 15:46	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-006

Client Sample ID: LSNISK6

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 15:50	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW/LSN HS
Lab ID: 23080087-007
Matrix: DRINKING WATER

Work Order: 23080087
Report Date: 19-Sep-23
Client Sample ID: LSNISK7
Collection Date: 07/28/2023 9:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.1	µg/L	1	09/13/2023 15:54	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-008

Client Sample ID: LSNISK8

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.2	µg/L	1	09/13/2023 15:57	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-009

Client Sample ID: LSNISK9

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.7	µg/L	1	09/13/2023 16:01	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-010

Client Sample ID: LSNISK10

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.3	µg/L	5	09/12/2023 15:19	210963



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-011

Client Sample ID: LSNISK11

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.0	µg/L	1	09/13/2023 16:05	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-012

Client Sample ID: LSNISK12

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.0	µg/L	1	09/13/2023 16:08	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-013

Client Sample ID: LSNISK13

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.0	µg/L	1	09/13/2023 16:12	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-014

Client Sample ID: LSNISK14

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		9.6	µg/L	1	09/13/2023 16:16	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-015

Client Sample ID: LSNISK15

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.6	µg/L	1	09/13/2023 16:19	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-016

Client Sample ID: LSNISK16

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.5	µg/L	1	09/14/2023 19:41	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-017

Client Sample ID: LSNISK17

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		19.4	µg/L	1	09/13/2023 16:45	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-018

Client Sample ID: LSNISK18

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.3	µg/L	1	09/13/2023 16:49	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-019

Client Sample ID: LSNISK19

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.5	µg/L	1	09/13/2023 16:52	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-020

Client Sample ID: LSNISK20

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.1	µg/L	1	09/13/2023 16:56	210891



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-021

Client Sample ID: LSNISK21

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.1	µg/L	1	09/13/2023 17:00	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-022

Client Sample ID: LSNISK22

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.4	µg/L	1	09/13/2023 17:03	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-023

Client Sample ID: LSNISK23

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.8	µg/L	1	09/13/2023 17:07	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-024

Client Sample ID: LSNISK24

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		24.5	µg/L	1	09/13/2023 17:22	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-025

Client Sample ID: LSNISK25

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.0	µg/L	1	09/13/2023 17:25	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-026

Client Sample ID: LSNISK26

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		35.0	µg/L	1	09/13/2023 17:29	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-027

Client Sample ID: LSNISK27

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		13.1	µg/L	1	09/13/2023 17:33	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-028

Client Sample ID: LSNISK28

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		21.5	µg/L	1	09/13/2023 17:36	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-029

Client Sample ID: LSNISK29

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		18.9	µg/L	1	09/14/2023 19:52	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-030

Client Sample ID: LSNISK30

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		15.6	µg/L	1	09/13/2023 17:51	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-031

Client Sample ID: LSNISK31

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		30.7	µg/L	1	09/14/2023 20:14	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-032

Client Sample ID: LSNISK32

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		22.8	µg/L	1	09/13/2023 18:17	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-033

Client Sample ID: LSNISK33

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		7.7	µg/L	1	09/13/2023 18:20	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-034

Client Sample ID: LSNISK34

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		36.1	µg/L	1	09/13/2023 18:24	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-035

Client Sample ID: LSNISK35

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.4	µg/L	1	09/13/2023 18:28	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-036

Client Sample ID: LSNISK36

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		9.6	µg/L	1	09/13/2023 18:31	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-037

Client Sample ID: LSNISK37

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		7.6	µg/L	1	09/13/2023 18:35	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-038

Client Sample ID: LSNISK38

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.8	µg/L	1	09/13/2023 18:39	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-039

Client Sample ID: LSNISK39

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		9.5	µg/L	1	09/13/2023 18:42	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-040

Client Sample ID: LSNISK40

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.8	µg/L	1	09/13/2023 18:57	210894



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-041

Client Sample ID: LSNISK41

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.4	µg/L	1	09/13/2023 19:01	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-042

Client Sample ID: LSNISK42

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		26.8	µg/L	1	09/13/2023 19:04	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-043

Client Sample ID: LSNISK43

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.1	µg/L	1	09/13/2023 19:08	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-044

Client Sample ID: LSNISK44

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.8	µg/L	1	09/13/2023 19:12	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-045

Client Sample ID: LSNISK46

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.2	µg/L	1	09/13/2023 19:15	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-046

Client Sample ID: LSNISK47

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		13.7	µg/L	1	09/13/2023 19:19	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-047

Client Sample ID: LSNISK48

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		7.8	µg/L	1	09/13/2023 19:23	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-048

Client Sample ID: LSNISK49

Matrix: DRINKING WATER

Collection Date: 07/28/2023 9:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		19.7	µg/L	1	09/13/2023 19:26	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-049

Client Sample ID: LSNISK50

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		27.7	µg/L	1	09/13/2023 19:48	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-050

Client Sample ID: LSNISK51

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		24.9	µg/L	1	09/13/2023 19:52	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-051

Client Sample ID: LSNISK52

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		14.4	µg/L	1	09/13/2023 19:55	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-052

Client Sample ID: LSNISK53

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		17.0	µg/L	1	09/13/2023 19:59	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-053

Client Sample ID: LSNISK54

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		83.9	µg/L	1	09/13/2023 20:03	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-054

Client Sample ID: LSNISK55

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		15.9	µg/L	1	09/13/2023 20:06	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-055

Client Sample ID: LSNISK56

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		15.5	µg/L	1	09/13/2023 20:10	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-056

Client Sample ID: LSNISK57

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.1	µg/L	1	09/13/2023 20:14	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-057

Client Sample ID: LSNISK58

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		43.3	µg/L	1	09/13/2023 20:36	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-058

Client Sample ID: LSNISK59

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		9.1	µg/L	1	09/13/2023 20:39	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-059

Client Sample ID: LSNISK60

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		17.4	µg/L	1	09/13/2023 20:43	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-060

Client Sample ID: LSNISK61

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		15.9	µg/L	1	09/13/2023 20:47	210895



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-061

Client Sample ID: LSNISK62

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		17.9	µg/L	1	09/13/2023 20:50	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-062

Client Sample ID: LSNISK63

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		20.5	µg/L	1	09/13/2023 20:54	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-063

Client Sample ID: LSNISK64

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		15.9	µg/L	1	09/13/2023 20:58	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-064

Client Sample ID: LSNISK65

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		15.2	µg/L	1	09/13/2023 21:01	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-065

Client Sample ID: LSNISK66

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		15.0	µg/L	1	09/13/2023 21:05	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-066

Client Sample ID: LSNISK67

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		13.1	µg/L	1	09/14/2023 20:25	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-067

Client Sample ID: LSNISK68

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.1	µg/L	1	09/14/2023 20:29	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-068

Client Sample ID: LSNISK69

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		32.1	µg/L	1	09/14/2023 20:33	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-069

Client Sample ID: LSNISK70

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		14.1	µg/L	1	09/14/2023 20:55	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-070

Client Sample ID: LSNISK71

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.1	µg/L	1	09/14/2023 20:58	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-071

Client Sample ID: LSNISK72

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.6	µg/L	1	09/14/2023 21:02	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-072

Client Sample ID: LSNISK73

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		9.3	µg/L	1	09/14/2023 21:06	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-073

Client Sample ID: LSNISK74

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.3	µg/L	1	09/14/2023 21:09	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-074

Client Sample ID: LSNISK75

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		13.3	µg/L	1	09/14/2023 21:13	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-075

Client Sample ID: LSNISK76

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.8	µg/L	1	09/14/2023 21:17	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-076

Client Sample ID: LSNISK77

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		29.5	µg/L	1	09/13/2023 14:27	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-077

Client Sample ID: LSNISK78

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		17.6	µg/L	1	09/13/2023 14:30	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-078

Client Sample ID: LSNISK79

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		17.5	µg/L	1	09/13/2023 14:53	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-079

Client Sample ID: LSNISK80

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		20.5	µg/L	1	09/13/2023 14:56	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-080

Client Sample ID: LSNISK81

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		13.2	µg/L	1	09/13/2023 15:00	210893



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-081

Client Sample ID: LSNISK82

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		16.5	µg/L	1	09/13/2023 15:03	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-082

Client Sample ID: LSNISK83

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		19.2	µg/L	1	09/13/2023 15:06	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-083

Client Sample ID: LSNISK84

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.4	µg/L	1	09/13/2023 16:05	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-084

Client Sample ID: LSNISK85

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.6	µg/L	1	09/13/2023 15:10	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-085

Client Sample ID: LSNISK86

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		14.2	µg/L	1	09/13/2023 15:13	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-086

Client Sample ID: LSNISK87

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		15.2	µg/L	1	09/13/2023 15:42	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-087

Client Sample ID: LSNISK88

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		16.1	µg/L	5	09/12/2023 15:22	210963



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-088

Client Sample ID: LSNISK89

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.3	µg/L	1	09/13/2023 15:46	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-089

Client Sample ID: LSNISK90

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.9	µg/L	1	09/13/2023 15:49	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-090

Client Sample ID: LSNISK91

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.0	µg/L	1	09/13/2023 15:52	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-091

Client Sample ID: LSNISK92

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		12.5	µg/L	1	09/13/2023 15:56	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-092

Client Sample ID: LSNISK93

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.0	µg/L	1	09/13/2023 15:59	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-093

Client Sample ID: LSNISK94

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		53.0	µg/L	1	09/13/2023 16:02	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-094

Client Sample ID: LSNISK95

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	10.0		26.5	µg/L	10	09/15/2023 3:52	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-095

Client Sample ID: LSNISK96

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		29.7	µg/L	1	09/13/2023 16:25	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-096

Client Sample ID: LSNISK97

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		7.4	µg/L	1	09/13/2023 16:28	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-097

Client Sample ID: LSNISK98

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		14.7	µg/L	1	09/13/2023 16:32	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-098

Client Sample ID: LSNISK99

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		9.4	µg/L	1	09/13/2023 16:35	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-099

Client Sample ID: LSNISK100

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		19.7	µg/L	5	09/12/2023 15:26	210963



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-100

Client Sample ID: LSNISK101

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		15.1	µg/L	1	09/13/2023 16:38	210915



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-101

Client Sample ID: LSNISK102

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		37.0	µg/L	1	09/13/2023 16:42	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-102

Client Sample ID: LSNISK103

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		11.9	µg/L	1	09/13/2023 16:45	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-103

Client Sample ID: LSNISK104

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		175	µg/L	5	09/12/2023 15:30	210963



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-104

Client Sample ID: LSNISK105

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.0	µg/L	1	09/13/2023 17:31	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-105

Client Sample ID: LSNIDF106

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 17:08	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-106

Client Sample ID: LSNIDF107

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 17:11	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-107

Client Sample ID: LSNISK108

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.0	µg/L	1	09/13/2023 17:14	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-108

Client Sample ID: LSNISK109

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.0	µg/L	1	09/13/2023 17:18	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-109

Client Sample ID: LSNISK110

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.1	µg/L	1	09/13/2023 17:21	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-110

Client Sample ID: LSNISK111

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 17:24	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-111

Client Sample ID: LSNISK112

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.0	µg/L	1	09/13/2023 17:28	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-112

Client Sample ID: LSNISK113

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.5	µg/L	1	09/13/2023 17:51	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-113

Client Sample ID: LSNISK114

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	1	09/13/2023 18:13	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-114

Client Sample ID: LSNISK115

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 17:54	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-115

Client Sample ID: LSNISK116

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 17:57	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-116

Client Sample ID: LSNISK117

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.1	µg/L	1	09/13/2023 18:00	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-117

Client Sample ID: LSNISK118

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 18:04	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-118

Client Sample ID: LSNISK119

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 18:07	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-119

Client Sample ID: LSNISK120

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 18:10	210916



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-120

Client Sample ID: LSNISK0121

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/12/2023 15:33	210963



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-121

Client Sample ID: LSNISK122

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 19:19	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-122

Client Sample ID: LSNISK123

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.7	µg/L	1	09/13/2023 19:23	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-123

Client Sample ID: LSNISK124

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.2	µg/L	1	09/13/2023 19:26	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-124

Client Sample ID: LSNISK125

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 19:29	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-125

Client Sample ID: LSNISK126

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.7	µg/L	1	09/13/2023 19:46	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-126

Client Sample ID: LSNISK127

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.9	µg/L	1	09/13/2023 20:05	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-127

Client Sample ID: LSNISK128

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		10.1	µg/L	1	09/13/2023 20:09	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-128

Client Sample ID: LSNIDF129

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 20:12	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-129

Client Sample ID: LSNIDF130

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 20:15	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-130

Client Sample ID: LSNIDF131

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 20:19	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-131

Client Sample ID: LSNIDF132

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 20:22	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-132

Client Sample ID: LSNISK133

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.4	µg/L	1	09/13/2023 20:25	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-133

Client Sample ID: LSNISK134

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.5	µg/L	1	09/13/2023 20:28	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-134

Client Sample ID: LSNISK135

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.6	µg/L	1	09/13/2023 20:32	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-135

Client Sample ID: LSNISK136

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.1	µg/L	1	09/13/2023 20:35	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-136

Client Sample ID: LSNISK137

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 21:11	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-137

Client Sample ID: LSNISK138

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 20:48	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-138

Client Sample ID: LSNISK139

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 20:52	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-139

Client Sample ID: LSNISK140

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 20:55	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-140

Client Sample ID: LSNISK141

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 20:58	210917



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-141

Client Sample ID: LSNISK142

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.2	µg/L	1	09/13/2023 21:01	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-142

Client Sample ID: LSNISK143

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 21:05	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-143

Client Sample ID: LSNIDF144

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 21:08	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-144

Client Sample ID: LSNISK145

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.3	µg/L	1	09/13/2023 21:31	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-145

Client Sample ID: LSNISK146

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 21:34	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-146

Client Sample ID: LSNISK147

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.1	µg/L	1	09/13/2023 21:38	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-147

Client Sample ID: LSNIDF148

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 21:41	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-148

Client Sample ID: LSNISK149

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 21:44	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-149

Client Sample ID: LSNISK150

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.8	µg/L	1	09/13/2023 21:47	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-150

Client Sample ID: LSNISK151

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.2	µg/L	1	09/13/2023 21:54	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-151

Client Sample ID: LSNISK152

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 21:51	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-152

Client Sample ID: LSNIDF154

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 22:37	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-153

Client Sample ID: LSNIDF155

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 22:14	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-154

Client Sample ID: LSNIDF158

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 22:17	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-155

Client Sample ID: LSNIDF159

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 22:20	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-156

Client Sample ID: LSNIDF160

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 22:24	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-157

Client Sample ID: LSNIDF162

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 22:27	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-158

Client Sample ID: LSNIDF163

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 22:30	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-159

Client Sample ID: LSNIDF164

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 22:34	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-160

Client Sample ID: LSNISK165

Matrix: DRINKING WATER

Collection Date: 07/28/2023 11:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.1	µg/L	1	09/13/2023 22:57	210918



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-161

Client Sample ID: LSNISK166

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 23:00	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-162

Client Sample ID: LSNISK167

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.6	µg/L	1	09/15/2023 4:14	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-163

Client Sample ID: LSNISK168

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.2	µg/L	1	09/13/2023 23:03	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-164

Client Sample ID: LSNISK169

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		14.9	µg/L	1	09/13/2023 23:07	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-165

Client Sample ID: LSNISK170

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	1	09/13/2023 23:10	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-166

Client Sample ID: LSNISK171

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.1	µg/L	1	09/13/2023 23:13	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-167

Client Sample ID: LSNISK172

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 23:17	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-168

Client Sample ID: LSNISK173

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 8:27	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-169

Client Sample ID: LSNISK174

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.8	µg/L	1	09/14/2023 8:33	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-170

Client Sample ID: LSNIO175

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.7	µg/L	5	09/12/2023 15:44	210963



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-171

Client Sample ID: LSNISK176

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.8	µg/L	1	09/14/2023 8:36	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-172

Client Sample ID: LSNISK177

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		13.9	µg/L	1	09/14/2023 8:39	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-173

Client Sample ID: LSNISK178

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 8:42	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-174

Client Sample ID: LSNIO179

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.0	µg/L	1	09/14/2023 8:52	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-175

Client Sample ID: LSNIO180

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.2	µg/L	5	09/12/2023 15:59	210963



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-176

Client Sample ID: LSNISK181

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 8:46	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-177

Client Sample ID: LSNISK182

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 8:49	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-178

Client Sample ID: LSNISK183

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 9:12	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-179

Client Sample ID: LSNIO184

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/12/2023 16:03	210963



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-180

Client Sample ID: LSN2DF185

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 9:15	210922



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-181

Client Sample ID: LSN2DF186

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 9:19	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-182

Client Sample ID: LSN2DF187

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 9:22	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-183

Client Sample ID: LSN2DF188

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 9:35	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-184

Client Sample ID: LSN2DF189

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 9:25	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-185

Client Sample ID: LSN2DF190

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 9:28	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-186

Client Sample ID: LSN2DF191

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 9:32	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-187

Client Sample ID: LSN2SK192

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	1	09/14/2023 1:06	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-188

Client Sample ID: LSN2SK193

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 1:09	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-189

Client Sample ID: LSN2SK194

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.2	µg/L	1	09/14/2023 1:12	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-190

Client Sample ID: LSN2SK195

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.9	µg/L	1	09/14/2023 1:16	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-191

Client Sample ID: LSN2SK196

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		6.9	µg/L	1	09/14/2023 1:19	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-192

Client Sample ID: LSN2DF198

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.1	µg/L	1	09/14/2023 1:22	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-193

Client Sample ID: LSN2DF199

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/14/2023 1:26	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-194

Client Sample ID: LSN2DF200

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 21:32	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-195

Client Sample ID: LSNISK201

Matrix: DRINKING WATER

Collection Date: 07/28/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	10.0		14.1	µg/L	10	09/18/2023 20:04	210920



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Lab ID: 23080087-196

Client Sample ID: LSNISK202

Matrix: DRINKING WATER

Collection Date: 07/28/2023 12:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/15/2023 4:36	210920



Receiving Check List

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23080087

Client Project: Lees Summit School Dist DW/LSN HS

Report Date: 19-Sep-23

Carrier: Crossroads

Received By: ANC

Completed by:

On:

01-Aug-23

Allison Colin

Reviewed by:

On:

01-Aug-23

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

Shipping container/cooler in good condition?	Yes ☒	No ☐	Not Present ☐	Temp °C NA
Type of thermal preservation?	None ☒	Ice ☐	Blue Ice ☐	Dry Ice ☐
Chain of custody present?	Yes ☒	No ☐		
Chain of custody signed when relinquished and received?	Yes ☒	No ☐		
Chain of custody agrees with sample labels?	Yes ☒	No ☐		
Samples in proper container/bottle?	Yes ☒	No ☐		
Sample containers intact?	Yes ☒	No ☐		
Sufficient sample volume for indicated test?	Yes ☒	No ☐		
All samples received within holding time?	Yes ☒	No ☐		
Reported field parameters measured:	Field ☐	Lab ☐	NA ☒	
Container/Temp Blank temperature in compliance?	Yes ☒	No ☐		

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?	Yes ☐	No ☐	No VOA vials ☒
Water - TOX containers have zero headspace?	Yes ☐	No ☐	No TOX containers ☒
Water - pH acceptable upon receipt?	Yes ☒	No ☐	NA ☐
NPDES/CWA TCN interferences checked/treated in the field?	Yes ☐	No ☐	NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival at the laboratory.

CHAIN OF CUSTODY

pg. 1 of 2 Work order # 23080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: ☐ ICE ☐ BLUE ICE ☒ NO ICE ☐ °C ☐ LTG#
Address: 16200 Foster Street	Preserved in: ☒ LAB ☐ FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes:
Contact: Lindsay E. James (913) 495-9990	
E-Mail: ljames@blackstone-env.com	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No
 Are these samples known to be hazardous? ☐ Yes ☒ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Client Comments:

LSN HS

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED																
Lee's Summit School Dist. DW		RS BB																		
Results Requested		Billing Instructions		# and Type of Containers																
Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)				OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES																
Lab Use Only	Sample Identification	Date/Time Sampled		Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead										
23080087	001 LSNISK1	7/28/23 919	X		X															
	002 LSNISK2	921																		
	003 LSNIDF3	923																		
	004 LSNIDF4	923																		
	005 LSNIDF5	923																		
	006 LSNISK6	925																		
	007 LSNISK7	928																		
	008 LSNISK8	928																		
	009 LSNISK9	930																		
	010 LSNISK10	930																		

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7/28/23 1600	<i>[Signature]</i>	7/31/23 1300
<i>[Signature]</i>	7/31/23 1600	<i>[Signature]</i>	8/1/23 1420

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 2 of 2 Work order # 23080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
Address: 16200 Foster Street
City / State / Zip: Overland Park, KS 66085
Contact: Lindsay E. James (913) 495-9990
E-Mail: ljames@blackstone-env.com

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Preserved in: ☐ LAB ☐ FIELD **FOR LAB USE ONLY**

Lab Notes

Client Comments:

LSN HS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED																
Lee's Summit School Dist. DW		RS BB																		
Results Requested		Billing Instructions		# and Type of Containers																
☐ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)				OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES																
Lab Use Only	Sample Identification	Date/Time Sampled		Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead										
23080087	011 LSNISK11	7/28/23 930	X		X					X										
012	LSNISK12	930																		
013	LSNISK13	930																		
014	LSNISK14	935																		
015	LSNISK15	935																		
016	LSNISK16	935																		
017	LSNISK17	935																		
018	LSNISK18	935																		
019	LSNISK19	935																		
020	LSNISK20	935																		
Relinquished By				Received By												Date/Time				
[Signature]				[Signature]												7/28/23 1600				
[Signature]				[Signature]												7/31/23 1600				



CHAIN OF CUSTODY

pg. 3 of 21 Work order # 23080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
Address: 16200 Foster Street
City / State / Zip: Overland Park, KS 66085
Contact: Lindsay E. James (913) 495-9990
E-Mail: ljames@blackstone-env.com Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Preserved in: ☐ LAB ☐ FIELD **FOR LAB USE ONLY**
Lab Notes

Client Comments:

LSN HS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED																														
Lee's Summit School Dist. DW		BB RS		Billing Instructions				# and Type of Containers				MATRIX				Date/Time																		
Results Requested		Sample Identification		Date/Time Sampled		OTHER		NaHSO4		MeOH		HCL		H2SO4		NaOH		HNO3		UNPRES		Aqueous		Soil		Sludge		Special Waste		Groundwater		DW Lead		
Lab Use Only	Standard	Other	1-2 Day (100% Surcharge)	3 Day (50% Surcharge)	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28		
23080087	021	LSN1 SK 21	7/28/23	935	X																													
	022	LSN1 SK 22		940																														
	023	LSN1 SK 23		940																														
	024	LSN1 SK 24		944																														
	025	LSN1 SK 25		944																														
	026	LSN1 SK 26		944																														
	027	LSN1 SK 27		944																														
	028	LSN1 SK 28		944																														
	029	LSN1 SK 29		944																														
	030	LSN1 SK 30		944																														
Relinquished By				Date/Time				Received By				Date/Time																						
[Signature]				7/28/23 1600				[Signature]				7/31/23 1300																						
[Signature]				7/31/23 1600				[Signature]				8/1/23 1420																						

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 4 of 2 Work order # 23080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
Address: 16200 Foster Street
City / State / Zip: Overland Park, KS 66085
Contact: Lindsay E. James (913) 495-9990
E-Mail: ljames@blackstone-env.com **Fax:**

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Preserved in: ☐ LAB ☐ FIELD **FOR LAB USE ONLY**
Lab Notes

Client Comments:

LSN HS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED																
Lee's Summit School Dist. DW		RS BB																		
Results Requested		Billing Instructions		# and Type of Containers																
Standard ☐ 1-2 Day (100% Surcharge) Other ☐ 3 Day (50% Surcharge)				OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES																
Lab Use Only	Sample Identification	Date/Time Sampled		Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead											
23060087	LSN1 SK 31	7/28/23 944	X	X					X											
032	LSN1 SK 32	948																		
033	LSN1 SK 33	948																		
034	LSN1 SK 34	950																		
035	LSN1 SK 35	950																		
036	LSN1 SK 36	950																		
037	LSN1 SK 37	950																		
038	LSN1 SK 38	950																		
039	LSN1 SK 39	950																		
040	LSN1 SK 40	950																		
Relinquished By				Received By										Date/Time						
[Signature]				[Signature]										7/28/23 1600						
[Signature]				[Signature]										7/31/23 1400						



CHAIN OF CUSTODY

pg. 5 of 27 Work order # 22080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
Address: 16200 Foster Street
City / State / Zip: Overland Park, KS 66085
Contact: Lindsey E. James (913) 495-9990
E-Mail: ljames@blackstone-env.com

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Preserved in: ☐ LAB ☐ FIELD **FOR LAB USE ONLY**
Lab Notes

Client Comments:

LSN HS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number Lee's Summit School Dist. DW
Sample Collector's Name BB RS

Results Requested ☐ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)
Billing Instructions

Lab Use Only	Sample Identification	Date/Time Sampled	# and Type of Containers	OTHER
23080087	LSN1SK411	7/28/23 950	X	NaHSO4
042	LSN1SK412	958		MeOH
043	LSN1SK413	958		HCL
044	LSN1SK414	958		H2SO4
	LSN1SK415			NaOH
045	LSN1SK416	958		HNO3
046	LSN1SK417	958		UNPRES
047	LSN1SK418	958		
048	LSN1SK419	958		
049	LSN1SK420	1000		

MATRIX	INDICATE ANALYSIS REQUESTED									
Aqueous										
Drinking Water	X									
Soil										
Sludge										
Special Waste										
Groundwater										
DW Lead	X									

Relinquished By [Signature] **Date/Time** 7/28/23 1600
Received By [Signature] **Date/Time** 7/31/23 1300
 8/1/23 1420

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 6 of 21 Work order # 23080087

(618) 344-1004 - Fax: (618) 344-1005

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

pg. 7 of 24 Work order # 23080087

(618) 344-1004 - Fax: (618) 344-1005

Client:	Blackstone Environmental, Inc.		
Address:	16200 Foster Street		
City / State / Zip	Overland Park, KS 66085		
Contact:	Lindsay E. James	Phone:	(913) 495-9990
E-Mail:	ljames@blackstone-env.com		
Samples on:		☐ ICE	☐ BLUE ICE ☐ NO ICE
Preserved in:		☐ LAB	☐ FIELD
Lab Notes		FOR LAB USE ONLY	
Client Comments:			

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

LSN HS

[illegible]

Relinquished By	Date/Time	Received By	Date/Time
	7/28/23 1600		7/31/23 1300
	7/31/23 1600		8/1/23 1420



TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

[illegible]

CHAIN OF CUSTODY

pg. 9 of 21 Work order # 23080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Address: 16200 Foster Street	Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes:
Contact: Lindsay E. James (913) 495-9990	Client Comments:
E-Mail: ljames@blackstone-env.com	LSN HS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED																											
Lee's Summit School Dist. DW		LS BB		MATRIX																											
Results Requested		Billing Instructions		# and Type of Containers																											
Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)		Date/Time Sampled		OTHER																											
				NaHSO4																											
				MeOH																											
				HCL																											
				H2SO4																											
				NaOH																											
				HNO3																											
				UNPRES																											
Lab Use Only	Sample Identification	Date/Time Sampled		Drinking Water				Groundwater				Special Waste				Sludge				Soil				Aqueous				DW Lead			
23080087	LSN1SK81	7/28/23 1025		X																								X			
081	LSN1SK82	1025																													
082	LSN1SK83	1025																													
083	LSN1SK84	1025																													
084	LSN1SK85	1025																													
085	LSN1SK86	1025																													
086	LSN1SK87	1030																													
087	LSN1SK88	1030																													
088	LSN1SK89	1030																													
089	LSN1SK90	1030																													

Relinquished By		Received By		Date/Time	
[Signature]		[Signature]		7/31/23 1300	
[Signature]		[Signature]		8/1/23 1420	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000

pg. 10 of 21 Work order # 23080087

Fax: (618) 344-1005

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

82000

CHAIN OF CUSTODY

pg. 12 of 21 Work order # 23080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc. Address: 16200 Foster Street City / State / Zip: Overland Park, KS 66085 Contact: Lindsay E. James (913) 495-9990 E-Mail: ljames@blackstone-env.com		Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ LTG# Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY Lab Notes		Client Comments: LSN HS	
---	--	---	--	--	--

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name BB RS		INDICATE ANALYSIS REQUESTED	
Results Requested ☐ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)		Billing Instructions		DW Lead ☐	
Lab Use Only		Sample Identification		Groundwater ☐	
23080087 110 LSNISK111		7/28/23 1055 X		Special Waste ☐	
111 LSNISK112		1055		Sludge ☐	
112 LSNISK113		1055		Soil ☐	
113 LSNISK114		1100		Drinking Water ☐	
114 LSNISK115		1100		Aqueous ☐	
115 LSNISK116		1100		OTHER ☐	
116 LSNISK117		1100		NaHSO4 ☐	
117 LSNISK118		1100		MeOH ☐	
118 LSNISK119		1100		HCL ☐	
119 LSNISK120		1100		H2SO4 ☐	
				NaOH ☐	
				HNO3 ☐	
				UNPRES ☐	

Relinquished By 		Date/Time 7/28/23 1600		Received By 	
				Date/Time 7/23/23 1300	
				Date/Time 8/1/23 1420	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



pg. 13 of 21 Work order # 23080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc. Address: 16200 Foster Street City / State / Zip: Overland Park, KS 66085 Contact: Lindsay E. James Phone: (913) 495-9990 E-Mail: ljames@blackstone-env.com Fax:						Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE °C LTG# Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY Lab Notes 					
Project Name/Number Lee's Summit School Dist. DW						Sample Collector's Name BB LS					
Results Requested ☐ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)						Billing Instructions					
Lab Use Only						Date/Time Sampled					
1207057/120 LSN1 O121						7/28/23 1100 X					
121 LSN1 SK122						1110					
122 LSN1 SK123						1110					
123 LSN1 SK124						1110					
124 LSN1 SK125						1110					
125 LSN1 SK126						1115					
126 LSN1 SK127						1115					
127 LSN1 SK128						1115					
128 LSN1 DF129						1117					
129 LSN1 DF130						1117					

Matrix		Indicate Analysis Requested												Received By		Date/Time				
Aqueous															SD - Lindsay E. James	7/28/23 1600	7/28/23 1600			
Drinking Water	X																	SD - Lindsay E. James	7/28/23 1600	7/28/23 1600
Soil																				
Sludge																				
Special Waste																				
Groundwater																				
DW Lead	X																			

Client Comments:
 LSN HS

Are these samples known to be involved in litigation? If yes, a surcharge will apply Yes ☐ No ☒
 Are these samples known to be hazardous? Yes ☐ No ☒
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. Yes ☐ No ☒

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



CHAIN OF CUSTODY

pg. 14 of 24 Work order # 23080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Address: 16200 Foster Street	Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes:
Contact: Lindsay E. James (913) 495-9990	
E-Mail: ljames@blackstone-env.com	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Client Comments:

LSN HS

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED																											
Lee's Summit School Dist. DW		BB RS		Billing Instructions				Matrix																							
Results Requested		Sample Identification		Date/Time Sampled		# and Type of Containers		Aqueous				Groundwater				Special Waste				Sludge				Soil				Drinking Water			
Lab Use Only	Standard ☐ 1-2 Day (100% Surcharge) Other ☐ 3 Day (50% Surcharge)																														
23080087		LSN1 DF131	7/28/23	1117	X																										
131		LSN1 DF132		1117																											
132		LSN1 SK133		1120																											
133		LSN1 SK134		1122																											
134		LSN1 SK135		1122																											
135		LSN1 SK136		1122																											
136		LSN1 SK137		1124																											
137		LSN1 SK138		1124																											
138		LSN1 SK139		1124																											
139		LSN1 SK140		1124																											

Relinquished By

Date/Time

Received By

Date/Time

[Signature]

7/28/23 1600
7/31/23 1600

[Signature]

7/31/23 1300
8/1/23 1420

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 15 of 21 Work order # 2308087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.

Address: 16200 Foster Street

City / State / Zip: Overland Park, KS 66085

Contact: Lindsay E. James

Phone: (913) 495-9990

E-Mail: ljames@blackstone-env.com

Fax:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C LTG#

Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY

Lab Notes

Client Comments:

LSW HS

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED													
Lee's Summit School Dist. DW		BB RS		Billing Instructions				MATRIX									
Results Requested	Sample Identification	Date/Time Sampled	# and Type of Containers	Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead							
Standard ☐ 1-2 Day (100% Surcharge) Other ☐ 3 Day (50% Surcharge)																	
2308087 140	LSN1SK141	7/28/23 1126	X	X													
141	LSN1SK142	1126															
142	LSN1SK143	1130															
143	LSN1DF144	1130															
144	LSN1SK145	1135															
145	LSN1SK146	1135															
146	LSN1SK147	1138															
147	LSN1DF148	1138															
148	LSN1SK149	1140															
149	LSN1SK150	1140															

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7/28/23 1600	<i>[Signature]</i>	7/31/23 1300
<i>[Signature]</i>	7/31/23 1600	<i>[Signature]</i>	8/1/23 1420

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 16 of 24 Work order # 23080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

[illegible]

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 17 of 21 Work order # 23080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc. Address: 16200 Foster Street City / State / Zip: Overland Park, KS 66085 Contact: Lindsay E. James (913) 495-9990 E-Mail: ljames@blackstone-env.com		Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ LTG# _____ Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY Lab Notes		Client Comments: LSN HS	
---	--	---	--	--	--

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name RS BB		INDICATE ANALYSIS REQUESTED	
Results Requested ☐ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)		Billing Instructions		MATRIX	
Lab Use Only		Sample Identification		Groundwater Special Waste Sludge Soil Drinking Water Aqueous	
23080087		LSN1 DF 161		Drinking Water	
157		LSN1 DF 162		Groundwater	
158		LSN1 DF 163		Special Waste	
159		LSN1 DF 164		Sludge	
160		LSN1 SK 165		Soil	
161		LSN1 SK 166		Drinking Water	
162		LSN1 SK 167		Aqueous	
163		LSN1 SK 168			
164		LSN1 SK 169			
165		LSN1 SK 170			

Relinquished By 		Received By 		Date/Time	
7/28/23 1600		7/31/23 1300		7/31/23 1300	
7/31/23 1400		7/31/23 1420		7/31/23 1420	



CHAIN OF CUSTODY

pg. 18 of 21 Work order # 13080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
Address: 16200 Foster Street
City / State / Zip: Overland Park, KS 66085
Contact: Lindsay E. James (913) 495-9990
E-Mail: ljames@blackstone-env.com **Fax:**

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Preserved in: ☐ LAB ☐ FIELD **FOR LAB USE ONLY**
Lab Notes

Client Comments:

LSN HS

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED															
Lee's Summit School Dist. DW		LS BB		Billing Instructions		Date/Time Sampled		Matrix											
Lab Use Only	Sample Identification	Results Requested	Standard	Other	1-2 Day (100% Surcharge)	3 Day (50% Surcharge)	UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER					
23080087	LSN1SK171						7/28/23	1200	X										
107	LSN1SK172																		
108	LSN1SK173																		
109	LSN1SK174																		
170	LSN1O175																		
171	LSN1SK176																		
172	LSN1SK177																		
173	LSN1SK178																		
174	LSN1O179																		
175	LSN1O180																		

Relinquished By	Date/Time	Received By	Date/Time
LS	7/28/23 1600	SO	7/31/23 1300
SO	7/31/23 1600	LSN	8/1/23 1400

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 19 of 21 Work order # 23080087

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc. 16200 Foster Street Overland Park, KS 66085 Lindsay E. James ljames@blackstone-env.com		City / State / Zip Phone: (913) 495-9990 Fax:	
Address: 16200 Foster Street Overland Park, KS 66085		Contact: Lindsay E. James ljames@blackstone-env.com	
E-Mail: ljames@blackstone-env.com		Phone: (913) 495-9990	
Fax:			
Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No			
Are these samples known to be hazardous? ☐ Yes ☐ No			
Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No			
Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name BB RS	
Results Requested ☐ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)		Billing Instructions	
Lab Use Only		Date/Time Sampled	
23080057 176		7/28/23 1205	
177		1205	
178		1205	
179		1205	
180		1220	
181		1220	
182		1225	
183		1225	
184		1225	
185		1225	
LSN1 SK181		X	
LSN1 SK182			
LSN1 SK183			
LSN1 O184			
LSN2 DF185			
LSN2 DF186			
LSN2 DF187			
LSN2 DF188			
LSN2 DF189			
LSN2 DF190			
Matrix		Indicate Analysis Requested	
Aqueous			
Drinking Water		X	
Soil			
Sludge			
Special Waste			
Groundwater			
DW Lead		X	
Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE		°C	
Preserved in: ☐ LAB ☐ FIELD		FOR LAB USE ONLY	
Lab Notes			
Client Comments: LSN HS		Received By SD 8/1/23 1420	
Relinquished By SD		Date/Time 7/28/23 1600	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



23080087

(618) 344-1004 - Fax: (618) 344-1005

Client:	Blackstone Environmental, Inc.					
Address:	16200 Foster Street					
City / State / Zip	Overland Park, KS 66085					
Contact:	Lindsay E. James	Phone:	(913) 495-9990			
E-Mail:	ljames@blackstone-env.com	Fax:				

Samples on:	☐ ICE	☐ BLUE ICE	☐ NO ICE			°C	LTG#	
Preserved in:	☐ LAB	☐ FIELD	<u>FOR LAB USE ONLY</u>					
Lab Notes								
Client Comments:								

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

LSN HS

[illegible]

Relinquished By	Date/Time	Received By	Date/Time
	7/28/23 1600		7/31/23 1300
	7/31/23 1600		8/1/23 1420

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



pg. 21 of 27 Work order # 23080087

pg. 21 of 27 Work order # 23080087

Client:	Blackstone Environmental, Inc.
Address:	16200 Foster Street Overland Park, KS 66085
City / State / Zip	
Contact:	Lindsay E. James
E-Mail:	ljames@blackstone-env.com
Phone:	(913) 495-9990
Fax:	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number	Sample Collector's Name
Lee's Summit School Dist. DW	BS - BB

Results Requested ☐ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)	Billing Instructions	# and Type of Containers	OTHER
			NaHSO4
			MeOH
			HCL
			H2SO4
			NaOH
			HNO3
			UNPRES

Lap Use Only	Sample Identification	Date/Time Sampled
23080087 195	LS01SK201	7/28/23 1050
196	LS01SK202	7/28/23 1205

[illegible][illegible][illegible][illegible]

7/31/23	1618
---------	------

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.itslabinc.com for

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ LGT# _____ °C _____

Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY

Lab Notes

Client Comments:

LSN HS

		INDICATE ANALYSIS REQUESTED					
	DW Lead	X	X				
MATRIX	Groundwater						
	Special Waste						
	Sludge						
	Soil						
	Drinking Water	X	X				
	Aqueous						

Received By	Date/Time
	7/3/23 1300
	8/1/23 1420

