

ATTACHMENT B

Longview Farm Elementary Field Forms

Lee's Summit DW

Date Purged

Date Sampled

7/18

7/19

School

Longview Farm Elem.
(LFE)

Team

A+K

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
1	1		X		hallway fountain by office (right)	12:24	8:10
2	1		X		hallway fountain by office (middle)	12:24	8:11
3	1		X		hallway fountain by office (left)	12:24	8:12
4	1	X			nurses' work station	12:29	8:13
5	1	X			classroom #119 sink (left)	12:30	8:14
6	1	X			classroom #119 sink (right)	12:30	8:15
7	1		X		cafeteria fountain	12:39	8:16
8	1	X			Kitchen prep sink near oven	12:45	8:18
9	1	X			Kitchen prep sink by walk-in	12:45	8:19
10	1			X	steam injection oven	12:45	8:20
11	1	X			Kitchen prep sink	12:45	8:20
12	1	X			Kitchen sink	12:52	8:21
13	1			X	Kitchen dishwasher	12:52	8:22
14	1	X			Kitchen dish sink w/ sprayer	12:52	8:22
15	1	X			Kitchen dish sink (left)	12:52	8:23
16	1	X			Kitchen dish sink (right)	12:52	8:24
17	1			X	Kitchen dish sprayer (pre washer)	12:53	8:25
18	1	X			classroom #213 sink	13:03	8:25
19	1	X			classroom #214 sink	13:03	8:26
20	1	X			classroom #224 sink	13:05	8:27
21	1	X			classroom #223 sink	13:05	8:28
22	1		X		hallway fountain by restrooms (right)	13:11	8:30
23	1		X		hallway fountain by restrooms (mid)	13:11	8:31
24	1		X		hallway fountain by restrooms (left)	13:11	8:32

Lee's Summit DW

Date Purged 7/18
Date Sampled _____

School Longview Farm Elem.
(LFE)

Team A+K

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
25	1	X			classroom # 212 sink	13:18	8:32
26	1	X			classroom # 204 sink	13:18	8:33
27	1	X			classroom # 215 sink	13:19	8:34
28	1	X			classroom # 205 sink	13:19	8:35
29	1	X			classroom # 225 sink	13:26	8:36
30	1	X			classroom # 229 sink	13:26	8:37
31	1	X			classroom # 226 sink	13:27	8:37
32	1	X			classroom # 228 sink	13:27	8:38
33	1		X		fountains in middle hall (right)	13:33	8:38
34	1		X		fountains in middle hall (left)	13:33	8:38
35	1	X			classroom # 230 sink	13:41	8:39
36	1	X			classroom # 231 sink	13:41	8:40
37	1	X			classroom # 234 sink	13:41	8:41
38	1	X			classroom # 235 sink	13:41	8:42
39	1	X	X		hallway fountain (right)	13:48	8:43
40	1	X	X		hallway fountain (left)	13:48	8:44
41	1		X		hallway fountain on corner	13:51	8:44
42	1	X			classroom # 236 sink	13:58	8:45
43	1	X			classroom # 237 sink	13:58	8:46
44	1	X			classroom # 183 sink	13:58	8:46
45	1			X	classroom # 183 sink bubbler	13:59	8:47
46	1	X			classroom # 184 sink sink	13:59	8:51
47	1			X	classroom # 184 bubbler	13:59	8:51
48	1	X			classroom # 188 sink	14:58	8:53

Lee's Summit DW

Date Purged 7/18 School Longview Farm Elem. Team A+K
 Date Sampled _____ (LFE)

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
49	1			X	classroom #188 bubbler	14:08	8:53
50	1	X			classroom #189 sink	14:09	8:54
51	1			X	classroom #189 bubbler	14:09	8:54
52	1	X			classroom #193 sink	14:10	8:55
53	1	X			classroom #196 sink	14:11	8:56
54	1		X		fountain by Kindergarten	14:16	8:57
55	1	X			classroom #195 sink	14:26	8:58
56	1	X			classroom #194 sink	14:26	8:59
57	1	X			classroom #203 sink	14:27	9:00
58	1			X	classroom #203 bubbler	14:27	9:00
59	1	X			classroom #206 sink	14:28	9:01
60	1		X		fountains in gym (left)	14:35	9:03
61	1		X		fountain in gym (right)	14:35	9:03
62	1	X			sink in workroom	14:41	9:04
63	1			X	teacher's lounge ice machine	14:47	9:07
64	1			X	teacher's lounge dishwasher	14:47	9:08
65	1	X			teacher's lounge sink	14:47	9:08
66	1			X	teacher's lounge fridge water spicket	14:48	9:11
67	1		X		fountains right of capt. ct. (r)	14:53	9:12
68	1		X		fountains C capt. ct. (l)	14:53	9:12

ATTACHMENT C

Longview Farm Elementary Summary Table

**Summary Table
Longview Farm Elementary**

Sample ID	Date	Analyte	Result	Unit	Reporting Limit
LFEI-DF1	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF2	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF3	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S4	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S5	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S6	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF7	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S8	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S9	7/19/2023	Lead	ND	mg/L	0.001
LFEI-O10	7/19/2023	Lead	0.0012	mg/L	0.001
LFEI-S11	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S12	7/19/2023	Lead	0.0086	mg/L	0.001
LFEI-O13	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S14	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S15	7/19/2023	Lead	0.0068	mg/L	0.001
LFEI-S16	7/19/2023	Lead	0.0210	mg/L	0.001
LFEI-O17	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S18	7/19/2023	Lead	0.0013	mg/L	0.001
LFEI-S19	7/19/2023	Lead	0.0011	mg/L	0.001
LFEI-S20	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S21	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF22	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF23	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF24	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S25	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S26	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S27	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S28	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S29	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S30	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S31	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S32	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF33	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF34	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S35	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S36	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S37	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S38	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF39	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF40	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF41	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S42	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S43	7/19/2023	Lead	ND	mg/L	0.001

Longview Farm

LFEI-S44	7/19/2023	Lead	ND	mg/L	0.001
LFEI-O45	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S46	7/19/2023	Lead	ND	mg/L	0.001
LFEI-O47	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S48	7/19/2023	Lead	ND	mg/L	0.001
LFEI-O49	7/19/2023	Lead	0.0020	mg/L	0.001
LFEI-S50	7/19/2023	Lead	ND	mg/L	0.001
LFEI-O51	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S52	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S53	7/19/2023	Lead	0.0011	mg/L	0.001
LFEI-DF54	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S55	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S56	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S57	7/19/2023	Lead	ND	mg/L	0.001
LFEI-O58	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S59	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF60	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF61	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S62	7/19/2023	Lead	0.0011	mg/L	0.001
LFEI-O63	7/19/2023	Lead	ND	mg/L	0.001
LFEI-O64	7/19/2023	Lead	ND	mg/L	0.001
LFEI-S65	7/19/2023	Lead	ND	mg/L	0.001
LFEI-O66	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF67	7/19/2023	Lead	ND	mg/L	0.001
LFEI-DF68	7/19/2023	Lead	ND	mg/L	0.001

mg/L: milligrams per liter

Bolded results indicate detection above reporting limits

ATTACHMENT D

Longview Farm Elementary Laboratory Analytical Report

August 24, 2023

Lindsay E. James
Blackstone Environmental, Inc.
16200 Foster Street
Overland Park, KS 66085
TEL: (913) 956-4160
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: Lees Summit School Dist DW / Longview Farm
Elem.

WorkOrder: 23071472

Dear Lindsay E. James:

TEKLAB, INC received 68 samples on 7/21/2023 11:39:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley
Project Manager
(618)344-1004 ex 44
patrickriley@teklabinc.com

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	75
Chain of Custody	Appended

Client: Blackstone Environmental, Inc.**Work Order:** 23071472**Client Project:** Lees Summit School Dist DW / Longview Farm Elem.**Report Date:** 24-Aug-23**Abbr Definition**

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Cooler Receipt Temp: NA °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: Blackstone Environmental, Inc.**Work Order:** 23071472**Client Project:** Lees Summit School Dist DW / Longview Farm Elem.**Report Date:** 24-Aug-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2023	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-001

Client Sample ID: LFEI-DF1

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/22/2023 21:41	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-002

Client Sample ID: LFEI-DF2

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/22/2023 21:45	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-003

Client Sample ID: LFEI-DF3

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/22/2023 22:17	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-004

Client Sample ID: LFEI-S4

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:13

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/22/2023 22:21	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-005

Client Sample ID: LFEI-S5

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:14

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/22/2023 22:26	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-006

Client Sample ID: LFEI-S6

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 17:12	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-007

Client Sample ID: LFEI-DF7

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 17:16	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-008

Client Sample ID: LFEI-S8

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 17:20	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-009

Client Sample ID: LFEI-S9

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 17:38	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-010

Client Sample ID: LFEI-O10

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0012	mg/L	1	08/20/2023 14:30	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-011

Client Sample ID: LFEI-S11

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/20/2023 14:36	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-012

Client Sample ID: LFEI-S12

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0086	mg/L	1	08/20/2023 14:41	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-013

Client Sample ID: LFEI-O13

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:21

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	08/15/2023 11:10	210304



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-014

Client Sample ID: LFEI-S14

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/20/2023 14:47	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-015

Client Sample ID: LFEI-S15

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:23

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0068	mg/L	1	08/20/2023 14:53	210214



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-016

Client Sample ID: LFEI-S16

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0210	mg/L	1	08/23/2023 17:25	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-017

Client Sample ID: LFEI-O17

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 17:29	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-018

Client Sample ID: LFEI-S18

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0013	mg/L	1	08/23/2023 17:34	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-019

Client Sample ID: LFEI-S19

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0011	mg/L	1	08/23/2023 18:05	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-020

Client Sample ID: LFEI-S20

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 18:36	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-021

Client Sample ID: LFEI-S21

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 18:10	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-022

Client Sample ID: LFEI-DF22

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 18:14	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-023

Client Sample ID: LFEI-DF23

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 18:19	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-024

Client Sample ID: LFEI-DF24

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 18:23	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-025

Client Sample ID: LFEI-S25

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 18:27	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-026

Client Sample ID: LFEI-S26

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:33

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 18:32	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-027

Client Sample ID: LFEI-S27

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 19:03	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-028

Client Sample ID: LFEI-S28

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 19:08	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-029

Client Sample ID: LFEI-S29

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 19:12	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-030

Client Sample ID: LFEI-S30

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 19:35	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-031

Client Sample ID: LFEI-S31

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 19:17	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-032

Client Sample ID: LFEI-S32

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 19:21	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-033

Client Sample ID: LFEI-DF33

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 19:26	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-034

Client Sample ID: LFEI-DF34

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/23/2023 19:30	210215



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-035

Client Sample ID: LFEI-S35

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:39

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 20:50	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-036

Client Sample ID: LFEI-S36

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 21:22	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-037

Client Sample ID: LFEI-S37

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:41

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 21:26	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-038

Client Sample ID: LFEI-S38

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/20/2023 23:55	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-039

Client Sample ID: LFEI-DF39

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 21:31	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-040

Client Sample ID: LFEI-DF40

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 21:35	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-041

Client Sample ID: LFEI-DF41

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 21:40	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-042

Client Sample ID: LFEI-S42

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 21:44	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-043

Client Sample ID: LFEI-S43

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 21:49	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-044

Client Sample ID: LFEI-S44

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 21:53	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-045

Client Sample ID: LFEI-O45

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 21:58	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-046

Client Sample ID: LFEI-S46

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:51

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 22:02	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-047

Client Sample ID: LFEI-O47

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:51

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 1:09	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-048

Client Sample ID: LFEI-S48

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 22:20	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-049

Client Sample ID: LFEI-O49

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0020	mg/L	1	08/12/2023 22:25	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-050

Client Sample ID: LFEI-S50

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 22:29	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-051

Client Sample ID: LFEI-051

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 22:33	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-052

Client Sample ID: LFEI-S52

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 22:38	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-053

Client Sample ID: LFEI-S53

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:56

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0011	mg/L	1	08/12/2023 22:42	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-054

Client Sample ID: LFEI-DF54

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 22:47	210220



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-055

Client Sample ID: LFEI-S55

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 15:41	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-056

Client Sample ID: LFEI-S56

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:59

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/12/2023 15:46	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-057

Client Sample ID: LFEI-S57

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/15/2023 13:01	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-058

Client Sample ID: LFEI-O58

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/15/2023 13:06	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-059

Client Sample ID: LFEI-S59

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:01

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/15/2023 13:19	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-060

Client Sample ID: LFEI-DF60

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/15/2023 13:10	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-061

Client Sample ID: LFEI-DF61

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/15/2023 13:15	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-062

Client Sample ID: LFEI-S62

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0011	mg/L	1	08/15/2023 13:46	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-063

Client Sample ID: LFEI-O63

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:07

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/15/2023 13:50	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-064

Client Sample ID: LFEI-O64

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/15/2023 13:55	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-065

Client Sample ID: LFEI-S65

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/15/2023 11:59	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-066

Client Sample ID: LFEI-O66

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/15/2023 13:59	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-067

Client Sample ID: LFEI-DF67

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/15/2023 12:57	210288



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Lab ID: 23071472-068

Client Sample ID: LFEI-DF68

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/15/2023 14:04	210288



Receiving Check List

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071472

Client Project: Lees Summit School Dist DW / Longview Farm Elem.

Report Date: 24-Aug-23

Carrier: Crossroads

Received By: MBP

Completed by:

On:

24-Jul-23

Timothy W. Mathis

Reviewed by:

On:

25-Jul-23

Ellie Hopkins

Pages to follow: Chain of custody

7

Extra pages included

0

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C

NA

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice

☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☒

No ☐

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
Address: 16200 Foster Street
City / State / Zip: Overland Park, KS 66085
Contact: Lindsay E. James
E-Mail: ljames@blackstone-env.com
Phone: (913) 495-9990
Fax:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?, If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number	Sample Collector's Name
Lee's Summit School Dist. DW	KSM

Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)	Billing Instructions	# and Type of Containers	UNPP	HNO ₃	NaCl	H ₂ S	HC	MeC	NaHS	OTH

Lab Use Only	Sample Identification	Date/Time Sampled
23071472-001	LFE1 - DF1	7/17/73 @ 810
- 002	LFE1 - DF2	@ 811
- 003	LFE1 - DF3	@ 812
- 004	LFE1 - S4	@ 813
- 005	LFE1 - S5	@ 814
- 006	LFE1 - S6	@ 815
- 007	LFE1 - S7	@ 816
- 008	LFE1 - S8	@ 818
- 009	LFE1 - S9	@ 819
- 010	LFE1 - 010	@ 819

Relinquished By	Date/Time
Kalay m	7/17/13 @ 1700
W. J. [Signature]	7/20/13 1600

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☒ LTG# NA °C _____

Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY

Lab Notes

Client Comments:
Longview Farm
Elementary

	INDICATE ANALYSIS REQUESTED
DW Lead	
Groundwater	
Special Waste	
Sludge	
Soil	
Drinking Water	
Aqueous	

Received By	Date/Time
<i>[Signature]</i>	07/29/23 1200
<i>[Signature]</i>	7/21/23 139



CHAIN OF CUSTODY

pg. 2 of 7 Work order # 23071472

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James (913) 495-9990
 E-Mail: ljames@blackstone-env.com

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
 Preserved in: ☐ LAB ☐ FIELD
 Lab Notes: FOR LAB USE ONLY

Client Comments:

Longview Farm
 Elementary

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No
 Are these samples known to be hazardous? ☐ Yes ☒ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED													
Lee's Summit School Dist. DW		KSM		MATRIX													
Results Requested		Billing Instructions		# and Type of Containers													
Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) Other <input type="checkbox"/> 3 Day (50% Surcharge)				OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES													
Lab Use Only	Sample Identification	Date/Time Sampled		Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead								
23071742-011	LEE1-S11	7/19/23 @ 820															
-012	-S12	@ 820															
-013	-S13	@ 821															
-014	-S14	@ 822															
-015	-S15	@ 823															
-016	-S16	@ 824															
-017	-S17	@ 825															
-018	-S18	@ 825															
-019	-S19	@ 826															
-020	-S20	@ 827															

Relinquished By	Date/Time	Received By	Date/Time
Lindsay E. James	7/19/23 @ 1720	M. H. H. H.	7/20/23 1200
	7/20/23 1600	M. H. H. H.	7/21/23 1339

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 3 of 7 Work order # 23071472

(618) 344-1004 - Fax: (618) 344-1005

Client:	Blackstone Environmental, Inc.	
Address:	16200 Foster Street	
City / State / Zip	Overland Park, KS 66085	
Contact:	Lindsay E. James	Phone: (913) 495-9990
E-Mail:	ljames@blackstone-env.com	Fax:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number	Sample Collector's Name
Lee's Summit School Dist. DW	KSM

Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other _____ <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES
Lab Use Only		Sample Identification	Date/Time Sampled	

23071742-028	LF1	- S21	7/19/23	@828
- 028		- DF22		@830
- 023		- DF23		@831
- 024		- DF24		@832
- 025		- S25		@832
- 026		- S26		@833
- 027		- S27		@834
- 028		- S28		@835
- 029		- S29		@836
- 030		- S30		@836

Relinquished By	Date/Time
<i>Kelsey M. W.</i>	7/19/23 @ 1720
<i>W. J. [Signature]</i>	7/20/23 1600


Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE _____ °C LTG# _____

Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY

Lab Notes

Client Comments:
Longview Farm
Elementary

[illegible]

Received By	Date/Time
	07/20/23 1200
Alloyman (XX)	7/21/23 139

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



pg. 4 of 7 Work order # 23071472

pg. 4 of 7 Work order # 23071472

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
Address: 16200 Foster Street
City / State / Zip: Overland Park, KS 66085
Contact: Lindsay E. James (913) 495-9990
E-Mail: ljames@blackstone-env.com
Fax:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number	Sample Collector's Name
Lee's Summit School Dist. DW	KSM

Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)	Billing Instructions	# and Type of Containers	OTHE
			NaHSO
			MeOH
			HCL
			H2SO
			NaOH
			HNO3
			UNPRE

Lab Use Only	Sample Identification	Date/Time Sampled
23071742 031	FFE1-S31	7/19/23 @ 837
- 032	-S32	@ 837
- 033	-DF33	@ 838
- 034	-DF34	@ 838
- 035	-S35	@ 839
- 036	-S36	@ 840
- 037	-S37	@ 841
- 038	-S38	@ 842
- 039	-DF39	@ 843
- 040	-DF40	@ 844

Relinquished By	Date/Time
Kelsey [Signature]	7/19/23 @ 1720
E. [Signature]	7/20/25 1600

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ LGT# _____ °C _____

Preserved in: ☐ LAB ☐ FIELD

FOR LAB USE ONLY

Lab Notes

Client Comments:

Longview Farm
Elementary

[illegible]

CHAIN OF CUSTODY

pg. 5 of 7 Work order # 23071472

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James Phone: (913) 495-9990
 E-Mail: ljames@blackstone-env.com Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE °C LTG#
 Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY
 Lab Notes

Client Comments:
 Longview Farm
 Elementary

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☒ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☒ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED																											
Lee's Summit School Dist. DW		KSM		MATRIX																											
Results Requested		Billing Instructions		# and Type of Containers				Groundwater				Special Waste				Sludge				Soil				Drinking Water				Aqueous			
Lab Use Only	Sample Identification	Date/Time Sampled		OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES																				
23071472-041	LEE 1 - DF 41	7/19/23 @ 844																													
- 042	- 542	@ 845																													
- 043	- 543	@ 846																													
- 044	- 544	@ 846																													
- 045	- 045	@ 847																													
- 046	- 546	@ 851																													
- 047	- 047	@ 851																													
- 048	- 548	@ 853																													
- 049	- 049	@ 853																													
- 050	- 550	@ 854																													
Relinquished By		Date/Time		Received By		Date/Time																									
Kelsey Ward		7/19/23 @ 1720		L. Smith		7/20/23 1200																									
4. J. Smith		7/20/23 1600		Monique Petau (XX)		7/21/23 1139																									

CHAIN OF CUSTODY

pg. 6 of 7 Work order # 23071472

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
Address: 16200 Foster Street
City / State / Zip: Overland Park, KS 66085
Contact: Lindsay E. James (913) 495-9990
E-Mail: ljames@blackstone-env.com

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
Preserved in: ☐ LAB ☐ FIELD **FOR LAB USE ONLY**
Lab Notes

Client Comments:

Longview Farm
 Elementary

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No
 Are these samples known to be hazardous? ☐ Yes ☒ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name KSM		INDICATE ANALYSIS REQUESTED													
Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers		MATRIX											
Lab Use Only	Sample Identification	Date/Time Sampled		OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead
23071472-051	LFE1-051	7/19/23 @ 854															
-052	-052	@ 855															
-053	-053	@ 856															
-054	-054	@ 857															
-055	-055	@ 858															
-056	-056	@ 859															
-057	-057	@ 900															
-058	-058	@ 900															
-059	-059	@ 901															
-060	-060	@ 903															
Relinquished By		Date/Time		Received By		Date/Time											
K. L. James		7/19/23 @ 1720		K. L. James		7/20/23 1200											
L. E. James		7/20/23 1600		L. E. James		7/21/23 1339											

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 7 of 7 Work order # 23071472

fax: (618) 344-1005

Client:	Blackstone Environmental, Inc.	Samples on:	<input type="checkbox"/> ICE	<input type="checkbox"/> BLUE ICE	<input type="checkbox"/> NO ICE	°C	LTG#
Address:	16200 Foster Street	Preserved in:	<input type="checkbox"/> LAB	<input type="checkbox"/> FIELD	FOR LAB USE ONLY		
City / State / Zip	Overland Park, KS 66085	Lab Notes					
Contact:	Lindsay E. James	Phone:	(913) 495-9990				
E-Mail:	ljames@blackstone-env.com	Fax:					
			Client Comments:				

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name KSM		INDICATE ANALYSIS REQUESTED															
Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers		MATRIX					Received By							Date/Time	
Lab Use Only	Sample Identification	Date/Time Sampled	OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead	Received By	Date/Time	
23071742-001	LFE1-DF61	7/19/23 @ 903																	
-002	-S62	@ 904																	
-003	-063	@ 907																	
-004	-064	@ 910																	
-005	-S65	@ 908																	
-006	-066	@ 911																	
-007	-DF67	@ 912																	
-008	-DF68	@ 912																	
-009																			
1600																			
Relinquished By K. G. [Signature]		Date/Time 7/19/23 @ 1600		Received By W. [Signature]												Date/Time 7/20/23 1339			

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000

