

ATTACHMENT B

**Meadow Lane Elementary
Field Forms**

Lee's Summit DW

Date Purged
Date Sampled

7/20
7/21

School

Meadow Lane Elem.
(MLE)

Team

AK

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

| Test # | Floor # | Sink (SK) | Fountain (DF) | Other (O) | Location and Description | Time Purged | Time Sampled |
|--------|---------|-----------|---------------|-----------|-----------------------------------|-------------|--------------|
| 1 | 1 | X | | | teacher's lounge sink | 13:47 | 9:10 |
| 2 | 1 | | | X | teacher's lounge fridge ice maker | 13:47 | 9:11 |
| 3 | 1 | | | X | teacher's lounge ice maker | 13:47 | 9:12 |
| 4 | 1 | X | | | nurse's office sink | 13:50 | 9:13 |
| 5 | 1 | X | | | classroom 173 sink | 13:53 | 9:15 |
| 6 | 1 | | | X | classroom 173 bubbler | 13:53 | 9:15 |
| 7 | 1 | X | | | classroom 172 sink | 13:53 | 9:16 |
| 8 | 1 | | | X | classroom 172 bubbler | 13:53 | 9:16 |
| 9 | 1 | | X | | classroom 172/173 fountain | 13:54 | 9:17 |
| 10 | 1 | X | | | classroom 186 sink | 13:57 | 9:19 |
| 11 | 1 | X | | | classroom 186 sink | 13:58 | 9:20 |
| 12 | 1 | X | | | classroom 170 A sink | 14:04 | 9:21 |
| 13 | 1 | | | X | 170 A bubbler | 14:04 | 9:22 |
| 14 | 1 | X | | | 170 B sink | 14:05 | 9:23 |
| 15 | 1 | | | X | 170 B bubbler | 14:05 | 9:23 |
| 16 | 1 | X | | | 170 C sink | 14:06 | 9:24 |
| 17 | 1 | | | X | 170 C bubbler | 14:06 | 9:24 |
| 18 | 1 | X | | | 170 D sink | 14:11 | 9:25 |
| 19 | 1 | | | X | 170 D bubbler | 14:11 | 9:25 |
| 20 | 1 | | X | | fountain by 105 office | 14:20 | 9:27 |
| 21 | 1 | | X | | fountains in 118 corr. (1) | 14:21 | 9:28 |
| 22 | 1 | | X | | fountains in 118 corr. (2) | 14:21 | 9:28 |
| 23 | 1 | X | | | 169 A sink | 14:30 | 9:30 |
| 24 | 1 | | | X | 169 A bubbler | 14:30 | 9:30 |

Lee's Summit DW

Date Purged 7/20
Date Sampled 7/24

School

Meadows Lane Elem.
(MLE)

Team A+K

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

| Test # | Floor # | Sink (SK) | Fountain (DF) | Other (O) | Location and Description | Time Purged | Time Sampled |
|--------|---------|--------------|---------------|--------------|-----------------------------|-------------|--------------|
| 25 | 1 | X | | | 169 D sink | 14:31 | 9:32 |
| 26 | 1 | | | X | 169 D bubbler | 14:31 | 9:32 |
| 27 | 1 | X | | | 169 C sink | 14:32 | 9:33 |
| 28 | 1 | | | X | 169 C bubbler | 14:32 | 9:33 |
| 29 | 1 | X | | | 169 B sink | 14:33 | 9:34 |
| 30 | 1 | | | X | 169 B bubbler | 14:33 | 9:34 |
| 31 | 1 | | X | | fountain (r) by 165 girls | 14:42 | 9:36 |
| 32 | 1 | | X | | fountain (l) by 163 boys | 14:42 | 9:36 |
| 33 | 1 | X | | | 161 lounge sink | 14:44 | 9:37 |
| 34 | 1 | X | | | 159 sink | 14:45 | 9:38 |
| 35 | 1 | | X | X | 159 hall fountain (l) | 14:47 | 9:39 |
| 36 | 1 | | X | | 159 hall fountain (r) | 14:47 | 9:39 |
| 37 | 1 | X | X | | 203 sink | 14:50 | 9:40 |
| 38 | 1 | X | | | 201 sink (r) | 14:50 | 9:41 |
| 39 | 1 | X | | | 201 sink (l) | 14:50 | 9:41 |
| 40 | 1 | | X | | fountain by gym (r) | 14:57 | 9:42 |
| 41 | 1 | | X | | fountain by gym (l) | 14:57 | 9:42 |
| 42 | 1 | | X | | cafeteria fountain | 15:03 | 9:44 |
| 43 | 1 | X | | | sink w/ spray nozzle | 15:05 | 9:45 |
| 44 | 1 | X | | X | dishwasher | 15:05 | 9:47 |
| 45 | 1 | X | | X | dish washing sink (l) | 15:05 | 9:46 |
| 46 | 1 | X | | | dish washing sink (r) | 15:05 | 9:46 |
| 47 | 1 | X | | | dish washing sink w/ nozzle | 15:06 | 9:47 |
| 48 | 1 | | | X | steam over | 15:08 | 9:49 |

Lee's Summit DW

Date Purged 7/20
Date Sampled 7/24

School

Meadow Lane Elem.
(MCE)

Team AK

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

| Test # | Floor # | Sink (SK) | Fountain (DF) | Other (O) | Location and Description | Time Purged | Time Sampled |
|--------|---------|-----------|---------------|-----------|--------------------------|-------------|--------------|
| 49 | 1 | | X | | corridor 205 by cafe (1) | 15:12 | 9:51 |
| 50 | 1 | | X | | corridor 205 by cafe (1) | 15:12 | 9:52 |
| 51 | 1 | X | | | 146 sink | 15:13 | 9:53 |
| 52 | 1 | X | | | 136 sink | 15:13 | 9:53 |
| 53 | 1 | X | | | 134 A sink | 15:20 | 9:55 |
| 54 | 1 | X | | | 134 D sink | 15:20 | 9:55 |
| 55 | 1 | | | X | 134 D bubbler | 15:20 | 9:55 |
| 56 | 1 | X | | | 134 C sink | 15:21 | 9:56 |
| 57 | 1 | X | | X | 134 C bubbler | 15:21 | 9:57 |
| 58 | 1 | X | | | 134 B sink | 15:22 | 9:58 |
| 59 | 1 | | | X | 134 B bubbler | 15:22 | 9:58 |
| 60 | 1 | X | | | 135 D sink | 15:33 | 10:01 |
| 61 | 1 | | | X | 135 D bubbler | 15:33 | 10:01 |
| 62 | 1 | X | | | 135 B sink | 15:35 | 10:02 |
| 63 | 1 | | | X | 135 B bubbler | 15:35 | 10:02 |
| 64 | 1 | X | | | 135 C sink | 15:37 | 10:03 |
| 65 | 1 | X | | | 126 C sink | 15:43 | 10:03 |
| 66 | 1 | | | X | 126 C bubbler | 15:43 | 10:04 |
| 67 | 1 | X | | | 128 D sink | 15:46 | 10:09 |
| 68 | 1 | | | X | 128 D bubbler | 15:46 | 10:10 |
| 69 | 1 | X | | | 128 C sink | 15:47 | 10:11 |
| 70 | 1 | | | X | 128 C bubbler | 15:47 | 10:12 |
| 71 | B | X | | | Band D sink | 15:55 | 10:14 |

ATTACHMENT C

Meadow Lane Elementary Summary Table

Summary Table
Meadow Lane Elementary

| Sample ID | Date | Analyte | Result | Unit | Reporting Limit |
|-----------|-----------|---------|--------|------|-----------------|
| MLE1-S1 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-O2 | 7/21/2023 | Lead | 2.0 | µg/L | 1 |
| MLE1-O3 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S4 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S5 | 7/21/2023 | Lead | 5.9 | µg/L | 1 |
| MLE1-O6 | 7/21/2023 | Lead | 1.3 | µg/L | 1 |
| MLE1-S7 | 7/21/2023 | Lead | 3.5 | µg/L | 1 |
| MLE1-O8 | 7/21/2023 | Lead | 1.0 | µg/L | 1 |
| MLE1-DF9 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S10 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S11 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S12 | 7/21/2023 | Lead | 10.5 | µg/L | 1 |
| MLE1-O13 | 7/21/2023 | Lead | 2.9 | µg/L | 1 |
| MLE1-S14 | 7/21/2023 | Lead | 12.7 | µg/L | 1 |
| MLE1-O15 | 7/21/2023 | Lead | 2.5 | µg/L | 1 |
| MLE1-S16 | 7/21/2023 | Lead | 3.6 | µg/L | 1 |
| MLE1-O17 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S18 | 7/21/2023 | Lead | 2.3 | µg/L | 1 |
| MLE1-O19 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-DF20 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-DF21 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-DF22 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S23 | 7/21/2023 | Lead | 2.8 | µg/L | 1 |
| MLE1-O24 | 7/21/2023 | Lead | 1.6 | µg/L | 1 |
| MLE1-S25 | 7/21/2023 | Lead | 2.0 | µg/L | 1 |
| MLE1-O26 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S27 | 7/21/2023 | Lead | 1.8 | µg/L | 1 |
| MLE1-O28 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S29 | 7/21/2023 | Lead | 15.2 | µg/L | 1 |
| MLE1-O30 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-DF31 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-DF32 | 7/21/2023 | Lead | 1.0 | µg/L | 1 |
| MLE1-S33 | 7/21/2023 | Lead | 1.9 | µg/L | 1 |
| MLE1-S34 | 7/21/2023 | Lead | 2.5 | µg/L | 1 |
| MLE1-DF35 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-DF36 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S37 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S38 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S39 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-DF40 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-DF41 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-DF42 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S43 | 7/21/2023 | Lead | 1.7 | µg/L | 1 |

| | | | | | |
|-----------|-----------|------|-------------|------|---|
| MLE1-O44 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S45 | 7/21/2023 | Lead | 13.0 | µg/L | 1 |
| MLE1-S46 | 7/21/2023 | Lead | 4.4 | µg/L | 1 |
| MLE1-S47 | 7/21/2023 | Lead | 8.2 | µg/L | 1 |
| MLE1-O48 | 7/21/2023 | Lead | 6.4 | µg/L | 1 |
| MLE1-DF49 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-DF50 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S51 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S52 | 7/21/2023 | Lead | 1.9 | µg/L | 1 |
| MLE1-S53 | 7/21/2023 | Lead | 2.1 | µg/L | 1 |
| MLE1-S54 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-O55 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S56 | 7/21/2023 | Lead | 1.3 | µg/L | 1 |
| MLE1-O57 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S58 | 7/21/2023 | Lead | 7.7 | µg/L | 1 |
| MLE1-O59 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S60 | 7/21/2023 | Lead | 9.7 | µg/L | 1 |
| MLE1-O61 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S62 | 7/21/2023 | Lead | 2.7 | µg/L | 1 |
| MLE1-O63 | 7/21/2023 | Lead | 1.9 | µg/L | 1 |
| MLE1-S64 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S65 | 7/21/2023 | Lead | 34.7 | µg/L | 1 |
| MLE1-O66 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S67 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-O68 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-S69 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLE1-O70 | 7/21/2023 | Lead | ND | µg/L | 1 |
| MLEB-S71 | 7/21/2023 | Lead | 16.4 | µg/L | 1 |

µg/L: micrograms per liter

Bolded results indicate detection above reporting limits

ATTACHMENT D

Meadow Lane Elementary Laboratory Analytical Report

August 31, 2023

Lindsay E. James
Blackstone Environmental, Inc.
16200 Foster Street
Overland Park, KS 66085
TEL: (913) 956-4160
FAX:



| | |
|-----------|---------|
| Illinois | 100226 |
| Kansas | E-10374 |
| Louisiana | 05002 |
| Louisiana | 05003 |
| Oklahoma | 9978 |

RE: Lees Summit School Dist DW (MLE)

WorkOrder: 23071560

Dear Lindsay E. James:

TEKLAB, INC received 71 samples on 7/24/2023 11:35:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley
Project Manager
(618)344-1004 ex 44
patrickriley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

This reporting package includes the following:

| | |
|----------------------|----------|
| Cover Letter | 1 |
| Report Contents | 2 |
| Definitions | 3 |
| Case Narrative | 5 |
| Accreditations | 6 |
| Laboratory Results | 7 |
| Receiving Check List | 78 |
| Chain of Custody | Appended |

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Cooler Receipt Temp: NA °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: Blackstone Environmental, Inc.**Work Order:** 23071560**Client Project:** Lees Summit School Dist DW (MLE)**Report Date:** 31-Aug-23

| State | Dept | Cert # | NELAP | Exp Date | Lab |
|-----------|------|---------|-------|-----------|--------------|
| Illinois | IEPA | 100226 | NELAP | 1/31/2024 | Collinsville |
| Kansas | KDHE | E-10374 | NELAP | 4/30/2024 | Collinsville |
| Louisiana | LDEQ | 05002 | NELAP | 6/30/2024 | Collinsville |
| Louisiana | LDEQ | 05003 | NELAP | 6/30/2024 | Collinsville |
| Oklahoma | ODEQ | 9978 | NELAP | 8/31/2023 | Collinsville |
| Arkansas | ADEQ | 88-0966 | | 3/14/2024 | Collinsville |
| Illinois | IDPH | 17584 | | 5/31/2025 | Collinsville |
| Iowa | IDNR | 430 | | 6/1/2024 | Collinsville |
| Kentucky | UST | 0073 | | 1/31/2024 | Collinsville |
| Missouri | MDNR | 00930 | | 5/31/2023 | Collinsville |
| Missouri | MDNR | 930 | | 1/31/2025 | Collinsville |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-001
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S1
Collection Date: 07/21/2023 9:10

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 19:32 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-002
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O2
Collection Date: 07/21/2023 9:11

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 2.0 | µg/L | 5 | 08/30/2023 13:23 | 210433 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-003
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O3
Collection Date: 07/21/2023 9:12

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 19:36 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-004
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S4
Collection Date: 07/21/2023 9:13

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 19:40 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-005

Client Sample ID: MLE1-S5

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:15

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 5.9 | µg/L | 1 | 08/30/2023 19:43 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-006
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O6
Collection Date: 07/21/2023 9:15

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 1.3 | µg/L | 1 | 08/30/2023 20:09 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-007
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S7
Collection Date: 07/21/2023 9:16

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 3.5 | µg/L | 1 | 08/30/2023 20:12 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-008

Client Sample ID: MLE1-O8

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:16

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 1.0 | µg/L | 1 | 08/30/2023 20:16 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-009
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF9
Collection Date: 07/21/2023 9:17

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 20:20 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-010
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S10
Collection Date: 07/21/2023 9:19

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 20:23 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-011
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S11
Collection Date: 07/21/2023 9:20

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 20:27 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-012

Client Sample ID: MLE1-S12

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:21

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 10.5 | µg/L | 1 | 08/30/2023 20:34 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-013
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O13
Collection Date: 07/21/2023 9:22

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 2.9 | µg/L | 1 | 08/30/2023 20:31 | 210407 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-014
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S14
Collection Date: 07/21/2023 9:23

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 12.7 | µg/L | 1 | 08/29/2023 23:26 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-015
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O15
Collection Date: 07/21/2023 9:23

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 2.5 | µg/L | 1 | 08/30/2023 9:16 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-016
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S16
Collection Date: 07/21/2023 9:24

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 3.6 | µg/L | 1 | 08/30/2023 9:20 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-017

Client Sample ID: MLE1-O17

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:24

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 9:37 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-018
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S18
Collection Date: 07/21/2023 9:25

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 2.3 | µg/L | 1 | 08/30/2023 9:41 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-019

Client Sample ID: MLE1-O19

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:25

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 9:45 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-020
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF20
Collection Date: 07/21/2023 9:27

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 9:48 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-021
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF21
Collection Date: 07/21/2023 9:28

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/29/2023 22:27 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-022
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF22
Collection Date: 07/21/2023 9:28

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/29/2023 22:31 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-023
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S23
Collection Date: 07/21/2023 9:30

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 2.8 | µg/L | 1 | 08/29/2023 22:35 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-024
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O24
Collection Date: 07/21/2023 9:30

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 1.6 | µg/L | 1 | 08/29/2023 22:49 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-025
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S25
Collection Date: 07/21/2023 9:32

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 2.0 | µg/L | 1 | 08/29/2023 22:53 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-026
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O26
Collection Date: 07/21/2023 9:32

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/29/2023 22:57 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-027
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S27
Collection Date: 07/21/2023 9:33

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 1.8 | µg/L | 1 | 08/29/2023 23:00 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-028

Client Sample ID: MLE1-O28

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:33

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 0:14 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-029

Client Sample ID: MLE1-S29

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:34

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 15.2 | µg/L | 1 | 08/29/2023 23:15 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-030
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O30
Collection Date: 07/21/2023 9:34

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/29/2023 23:19 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-031

Client Sample ID: MLE1-DF31

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:36

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/29/2023 23:22 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-032
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF32
Collection Date: 07/21/2023 9:36

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 1.0 | µg/L | 1 | 08/29/2023 23:37 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-033

Client Sample ID: MLE1-S33

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:37

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 1.9 | µg/L | 1 | 08/29/2023 23:41 | 210402 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-034

Client Sample ID: MLE1-S34

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:38

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 2.5 | µg/L | 1 | 08/29/2023 23:44 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-035
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF35
Collection Date: 07/21/2023 9:39

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/29/2023 23:48 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-036
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF36
Collection Date: 07/21/2023 9:39

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 0:03 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-037

Client Sample ID: MLE1-S37

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:40

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 0:06 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-038
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S38
Collection Date: 07/21/2023 9:41

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|------------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 5 | 08/30/2023 12:57 | 210433 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-039
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S39
Collection Date: 07/21/2023 9:41

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 0:10 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-040
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF40
Collection Date: 07/21/2023 9:42

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 1:01 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-041
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF41
Collection Date: 07/21/2023 9:42

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 0:25 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-042
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF42
Collection Date: 07/21/2023 9:44

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 0:28 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-043
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S43
Collection Date: 07/21/2023 9:45

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 1.7 | µg/L | 1 | 08/30/2023 0:32 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-044

Client Sample ID: MLE1-O44

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:47

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 0:36 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-045

Client Sample ID: MLE1-S45

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:46

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 13.0 | µg/L | 1 | 08/30/2023 0:50 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-046

Client Sample ID: MLE1-S46

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:46

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 4.4 | µg/L | 1 | 08/30/2023 0:54 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-047

Client Sample ID: MLE1-S47

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:47

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 8.2 | µg/L | 1 | 08/30/2023 0:57 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-048
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O48
Collection Date: 07/21/2023 9:49

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 6.4 | µg/L | 1 | 08/30/2023 1:12 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-049
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF49
Collection Date: 07/21/2023 9:51

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 1:16 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-050
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-DF50
Collection Date: 07/21/2023 9:52

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 1:19 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-051
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S51
Collection Date: 07/21/2023 9:53

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 1:49 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-052
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S52
Collection Date: 07/21/2023 9:53

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 1.9 | µg/L | 1 | 08/30/2023 1:23 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-053

Client Sample ID: MLE1-S53

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:55

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 2.1 | µg/L | 1 | 08/30/2023 1:38 | 210403 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-054

Client Sample ID: MLE1-S54

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:55

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 1:41 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-055

Client Sample ID: MLE1-O55

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:55

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 1:45 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-056

Client Sample ID: MLE1-S56

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:56

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 1.3 | µg/L | 1 | 08/30/2023 2:00 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-057

Client Sample ID: MLE1-O57

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:57

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 2:03 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-058

Client Sample ID: MLE1-S58

Matrix: DRINKING WATER

Collection Date: 07/21/2023 9:58

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 7.7 | µg/L | 1 | 08/30/2023 2:07 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-059
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O59
Collection Date: 07/21/2023 9:58

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 2:11 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-060
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S60
Collection Date: 07/21/2023 10:01

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 9.7 | µg/L | 1 | 08/30/2023 2:25 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-061
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O61
Collection Date: 07/21/2023 10:01

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 2:29 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-062
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S62
Collection Date: 07/21/2023 10:02

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 2.7 | µg/L | 1 | 08/30/2023 2:33 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-063
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O63
Collection Date: 07/21/2023 10:02

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 1.9 | µg/L | 1 | 08/30/2023 2:36 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-064
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S64
Collection Date: 07/21/2023 10:03

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 2:47 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-065

Client Sample ID: MLE1-S65

Matrix: DRINKING WATER

Collection Date: 07/21/2023 10:03

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 34.7 | µg/L | 1 | 08/30/2023 2:51 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Lab ID: 23071560-066

Client Sample ID: MLE1-O66

Matrix: DRINKING WATER

Collection Date: 07/21/2023 10:04

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|---|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 2:55 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-067
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S67
Collection Date: 07/21/2023 10:09

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 2:58 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-068
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O68
Collection Date: 07/21/2023 10:10

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 3:13 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-069
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-S69
Collection Date: 07/21/2023 10:11

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 3:17 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-070
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLE1-O70
Collection Date: 07/21/2023 10:12

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | < 1.0 | µg/L | 1 | 08/30/2023 3:20 | 210404 |



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.
Client Project: Lees Summit School Dist DW (MLE)
Lab ID: 23071560-071
Matrix: DRINKING WATER

Work Order: 23071560
Report Date: 31-Aug-23
Client Sample ID: MLEB-S71
Collection Date: 07/21/2023 10:14

| Analyses | Certification | RL | Qual | Result | Units | DF | Date Analyzed | Batch |
|--|---------------|-----|------|--------|-------|----|-----------------|--------|
| EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL) | | | | | | | | |
| Lead | NELAP | 1.0 | | 16.4 | µg/L | 1 | 08/30/2023 3:35 | 210404 |



Receiving Check List

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071560

Client Project: Lees Summit School Dist DW (MLE)

Report Date: 31-Aug-23

Carrier: Skylar Mathis

Received By: MBP

Completed by:

Elizabeth A. Hurley

Reviewed by:

Ellie Hopkins

On:

26-Jul-23

On:

26-Jul-23

Elizabeth A. Hurley

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

| | | | | |
|---|--|------------------------------|--|----------------------------------|
| Shipping container/cooler in good condition? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | Not Present <input type="checkbox"/> | Temp °C NA |
| Type of thermal preservation? | None <input checked="" type="checkbox"/> | Ice <input type="checkbox"/> | Blue Ice <input type="checkbox"/> | Dry Ice <input type="checkbox"/> |
| Chain of custody present? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Chain of custody agrees with sample labels? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Samples in proper container/bottle? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sample containers intact? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Sufficient sample volume for indicated test? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| All samples received within holding time? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |
| Reported field parameters measured: | Field <input type="checkbox"/> | Lab <input type="checkbox"/> | NA <input checked="" type="checkbox"/> | |
| Container/Temp Blank temperature in compliance? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | | |

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

| | | | |
|---|---|-----------------------------|---|
| Water – at least one vial per sample has zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No VOA vials <input checked="" type="checkbox"/> |
| Water - TOX containers have zero headspace? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | No TOX containers <input checked="" type="checkbox"/> |
| Water - pH acceptable upon receipt? | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | NA <input type="checkbox"/> |
| NPDES/CWA TCN interferences checked/treated in the field? | Yes <input type="checkbox"/> | No <input type="checkbox"/> | NA <input checked="" type="checkbox"/> |

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

pg. 1 of 8 Work order # 23071560

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

| | | | | | |
|--------------------|--------------------------------|--------|--|--|--|
| Client: | Blackstone Environmental, Inc. | | Are these samples known to be involved in litigation? If yes, a surcharge will apply | <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No |
| Address: | 16200 Foster Street | | Are these samples known to be hazardous? <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No | |
| City / State / Zip | Overland Park, KS 66085 | Phone: | (913) 495-9990 | | |
| Contact: | Lindsey E. James | Fax: | | | |
| E-Mail: | ljames@blackstone-env.com | | | | |

| | | | | | |
|------------------|---|-----------------------------------|--|----|------|
| Samples on: | <input type="checkbox"/> ICE | <input type="checkbox"/> BLUE ICE | <input checked="" type="checkbox"/> NO ICE | °C | LTG# |
| Preserved in: | <input checked="" type="checkbox"/> LAB | <input type="checkbox"/> FIELD | | | |
| Lab Notes | | | | | |
| Client Comments: | Meadow lane Elem. (ME) | | | | |

| Project Name/Number Lee's Summit School Dist. DW | | Sample Collector's Name KSM | | INDICATE ANALYSIS REQUESTED | | | | | | | | | | | | | |
|--|-----------------------|--------------------------------|----------------|-----------------------------|--------|------|-----|-------|------|------|--------|----------------|------|--------|---------------|-------------|--------------|
| Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge) | | Billing Instructions | | # and Type of Containers | | | | | | | | | | | | | |
| Lab Use Only | Sample Identification | Date/Time Sampled | | OTHER | NaHSO4 | MeOH | HCL | H2SO4 | NaOH | HNO3 | UNPRES | Drinking Water | Soil | Sludge | Special Waste | Groundwater | DW Lead |
| 33071900-001 | MLE1-S1 | 7/21/23 @ 910 | | | | | | | | | | | | | | | |
| 002 | MLE1-02 | @ 911 | | | | | | | | | | | | | | | |
| 003 | MLE1-03 | @ 912 | | | | | | | | | | | | | | | |
| 004 | MLE1-S4 | @ 913 | | | | | | | | | | | | | | | |
| 005 | MLE1-S5 | @ 915 | | | | | | | | | | | | | | | |
| 006 | MLE1-06 | @ 915 | | | | | | | | | | | | | | | |
| 007 | MLE1-S7 | @ 916 | | | | | | | | | | | | | | | |
| 008 | MLE1-08 | @ 916 | | | | | | | | | | | | | | | |
| 009 | MLE1-DF9 | @ 917 | | | | | | | | | | | | | | | |
| 010 | MLE1-S10 | @ 919 | ✓ | | | | | | | | | | | | | | |
| Relinquished By | | | Date/Time | Received By | | | | | | | | | | | | | Date/Time |
| Karen Truitt | | | 7/21/23 @ 1245 | G. [Signature] | | | | | | | | | | | | | 7/21/23 1330 |
| B. [Signature] | | | 7/21/23 1600 | Angela Matthews | | | | | | | | | | | | | 7/22/23 |
| Angela Matthews | | | 7/24/23 1135 | Tracy [Signature] | | | | | | | | | | | | | 7/24/23 1135 |

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



pg. 2 of 8 Work order # 23671560

pg. 2 of 8 Work order # 23671560

| | |
|---------------------------------|--------------------------------|
| Client: _____ | Blackstone Environmental, Inc. |
| Address: _____ | 16200 Foster Street |
| City / State / Zip _____ | Overland Park, KS 66085 |
| Contact: _____ | Lindsay E. James |
| E-Mail: _____ | ljames@blackstone-env.com |
| Phone: _____ | (913) 495-9990 |
| Fax: _____ | |

| | | |
|---|--------------------------------|------------|
| Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE | _____ °C | _____ LTG# |
| Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD | <u>FOR LAB USE ONLY</u> | |
| Lab Notes | | |
| Client Comments: | | |

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

| Project Name/Number Lee's Summit School Dist. DW | | | | | | Sample Collector's Name KSM | | | | | | | | INDICATE ANALYSIS REQUESTED | | | | | | | | | |
|---|--|--|--|--|--|---------------------------------------|--|--|--|--|--|--|--|-----------------------------|--|--|--|--|--|--|--|--|--|
| Matrix | | | | | | | | | | | | | | | | | | | | | | | |
| Groundwater | | | | | | | | | | | | | | | | | | | | | | | |
| Special Waste | | | | | | | | | | | | | | | | | | | | | | | |
| Sludge | | | | | | | | | | | | | | | | | | | | | | | |
| Soil | | | | | | | | | | | | | | | | | | | | | | | |
| Drinking Water | | | | | | | | | | | | | | | | | | | | | | | |
| Aqueous | | | | | | | | | | | | | | | | | | | | | | | |
| Billing Instructions | | | | | | # and Type of Containers | | | | | | | | | | | | | | | | | |
| | | | | | | OTHER | | | | | | | | | | | | | | | | | |
| | | | | | | NaHSO ₄ | | | | | | | | | | | | | | | | | |
| | | | | | | MeOH | | | | | | | | | | | | | | | | | |
| | | | | | | HCL | | | | | | | | | | | | | | | | | |
| | | | | | | H ₂ SO ₄ | | | | | | | | | | | | | | | | | |
| | | | | | | NaOH | | | | | | | | | | | | | | | | | |
| | | | | | | HNO ₃ | | | | | | | | | | | | | | | | | |
| UNPRES | | | | | | | | | | | | | | | | | | | | | | | |
| Date/Time Sampled | | | | | | | | | | | | | | | | | | | | | | | |
| 7/27/23 @ 920 | | | | | | | | | | | | | | | | | | | | | | | |
| @ 921 | | | | | | | | | | | | | | | | | | | | | | | |
| @ 922 | | | | | | | | | | | | | | | | | | | | | | | |
| @ 923 | | | | | | | | | | | | | | | | | | | | | | | |
| @ 923 | | | | | | | | | | | | | | | | | | | | | | | |
| @ 924 | | | | | | | | | | | | | | | | | | | | | | | |
| @ 924 | | | | | | | | | | | | | | | | | | | | | | | |
| @ 925 | | | | | | | | | | | | | | | | | | | | | | | |
| @ 925 | | | | | | | | | | | | | | | | | | | | | | | |
| @ 927 | | | | | | | | | | | | | | | | | | | | | | | |
| @ 927 | | | | | | | | | | | | | | | | | | | | | | | |

| Relinquished By | Date/Time | Received By | Date/Time |
|-------------------|----------------|-------------------------|--------------|
| Kaduna, Zuma | 7/21/23 @ 1245 | N. G. [Signature] | 7/21/23 1350 |
| N. G. [Signature] | 7/21/23 1600 | Angela Matha crossroads | 7/22/23 |
| Angela Matha | 7/24/23 4:35 | Angela Matha | 7/24/23 135 |

BottleOrder: 82000



TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

| | | | |
|---------------------------|--------------------------------|---------------|----------------|
| Client: | Blackstone Environmental, Inc. | | |
| Address: | 16200 Foster Street | | |
| City / State / Zip | Overland Park, KS | 66085 | |
| Contact: | Lindsay E. James | Phone: | (913) 495-9990 |
| E-Mail: | ljames@blackstone-env.com | | |

| | | | | |
|-------------------------|------------------------------|-----------------------------------|---------------------------------|-------------------|
| Samples on: | <input type="checkbox"/> ICE | <input type="checkbox"/> BLUE ICE | <input type="checkbox"/> NO ICE | LTG# _____ |
| Preserved in: | <input type="checkbox"/> LAB | <input type="checkbox"/> FIELD | FOR LAB USE ONLY | |
| Lab Notes | _____ | | | |
| Client Comments: | MLE | | | |

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

[illegible]

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
Address: 16200 Foster Street
City / State / Zip: Overland Park, KS 66085
Contact: Lindsay E. James
E-Mail: ljames@blackstone-env.com
Phone: (913) 495-9990
Fax:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

| Project Name/Number Lee's Summit School Dist. DW | | Sample Collector's Name KSM | |
|--|-----------------------|--------------------------------|---|
| Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge) | | Billing Instructions | # and Type of Containers |
| Lab Use Only | Sample Identification | Date/Time Sampled | OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES |
| 03011500-031 | MVE1 - DF31 | 7/11/23 @ 930 | |
| 032 | - DF32 | @ 930 | |
| 033 | - S33 | @ 937 | |
| 034 | - S34 | @ 938 | |
| 035 | - DF35 | @ 939 | |
| 036 | - DF36 | @ 939 | |
| 037 | - S37 | @ 940 | |
| 038 | - S38 | @ 941 | |
| 039 | - S39 | @ 941 | |
| 040 | - DF40 | @ 942 | |

| Relinquished By | Date/Time |
|-------------------------|---------------|
| Karlus Vinas | 7/2/23 @ 1245 |
| Karlus Vinas | 7/2/23 1600 |
| Karlus Vinas | 7/2/23 1135 |

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE _____ °C LTG# _____

Preserved in: ☐ LAB ☐ FIELD

FOR LAB USE ONLY

Lab Notes

Client Comments:

[illegible]

| Received By | Date/Time |
|------------------------|--------------|
| W. [Signature] | 7/21/23 1350 |
| Spencer M. [Signature] | 7/22/23 |
| William [Signature] | 7/24/23 135 |



Work order # 2307560

fax: (618) 344-1005

| | | | |
|---------------------------|--------------------------------|---------------|----------------|
| Client: | Blackstone Environmental, Inc. | | |
| Address: | 16200 Foster Street | | |
| City / State / Zip | Overland Park, KS 66085 | | |
| Contact: | Lindsay E. James | Phone: | (913) 495-9990 |
| E-Mail: | ljames@blackstone-env.com | Fax: | |

| | | |
|---|-------------------------|------|
| Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE | °C | LTG# |
| Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD | FOR LAB USE ONLY | |
| Lab Notes | | |
| Client Comments: | | |

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

[illegible]

| Relinquished By | Date/Time | Received By | Date/Time |
|--------------------|----------------|--------------------|--------------|
| Kelsey Brown | 7/21/23 @ 1245 | K. [Signature] | 7/21/23 1350 |
| K. [Signature] | 7/21/23 1600 | Snyder [Signature] | 7/22/23 |
| Snyder [Signature] | 7/24/23 1135 | Morgan [Signature] | 7/24/23 135 |



pg. 6 of 8 Work order # 23071560pg. 6 of 8 Work order # 23071560

Client: Blackstone Environmental, Inc.

Address: 16200 Foster Street

City / State / Zip Overland Park, KS 66085

Contact: Lindsey E. James **Phone:** (913) 495-9990

E-Mail: ljames@blackstone-env.com **Fax:** _____

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

[illegible]

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



TEKLAB, INC., 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

| | | | | | | |
|---------------------------|--------------------------------|---------------|----------------|--|--|--|
| Client: | Blackstone Environmental, Inc. | | | | | |
| Address: | 16200 Foster Street | | | | | |
| City / State / Zip | Overland Park, KS 66085 | | | | | |
| Contact: | Lindsay E. James | Phone: | (913) 495-9990 | | | |
| E-Mail: | ljames@blackstone-env.com | | Fax: | | | |

| | | | | | | | |
|-------------------------|------------------------------|-----------------------------------|---------------------------------|----------------------|----------------------|----------------------|----------------------|
| Samples on: | <input type="checkbox"/> ICE | <input type="checkbox"/> BLUE ICE | <input type="checkbox"/> NO ICE | <input type="text"/> | <input type="text"/> | <input type="text"/> | <input type="text"/> |
| Preserved in: | <input type="checkbox"/> LAB | <input type="checkbox"/> FIELD | <u>FOR LAB USE ONLY</u> | | | | |
| Lab Notes | | | | | | | |
| Client Comments: | | | | | | | |

ML

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

[illegible]

| Relinquished By | Date/Time | Received By | Date/Time |
|-------------------|----------------|-------------------|--------------|
| Kelsey Truitt | 7/21/23 @ 1245 | E. G. [Signature] | 7/21/23 1350 |
| E. G. [Signature] | 7/21/23 1600 | Angela Matto | 7/22/23 |
| Angela Matto | 7/24/23 1335 | Angela Matto | 7/24/23 135 |

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



pg. 8 of 8 Work order # 23071560pg. 8 of 8 Work order # 23071560[illegible]

BottleOrder: 82000

