

ATTACHMENT B

**Pleasant Lea Elementary
Field Forms**

Lee's Summit DW

Team ZS & BB

School Pleasant USA Elem

Date Purged 7/26/23

Date Sampled 7/27/23

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
1	1		X		DW Fountain outside 138	1304	956
2	1	X			Sink in Nurse/138	1305	958
3	1	X			Sink in 112	1306	959
4	1		X		L DW Fountain outside 150	1308	1000
5	1		X		R DW Fountain outside 150	1308	1000
6	1	X			Sink in 170/Library	1311	1001
7	1	X			L Sink in 114	1314	1003
8	1	X			R Sink in 114	1314	1003
9	1	X			L Sink in 116	1317	1004
10	1	X			R Sink in 116	1317	1004
11	1		X		L DW Fountain outside 119	1320	1008
12	1		X		2nd floor L DW Fountain outside 119	1320	1008
13	1		X		M DW Fountain outside 119	1320	—
14	1		X		2nd floor R DW Fountain outside 119	1320	—
15	1		X		R DW Fountain outside 119	1320	1008
16	1	X			L Sink in 197	1322	1011
17	1	X			R Sink in 197	1322	1011
18	1	X			L Sink in 117	1325	1011
19	1	X			M Sink in 117	1325	1011
20	1	X			R Sink in 117	1325	1011
21	1	X			L Sink in 115	1326	1015
22	1	X			M Sink in 115	1326	1015
23	1	X			R Sink in 115	1326	1015
24	1	X			L Sink in 113	1328	1017



Lee's Summit DW

Team RS-1313

Date Purged 7/26/23
Date Sampled 7/27/23

School Lee's Summit LSA Elem

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
25	1	X			M Sink in 113	1328	1017
26	1	X			R Sink in 113	1328	1017
27	1	X			L Sink in 111	1330	1018
28	1	X			M Sink in 111	1330	1018
29	1	X			R Sink in 111	1330	1018
30	1	X			Sink in 101	1337	1028
31	1	X			Sink in 100	1341	1025
32	1	X			Sink in 103	1342	1025
33	1	X			Sink in 105	1342	1026
34	1	X			Sink in 102	1345	1027
35	1	X			Sink in 104	1349	1027
36	1	X			Sink in 107	1350	1028
37	1	X			Sink in 109	1350	1028
38	1	X			Sink in 106	1353	1029
39	1	X			Sink in 108	1353	1029
40	1		X		L DW Fountain outside 108	1357	1034
41	1		X		M DW Fountain outside 108	1357	1034
42	1		X		R DW Fountain outside 108	1357	1034
43	1	X			Sink in 110A	1359	1036
44	1	X			Sink in 110	1359	1036
45	1				Sink in 104	---	---
46	1		X		DW Fountain in CAFE	1402	1040
47	1	X			Sink opposite 46	1404	1040
48	1			X	DISHWASHER	1404	1040

Lee's Summit DW

Date Purged 7/26/23
Date Sampled 7/27/23

School PLEASANT LEA ELEM

Team RS + BS

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
49	1	X			SINK OPPOSITE 48	1404	1040
50	1	X			L SINK OPPOSITE 48	1404	1040
51	1	X			M " "	1404	1040
52	1	X			R " "	1404	1040
53	1	X			SINK OPPOSITE 50-52	1405	1040
54	1	X			SINK ACCESS FROM REFRIG	1405	1040
55	1	X			SINK OPPOSITE 54	1405	1040
56	1	X			SINK R OF COMB OVEN	1406	1040
57	1			X	COMB OVEN	1408	1040
58	1	X			SINK IN R24/LOUNGE	1414	1047
59	1			X	ICE MACHINE IN R4/LOUNGE	1414	1047
60	2		X		L DW FOUNTAIN OUTSIDE 210	1418	1050
61	2		X		M DW FOUNTAIN OUTSIDE 210	1418	1050
62	2		X		R DW FOUNTAIN OUTSIDE 210	1418	1050
63	2	X			SINK IN 210	1419	1052
64	2	X			SINK IN 209	1421	1052
65	2	X			SINK IN 208	1424	1052
66	2	X			SINK IN 207	1426	1052
67	2	X			SINK IN 206	1428	1054
68	2	X			SINK IN 205	1430	1054
69	2	X			SINK IN 204	1435	1054
70	2	X			SINK IN 203	1430	1054
71	2	X			SINK IN 202	1437	1056
72	2	X			SINK IN 201	1438	1056

Date Purged
Date Sampled

School PLEASEANT LSA ELEM

Team 5 + 28

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

[illegible]

ATTACHMENT C

Pleasant Lea Elementary Summary Table

Summary Table
Pleasant Lea Elementary

Sample ID	Date	Analyte	Result	Unit	Reporting Limit
PLE 1 DF 1	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 2	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 3	7/27/2023	Lead	1.3	µg/L	1
PLE 1 DF 4	7/27/2023	Lead	ND	µg/L	1
PLE 1 DF 5	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 6	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 7	7/27/2023	Lead	2.2	µg/L	1
PLE 1 SK 8	7/27/2023	Lead	1.4	µg/L	1
PLE 1 SK 9	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 10	7/27/2023	Lead	1.3	µg/L	1
PLE 1 DF 11	7/27/2023	Lead	ND	µg/L	1
PLE 1 DF 12	7/27/2023	Lead	ND	µg/L	1
PLE 1 DF 15	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 16	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 17	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 18	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 19	7/27/2023	Lead	3.4	µg/L	1
PLE 1 SK 20	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 21	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 22	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 23	7/27/2023	Lead	1.7	µg/L	1
PLE 1 SK 24	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 25	7/27/2023	Lead	2.0	µg/L	1
PLE 1 SK 26	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 27	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 28	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 29	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 30	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 31	7/27/2023	Lead	5.9	µg/L	1
PLE 1 SK 32	7/27/2023	Lead	1.4	µg/L	1
PLE 1 SK 33	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 34	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 35	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 36	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 37	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 38	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 39	7/27/2023	Lead	ND	µg/L	1
PLE 1 DF 40	7/27/2023	Lead	ND	µg/L	1
PLE 1 DF 41	7/27/2023	Lead	ND	µg/L	1
PLE 1 DF 42	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 43	7/27/2023	Lead	1.4	µg/L	1
PLE 1 SK 44	7/27/2023	Lead	2.0	µg/L	1
PLE 1 DF 46	7/27/2023	Lead	ND	µg/L	1

PLE 1 SK 47	7/27/2023	Lead	2.3	µg/L	1
PLE 1 O48	7/27/2023	Lead	8.6	µg/L	1
PLE 1 SK 49	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 50	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 51	7/27/2023	Lead	5.5	µg/L	1
PLE 1 SK 52	7/27/2023	Lead	2.9	µg/L	1
PLE 1 SK 53	7/27/2023	Lead	3.8	µg/L	1
PLE 1 SK 54	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 55	7/27/2023	Lead	ND	µg/L	1
PLE 1 SK 56	7/27/2023	Lead	ND	µg/L	1
PLE 1 O57	7/27/2023	Lead	4.1	µg/L	1
PLE 1 SK 58	7/27/2023	Lead	ND	µg/L	1
PLE 1 O59	7/27/2023	Lead	ND	µg/L	1
PLE 2 DF 60	7/27/2023	Lead	ND	µg/L	1
PLE 2 DF 61	7/27/2023	Lead	ND	µg/L	1
PLE 2 DF 62	7/27/2023	Lead	ND	µg/L	1
PLE 2 SK 63	7/27/2023	Lead	1.1	µg/L	1
PLE 2 SK 64	7/27/2023	Lead	ND	µg/L	1
PLE 2 SK 65	7/27/2023	Lead	ND	µg/L	1
PLE 2 SK 66	7/27/2023	Lead	2.1	µg/L	1
PLE 2 SK 67	7/27/2023	Lead	ND	µg/L	1
PLE 2 SK 68	7/27/2023	Lead	1.3	µg/L	1
PLE 2 SK 69	7/27/2023	Lead	2.8	µg/L	1
PLE 2 SK 70	7/27/2023	Lead	3.6	µg/L	1
PLE 2 SK 71	7/27/2023	Lead	1.5	µg/L	1
PLE 2 SK 72	7/27/2023	Lead	ND	µg/L	1
PLE 2 SK 73	7/27/2023	Lead	2.9	µg/L	1

µg/L: micrograms per liter

Bolded results indicate detection above reporting limits

ATTACHMENT D

Pleasant Lea Elementary Laboratory Analytical Report

September 15, 2023

Lindsay E. James
Blackstone Environmental, Inc.
16200 Foster Street
Overland Park, KS 66085
TEL: (913) 956-4160
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: Lees Summit School Dist DW/Pleasant Lea Elem.

WorkOrder: 23072178

Dear Lindsay E. James:

TEKLAB, INC received 70 samples on 7/31/2023 12:40:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley
Project Manager
(618)344-1004 ex 44
patrickriley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	77
Chain of Custody	Appended

Client: Blackstone Environmental, Inc.**Work Order:** 23072178**Client Project:** Lees Summit School Dist DW/Pleasant Lea Elem.**Report Date:** 15-Sep-23**Abbr Definition**

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Cooler Receipt Temp: NA °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: Blackstone Environmental, Inc.**Work Order:** 23072178**Client Project:** Lees Summit School Dist DW/Pleasant Lea Elem.**Report Date:** 15-Sep-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2023	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-001

Client Sample ID: PLE 1 DF 1

Matrix: DRINKING WATER

Collection Date: 07/27/2023 9:56

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 0:01	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-002

Client Sample ID: PLE 1 SK 2

Matrix: DRINKING WATER

Collection Date: 07/27/2023 9:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 0:05	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-003

Client Sample ID: PLE 1 SK 3

Matrix: DRINKING WATER

Collection Date: 07/27/2023 9:59

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/12/2023 0:09	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-004

Client Sample ID: PLE 1 DF 4

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 0:12	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-005

Client Sample ID: PLE 1 DF 5

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 0:27	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-006

Client Sample ID: PLE 1 SK 6

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:01

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 0:31	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-007

Client Sample ID: PLE 1 SK 7

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.2	µg/L	1	09/12/2023 0:34	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-008

Client Sample ID: PLE 1 SK 8

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	1	09/12/2023 0:45	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-009

Client Sample ID: PLE 1 SK 9

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 0:49	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-010

Client Sample ID: PLE 1 SK 10

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/12/2023 0:53	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-011

Client Sample ID: PLE 1 DF 11

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 0:56	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-012

Client Sample ID: PLE 1 DF 12

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 1:00	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-013

Client Sample ID: PLE 1 DF 15

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 1:15	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-014

Client Sample ID: PLE 1 SK 16

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 1:18	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-015

Client Sample ID: PLE 1 SK 17

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 1:22	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-016

Client Sample ID: PLE 1 SK 18

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 1:33	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-017

Client Sample ID: PLE 1 SK 19

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.4	µg/L	5	09/13/2023 12:17	210907



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-018

Client Sample ID: PLE 1 SK 20

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 1:37	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-019

Client Sample ID: PLE 1 SK 21

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 1:40	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-020

Client Sample ID: PLE 1 SK 22

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 1:44	210833



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-021

Client Sample ID: PLE 1 SK 23

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.7	µg/L	1	09/12/2023 1:48	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-022

Client Sample ID: PLE 1 SK 24

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 2:02	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-023

Client Sample ID: PLE 1 SK 25

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.0	µg/L	1	09/12/2023 2:13	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-024

Client Sample ID: PLE 1 SK 26

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 2:17	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-025

Client Sample ID: PLE 1 SK 27

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 2:20	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-026

Client Sample ID: PLE 1 SK 28

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 2:24	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-027

Client Sample ID: PLE 1 SK 29

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 2:28	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-028

Client Sample ID: PLE 1 SK 30

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 2:31	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-029

Client Sample ID: PLE 1 SK 31

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		5.9	µg/L	1	09/12/2023 2:35	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-030

Client Sample ID: PLE 1 SK 32

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	1	09/12/2023 2:50	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-031

Client Sample ID: PLE 1 SK 33

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 2:53	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-032

Client Sample ID: PLE 1 SK 34

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/13/2023 12:21	210907



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-033

Client Sample ID: PLE 1 SK 35

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 2:57	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-034

Client Sample ID: PLE 1 SK 36

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 3:01	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-035

Client Sample ID: PLE 1 SK 37

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 3:04	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-036

Client Sample ID: PLE 1 SK 38

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 3:15	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-037

Client Sample ID: PLE 1 SK 39

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 3:19	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-038

Client Sample ID: PLE 1 DF 40

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 3:23	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-039

Client Sample ID: PLE 1 DF 41

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 3:37	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-040

Client Sample ID: PLE 1 DF 42

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 3:41	210834



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-041

Client Sample ID: PLE 1 SK 43

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.4	µg/L	1	09/12/2023 3:45	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-042

Client Sample ID: PLE 1 SK 44

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.0	µg/L	1	09/12/2023 3:48	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-043

Client Sample ID: PLE 1 DF 46

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 3:59	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-044

Client Sample ID: PLE 1 SK 47

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.3	µg/L	1	09/12/2023 4:03	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-045

Client Sample ID: PLE 1 O48

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		8.6	µg/L	5	09/13/2023 12:36	210907



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-046

Client Sample ID: PLE 1 SK 49

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 4:07	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-047

Client Sample ID: PLE 1 SK 50

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 4:10	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-048

Client Sample ID: PLE 1 SK 51

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		5.5	µg/L	1	09/12/2023 4:25	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-049

Client Sample ID: PLE 1 SK 52

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.9	µg/L	1	09/12/2023 4:28	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-050

Client Sample ID: PLE 1 SK 53

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.8	µg/L	1	09/12/2023 4:32	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-051

Client Sample ID: PLE 1 SK 54

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 4:36	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-052

Client Sample ID: PLE 1 SK 55

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 4:39	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-053

Client Sample ID: PLE 1 SK 56

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 4:43	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-054

Client Sample ID: PLE 1 O57

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		4.1	µg/L	1	09/12/2023 4:54	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-055

Client Sample ID: PLE 1 SK 58

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 4:58	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-056

Client Sample ID: PLE 1 O59

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 5:12	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-057

Client Sample ID: PLE 2 DF 60

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 10:35	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-058

Client Sample ID: PLE 2 DF 61

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 10:38	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-059

Client Sample ID: PLE 2 DF 62

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/13/2023 10:42	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-060

Client Sample ID: PLE 2 SK 63

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.1	µg/L	1	09/14/2023 9:56	210835



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-061

Client Sample ID: PLE 2 SK 64

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 9:53	210836



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-062

Client Sample ID: PLE 2 SK 65

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 9:56	210836



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-063

Client Sample ID: PLE 2 SK 66

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.1	µg/L	1	09/12/2023 10:00	210836



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-064

Client Sample ID: PLE 2 SK 67

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 10:04	210836



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-065

Client Sample ID: PLE 2 SK 68

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.3	µg/L	1	09/12/2023 10:08	210836



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-066

Client Sample ID: PLE 2 SK 69

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.8	µg/L	1	09/12/2023 10:11	210836



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-067

Client Sample ID: PLE 2 SK 70

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		3.6	µg/L	1	09/12/2023 10:33	210836



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-068

Client Sample ID: PLE 2 SK 71

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:56

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		1.5	µg/L	1	09/12/2023 10:37	210836



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-069

Client Sample ID: PLE 2 SK 72

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:56

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/12/2023 10:40	210836



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Lab ID: 23072178-070

Client Sample ID: PLE 2 SK 73

Matrix: DRINKING WATER

Collection Date: 07/27/2023 10:56

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		2.9	µg/L	1	09/12/2023 10:44	210836



Receiving Check List

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23072178

Client Project: Lees Summit School Dist DW/Pleasant Lea Elem.

Report Date: 15-Sep-23

Carrier: Skylar Mathis

Received By: MBP

Completed by:

On:

01-Aug-23

Amber Dilallo

Reviewed by:

On:

01-Aug-23

Ellie Hopkins

Pages to follow:

Chain of custody

8

Extra pages included

0

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C

NA

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice

☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☐

No ☒

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water - at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory. - amberdilallo - 7/31/2023 3:31:54 PM

Sample -012 labeled PLE 1 DF 12 rather than PLE 1 DF 14. Per Randy Seamans, the correct sample id is PLE 1 DF 2. AMD 8/1/23

CHAIN OF CUSTODY

pg. 1 of 8 Work order # 23072178

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James (913) 495-9990
 E-Mail: ljames@blackstone-env.com

Samples on: ☐ ICE ☐ BLUE ICE ☒ NO ICE ☐ LG# _____
 Preserved in: ☒ LAB ☐ FIELD FOR LAB USE ONLY
 Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

PLEASE NOT LEA ELEM

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED															
Lee's Summit School Dist. DW		PS-33		Billing Instructions		# and Type of Containers		MATRIX											
Results Requested	Sample Identification	Date/Time Sampled	OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead	Date/Time	Received By	
Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) Other <input type="checkbox"/> 3 Day (50% Surcharge)	23072178	7/27/23 956									X							7/27/23 1400	
	002 PLE/SK2	958									X							7/30/23	1430
	003 PLE/SK3	959									X							7/30/23	
	004 PLE/DF4	1000									X							7/30/23	1240
	005 PLE/DF5	1000									X							7/31/23	
	006 PLE/SK6	1001									X								
	007 PLE/SK7	1003									X								
	008 PLE/SK8	1003									X								
	009 PLE/SK9	1004									X								
	010 PLE/SK10	1007									X								
Relinquished By		Date/Time		Date/Time		Date/Time		Date/Time		Date/Time		Date/Time		Date/Time		Date/Time		Date/Time	
		7/27/23 1400		7/28/23 1600		7/31/23 1240		7/31/23		7/31/23		7/31/23		7/31/23		7/31/23		7/31/23	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000

CHAIN OF CUSTODY

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

pg. 2 of 8 Work order # 23072178

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James Phone: (913) 495-9990
 E-Mail: ljames@blackstone-env.com Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C LTG# _____
 Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY
 Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

PLEASANT LEA ELEM

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED	
Lee's Summit School Dist. DW		25-33			
Results Requested	Billing Instructions	# and Type of Containers			
Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) Other <input type="checkbox"/> 3 Day (50% Surcharge)		OTHER	NaHSO4	MeOH	HCL
		H2SO4	NaOH	HNO3	UNPRES
Lab Use Only	Sample Identification	Date/Time Sampled			
23072178-01	PLE/DF11	7/27/23 1008			
	PLE/DF12	1008			
	PLE/DF13				
01	PLE/DF14				
013	PLE/DF15	1008			
014	PLE/SK16	1011			
015	PLE/SK17	1011			
016	PLE/SK18	1011			
017	PLE/SK19	1011			
018	PLE/SK20	1011			
Relinquished By		Date/Time	Received By		
[Signature]		7/27/23 1900	[Signature]		
[Signature]		7/28/23 600	[Signature]		
[Signature]		7/31/23 1240	[Signature]		
			Date/Time		
			7/28/23 1430		
			7/30/23		
			7/30/23 1240		
			7/31/23		

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

pg. 3 of 8

Work order # 23072178

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James
 E-Mail: ljames@blackstone-env.com
 Phone: (913) 496-9990
 Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C LTG#
 Preserved in: ☐ LAB ☐ FIELD
 Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

PLEASANT LEA ELEM

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED												
Lee's Summit School Dist. DW		PS-33		MATRIX												
Results Requested		Billing Instructions		# and Type of Containers												
<input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)				OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES												
Lab Use Only	Sample Identification	Date/Time Sampled		Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead							
2301478	PLE/SK21	7/27/23 1015		X					X							
020	PLE/SK22	1015		X					X							
021	PLE/SK23	1015		X					X							
022	PLE/SK24	1017		X					X							
023	PLE/SK25	1017		X					X							
024	PLE/SK26	1017		X					X							
025	PLE/SK27	1018		X					X							
026	PLE/SK28	1018		X					X							
027	PLE/SK29	1018		X					X							
028	PLE/SK30	1024		X					X							

Relinquished By: *[Signature]* Date/Time: 7/27/23 1900
 Received By: *[Signature]* Date/Time: 7/28/23 1430
[Signature] 7/28/23 1600
[Signature] 7/30/23 1240
 7/31/23 1240
 1/31/23

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 4 of 8 Work order # 23077178

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James Phone: (913) 495-9990
 E-Mail: ljames@blackstone-env.com Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C LTG#
 Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY
 Lab Notes

Client Comments:

PLEASANT LEA ELEM

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED													
Lee's Summit School Dist. DW		PS-33		MATRIX													
Results Requested		Billing Instructions		# and Type of Containers													
Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) Other <input type="checkbox"/> 3 Day (50% Surcharge)				OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES													
Lab Use Only	Sample Identification	Date/Time Sampled		Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead								
23072178	PLE/SK31	7/27/23	1025	X					X								
030	PLE/SK32		1025	X					X								
031	PLE/SK33		1026	X					X								
032	PLE/SK34		1027	X					X								
033	PLE/SK35		1027	X					X								
034	PLE/SK36		1028	X					X								
035	PLE/SK37		1028	X					X								
036	PLE/SK38		1029	X					X								
037	PLE/SK39		1029	X					X								
038	PLE/DG40		1034	X					X								

Relinquished By: [Signature] Date/Time: 7/27/23 1900
 Received By: [Signature] Date/Time: 7/28/23 1430
 [Signature] Date/Time: 7/30/23
 [Signature] Date/Time: 7/30/23 1240
 [Signature] Date/Time: 7/31/23



CHAIN OF CUSTODY

pg. 5 of 8 Work order # 23072178

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James Phone: (913) 495-9990
 E-Mail: ljames@blackstone-env.com Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
 Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY

Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

PLEASANT LEA ELEM

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED	
Lee's Summit School Dist DW		RS-33			
Results Requested	Billing Instructions	# and Type of Containers			
<input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge)		OTHER	NaHSO4	MeOH	HCL
<input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		H2SO4	NaOH	HNO3	UNPRES
23072178	7/27/23 1034				
040	7/27/23 1034				
041	7/27/23 1036				
042	7/27/23 1036				
043	7/27/23 1040				
044	7/27/23 1040				
045	7/27/23 1040				
046	7/27/23 1040				
047	7/27/23 1040				
048	7/27/23 1040				

MATRIX	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead	Received By	Date/Time
Aqueous	X					X	7/27/23 1900	7/27/23 1900
	X					X	7/27/23 1600	7/27/23 1600
	X					X	7/31/23 1740	7/31/23 1740

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 6 of 8 Work order # 22072178

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James
 E-Mail: ljames@blackstone-env.com
 Phone: (913) 495-9990
 Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
 Preserved in: ☐ LAB ☐ FIELD ☐ FOR LAB USE ONLY
 Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

PLEASE NOT LEA EVEN

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED	
Lee's Summit School Dist. DW		RS - B3			
Results Requested	Billing Instructions	# and Type of Containers		MATRIX	
<input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		OTHER	NaHSO4	MeOH	HCL
		H2SO4	NaOH	HNO3	UNPRES
Lab Use Only	Sample Identification	Date/Time Sampled	Aqueous	Drinking Water	Soil
			Sludge	Special Waste	Groundwater
			DW Lead		
22072178	PLF/SK52	7/27/23 1040			
OS0	PLF/SK53	1040			
OS1	PLF/SK54	1040			
OS2	PLF/SK55	1040			
OS3	PLF/SK56	1040			
OS4	PLF/SK57	1040			
OS5	PLF/SK58	1047			
OS6	PLF/SK59	1047			
OS7	PLF/SK60	1050			
OS8	PLF/SK61	1050			
Relinquished By	Date/Time	Received By	Date/Time		
L. E. James	7/27/23 1900	L. E. James	7/28/23 1430		
L. E. James	7/28/23 1600	L. E. James	7/28/23 1600		
L. E. James	7/28/23 1240	L. E. James	7/28/23 1240		

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 8 of 8 Work order # 1507272

TEKLAB, INC., 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client:	Blackstone Environmental, Inc.	Samples on:	<input type="checkbox"/> ICE	<input type="checkbox"/> BLUE ICE	<input type="checkbox"/> NO ICE	°C	LTO#
Address:	16200 Foster Street	Preserved in:	<input type="checkbox"/> LAB	<input type="checkbox"/> FIELD	FOR LAB USE ONLY		
City / State / Zip	Overland Park, KS 66085	Lab Notes					
Contact:	Lindsey E. James	Phone:	(913) 495-9990				
E-Mail:	ljames@blackstone-env.com	Fax:					
		Client Comments:					

Client Comments:

PLEASEST USA ELEM

[illegible]

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82008

