

## **ATTACHMENT B**

---

**Prairie View Elementary  
Field Forms**

# Lee's Summit DW

Date Purged 7/24  
Date Sampled 7/25

School Prairie View Elem.  
(PVE)

Team AK

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
1	1	X			lounge sink	12:08	8:18
2	1			X	lounge ice maker	12:08	8:18
3	1	X			focus room 1st sink	12:11	8:19
4	1	<del>X</del>	X		multipurpose fountain (1)	12:17	8:20
5	1	<del>X</del>	X		multipurpose fountain (r)	12:17	8:20
6	1	X			dish sink	12:23	8:21
7	1			X	dishwasher	12:23	8:22
8	1	X			dishwashing sink (r)	12:24	8:23
9	1	X			dishwashing sink (m)	12:24	8:24
10	1	X			dishwashing sink (1) w/ nozzles	12:24	8:24
11	1	X			food prep sink	12:25	8:25
12	1	X			food prep sink	12:25	8:25
13	1	X			food prep sink	12:25	8:26
14	1			X	steam oven (r)	12:29	8:26
15	1			X	steam oven (1)	12:32	8:26
16	1	X			art room sink 1	12:34	8:29
17	1	X			art room sink 2	12:34	8:29
18	1	X			art room sink 3	12:34	8:29
19	1	X			art room sink 4	12:34	8:30
20	1	X			art room sink 5	12:34	8:30
21	1	X			art room sink 6	12:34	8:30
22	1	X			work room 1st sink	12:35	8:31
23	1	X			library office sink	12:37	8:32
24	1	X			135 sink	12:42	8:33



Lee's Summit DW

Team AK

School Prairie View Elem.  
(PVE)

Date Purged 7/24  
Date Sampled 7/25

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
25	1			X	135 bubbler	12:42	8:34
26	1	X			139 sink	12:44	8:35
27	1			X	139 bubbler	12:44	8:35
28	1	X			138 sink	12:45	8:36
29	1	X			146 sink	12:52	8:38
30	1	<del>X</del>		X	146 bubbler	12:52	8:38
31	1	X			145 sink	12:52	8:38
32	1	<del>X</del>		X	145 bubbler	12:52	8:38
33	1	X			144 sink	12:52	8:40
34	1	<del>X</del>		X	144 bubbler	12:52	8:40
35	1	X			143 sink	12:52	8:41
36	1	<del>X</del>		X	143 bubbler	12:52	8:42
37	1	X			142 sink	13:00	8:44
38	1			X	142 bubbler	13:00	8:44
39	1	X			141 sink	13:00	8:45
40	1			X	141 bubbler	13:00	8:45
41	1	X			140 sink	13:00	8:46
42	1			X	140 bubbler	13:00	8:47
43	1	X			<del>140</del> 139 sink	13:00	8:47
44	1			X	139 bubbler	13:00	8:48
45	1				174 sink	13:06	8:50
46	1	X		X	174 bubbler	13:06	8:51
47	1	X			173 sink	13:06	8:51
48	1			X	173 bubbler	13:06	8:51



# Lee's Summit DW

Date Purged  
Date Sampled

School  
Prairie View Elem.  
(PVE)

Team  
OK

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
49	1	X			160 sink	13:06	8:52
50	1			X	160 bubbler	13:06	8:53
51	1		X		girls fountain (r)	13:07	8:54
52	1		X		girls fountain (r)	13:07	8:54
53	1		X		boys fountain (r)	13:08	8:55
54	1		X		boys fountain (r)	13:08	8:55
55	1	X			1910 sink	13:15	9:57
56	1			X	191 bubbler	13:15	8:58
57	1	X			190 sink	13:15	8:58
58	1			X	190 bubbler	13:15	8:58
59	1	X			188 sink	13:23	9:00
60	1			X	188 bubbler	13:23	9:00
61	1	X			187 sink	13:24	9:01
62	1			X	187 bubbler	13:24	9:02
63	1	X			186 sink	13:25	9:03
64	1			X	186 bubbler	13:25	9:03
65	1	X			164 sink	13:30	9:05
66	1			X	164 bubbler	13:30	9:06
67	1	X			1603 sink	13:30	9:07
68	1			X	1603 bubbler	13:30	9:07
69	1	X			160 sink	13:31	9:09
70	1			X	160 bubbler	13:31	9:08
71	1	X			165 sink	13:31	9:09
72	1			X	165 bubbler	13:31	9:09



# Lee's Summit DW

Date Purged

Date Sampled

7/24

7/25

School

Prairie View Elem.  
(PVE)

Team

OK

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
73	1	X			155 sink	13:36	9:11
74	1			X	155 bubbler	13:36	9:12
75	1	X			158 sink	13:37	9:13
76	1			X	158 bubbler	13:37	9:14
77	1	X			157 sink	13:38	9:14
78	1			X	157 bubbler	13:38	9:15
79	1		X		for right by gym	13:45	9:17
80	1		X		2nd right by gym	13:43	9:17
81	1		X		for left by gym	13:43	9:18
82	1		X		2nd left by gym	13:43	9:18
83	1	X			nurse sink	13:49	9:22
84	1	X			83 sink	13:50	9:23
85	1	X			82 sink	13:50	9:24
86	1	X			81 sink	13:50	9:24
87	1	X			72 sink	13:56	9:27
88	1	X			74 sink	13:56	9:27
89	1	X			60 sink	14:02	9:29
90	1	X			62 sink	14:02	9:30
91	1	X			61 sink	14:02	9:30
92	1		X		boys fountain (r)	14:04	9:31
93	1		X		boys fountain (l)	14:04	9:31
94	1		X		girls fountain (r)	14:04	9:32
95	1		X		girls fountain (l)	14:04	9:32
96	1	X			193 sink	14:12	9:34



Lee's Summit DW

Date Purged

Date Sampled

7/24  
7/25

School

Prairie View Elem.  
(PVE)

Team

ARK

Sample ID = School abbrev + Floor + Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
97	1	X			195 sink	14:12	9:34
98	1	X			194 sink	14:12	9:35
99	1	X			library 740 office sink	14:19	9:37
100	1	X			603 sink	14:20	9:38
101	1	X			604 sink	14:20	9:38
102	1		X		Kindergarten fountain (1)	14:20	9:39
103	1		X		Kindergarten fountain (1)	14:20	9:40
104	1	X			counselor 47 sink	14:20	9:42
105	1		X		lobby 59 (1) fountain	14:28	9:43
106	1		X		lobby 59 (1) fountain	14:28	9:43
107	1	X			68 sink	14:28	9:44
108	1	X			69 teacher's lounge	14:29	9:45
109	1	X			79 sink	14:35	9:46
110	1	X			77 sink	14:35	9:47
111	1	X			78 sink	14:35	9:48
112	1	X			88 sink	14:36	9:49
113	1	X			90 sink	14:36	9:50
114	1	X			84 sink	14:42	9:54
115	1	X			87 sink	14:42	9:52
116	1	X			85 sink	14:42	9:54
117	1	X			SPED sink	14:43	9:57
118	1			X	SPED dishwasher	14:43	10:00
119	1		X		boys fountain (1)	14:44	10:04
120	1		X		boys fountain (1)	14:44	10:04



Team QAK

Date Sampled

## Pairwise Elem. (PVE)

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

[illegible]

## **ATTACHMENT C**

---

### **Prairie View Elementary Summary Table**



**Summary Table**  
**Prairie View Elementary**

Sample ID	Date	Analyte	Result	Unit	Reporting Limit
PVEI-S1	7/25/2023	Lead	ND	µg/L	1
PVEI-O2	7/25/2023	Lead	ND	µg/L	1
PVEI-S3	7/25/2023	Lead	1.8	µg/L	1
PVEI-DF4	7/25/2023	Lead	ND	µg/L	1
PVEI-DF5	7/25/2023	Lead	ND	µg/L	1
PVEI-S6	7/25/2023	Lead	7.2	µg/L	1
PVEI-O7	7/25/2023	Lead	ND	µg/L	1
PVEI-S8	7/25/2023	Lead	ND	µg/L	1
PVEI-S9	7/25/2023	Lead	1.4	µg/L	1
PVEI-S10	7/25/2023	Lead	1.6	µg/L	1
PVEI-S11	7/25/2023	Lead	ND	µg/L	1
PVEI-S12	7/25/2023	Lead	ND	µg/L	1
PVEI-S13	7/25/2023	Lead	ND	µg/L	1
PVEI-O14	7/25/2023	Lead	7.7	µg/L	1
PVEI-O15	7/25/2023	Lead	3.1	µg/L	1
PVEI-S16	7/25/2023	Lead	3.1	µg/L	1
PVEI-S17	7/25/2023	Lead	1.6	µg/L	1
PVEI-S18	7/25/2023	Lead	2.4	µg/L	1
PVEI-S19	7/25/2023	Lead	4.9	µg/L	1
PVEI-S20	7/25/2023	Lead	3.9	µg/L	1
PVEI-S21	7/25/2023	Lead	7.3	µg/L	1
PVEI-S22	7/25/2023	Lead	1.9	µg/L	1
PVEI-S23	7/25/2023	Lead	7.3	µg/L	1
PVEI-S24	7/25/2023	Lead	1.5	µg/L	1
PVEI-O25	7/25/2023	Lead	ND	µg/L	1
PVEI-S26	7/25/2023	Lead	1.3	µg/L	1
PVEI-O27	7/25/2023	Lead	ND	µg/L	1
PVEI-S28	7/25/2023	Lead	61.4	µg/L	1
PVEI-S29	7/25/2023	Lead	ND	µg/L	1
PVEI-O30	7/25/2023	Lead	ND	µg/L	1
PVEI-S31	7/25/2023	Lead	1.1	µg/L	1
PVEI-O32	7/25/2023	Lead	ND	µg/L	1
PVEI-S33	7/25/2023	Lead	43.0	µg/L	1
PVEI-O34	7/25/2023	Lead	1.4	µg/L	1
PVEI-S35	7/25/2023	Lead	2.4	µg/L	1
PVEI-O36	7/25/2023	Lead	ND	µg/L	1
PVEI-S37	7/25/2023	Lead	2.4	µg/L	1
PVEI-O38	7/25/2023	Lead	ND	µg/L	1
PVEI-S39	7/25/2023	Lead	1.1	µg/L	1
PVEI-O40	7/25/2023	Lead	ND	µg/L	1
PVEI-S41	7/25/2023	Lead	2.4	µg/L	1
PVEI-O42	7/25/2023	Lead	ND	µg/L	1
PVEI-S43	7/25/2023	Lead	2.0	µg/L	1

PVEI-O44	7/25/2023	Lead	ND	µg/L	1
PVEI-S45	7/25/2023	Lead	1.3	µg/L	1
PVEI-O46	7/25/2023	Lead	ND	µg/L	1
PVEI-S47	7/25/2023	Lead	2.6	µg/L	1
PVEI-O48	7/25/2023	Lead	ND	µg/L	1
PVEI-S49	7/25/2023	Lead	2.0	µg/L	1
PVEI-O50	7/25/2023	Lead	ND	µg/L	1
PVEI-DF51	7/25/2023	Lead	ND	µg/L	1
PVEI-DF52	7/25/2023	Lead	ND	µg/L	1
PVEI-DF53	7/25/2023	Lead	ND	µg/L	1
PVEI-DF54	7/25/2023	Lead	ND	µg/L	1
PVEI-S55	7/25/2023	Lead	ND	µg/L	1
PVEI-O56	7/25/2023	Lead	ND	µg/L	1
PVEI-S57	7/25/2023	Lead	ND	µg/L	1
PVEI-O58	7/25/2023	Lead	ND	µg/L	1
PVEI-S59	7/25/2023	Lead	4.6	µg/L	1
PVEI-O60	7/25/2023	Lead	4.4	µg/L	1
PVEI-S61	7/25/2023	Lead	1.8	µg/L	1
PVEI-O62	7/25/2023	Lead	4.9	µg/L	1
PVEI-S63	7/25/2023	Lead	2.0	µg/L	1
PVEI-O64	7/25/2023	Lead	6.4	µg/L	1
PVEI-S65	7/25/2023	Lead	1.6	µg/L	1
PVEI-O66	7/25/2023	Lead	ND	µg/L	1
PVEI-S67	7/25/2023	Lead	3.0	µg/L	1
PVEI-O68	7/25/2023	Lead	ND	µg/L	1
PVEI-S69	7/25/2023	Lead	469	µg/L	20
PVEI-O70	7/25/2023	Lead	1.4	µg/L	1
PVEI-S71	7/25/2023	Lead	4.1	µg/L	1
PVEI-O72	7/25/2023	Lead	2.2	µg/L	1
PVEI-S73	7/25/2023	Lead	3.2	µg/L	1
PVEI-O74	7/25/2023	Lead	ND	µg/L	1
PVEI-S75	7/25/2023	Lead	8.8	µg/L	1
PVEI-O76	7/25/2023	Lead	1.3	µg/L	1
PVEI-S77	7/25/2023	Lead	1.6	µg/L	1
PVEI-O78	7/25/2023	Lead	ND	µg/L	1
PVEI-DF79	7/25/2023	Lead	ND	µg/L	1
PVEI-DF80	7/25/2023	Lead	ND	µg/L	1
PVEI-DF81	7/25/2023	Lead	ND	µg/L	1
PVEI-DF82	7/25/2023	Lead	ND	µg/L	1
PVEI-S83	7/25/2023	Lead	1.0	µg/L	1
PVEI-S84	7/25/2023	Lead	5.6	µg/L	1
PVEI-S85	7/25/2023	Lead	7.2	µg/L	1
PVEI-S86	7/25/2023	Lead	5.2	µg/L	1
PVEI-S87	7/25/2023	Lead	4.7	µg/L	1
PVEI-S88	7/25/2023	Lead	3.9	µg/L	1
PVEI-S89	7/25/2023	Lead	6.1	µg/L	1
PVEI-S90	7/25/2023	Lead	ND	µg/L	1
PVEI-S91	7/25/2023	Lead	4.8	µg/L	1



PVEI-DF92	7/25/2023	Lead	<b>40.5</b>	µg/L	1
PVEI-DF93	7/25/2023	Lead	<b>3.3</b>	µg/L	1
PVEI-DF94	7/25/2023	Lead	ND	µg/L	1
PVEI-DF95	7/25/2023	Lead	ND	µg/L	1
PVEI-S96	7/25/2023	Lead	ND	µg/L	1
PVEI-S97	7/25/2023	Lead	ND	µg/L	1
PVEI-S98	7/25/2023	Lead	ND	µg/L	1
PVEI-S99	7/25/2023	Lead	<b>4.3</b>	µg/L	1
PVEI-S100	7/25/2023	Lead	<b>9.1</b>	µg/L	1
PVEI-S101	7/25/2023	Lead	<b>6.9</b>	µg/L	1
PVEI-DF102	7/25/2023	Lead	<b>1.4</b>	µg/L	1
PVEI-DF103	7/25/2023	Lead	ND	µg/L	1
PVEI-S104	7/25/2023	Lead	<b>1.4</b>	µg/L	1
PVEI-DF105	7/25/2023	Lead	ND	µg/L	1
PVEI-DF106	7/25/2023	Lead	ND	µg/L	1
PVEI-S107	7/25/2023	Lead	<b>4.5</b>	µg/L	1
PVEI-S108	7/25/2023	Lead	ND	µg/L	1
PVEI-S109	7/25/2023	Lead	<b>7.0</b>	µg/L	1
PVEI-S110	7/25/2023	Lead	<b>5.3</b>	µg/L	1
PVEI-S111	7/25/2023	Lead	<b>3.3</b>	µg/L	1
PVEI-S112	7/25/2023	Lead	<b>4.8</b>	µg/L	1
PVEI-S113	7/25/2023	Lead	<b>5.0</b>	µg/L	1
PVEI-S114	7/25/2023	Lead	<b>5.0</b>	µg/L	1
PVEI-S115	7/25/2023	Lead	<b>5.7</b>	µg/L	1
PVEI-S116	7/25/2023	Lead	<b>5.4</b>	µg/L	1
PVEI-S117	7/25/2023	Lead	<b>2.2</b>	µg/L	1
PVEI-0118	7/25/2023	Lead	<b>1.8</b>	µg/L	1
PVEI-DF119	7/25/2023	Lead	ND	µg/L	1
PVEI-DF120	7/25/2023	Lead	ND	µg/L	1
PVEI-DF121	7/25/2023	Lead	ND	µg/L	1
PVEI-DF122	7/25/2023	Lead	ND	µg/L	1
PVEI-S123	7/25/2023	Lead	<b>4.1</b>	µg/L	1
PVEI-DF124	7/25/2023	Lead	ND	µg/L	1

µg/L: micrograms per liter

Bolded results indicate detection above reporting limits

## **ATTACHMENT D**

---

### **Prairie View Elementary Laboratory Analytical Report**



September 12, 2023

Lindsay E. James  
Blackstone Environmental, Inc.  
16200 Foster Street  
Overland Park, KS 66085  
TEL: (913) 956-4160  
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

**RE:** Lees Summit School Dist DW Prairie View  
Elementary

**WorkOrder:** 23071901

Dear Lindsay E. James:

TEKLAB, INC received 124 samples on 7/27/2023 10:10:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley  
Project Manager  
(618)344-1004 ex 44  
[patrickriley@teklabinc.com](mailto:patrickriley@teklabinc.com)



## Report Contents

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**This reporting package includes the following:**

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	131
Chain of Custody	Appended



**Client:** Blackstone Environmental, Inc.**Work Order:** 23071901**Client Project:** Lees Summit School Dist DW Prairie View Elementary**Report Date:** 12-Sep-23**Abbr Definition**

\* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count ( > 200 CFU )

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

### Qualifiers

- |   |  |
|---|--|
| # - Unknown hydrocarbon                               | B - Analyte detected in associated Method Blank              |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range                           |
| H - Holding times exceeded                            | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits        | M - Manual Integration used to determine area response       |
| ND - Not Detected at the Reporting Limit              | R - RPD outside accepted recovery limits                     |
| S - Spike Recovery outside recovery limits            | T - TIC(Tentatively identified compound)                     |
| X - Value exceeds Maximum Contaminant Level           |  |



## Case Narrative

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Cooler Receipt Temp:** NA °C

### Locations

#### Collinsville

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** jhriley@teklabinc.com

#### Collinsville Air

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** EHurley@teklabinc.com

#### Springfield

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415  
**Phone** (217) 698-1004  
**Fax** (217) 698-1005  
**Email** KKlostermann@teklabinc.com

#### Chicago

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515  
**Phone** (630) 324-6855  
**Fax**  
**Email** arenner@teklabinc.com

#### Kansas City

**Address** 8421 Nieman Road  
Lenexa, KS 66214  
**Phone** (913) 541-1998  
**Fax** (913) 541-1998  
**Email** jhriley@teklabinc.com



**Client:** Blackstone Environmental, Inc.**Work Order:** 23071901**Client Project:** Lees Summit School Dist DW Prairie View Elementary**Report Date:** 12-Sep-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2023	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-001

**Client Sample ID:** PVEI-S1

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 11:16	210498



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-002

**Client Sample ID:** PVEI-02

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 11:20	210498





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-003

**Client Sample ID:** PVEI-S3

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.8	µg/L	1	09/02/2023 11:23	210498



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-004

**Client Sample ID:** PVEI-DF4

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 11:27	210498



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-005

**Client Sample ID:** PVEI-DF5

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 11:31	210498





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-006

**Client Sample ID:** PVEI-S6

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:21

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		7.2	µg/L	5	09/11/2023 12:04	210907



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-007

**Client Sample ID:** PVEI-07

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 11:45	210498



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-008

**Client Sample ID:** PVEI-S8

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:23

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 11:49	210498





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-009

**Client Sample ID:** PVEI-S9

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.4	µg/L	1	09/02/2023 11:53	210498



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-010

**Client Sample ID:** PVEI-S10

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.6	µg/L	1	09/02/2023 11:56	210498



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-011

**Client Sample ID:** PVEI-S11

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 12:00	210498



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-012

**Client Sample ID:** PVEI-S12

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 12:04	210498





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-013

**Client Sample ID:** PVEI-S13

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 12:15	210498



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-014

**Client Sample ID:** PVEI-O14

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		7.7	µg/L	5	09/11/2023 12:08	210907



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-015

**Client Sample ID:** PVEI-O15

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.1	µg/L	1	09/02/2023 12:18	210498



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-016

**Client Sample ID:** PVEI-S16

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.1	µg/L	1	09/02/2023 12:33	210498



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-017

**Client Sample ID:** PVEI-S17

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.6	µg/L	1	09/02/2023 12:37	210498





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-018

**Client Sample ID:** PVEI-S18

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.4	µg/L	1	09/02/2023 12:40	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-019

**Client Sample ID:** PVEI-S19

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		<b>4.9</b>	µg/L	1	09/02/2023 12:44	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-020

**Client Sample ID:** PVEI-S20

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.9	µg/L	1	09/02/2023 12:48	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-021

**Client Sample ID:** PVEI-S21

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		7.3	µg/L	1	09/02/2023 12:51	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-022

**Client Sample ID:** PVEI-S22

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.9	µg/L	1	09/02/2023 12:55	210569





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-023

**Client Sample ID:** PVEI-S23

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		7.3	µg/L	1	09/02/2023 12:59	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-024

**Client Sample ID:** PVEI-S24

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:33

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.5	µg/L	1	09/02/2023 13:02	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-025

**Client Sample ID:** PVEI-025

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 13:24	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-026

**Client Sample ID:** PVEI-S26

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.3	µg/L	1	09/02/2023 13:28	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-027

**Client Sample ID:** PVEI-027

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 13:32	210569





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-028

**Client Sample ID:** PVEI-S28

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:36

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		61.4	µg/L	1	09/02/2023 13:35	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-029

**Client Sample ID:** PVEI-S29

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 13:39	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-030

**Client Sample ID:** PVEI-O30

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 13:43	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-031

**Client Sample ID:** PVEI-S31

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.1	µg/L	1	09/02/2023 13:46	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-032

**Client Sample ID:** PVEI-032

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 13:50	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-033

**Client Sample ID:** PVEI-S33

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		43.0	µg/L	1	09/05/2023 9:31	210569





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-034

**Client Sample ID:** PVEI-034

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.4	µg/L	1	09/02/2023 14:16	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-035

**Client Sample ID:** PVEI-S35

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:41

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.4	µg/L	1	09/02/2023 14:19	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-036

**Client Sample ID:** PVEI-036

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 14:23	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-037

**Client Sample ID:** PVEI-S37

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.4	µg/L	1	09/02/2023 14:27	210569



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-038

**Client Sample ID:** PVEI-038

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 14:30	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-039

**Client Sample ID:** PVEI-S39

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.1	µg/L	1	09/02/2023 14:34	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-040

**Client Sample ID:** PVEI-O40

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 14:38	210570





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-041

**Client Sample ID:** PVEI-S41

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.4	µg/L	1	09/02/2023 15:00	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-042

**Client Sample ID:** PVEI-O42

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 15:03	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-043

**Client Sample ID:** PVEI-S43

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.0	µg/L	1	09/02/2023 15:07	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-044

**Client Sample ID:** PVEI-O44

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 15:10	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-045

**Client Sample ID:** PVEI-S45

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.3	µg/L	1	09/02/2023 15:14	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-046

**Client Sample ID:** PVEI-O46

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 15:18	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-047

**Client Sample ID:** PVEI-S47

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:51

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.6	µg/L	1	09/02/2023 15:21	210570





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-048

**Client Sample ID:** PVEI-O48

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:51

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 15:25	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-049

**Client Sample ID:** PVEI-S49

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		<b>2.0</b>	µg/L	1	09/02/2023 15:29	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-050

**Client Sample ID:** PVEI-O50

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 15:43	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-051

**Client Sample ID:** PVEI-DF51

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 15:47	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-052

**Client Sample ID:** PVEI-DF52

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 15:51	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-053

**Client Sample ID:** PVEI-DF53

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 16:02	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-054

**Client Sample ID:** PVEI-DF54

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 16:05	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-055

**Client Sample ID:** PVEI-S55

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 16:09	210570





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-056

**Client Sample ID:** PVEI-056

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 16:13	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-057

**Client Sample ID:** PVEI-S57

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 16:16	210570



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-058

**Client Sample ID:** PVEI-058

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 8:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 16:31	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-059

**Client Sample ID:** PVEI-S59

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.6	µg/L	1	09/02/2023 16:35	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-060

**Client Sample ID:** PVEI-O60

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.4	µg/L	1	09/02/2023 16:38	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-061

**Client Sample ID:** PVEI-S61

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:01

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.8	µg/L	1	09/02/2023 16:42	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-062

**Client Sample ID:** PVEI-O62

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:02

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		<b>4.9</b>	µg/L	1	09/02/2023 16:46	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-063

**Client Sample ID:** PVEI-S63

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.0	µg/L	1	09/02/2023 16:57	210571





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-064

**Client Sample ID:** PVEI-064

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:03

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		6.4	µg/L	1	09/02/2023 17:00	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-065

**Client Sample ID:** PVEI-S65

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.6	µg/L	1	09/02/2023 17:04	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-066

**Client Sample ID:** PVEI-O66

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:06

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 17:19	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-067

**Client Sample ID:** PVEI-S67

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:07

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.0	µg/L	1	09/02/2023 17:22	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-068

**Client Sample ID:** PVEI-O68

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:07

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 17:26	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-069

**Client Sample ID:** PVEI-S69

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	20.0		<b>469</b>	µg/L	20	09/05/2023 9:42	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-070

**Client Sample ID:** PVEI-070

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.4	µg/L	1	09/02/2023 17:40	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-071

**Client Sample ID:** PVEI-S71

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.1	µg/L	1	09/02/2023 17:44	210571





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-072

**Client Sample ID:** PVEI-072

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.2	µg/L	1	09/02/2023 17:48	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-073

**Client Sample ID:** PVEI-S73

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.2	µg/L	1	09/02/2023 17:51	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-074

**Client Sample ID:** PVEI-074

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 18:06	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-075

**Client Sample ID:** PVEI-S75

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:13

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		<b>8.8</b>	µg/L	1	09/02/2023 18:10	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-076

**Client Sample ID:** PVEI-076

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:14

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.3	µg/L	1	09/02/2023 18:13	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-077

**Client Sample ID:** PVEI-S77

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:14

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.6	µg/L	1	09/02/2023 18:17	210571



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-078

**Client Sample ID:** PVEI-078

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 18:21	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-079

**Client Sample ID:** PVEI-DF79

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 18:24	210620





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-080

**Client Sample ID:** PVEI-DF80

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 18:28	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-081

**Client Sample ID:** PVEI-DF81

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 18:39	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-082

**Client Sample ID:** PVEI-DF82

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 18:54	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-083

**Client Sample ID:** PVEI-S83

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.0	µg/L	1	09/02/2023 18:57	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-084

**Client Sample ID:** PVEI-S84

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:23

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.6	µg/L	1	09/02/2023 19:01	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-085

**Client Sample ID:** PVEI-S85

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		7.2	µg/L	1	09/02/2023 19:05	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-086

**Client Sample ID:** PVEI-S86

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.2	µg/L	1	09/02/2023 19:08	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-087

**Client Sample ID:** PVEI-S87

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.7	µg/L	1	09/02/2023 19:12	210620





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-088

**Client Sample ID:** PVEI-S88

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.9	µg/L	1	09/02/2023 19:16	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-089

**Client Sample ID:** PVEI-S89

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		6.1	µg/L	1	09/05/2023 9:53	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-090

**Client Sample ID:** PVEI-S90

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/05/2023 13:19	210691



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-091

**Client Sample ID:** PVEI-S91

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		<b>4.8</b>	µg/L	5	09/05/2023 13:22	210691



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-092

**Client Sample ID:** PVEI-DF92

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		40.5	µg/L	1	09/02/2023 19:23	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-093

**Client Sample ID:** PVEI-DF93

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.3	µg/L	1	09/02/2023 19:27	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-094

**Client Sample ID:** PVEI-DF94

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 19:41	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-095

**Client Sample ID:** PVEI-DF95

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 19:52	210620





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-096

**Client Sample ID:** PVEI-S96

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 19:56	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-097

**Client Sample ID:** PVEI-S97

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 20:00	210620



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-098

**Client Sample ID:** PVEI-S98

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 20:03	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-099

**Client Sample ID:** PVEI-S99

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:37

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.3	µg/L	1	09/02/2023 20:07	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-100

**Client Sample ID:** PVEI-S100

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		9.1	µg/L	1	09/02/2023 20:11	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-101

**Client Sample ID:** PVEI-S101

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		6.9	µg/L	1	09/02/2023 20:14	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-102

**Client Sample ID:** PVEI-DF102

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:39

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.4	µg/L	1	09/02/2023 20:29	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-103

**Client Sample ID:** PVEI-DF103

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 20:40	210629





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-104

**Client Sample ID:** PVEI-S104

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.4	µg/L	1	09/02/2023 20:44	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-105

**Client Sample ID:** PVEI-DF105

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 20:47	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-106

**Client Sample ID:** PVEI-DF106

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 20:51	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-107

**Client Sample ID:** PVEI-S107

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.5	µg/L	1	09/02/2023 20:55	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-108

**Client Sample ID:** PVEI-S108

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 20:58	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-109

**Client Sample ID:** PVEI-S109

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		7.0	µg/L	1	09/02/2023 21:02	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-110

**Client Sample ID:** PVEI-S110

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.3	µg/L	1	09/02/2023 21:17	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-111

**Client Sample ID:** PVEI-S111

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.3	µg/L	1	09/02/2023 21:20	210629





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-112

**Client Sample ID:** PVEI-S112

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		<b>4.8</b>	µg/L	1	09/02/2023 21:24	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-113

**Client Sample ID:** PVEI-S113

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.0	µg/L	1	09/02/2023 21:35	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-114

**Client Sample ID:** PVEI-S114

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.0	µg/L	1	09/02/2023 21:39	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-115

**Client Sample ID:** PVEI-S115

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.7	µg/L	1	09/02/2023 21:42	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-116

**Client Sample ID:** PVEI-S116

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.4	µg/L	1	09/02/2023 21:46	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-117

**Client Sample ID:** PVEI-S117

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 9:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.2	µg/L	1	09/02/2023 21:50	210629



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-118

**Client Sample ID:** PVEI-0118

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 10:06

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.8	µg/L	5	09/05/2023 13:37	210691



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-119

**Client Sample ID:** PVEI-DF119

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 10:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 22:08	210631





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-120

**Client Sample ID:** PVEI-DF120

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 10:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 22:11	210631



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-121

**Client Sample ID:** PVEI-DF121

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 10:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 22:15	210631



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-122

**Client Sample ID:** PVEI-DF122

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 10:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 22:26	210631



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-123

**Client Sample ID:** PVEI-S123

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 10:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.1	µg/L	1	09/02/2023 22:30	210631



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071901

**Client Project:** Lees Summit School Dist DW Prairie View Elementary

**Report Date:** 12-Sep-23

**Lab ID:** 23071901-124

**Client Sample ID:** PVEI-DF124

**Matrix:** DRINKING WATER

**Collection Date:** 07/25/2023 10:13

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/02/2023 22:33	210631



## Receiving Check List

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071901

Client Project: Lees Summit School Dist DW Prairie View Elementary

Report Date: 12-Sep-23

Carrier: Crossroads

Received By: CET

Completed by:

On:

31-Jul-23

Allison Colin

Reviewed by:

On:

31-Jul-23

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

Shipping container/cooler in good condition?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	Not Present <input type="checkbox"/>	Temp °C <b>NA</b>
Type of thermal preservation?	None <input checked="" type="checkbox"/>	Ice <input type="checkbox"/>	Blue Ice <input type="checkbox"/>	Dry Ice <input type="checkbox"/>
Chain of custody present?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody signed when relinquished and received?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody agrees with sample labels?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Samples in proper container/bottle?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Sample containers intact?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Sufficient sample volume for indicated test?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
All samples received within holding time?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Reported field parameters measured:	Field <input type="checkbox"/>	Lab <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	
Container/Temp Blank temperature in compliance?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		

*When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.*

Water – at least one vial per sample has zero headspace?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	No VOA vials <input checked="" type="checkbox"/>
Water - TOX containers have zero headspace?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	No TOX containers <input checked="" type="checkbox"/>
Water - pH acceptable upon receipt?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>
NPDES/CWA TCN interferences checked/treated in the field?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>

**Any No responses must be detailed below or on the COC.**

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

## 230/140

**Fax: (618) 344-1005**

<b>Client:</b>	Blackstone Environmental, Inc.		
<b>Address:</b>	16200 Foster Street		
<b>City / State / Zip</b>	Overland Park, KS 66085	<b>Phone:</b>	(913) 495-9980
<b>Contact:</b>	Lindsay E. James	<b>Fax:</b>	
<b>E-Mail:</b>	ljames@blackstone-env.com		

  

Are these samples known to be involved in litigation? If yes, a surcharge will apply	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Are these samples known to be hazardous?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section.		
	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name LM		INDICATE ANALYSIS REQUESTED													
Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers								MATRIX					
Lab Use Only	Sample Identification	Date/Time Sampled		OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead
001	PVE1-S1	7/25 @ 8:19															
002	-02	8:18															
003	-S3	8:19															
004	-DF4	8:20															
005	-DFS	8:20															
006	-S6	8:21															
007	-07	8:22															
008	-S8	8:23															
009	-S9	8:24															
010	-S10	8:24															
Relinquished By Kalen Turner V. [Signature]				Date/Time 7/25/23 @ 1615 7/26/23 1600				Received By V. [Signature] [Signature]				Date/Time 7/26/23 1130 7-27-23 1010					



# CHAIN OF CUSTODY

pg. 2 of 13 Work order # 23071901

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

<b>Client:</b> Blackstone Environmental, Inc. <b>Address:</b> 16200 Foster Street Overland Park, KS 66085 <b>City / State / Zip</b> <b>Contact:</b> Lindsey E. James (913) 495-9990 <b>E-Mail:</b> ljames@blackstone-env.com		<b>Samples on:</b> <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG# <b>Preserved in:</b> <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <b>FOR LAB USE ONLY</b> <b>Lab Notes</b>		<b>Client Comments:</b> Preview View Elementary	
<b>Project Name/Number</b> Lee's Summit School Dist. DW		<b>Sample Collector's Name</b> KM		<b>INDICATE ANALYSIS REQUESTED</b>	
<b>Results Requested</b> <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		<b>Billing Instructions</b>		MATRIX Drinking Water Aqueous Soil Sludge Special Waste Groundwater DW Lead	
<b>Relinquished By</b> Kelley [Signature]		<b>Date/Time</b> 7/25/13 @ 10:15		<b>Received By</b> [Signature]	
<b>Date/Time</b> 7/26/13		<b>Date/Time</b> 7/26/13		<b>Date/Time</b> 7/27/13	

Lab Use Only	Sample Identification	Date/Time Sampled	# and Type of Containers
23071901	PV61-S11	7/25 @ 8:25	OTHER
012	-S12	8:25	NaHSO4
013	-S13	8:26	MeOH
014	-014	8:26	HCL
015	-015	8:26	H2SO4
016	-S16	8:29	NaOH
017	-S17	8:29	HNO3
018	-S18	8:29	UNPRES
019	-S19	8:30	
020	-S20	8:30	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

Bottle Order: 82000





pg. 3 of 13 Work order # 23071901

**TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005**

<b>Client:</b> Blackstone Environmental, Inc. <b>Address:</b> 16200 Foster Street <b>City / State / Zip:</b> Overland Park, KS 66085 <b>Contact:</b> Lindsay E. James <b>E-Mail:</b> ljames@blackstone-env.com <b>Phone:</b> (913) 495-9990 <b>Fax:</b>		<b>Samples on:</b> <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> °F <b>Preserved in:</b> <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <b>Lab Notes</b>		<b>FOR LAB USE ONLY</b>	
<b>Client Comments:</b> Prairie View Elementary					

  

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED	
Lee's Summit School Dist. DW		KM			
Lab Use Only	Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)	Sample Identification	Billing Instructions	# and Type of Containers	MATRIX
					Drinking Water Aqueous Soil Sludge Special Waste Groundwater DW Lead
021		PV61-S21	7/25/23 9:30	1	
022		-S22	8:31	1	
023		-S23	8:32	1	
024		-S24	8:33	1	
025		-D25	8:34	1	
026		-S26	8:35	1	
027		-D27	8:35	1	
028		-S28	8:36	1	
029		-S29	8:38	1	
030		-D30	8:38	1	

  

Relinquished By		Date/Time		Received By		Date/Time	
Kelsey James		7/25/23 @ 1615		K. James		7/26/23 1130	
L. E. James		7/26/23 1600		C. James		7/27/23 1010	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

Bottle Order: 82000



# CHAIN OF CUSTODY

pg. 4 of 13 Work order # 23071901

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

**Client:** Blackstone Environmental, Inc.  
**Address:** 16200 Foster Street  
**City / State / Zip:** Overland Park, KS 66085  
**Contact:** Lindsey E. James (913) 495-9990  
**E-Mail:** ljames@blackstone-env.com  
**Phone:**  
**Fax:**

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No  
 Are these samples known to be hazardous? ☐ Yes ☒ No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

**Samples on:** ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#  
**Preserved in:** ☐ LAB ☐ FIELD **FOR LAB USE ONLY**  
**Lab Notes**

**Client Comments:**

Prairie View  
 Elementary

Project Name/Number			Sample Collector's Name			INDICATE ANALYSIS REQUESTED																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					
Lee's Summit School Dist. DW			KM																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
Lab Use Only	Results Requested		Sample Identification	Billing Instructions	Date/Time Sampled	# and Type of Containers																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					
	Standard <input checked="" type="checkbox"/>	Other <input type="checkbox"/>				OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
23071901			P161-S31		7/25 @ 8:38																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																						

Relinquished By		Date/Time		Received By		Date/Time	
Kathy Lemo		7/25/23 @ 1615		[Signature]		7/26/23 1130	
[Signature]		7/26/23 1600		[Signature]		7-27-23 1010	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

Bottle Order: 82000



# CHAIN OF CUSTODY

pg. 5 of 13 Work order # 23071901

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

<b>Client:</b> Blackstone Environmental, Inc.	<b>City / State / Zip</b> Overland Park, KS 66085	<b>Phone:</b> (913) 495-9990
<b>Address:</b> 16200 Foster Street	<b>Contact:</b> Lindsay E. James	<b>Fax:</b>
<b>E-Mail:</b> ljames@blackstone-env.com		

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No  
 Are these samples known to be hazardous? ☐ Yes ☒ No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

<b>Project Name/Number</b> Lee's Summit School Dist. DW	<b>Sample Collector's Name</b> KM
--	--------------------------------------

Lab Use Only	Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)	Sample Identification	Billing Instructions	Date/Time Sampled	INDICATE ANALYSIS REQUESTED									
					Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead				
23071901	041	PV61-541		7/25 @ 8:40										
	042	-042		8:47										
	043	-043		8:47										
	044	-044		8:48										
	045	-045		8:50										
	046	-046		8:50										
	047	-047		8:51										
	048	-048		8:51										
	049	-049		8:52										
	050	-050		8:53										

<b>Relinquished By</b> Katelyn James	<b>Date/Time</b> 7/25/23 @ 16:15	<b>Received By</b> Katelyn James	<b>Date/Time</b> 7/26/23 11:30
<b>Signature</b> Katelyn James	<b>Signature</b> Katelyn James	<b>Signature</b> Katelyn James	<b>Signature</b> Katelyn James

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



# CHAIN OF CUSTODY

pg. 6 of 13 Work order # 23071901

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

<b>Client:</b> Blackstone Environmental, Inc. <b>Address:</b> 16200 Foster Street Overland Park, KS 66085 <b>City / State / Zip</b> <b>Contact:</b> Lindsay E. James (913) 495-9990 lames@blackstone-env.com <b>E-Mail:</b>		<b>Phone:</b> <b>Fax:</b>	
Are these samples known to be involved in litigation? If yes, a surcharge will apply <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		<b>Samples on:</b> <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG# <b>Preserved in:</b> <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <b>FOR LAB USE ONLY</b> <b>Lab Notes</b> <b>Client Comments:</b> Prairie View Elementary	

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED													
Lee's Summit School Dist. DW		KM		MATRIX													
				Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead								
<input checked="" type="checkbox"/> Standard	<input type="checkbox"/> 1-2 Day (100% Surcharge)	<input type="checkbox"/> Other	<input type="checkbox"/> 3 Day (50% Surcharge)	Billing Instructions		# and Type of Containers											
						OTHER											
						NaHSO4											
						MeOH											
						HCL											
						H2SO4											
						NaOH											
						HNO3											
						UNPRES											
Lab Use Only	Sample Identification	Date/Time Sampled															
051	PVCL-DFS1	7/25/23 8:54															
052	-DFS2	8:54															
053	-DFS3	8:55															
054	-DFS4	8:55															
055	-855	8:57															
056	-056	8:58															
057	-S57	8:58															
058	-058	8:58															
059	-S59	9:00															
060	-060	9:00															
Relinquished By			Date/Time			Received By			Date/Time								
Kagay James			7/25/23 @ 1615			L. James			7/26/23 1130								
L. James			7/26/23 1600			L. James			7/27/23 1010								

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



## CHAIN OF CUSTODY

**TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005**

<b>Client:</b>	Blackstone Environmental, Inc.	<b>Samples on:</b>	<input type="checkbox"/> ICE	<input type="checkbox"/> BLUE ICE	<input type="checkbox"/> NO ICE	°C	LTG#
<b>Address:</b>	16200 Foster Street	<b>Preserved in:</b>	<input type="checkbox"/> LAB	<input type="checkbox"/> FIELD	<b>FOR LAB USE ONLY</b>		
<b>City / State / Zip</b>	Overland Park, KS 66085	<b>Lab Notes</b>					
<b>Contact:</b>	Lindsay E. James						
<b>E-Mail:</b>	ljames@blackstone-env.com						
		<b>Client Comments:</b>					

Prairie View  
Elementary

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name <i>KM</i>		INDICATE ANALYSIS REQUESTED																	
		MATRIX								Date/Time											
		DW Lead																			
		Groundwater																			
		Special Waste																			
		Sludge																			
		Soil																			
		Drinking Water																			
		Aqueous																			
<b>Results Requested</b> <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other _____ <input type="checkbox"/> 3 Day (50% Surcharge)		<b>Billing Instructions</b>		# and Type of Containers																	
				OTHER																	
				NaHSO <sub>4</sub>																	
				MeOH																	
				HCL																	
				H <sub>2</sub> SO <sub>4</sub>																	
				NaOH																	
				HNO <sub>3</sub>																	
				UNPRES																	
<b>Lab Use Only</b>		<b>Sample Identification</b>		<b>Date/Time Sampled</b>																	
061		RVEI-SU1		7/25C 9:01																	
062		-DUE2		9:02																	
063		-SUE3		9:03																	
064		-DUE4		9:03																	
065		-SUE5		9:05																	
066		-DUE6		9:06																	
067		-SUE7		9:07																	
068		-DUE8		9:07																	
069		-SUE9		9:08																	
070		-DUE0		9:08																	
<b>Relinquished By</b>				<b>Date/Time</b>				<b>Received By</b>				<b>Date/Time</b>									
<i>Kalvin Lino</i>				7/25/23 0615				<i>[Signature]</i>				7/26/23 1130									
<i>L. O'Neil</i>				7/26/23 1600				<i>[Signature]</i>				7/27/23 1010									

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

BottleOrder: 82000



# CHAIN OF CUSTODY

pg. 8 of 13 Work order # 23071901

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

<b>Client:</b> Blackstone Environmental, Inc. <b>Address:</b> 16200 Foster Street <b>City / State / Zip:</b> Overland Park, KS 66085 <b>Contact:</b> Lindsay E. James (913) 495-9990 <b>E-Mail:</b> ljames@blackstone-env.com		<b>Preserved in:</b> <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> FIELD <input type="checkbox"/> LAB <input type="checkbox"/> FOR LAB USE ONLY <b>Lab Notes:</b>		<b>Samples on:</b> <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG# <b>Client Comments:</b> Prairie View ELM (PVE)	
Are these samples known to be involved in litigation? If yes, a surcharge will apply <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		<b>Project Name/Number:</b> Lee's Summit School Dist. DW <b>Sample Collector's Name:</b> KSM			
<b>Results Requested</b> <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		<b>Billing Instructions</b> Date/Time Sampled: 7/25/23 @ 9:09			
<b>Lab Use Only</b> Sample Identification: PVE1-S71		# and Type of Containers: OTHER, NaHSO4, MeOH, HCL, H2SO4, NaOH, HNO3, UNPRES			
Lab Use Only: 071 PVE1-S71		Date/Time Sampled: 7/25/23 @ 9:09			
Lab Use Only: 072 PVE1-S72		Date/Time Sampled: @ 9:11			
Lab Use Only: 073 PVE1-S73		Date/Time Sampled: @ 9:12			
Lab Use Only: 074 PVE1-S74		Date/Time Sampled: @ 9:13			
Lab Use Only: 075 PVE1-S75		Date/Time Sampled: @ 9:14			
Lab Use Only: 076 PVE1-S76		Date/Time Sampled: @ 9:14			
Lab Use Only: 077 PVE1-S77		Date/Time Sampled: @ 9:15			
Lab Use Only: 078 PVE1-S78		Date/Time Sampled: @ 9:17			
Lab Use Only: 079 PVE1-S79		Date/Time Sampled: @ 9:17			
Lab Use Only: 080 PVE1-S80		Date/Time Sampled: @ 9:17			
<b>Relinquished By:</b> T. B. James		<b>Date/Time:</b> 7/25/23 @ 1:05		<b>Received By:</b> K. Smith	
<b>Date/Time:</b> 7/26/23 1:00		<b>Date/Time:</b> 7/26/23 1:00		<b>Date/Time:</b> 7/26/23 1:00	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 9 of 13 Work order # 2307/901

**TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005**

<b>Client:</b>	Blackstone Environmental, Inc.	<b>Samples on:</b>	<input type="checkbox"/> ICE	<input type="checkbox"/> BLUE ICE	<input type="checkbox"/> NO ICE	°C	LTG#
<b>Address:</b>	16200 Foster Street	<b>Preserved in:</b>	<input type="checkbox"/> LAB	<input type="checkbox"/> FIELD	<b>FOR LAB USE ONLY</b>		
<b>City / State / Zip</b>	Overland Park, KS 66085	<b>Lab Notes</b>					
<b>Contact:</b>	Lindsay E. James	<b>Client Comments:</b>					
<b>E-Mail:</b>	ljames@blackstone-env.com						
<b>Phone:</b>	(913) 495-9990						
<b>Fax:</b>							

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name <i>KSM</i>		INDICATE ANALYSIS REQUESTED																	
				MATRIX																	
				Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead												
<b>Results Requested</b> Standard <input checked="" type="checkbox"/> 1-2 Day (100% Surcharge) Other <input type="checkbox"/> 3 Day (50% Surcharge)		<b>Billing Instructions</b>		# and Type of Containers																	
				OTHER																	
				NaHSO <sub>4</sub>																	
				MeOH																	
				HCL																	
				H <sub>2</sub> SO <sub>4</sub>																	
				NaOH																	
				HNO <sub>3</sub>																	
				UNPRES																	
Lab Use Only	Sample Identification	Date/Time Sampled																			
081	PVEI - DF81	7/25/23 @ 918																			
082	- DF82	@ 918																			
083	- S83	@ 922																			
084	- S84	@ 923																			
085	- S85	@ 924																			
086	- S86	@ 924																			
087	- S87	@ 927																			
088	- S88	@ 974																			
089	- S89	@ 929																			
090	- S90	@ 930																			
Relinquished By				Date/Time				Received By				Date/Time									
<i>[Signature]</i>				7/25/23 @ 1615				<i>[Signature]</i>				7/26/23 1130									
<i>[Signature]</i>				7/26/23 1600				<i>[Signature]</i>				7/27/23 1010									

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

Bottle Order: 82000



Work order # 23071901

Work order # 23071901

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.tektlabinc.com](http://www.tektlabinc.com) for terms and conditions.

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.tektlabinc.com](http://www.tektlabinc.com) for terms and conditions.



# CHAIN OF CUSTODY

pg. 11 of 13 Work order # 23071901

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

<b>Client:</b> Blackstone Environmental, Inc.	<b>City / State / Zip</b> 16200 Foster Street Overland Park, KS 66085	<b>Phone:</b> (913) 495-9990	<b>LTG#</b> _____
<b>Address:</b> 16200 Foster Street	<b>Contact:</b> Lindsay E. James	<b>Fax:</b> james@blackstone-env.com	<b>Samples on:</b> <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C
<b>City / State / Zip</b> Overland Park, KS 66085	<b>E-Mail:</b> james@blackstone-env.com	<b>Preserved in:</b> <input type="checkbox"/> LAB <input type="checkbox"/> FIELD	<b>FOR LAB USE ONLY</b>
<b>Lab Notes</b>	<b>Client Comments:</b> PVE		

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No  
 Are these samples known to be hazardous? ☐ Yes ☒ No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name KSM		INDICATE ANALYSIS REQUESTED														
Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers		MATRIX												
Lab Use Only	Sample Identification	Date/Time Sampled		OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead	
101	PVE1-S101	7/25/23 @ 938																
102	-DF102	@ 939																
103	-DF103	@ 940																
104	-S104	@ 942																
105	-DF105	@ 943																
106	-DF106	@ 943																
107	-S107	@ 944																
108	-S108	@ 945																
109	-S109	@ 946																
110	-S110	@ 947																
Relinquished By H. James		Date/Time 7/25/23 @ 1615		Received By K. Smith						Date/Time 7/26/23 1130								
Signature H. James		Signature K. Smith		Signature K. Smith						Signature K. Smith								

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



# CHAIN OF CUSTODY

pg. 12 of 13 Work order # 23071901

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

<b>Client:</b> Blackstone Environmental, Inc. <b>Address:</b> 16200 Foster Street <b>City / State / Zip:</b> Overland Park, KS 66085 <b>Contact:</b> Lindsay E. James <b>E-Mail:</b> ljames@blackstone-env.com <b>Phone:</b> (913) 495-9990 <b>Fax:</b>	<b>Samples on:</b> <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG# <b>Preserved in:</b> <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <b>FOR LAB USE ONLY</b> <b>Lab Notes</b> <b>Client Comments:</b> PVE
---	--

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No  
 Are these samples known to be hazardous? ☐ Yes ☒ No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name KSM	INDICATE ANALYSIS REQUESTED															
Lab Use Only	Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)	Billing Instructions	Date/Time Sampled	MATRIX					DATE/TIME									
				Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead	Received By	Date/Time							
111	PVE1-S111		7/25/23 @ 9:48															
112	-S112		@ 9:49															
113	-S113		@ 9:50															
114	-S114		@ 9:54															
115	-S115		@ 9:52															
116	-S116		@ 9:54															
117	-S117		@ 9:57															
118	-O118		@ 10:06															
119	-DF119		@ 10:04															
120	-DF120		@ 10:01															
Relinquished By				Date/Time					Received By					Date/Time				
Karlina James				7/25/23 @ 10:15					w. [Signature]					7/26/23 11:30				
[Signature]				7/26/23 16:00					[Signature]					7/27/23 10:10				

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 13 of 13 Work order # 230730

**TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005**

<b>Client:</b> Blackstone Environmental, Inc. <b>Address:</b> 16200 Foster Street <b>City / State / Zip:</b> Overland Park, KS 66085 <b>Contact:</b> Lindsay E. James (913) 495-9990 <b>E-Mail:</b> ljames@blackstone-env.com		<b>Project Name/Number:</b> Lee's Summit School Dist. DW <b>Sample Collector's Name:</b> KSM		<b>INDICATE ANALYSIS REQUESTED</b> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>MATRIX</th> <th>Groundwater</th> <th>Special Waste</th> <th>Sludge</th> <th>Soil</th> <th>Drinking Water</th> <th>Aqueous</th> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		MATRIX	Groundwater	Special Waste	Sludge	Soil	Drinking Water	Aqueous							
MATRIX	Groundwater	Special Waste	Sludge	Soil	Drinking Water	Aqueous													
<b>Results Requested</b> <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		<b>Billing Instructions</b> Date/Time Sampled		<b># and Type of Containers</b> OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES															
Lab Use Only	Sample Identification	Date/Time Sampled																	
	121 PVE1-DF121	7/25/23 @ 1005																	
	122 -DF122	@ 1005																	
	123 -S123	@ 1010																	
	124 -DF124	@ 1013																	

  

<b>Client Comments:</b> PVE	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th>Relinquished By</th> <th>Date/Time</th> <th>Received By</th> <th>Date/Time</th> </tr> <tr> <td>Klaus Ginn</td> <td>7/25/23 @ 1015</td> <td>L. Ginn</td> <td>7/25/23 1130</td> </tr> <tr> <td>L. Ginn</td> <td>7/26/23 1600</td> <td><del>L. Ginn</del></td> <td>7/27/23 1010</td> </tr> </table>	Relinquished By	Date/Time	Received By	Date/Time	Klaus Ginn	7/25/23 @ 1015	L. Ginn	7/25/23 1130	L. Ginn	7/26/23 1600	<del>L. Ginn</del>	7/27/23 1010
Relinquished By	Date/Time	Received By	Date/Time										
Klaus Ginn	7/25/23 @ 1015	L. Ginn	7/25/23 1130										
L. Ginn	7/26/23 1600	<del>L. Ginn</del>	7/27/23 1010										

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

Bottle Order: 82000

