

ATTACHMENT B

Summit Lakes Middle School Field Forms

Lee's Summit DW

Team ZS + BS

School Summit Lakes MS

Date Purged 7/18/23

Date Sampled 7/19/23

Sample ID = School abbrev + Floor + Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
1	1	X			LEFT SINK IN 150	1200	828
2	1	X			BY LEFT SINK IN 150	1200	828
3	1	X			BY RIGHT SINK IN 150	1200	828
4	1	X			RIGHT SINK IN 150	1200	828
5	1	X			LEFT SINK IN 117	1202	842
6	1	X			M LEFT SINK IN 117	1202	842
7	1	X			M RIGHT SINK IN 117	1202	842
8	1	X			RIGHT SINK IN 117	1202	842
9	1	X			LEFT SINK IN 110	1204	846
10	1	X			M LEFT SINK IN 110	1204	846
11	1	X			M RIGHT SINK IN 110	1204	846
12	1	X			RIGHT SINK IN 110	1204	846
13	1		X		LEFT DW FOUNTAIN OUTSIDE 110	1205	849
14	1		X		RIGHT DW FOUNTAIN OUTSIDE 110	1205	849
15	1	X			1 - SINK IN 121 - INACCESSIBLE	—	—
16	1	X			2 - SINK IN 121 - INACCESSIBLE	—	—
17	1	X			3 - SINK IN 121	1207	853
18	1	X			4 - SINK IN 121 - INACCESSIBLE	—	853
19	1	X			5 - SINK IN 121 - INACCESSIBLE	—	—
20	1	X			6 - SINK IN 121	1207	853
21	1	X			7 - SINK IN 121	1207	853
22	1	X			SINK IN PANTRY OFF 121	1208	855
23	1			X	DISHWASHER IN PANTRY OFF 121 - LEFT	1208	855
24	1			X	DISHWASHER IN PANTRY OFF 121 - RIGHT	1208	855

Lee's Summit DW

Date Purged 7/18/23
Date Sampled 7/19/23

School Summit Lakes MS

Team RS + BR

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
25	1	X			SINK IN 122 - INACCESSIBLE	—	—
26	1	X			SINK IN 123 - INACCESSIBLE	—	—
27	1	X			SINK IN 124	1210	858
28	1	X			SINK IN 132	1217	908
29	1	X			SINK IN 135	1219	908
30	1	X			SINK IN 140	1220	908
31	1	X			SINK IN FOOD PREP	1228	912
32	1	X			SINK - LEFT IN MIDDLE FOOD PREP	1228	912
33	1	X			SINK - RIGHT IN MIDDLE FOOD PREP	1228	912
34	1	X			SINK - BY MANT	1230	915
35	1	X			SINK - LEFT	1230	916
36	1	X			SINK - MIDDLE	1230	916
37	1	X			SINK - RIGHT	1230	916
38	1	X		X	DISHWASHER	1232	916
39	1	X			SINK IN FACULTY LOUNGE	1238	920
40	1	X		X	ICE MACHINE IN FACULTY LOUNGE	1238	920
41	1	X			LEFT FOUNTAIN IN GYM	1240	924
42	1	X			RIGHT FOUNTAIN IN GYM	1240	924
43	1	X			FOUNTAIN/BF RIGHT COMMONS	1244	926
44	1	X			FOUNTAIN OUTSIDE (L) GYM NEAR 318	1247	927
45	1	X			FOUNTAIN OUTSIDE (R) GYM NEAR 318	1247	927
46	1	X			BOTTLE FILLER NEAR 330	1250	929
47	1	X			DW FOUNTAIN NEAR 330	1250	929
48	1	X			LEFT DW FOUNTAIN IN GIRLS LOCKER ROOM	1254	932

Lee's Summit DW

Team ZS + B3

School Summit Lakes MS

Date Purged 7/18/23

Date Sampled 7/19/23

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
49	1		x		RIGHT DW FOUNTAIN IN 615 LOCKER ROOM	1254	932
50	1		x		LEFT DW FOUNTAIN IN Boys LOCKER ROOM	1258	934
51	1		x		RIGHT DW FOUNTAIN IN Boys LOCKER ROOM	1258	934
52	1	x			SINK IN 402 402	1301	942
53	1	x			SINK IN 403	1301	942
54	1	x			SINK IN 408 NURSE	1306	944
55	1	x			SINK IN 406 NURSE	1306	944
56	1	x			SINK IN 512	1308	1004
57	1	x			SINK IN DRESSING ROOM ⁵¹⁸ 401/614	1313	1005
58	1		x		DW FOUNTAIN (L) NEAR 805	1318	1015
59	1		x		DW FOUNTAIN/806 (R) NEAR 805	1318	1015
60		x			R (E) SINK IN 811	1320	1019
61		x			CLOCKWISE SINK IN 811	1320	1019
62		x			SINK IN 811	1320	1019
63		x			SINK IN 811	1320	1019
64		x			SINK IN 811	1320	1019
65		x			SINK IN 811	1320	1019
66		x			SINK IN 811	1320	1019
67		x			SINK IN 811	1320	1019
68		x			CTR SINK IN 811	1320	1019
70 69		x			SINK BETWEEN 711 + 821	1320	1020
71		x			SINK NEAR 801 IN 821	1324	1022
72		x			CLOCKWISE SINK IN 821	1324	1022
73		x			" SINK IN 821	1324	1022

Lee's Summit DW

Team RS - BS

Date Purged 7/18/23
Date Sampled 7/19/23

School Summit Lane's MS

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
74	1	X			CLOCKWISE FROM L&L IN 821	1324	1022
75	1	X			" SINK IN 821	1324	1022
76	1	X			" SINK IN 821	1324	1022
77	1	X			" SINK IN 821	1324	1022
78	1	X			" SINK IN 821	1324	1022
79	1	X			CTR SINK - NOT WORKING IN 821	1324	—
80	1		X		DW FOUNTAIN OUTSIDE 821	1333	1034
81	1	X			CTR SINK IN 841	1335	1035
82	1	X			CLOCKWISE FROM WINDOWS IN 841	1335	1035
83	1	X			" 841	1335	1035
84	1	X			"	1335	1035
85	1	X			"	1335	1035
86	1	X			"	1335	1035
87	1	X			"	1335	1035
88	1	X			"	1335	1035
89	1	X			"	1335	1035
90	1	X			SINK IN 912	1341	1038
91	1	X			SINK IN 913	1342	1038
92	1	X			SINK IN 920 750	1345	1038
93	1	X			721 CTR SINK	1350	1050
94	1	X			CLOCKWISE FROM E IN 721	1350	1050
95	1	X			CLOCKWISE FROM E IN 721	1350	1050
96	1	X			"	1350	1050
97	1	X			"	1350	1050

Lee's Summit DW

Team RS + RB

Date Purged 7/18/23
Date Sampled 7/19/23

School Summit Lakes MS

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
98	1	X			721 "	1350	1050
99	1	X			724 "	1350	1050
100	1	X			724 "	1350	1050
101	1	X			SINK BETWEEN 721 + 711	1350	1052
102	1	X			CTR SINK ID 711	1350	1055
103	1	X			CLOCKWISE FROM MAIN DOOR 711	1350	1055
104	1	X			"	1350	1055
105	1	X			"	1350	1055
106	1	X			"	1350	1055
107	1	X			"	1350	1055
108	1	X			"	1350	1055
109	1	X			"	1350	1055
110	1	X			"	1350	1055
111	1		X		LEFT END FOUNTAIN/BF OUTSIDE GIRLS BATHROOM	1355	1056
112	1		X		RIGHT END FOUNTAIN OUTSIDE GIRLS BATHROOM	1355	1056
113		X			741 CTR SINK	1400	1105
114		X			CLOCKWISE FROM DOOR 741	1400	1105
115		X			"	1400	1105
116		X			"	1400	1105
117		X			"	1400	1105
118		X			"	1400	1105
119		X			"	1400	1105
120		X			"	1400	1105
120		X			"	1400	1105

Lee's Summit DW

Team RS + RB

School Summit Lakes MS

Date Purged 7/18/23

Date Sampled 7/19/23

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
122	1		X		DW/BLD FOUNTAIN OUTSIDE 721	1408	1108
123	1		X		L DW FOUNTAIN OUTSIDE 731	1410	1110
124	1		X		R DW FOUNTAIN/BF OUTSIDE 731	1410	1110
125	1	X			SINK IN CHEM STORAGE 725/780	1411	1112
126		X			831 CTR SINK	1413	1120
127		X			CLOCKWISE FROM DOOR w/ LIGHT SWITCH 831	1413	1120
128		X			" 831	1413	1120
129		X			" 831	1413	1120
130		X			" 831	1413	1120
131		X			" 831	1413	1120
132		X			" 831	1413	1120
133		X			" 831	1413	1120
134		X			SINK NEAR CHEM STORAGE - NOT WORKING	1413	—
135		X			731 CTR SINK	1415	1125
136		X			CLOCKWISE FROM CHEM STORAGE	1415	1125
137		X			" 731	1415	1125
138		X			" "	1415	1125
139		X			" "	1415	1125
140		X			" "	1415	1125
141		X			" "	1415	1125
142		X			" "	1415	1125
143		X			" "	1415	1125
144		X			611 CTR SINK	1428	1138
145		X			CLOCKWISE FROM DOOR 611	1428	1138

Team RS & B13

Date Purged	Date Sampled
7/18/23	7/19/23

School Summit Lakes MS

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

[illegible]

ATTACHMENT C

Summit Lakes Middle School Summary Table

Summary Table
Summit Lakes Middle School

Sample ID	Date	Analyte	Result	Unit	Reporting Limit
SLMS SK1	7/19/2023	Lead	2.8	µg/L	1
SLMS SK2	7/19/2023	Lead	ND	µg/L	1
SLMS SK3	7/19/2023	Lead	1.9	µg/L	1
SLMS SK4	7/19/2023	Lead	ND	µg/L	1
SLMS SK5	7/19/2023	Lead	ND	µg/L	1
SLMS SK6	7/19/2023	Lead	ND	µg/L	1
SLMS SK7	7/19/2023	Lead	ND	µg/L	1
SLMS SK8	7/19/2023	Lead	4.4	µg/L	1
SLMS SK9	7/19/2023	Lead	ND	µg/L	1
SLMS SK10	7/19/2023	Lead	ND	µg/L	1
SLMS SK11	7/19/2023	Lead	ND	µg/L	1
SLMS SK12	7/19/2023	Lead	ND	µg/L	1
SLMS DF13	7/19/2023	Lead	ND	µg/L	1
SLMS DF14	7/19/2023	Lead	ND	µg/L	1
SLMS SK17	7/19/2023	Lead	1.4	µg/L	1
SLMS SK20	7/19/2023	Lead	ND	µg/L	1
SLMS SK21	7/19/2023	Lead	ND	µg/L	1
SLMS SK22	7/19/2023	Lead	ND	µg/L	1
SLMS 023	7/19/2023	Lead	ND	µg/L	1
SLMS 024	7/19/2023	Lead	ND	µg/L	1
SLMS SK27	7/19/2023	Lead	2.7	µg/L	1
SLMS SK28	7/19/2023	Lead	2.4	µg/L	1
SLMS SK29	7/19/2023	Lead	2.7	µg/L	1
SLMS SK30	7/19/2023	Lead	1.0	µg/L	1
SLMS SK31	7/19/2023	Lead	ND	µg/L	1
SLMS SK32	7/19/2023	Lead	ND	µg/L	1
SLMS SK33	7/19/2023	Lead	1.6	µg/L	1
SLMS SK34	7/19/2023	Lead	ND	µg/L	1
SLMS SK35	7/19/2023	Lead	ND	µg/L	1
SLMS SK36	7/19/2023	Lead	ND	µg/L	1
SLMS SK37	7/19/2023	Lead	2.0	µg/L	1
SLMS 038	7/19/2023	Lead	ND	µg/L	1
SLMS SK39	7/19/2023	Lead	ND	µg/L	1
SLMS 040	7/19/2023	Lead	ND	µg/L	1
SLMS DF41	7/19/2023	Lead	ND	µg/L	1
SLMS DF42	7/19/2023	Lead	ND	µg/L	1
SLMS DF43	7/19/2023	Lead	ND	µg/L	1
SLMS DF44	7/19/2023	Lead	ND	µg/L	1
SLMS DF45	7/19/2023	Lead	ND	µg/L	1
SLMS DF46	7/19/2023	Lead	ND	µg/L	1
SLMS DF47	7/19/2023	Lead	ND	µg/L	1
SLMS DF48	7/19/2023	Lead	ND	µg/L	1
SLMS DF49	7/19/2023	Lead	ND	µg/L	1

SLMS DF50	7/19/2023	Lead	ND	µg/L	1
SLMS DF51	7/19/2023	Lead	ND	µg/L	1
SLMS SK52	7/19/2023	Lead	ND	µg/L	1
SLMS SK53	7/19/2023	Lead	3.6	µg/L	1
SLMS SK54	7/19/2023	Lead	ND	µg/L	1
SLMS SK55	7/19/2023	Lead	2.4	µg/L	1
SLMS SK56	7/19/2023	Lead	ND	µg/L	1
SLMS SK57	7/19/2023	Lead	1.2	µg/L	1
SLMS DF58	7/19/2023	Lead	ND	µg/L	1
SLMS DF59	7/19/2023	Lead	ND	µg/L	1
SLMS SK60	7/19/2023	Lead	18.7	µg/L	1
SLMS SK61	7/19/2023	Lead	19.9	µg/L	1
SLMS SK62	7/19/2023	Lead	13.5	µg/L	1
SLMS SK63	7/19/2023	Lead	17.9	µg/L	1
SLMS SK64	7/19/2023	Lead	17.0	µg/L	1
SLMS SK65	7/19/2023	Lead	18.5	µg/L	1
SLMS SK66	7/19/2023	Lead	21.7	µg/L	1
SLMS SK67	7/19/2023	Lead	15.1	µg/L	1
SLMS SK68	7/19/2023	Lead	16.6	µg/L	1
SLMS SK69	7/19/2023	Lead	3.5	µg/L	1
SLMS SK71	7/19/2023	Lead	14.9	µg/L	1
SLMS SK72	7/19/2023	Lead	19.1	µg/L	1
SLMS SK73	7/19/2023	Lead	37.3	µg/L	1
SLMS SK74	7/19/2023	Lead	16.3	µg/L	1
SLMS SK75	7/19/2023	Lead	12.0	µg/L	1
SLMS SK76	7/19/2023	Lead	11.1	µg/L	1
SLMS SK77	7/19/2023	Lead	15.1	µg/L	1
SLMS SK78	7/19/2023	Lead	28.2	µg/L	1
SLMS DF80	7/19/2023	Lead	ND	µg/L	1
SLMS SK81	7/19/2023	Lead	11.4	µg/L	1
SLMS SK82	7/19/2023	Lead	2.7	µg/L	1
SLMS SK83	7/19/2023	Lead	2.1	µg/L	1
SLMS SK84	7/19/2023	Lead	3.2	µg/L	1
SLMS SK85	7/19/2023	Lead	2.7	µg/L	1
SLMS SK86	7/19/2023	Lead	1.6	µg/L	1
SLMS SK87	7/19/2023	Lead	1.1	µg/L	1
SLMS SK88	7/19/2023	Lead	ND	µg/L	1
SLMS SK89	7/19/2023	Lead	1.2	µg/L	1
SLMS SK90	7/19/2023	Lead	ND	µg/L	1
SLMS SK91	7/19/2023	Lead	2.2	µg/L	1
SLMS SK92	7/19/2023	Lead	408	µg/L	1
SLMS SK93	7/19/2023	Lead	55.8	µg/L	1
SLMS SK94	7/19/2023	Lead	8.9	µg/L	1
SLMS SK95	7/19/2023	Lead	11.3	µg/L	1
SLMS SK96	7/19/2023	Lead	20.9	µg/L	1
SLMS SK97	7/19/2023	Lead	31.2	µg/L	1
SLMS SK98	7/19/2023	Lead	24.5	µg/L	1
SLMS SK99	7/19/2023	Lead	17.8	µg/L	1

SLMS	SK100	7/19/2023	Lead	17.7	µg/L	1
SLMS	SK101	7/19/2023	Lead	18.7	µg/L	1
SLMS	SK102	7/19/2023	Lead	142	µg/L	1
SLMS	SK103	7/19/2023	Lead	13.1	µg/L	1
SLMS	SK104	7/19/2023	Lead	19.9	µg/L	1
SLMS	SK105	7/19/2023	Lead	13.8	µg/L	1
SLMS	SK106	7/19/2023	Lead	20.1	µg/L	1
SLMS	SK107	7/19/2023	Lead	11.5	µg/L	1
SLMS	SK108	7/19/2023	Lead	13.9	µg/L	1
SLMS	SK109	7/19/2023	Lead	13.0	µg/L	1
SLMS	SK110	7/19/2023	Lead	24.7	µg/L	1
SLMS	SK111	7/19/2023	Lead	ND	µg/L	1
SLMS	DF112	7/19/2023	Lead	ND	µg/L	1
SLMS	DF113	7/19/2023	Lead	3.8	µg/L	1
SLMS	SK114	7/19/2023	Lead	ND	µg/L	1
SLMS	SK115	7/19/2023	Lead	ND	µg/L	1
SLMS	SK116	7/19/2023	Lead	ND	µg/L	1
SLMS	SK117	7/19/2023	Lead	ND	µg/L	1
SLMS	SK118	7/19/2023	Lead	ND	µg/L	1
SLMS	SK119	7/19/2023	Lead	ND	µg/L	1
SLMS	SK120	7/19/2023	Lead	ND	µg/L	1
SLMS	SK121	7/19/2023	Lead	ND	µg/L	1
SLMS	DF22	7/19/2023	Lead	ND	µg/L	1
SLMS	DF123	7/19/2023	Lead	ND	µg/L	1
SLMS	DF124	7/19/2023	Lead	ND	µg/L	1
SLMS	DF125	7/19/2023	Lead	110	µg/L	1
SLMS	SK126	7/19/2023	Lead	10.1	µg/L	5
SLMS	SK127	7/19/2023	Lead	87.5	µg/L	1
SLMS	SK128	7/19/2023	Lead	9.2	µg/L	1
SLMS	SK129	7/19/2023	Lead	13.5	µg/L	1
SLMS	SK130	7/19/2023	Lead	15.0	µg/L	1
SLMS	SK131	7/19/2023	Lead	12.5	µg/L	1
SLMS	SK132	7/19/2023	Lead	18.4	µg/L	1
SLMS	SK133	7/19/2023	Lead	8.2	µg/L	1
SLMS	SK135	7/19/2023	Lead	30.4	µg/L	1
SLMS	SK136	7/19/2023	Lead	19.3	µg/L	1
SLMS	SK137	7/19/2023	Lead	6.9	µg/L	1
SLMS	SK138	7/19/2023	Lead	10.3	µg/L	1
SLMS	SK139	7/19/2023	Lead	8.3	µg/L	1
SLMS	SK140	7/19/2023	Lead	12.7	µg/L	1
SLMS	SK141	7/19/2023	Lead	13.0	µg/L	1
SLMS	SK142	7/19/2023	Lead	15.0	µg/L	1
SLMS	SK143	7/19/2023	Lead	9.6	µg/L	1
SLMS	SK144	7/19/2023	Lead	10.1	µg/L	1
SLMS	SK145	7/19/2023	Lead	ND	µg/L	1
SLMS	SK146	7/19/2023	Lead	ND	µg/L	1
SLMS	SK147	7/19/2023	Lead	ND	µg/L	1
SLMS	SK148	7/19/2023	Lead	ND	µg/L	1

SLMS	SK149	7/19/2023	Lead	ND	µg/L	1
SLMS	SK150	7/19/2023	Lead	ND	µg/L	1
SLMS	SK151	7/19/2023	Lead	ND	µg/L	1
SLMS	SK152	7/19/2023	Lead	ND	µg/L	1
SLMS	SK153	7/19/2023	Lead	3.7	µg/L	1
SLMS	SK154	7/19/2023	Lead	ND	µg/L	1

µg/L: micrograms per liter

Bolded results indicate detection above reporting limits.

ATTACHMENT D

Summit Lakes Middle School Laboratory Analytical Report

August 23, 2023

Lindsay E. James
Blackstone Environmental, Inc.
16200 Foster Street
Overland Park, KS 66085
TEL: (913) 956-4160
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: Lees Summit School Dist DW / Summit Lakes MS

WorkOrder: 23071465

Dear Lindsay E. James:

TEKLAB, INC received 145 samples on 7/21/2023 11:39:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley
Project Manager
(618)344-1004 ex 44
patrickriley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	152
Chain of Custody	Appended

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Cooler Receipt Temp: NA °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: Blackstone Environmental, Inc.**Work Order:** 23071465**Client Project:** Lees Summit School Dist DW / Summit Lakes MS**Report Date:** 23-Aug-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2023	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-001

Client Sample ID: SLMS | SK1

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0028	mg/L	5	08/20/2023 20:01	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-002

Client Sample ID: SLMS | SK2

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	08/20/2023 22:07	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-003

Client Sample ID: SLMS | SK3

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0019	mg/L	5	08/20/2023 22:12	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-004

Client Sample ID: SLMS | SK4

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	08/20/2023 22:18	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-005

Client Sample ID: SLMS | SK5

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 9:34	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-006

Client Sample ID: SLMS | SK6

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 9:05	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-007

Client Sample ID: SLMS | SK7

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 9:09	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-008

Client Sample ID: SLMS | SK8

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0044	mg/L	5	08/20/2023 22:24	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-009

Client Sample ID: SLMS | SK9

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 9:13	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-010

Client Sample ID: SLMS | SK10

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	08/20/2023 23:15	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-011

Client Sample ID: SLMS | SK11

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 9:18	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-012

Client Sample ID: SLMS | SK12

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:46

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	08/20/2023 23:21	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-013

Client Sample ID: SLMS | DF13

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 9:22	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-014

Client Sample ID: SLMS | DF14

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 9:26	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-015

Client Sample ID: SLMS | SK17

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0014	mg/L	1	08/16/2023 9:30	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-016

Client Sample ID: SLMS | SK20

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 10:05	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-017

Client Sample ID: SLMS | SK21

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:53

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 10:09	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-018

Client Sample ID: SLMS | SK22

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 10:21	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-019

Client Sample ID: SLMS | 023

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 10:13	210040



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-020

Client Sample ID: SLMS | 024

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	08/20/2023 21:15	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-021

Client Sample ID: SLMS | SK27

Matrix: DRINKING WATER

Collection Date: 07/19/2023 8:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0027	mg/L	1	08/16/2023 10:38	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-022

Client Sample ID: SLMS | SK28

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0024	mg/L	5	08/20/2023 23:26	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-023

Client Sample ID: SLMS | SK29

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0027	mg/L	1	08/18/2023 11:06	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-024

Client Sample ID: SLMS | SK30

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0010	mg/L	5	08/20/2023 23:32	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-025

Client Sample ID: SLMS | SK31

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 11:02	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-026

Client Sample ID: SLMS | SK32

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 11:14	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-027

Client Sample ID: SLMS | SK33

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0016	mg/L	1	08/16/2023 11:18	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-028

Client Sample ID: SLMS | SK34

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 9:37	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-029

Client Sample ID: SLMS | SK35

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 11:22	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-030

Client Sample ID: SLMS | SK36

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 11:26	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-031

Client Sample ID: SLMS | SK37

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0020	mg/L	1	08/16/2023 11:30	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-032

Client Sample ID: SLMS | 038

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 11:34	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-033

Client Sample ID: SLMS | SK39

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 12:57	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-034

Client Sample ID: SLMS | 040

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 13:01	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-035

Client Sample ID: SLMS | DF41

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 13:05	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-036

Client Sample ID: SLMS | DF42

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:24

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 13:09	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-037

Client Sample ID: SLMS | DF43

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 13:13	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-038

Client Sample ID: SLMS | DF44

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 13:17	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-039

Client Sample ID: SLMS | DF45

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:27

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 13:21	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-040

Client Sample ID: SLMS | DF46

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/16/2023 13:25	210044



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-041

Client Sample ID: SLMS | DF47

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/18/2023 11:42	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-042

Client Sample ID: SLMS | DF48

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/18/2023 11:29	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-043

Client Sample ID: SLMS | DF49

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/18/2023 11:33	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-044

Client Sample ID: SLMS | DF50

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	08/20/2023 23:38	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-045

Client Sample ID: SLMS | DF51

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/17/2023 17:15	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-046

Client Sample ID: SLMS | SK52

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/17/2023 17:19	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-047

Client Sample ID: SLMS | SK53

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0036	mg/L	1	08/17/2023 17:24	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-048

Client Sample ID: SLMS | SK54

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/17/2023 17:28	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-049

Client Sample ID: SLMS | SK55

Matrix: DRINKING WATER

Collection Date: 07/19/2023 9:44

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0024	mg/L	1	08/17/2023 17:33	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-050

Client Sample ID: SLMS | SK56

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/17/2023 17:37	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-051

Client Sample ID: SLMS | SK57

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0012	mg/L	1	08/17/2023 17:42	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-052

Client Sample ID: SLMS | DF58

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/18/2023 11:38	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-053

Client Sample ID: SLMS | DF59

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/18/2023 12:09	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-054

Client Sample ID: SLMS | SK60

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0187	mg/L	1	08/18/2023 12:13	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-055

Client Sample ID: SLMS | SK61

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0199	mg/L	1	08/18/2023 12:18	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-056

Client Sample ID: SLMS | SK62

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0135	mg/L	1	08/16/2023 16:00	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-057

Client Sample ID: SLMS | SK63

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0179	mg/L	1	08/16/2023 16:04	210043



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-058

Client Sample ID: SLMS | SK64

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0170	mg/L	1	08/16/2023 16:29	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-059

Client Sample ID: SLMS | SK65

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0185	mg/L	1	08/16/2023 16:08	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-060

Client Sample ID: SLMS | SK66

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0217	mg/L	1	08/16/2023 16:13	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-061

Client Sample ID: SLMS | SK67

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0151	mg/L	1	08/16/2023 16:17	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-062

Client Sample ID: SLMS | SK68

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0166	mg/L	1	08/16/2023 16:21	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-063

Client Sample ID: SLMS | SK69

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0035	mg/L	1	08/16/2023 16:25	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-064

Client Sample ID: SLMS | SK71

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0149	mg/L	5	08/20/2023 23:44	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-065

Client Sample ID: SLMS | SK72

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0191	mg/L	1	08/18/2023 12:27	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-066

Client Sample ID: SLMS | SK73

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0373	mg/L	1	08/18/2023 12:31	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-067

Client Sample ID: SLMS | SK74

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0163	mg/L	1	08/18/2023 12:36	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-068

Client Sample ID: SLMS | SK75

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0120	mg/L	1	08/18/2023 13:07	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-069

Client Sample ID: SLMS | SK76

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0111	mg/L	1	08/21/2023 9:55	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-070

Client Sample ID: SLMS | SK77

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0151	mg/L	1	08/18/2023 13:12	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-071

Client Sample ID: SLMS | SK78

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0282	mg/L	1	08/18/2023 13:16	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-072

Client Sample ID: SLMS | DF80

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:34

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/18/2023 13:21	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-073

Client Sample ID: SLMS | SK81

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0114	mg/L	1	08/18/2023 13:25	210046



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-074

Client Sample ID: SLMS | SK82

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0027	mg/L	5	08/20/2023 23:49	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-075

Client Sample ID: SLMS | SK83

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0021	mg/L	1	08/21/2023 10:17	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-076

Client Sample ID: SLMS | SK84

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0032	mg/L	1	08/18/2023 14:10	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-077

Client Sample ID: SLMS | SK85

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0027	mg/L	5	08/21/2023 0:52	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-078

Client Sample ID: SLMS | SK86

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0016	mg/L	1	08/18/2023 14:14	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-079

Client Sample ID: SLMS | SK87

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0011	mg/L	1	08/18/2023 14:19	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-080

Client Sample ID: SLMS | SK88

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/18/2023 14:23	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-081

Client Sample ID: SLMS | SK89

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0012	mg/L	1	08/18/2023 14:28	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-082

Client Sample ID: SLMS | SK90

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/18/2023 14:32	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-083

Client Sample ID: SLMS | SK91

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0022	mg/L	1	08/18/2023 15:04	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-084

Client Sample ID: SLMS | SK92

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.408	mg/L	5	08/21/2023 0:58	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-085

Client Sample ID: SLMS | SK93

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0558	mg/L	5	08/21/2023 1:03	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-086

Client Sample ID: SLMS | SK94

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0089	mg/L	1	08/21/2023 10:49	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-087

Client Sample ID: SLMS | SK95

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0113	mg/L	5	08/21/2023 0:35	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-088

Client Sample ID: SLMS | SK96

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0209	mg/L	1	08/18/2023 15:08	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-089

Client Sample ID: SLMS | SK97

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0312	mg/L	1	08/18/2023 15:13	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-090

Client Sample ID: SLMS | SK98

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0245	mg/L	1	08/18/2023 15:17	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-091

Client Sample ID: SLMS | SK99

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0178	mg/L	5	08/21/2023 0:41	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-092

Client Sample ID: SLMS | SK100

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0177	mg/L	1	08/18/2023 15:22	210047



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-093

Client Sample ID: SLMS | SK101

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0187	mg/L	5	08/21/2023 0:46	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-094

Client Sample ID: SLMS | SK102

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.142	mg/L	5	08/21/2023 0:29	210287



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-095

Client Sample ID: SLMS | SK103

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0131	mg/L	1	08/18/2023 15:35	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-096

Client Sample ID: SLMS | SK104

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0199	mg/L	5	08/15/2023 14:08	210260



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-097

Client Sample ID: SLMS | SK105

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0138	mg/L	1	08/18/2023 15:26	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-098

Client Sample ID: SLMS | SK106

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0201	mg/L	5	08/21/2023 1:49	210260



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-099

Client Sample ID: SLMS | SK107

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0115	mg/L	1	08/18/2023 15:30	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-100

Client Sample ID: SLMS | SK108

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0139	mg/L	1	08/18/2023 16:02	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-101

Client Sample ID: SLMS | SK109

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0130	mg/L	1	08/18/2023 16:06	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-102

Client Sample ID: SLMS | SK110

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0247	mg/L	1	08/18/2023 16:11	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-103

Client Sample ID: SLMS | SK111

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:56

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/18/2023 16:15	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-104

Client Sample ID: SLMS | DF112

Matrix: DRINKING WATER

Collection Date: 07/19/2023 10:56

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/18/2023 16:20	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-105

Client Sample ID: SLMS | DF113

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0038	mg/L	1	08/18/2023 16:24	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-106

Client Sample ID: SLMS | SK114

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/18/2023 16:29	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-107

Client Sample ID: SLMS | SK115

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 11:11	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-108

Client Sample ID: SLMS | SK116

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 11:16	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-109

Client Sample ID: SLMS | SK117

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 11:20	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-110

Client Sample ID: SLMS | SK118

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 11:52	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-111

Client Sample ID: SLMS | SK119

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 11:56	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-112

Client Sample ID: SLMS | SK120

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 12:01	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-113

Client Sample ID: SLMS | SK121

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 12:05	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-114

Client Sample ID: SLMS | DF22

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 12:10	210117



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-115

Client Sample ID: SLMS | DF123

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 12:14	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-116

Client Sample ID: SLMS | DF124

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 12:46	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-117

Client Sample ID: SLMS | DF125

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.110	mg/L	5	08/15/2023 14:13	210260



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-118

Client Sample ID: SLMS | SK126

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0050		0.0101	mg/L	5	08/22/2023 12:21	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-119

Client Sample ID: SLMS | SK127

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0875	mg/L	5	08/15/2023 14:17	210260



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-120

Client Sample ID: SLMS | SK128

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0092	mg/L	1	08/21/2023 12:50	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-121

Client Sample ID: SLMS | SK129

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0135	mg/L	1	08/21/2023 12:55	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-122

Client Sample ID: SLMS | SK130

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0150	mg/L	1	08/21/2023 12:59	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-123

Client Sample ID: SLMS | SK131

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0125	mg/L	1	08/21/2023 13:04	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-124

Client Sample ID: SLMS | SK132

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0184	mg/L	1	08/21/2023 13:48	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-125

Client Sample ID: SLMS | SK133

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0082	mg/L	1	08/21/2023 13:53	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-126

Client Sample ID: SLMS | SK135

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0304	mg/L	1	08/21/2023 13:57	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-127

Client Sample ID: SLMS | SK136

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0193	mg/L	1	08/21/2023 14:02	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-128

Client Sample ID: SLMS | SK137

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0069	mg/L	1	08/21/2023 14:06	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-129

Client Sample ID: SLMS | SK138

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0103	mg/L	1	08/21/2023 14:11	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-130

Client Sample ID: SLMS | SK139

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0083	mg/L	1	08/21/2023 13:08	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-131

Client Sample ID: SLMS | SK140

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0127	mg/L	1	08/21/2023 14:15	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-132

Client Sample ID: SLMS | SK141

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0130	mg/L	1	08/21/2023 14:20	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-133

Client Sample ID: SLMS | SK142

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0150	mg/L	1	08/21/2023 14:24	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-134

Client Sample ID: SLMS | SK143

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0096	mg/L	1	08/21/2023 14:29	210116



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-135

Client Sample ID: SLMS | SK144

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0101	mg/L	5	08/15/2023 14:22	210260



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-136

Client Sample ID: SLMS | SK145

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	08/15/2023 14:26	210260



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-137

Client Sample ID: SLMS | SK146

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 14:47	210115



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-138

Client Sample ID: SLMS | SK147

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 14:51	210115



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-139

Client Sample ID: SLMS | SK148

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	5	08/21/2023 2:12	210260



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-140

Client Sample ID: SLMS | SK149

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 14:56	210115



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-141

Client Sample ID: SLMS | SK150

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 15:00	210115



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-142

Client Sample ID: SLMS | SK151

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/22/2023 11:50	210115



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-143

Client Sample ID: SLMS | SK152

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/22/2023 11:54	210115



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-144

Client Sample ID: SLMS | SK153

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		0.0037	mg/L	5	08/21/2023 2:29	210260



Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Lab ID: 23071465-145

Client Sample ID: SLMS | SK154

Matrix: DRINKING WATER

Collection Date: 07/19/2023 11:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	0.0010		< 0.0010	mg/L	1	08/21/2023 15:04	210115



Receiving Check List

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071465

Client Project: Lees Summit School Dist DW / Summit Lakes MS

Report Date: 23-Aug-23

Carrier: Crossroads

Received By: MBP

Completed by:

On:

24-Jul-23

Allison Colin

Reviewed by:

On:

24-Jul-23

Elizabeth A. Hurley

Pages to follow: Chain of custody

Extra pages included

Shipping container/cooler in good condition?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	Not Present <input type="checkbox"/>	Temp °C NA
Type of thermal preservation?	None <input checked="" type="checkbox"/>	Ice <input type="checkbox"/>	Blue Ice <input type="checkbox"/>	Dry Ice <input type="checkbox"/>
Chain of custody present?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody signed when relinquished and received?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody agrees with sample labels?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Samples in proper container/bottle?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Sample containers intact?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Sufficient sample volume for indicated test?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
All samples received within holding time?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Reported field parameters measured:	Field <input type="checkbox"/>	Lab <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	
Container/Temp Blank temperature in compliance?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	No VOA vials <input checked="" type="checkbox"/>
Water - TOX containers have zero headspace?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	No TOX containers <input checked="" type="checkbox"/>
Water - pH acceptable upon receipt?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>
NPDES/CWA TCN interferences checked/treated in the field?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

CHAIN OF CUSTODY

pg. 1 of 16 Work order # 23071465

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James Phone: (913) 495-9990
 E-Mail: ljames@blackstone-env.com Fax:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Samples on: ☐ ICE ☐ BLUE ICE ☒ NO ICE ☐ LG#
 Preserved in: ☒ LAB ☐ FIELD FOR LAB USE ONLY
 Lab Notes
 COURIER

Client Comments:

Summit Lakes MS

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED											
Lee's Summit School Dist. DW		DS + BS		MATRIX											
Results Requested		Billing Instructions		OTHER											
Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) Other <input type="checkbox"/> 3 Day (50% Surcharge)				NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES											
Lab Use Only	Sample Identification	Date/Time Sampled		Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead						
23071465	SLMS1 SK1	7/19/23 828		X					X						
002	SLMS1 SK2	828		X					X						
003	SLMS1 SK3	828		X					X						
004	SLMS1 SK4	828		X					X						
005	SLMS1 SK5	842		X					X						
006	SLMS1 SK6	842		X					X						
007	SLMS1 SK7	842		X					X						
008	SLMS1 SK8	842		X					X						
009	SLMS1 SK9	846		X					X						
010	SLMS1 SK10	846		X					X						

Relinquished By		Date/Time		Received By		Date/Time	
[Signature]		7/19/23 1730		[Signature]		7/19/23 1700	
[Signature]		7/19/23 1600		[Signature]		7/12/23 1309	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 2 of 16 Work order # 23071465

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: _____ Blackstone Environmental, Inc.		Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE	_____ °C	_____ LTG#
Address: _____ 16200 Foster Street		Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD	FOR LAB USE ONLY	
City / State / Zip _____ Overland Park, KS 66085		Lab Notes		
Contact: _____ Lindsay E. James		Phone: _____ (913) 495-9990		
E-Mail: _____ ljames@blackstone-env.com		Fax: _____		
Client Comments: _____				

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

Sumner T. Ladd MS

[illegible]

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



CHAIN OF CUSTODY

pg. 3 of 16 Work order # 13071465

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc. Address: 16200 Foster Street City / State / Zip: Overland Park, KS 66085 Contact: Lindsay E. James (913) 495-9990 E-Mail: ljames@blackstone-env.com		Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> LTG# _____ Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY Lab Notes Client Comments:		Summit Lakes MS	
Are these samples known to be involved in litigation? If yes, a surcharge will apply <input type="checkbox"/> Yes <input type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. <input type="checkbox"/> Yes <input type="checkbox"/> No					
Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name RS + BS		MATRIX	
Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		INDICATE ANALYSIS REQUESTED	
Lab Use Only		# and Type of Containers		Drinking Water Aqueous Soil Sludge Special Waste Groundwater DW Lead	
Sample Identification		Date/Time Sampled			
23071465 617 Sums 1 SK 21		7/19/23 853			
618 Sums 1 SK 22		855			
619 Sums 1 O 23		855			
620 Sums 1 O 24		855			
621 Sums 1 SK 25		855			
622 Sums 1 SK 26		855			
621 Sums 1 SK 27		858			
622 Sums 1 SK 28		908			
623 Sums 1 SK 29		908			
624 Sums 1 SK 30		908			
Relinquished By		Date/Time		Received By	
[Signature]		7/19/23 1730		[Signature] 7/20/23 1700	
[Signature]		7/19/23 1400		[Signature] 7/12/23 1339	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 4 of 16 Work order # 23071465

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: _____ Blackstone Environmental, Inc. Address: _____ 16200 Foster Street City / State / Zip: _____ Overland Park, KS 66085 Contact: _____ Lindsay E. James E-Mail: _____ ljames@blackstone-env.com	Phone: _____ (913) 495-9990 Fax: _____	Are these samples known to be involved in litigation? If yes, a surcharge will apply <input type="checkbox"/> Yes <input type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. <input type="checkbox"/> Yes <input type="checkbox"/> No
<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE °C LTG# _____ Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u> </div> <div style="width: 50%; text-align: right;"> <i>Summit Lakes MS</i> </div> </div>		
Lab Notes		
Client Comments:		

[illegible]

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7/19/23 1730	<i>[Signature]</i>	7/20/23 1200
<i>[Signature]</i>	7/20/23 1600	<i>[Signature]</i>	7/20/23 1139

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: _____	Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE _____ °C	LTG# _____
Address: _____	16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD	FOR LAB USE ONLY
City / State / Zip _____	Overland Park, KS 66085	Lab Notes	
Contact: _____	Lindsay E. James		
E-Mail: _____	ljames@blackstone-env.com		
	Phone: _____		
	Fax: _____		
		Client Comments:	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

Summit Lane's MS

[illegible]

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



pg. 6 of 16 Work order # 23071465

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client:	Blackstone Environmental, Inc.	
Address:	16200 Foster Street	
City / State / Zip	Overland Park, KS 66085	
Contact:	Lindsay E. James	Phone: (913) 495-9990
E-Mail:	ljames@blackstone-env.com	Fax:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No


Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number Lee's Summit School Dist. DW	Sample Collector's Name ZS + BB
---	------------------------------------

Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions	# and Type of Containers	OTHE
				NaHSC
				MeOH
				HCL
				H2SO
				NaOH
				HNO
				UNPRE

Lab Use Only	Sample Identification	Date/Time Sampled	ms	3	4	H	04	R
22071465	SLMS / DF 51	7/19/23 934						
045								
046	SLMS / SK 52	942						
047	SLMS / SK 53	942						
048	SLMS / SK 54	944						
049	SLMS / SK 55	944						
050	SLMS / SK 56	1004						
051	SLMS / SK 57	1005						
052	SLMS / DF 58	1015						
053	SLMS / DF 59	1015						
054	SLMS / SK 60	1019						

Relinquished By	Date/Time
<i>[Signature]</i>	7/19/23 1730
<i>[Signature]</i>	7/20/23 1600

Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE	°C	LTG# _____
Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD	<u>FOR LAB USE ONLY</u>	
Lab Notes		
Client Comments:		
		

[illegible]

Received By	Date/Time
<i>H. B. [Signature]</i>	7/20/27 1200
<i>Maryann Carter (XX)</i>	7/21/23 1139

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 82000



CHAIN OF CUSTODY

pg. 7 of 16 Work order # 23071465

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James (913) 495-9990
 E-Mail: ljames@blackstone-env.com
 Phone:
 Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG#
 Preserved in: ☐ LAB ☐ FIELD
 Lab Notes:
 FOR LAB USE ONLY

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Summit Lakes MS

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name RS + BS		INDICATE ANALYSIS REQUESTED													
Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers		MATRIX											
Lab Use Only	Sample Identification	Date/Time Sampled		OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead
23071465	SLMS / SK61	7/19/23 1019										X					X
056	SLMS / SK62	1019										X					X
057	SLMS / SK63	1019										X					X
058	SLMS / SK64	1019										X					X
059	SLMS / SK65	1019										X					X
060	SLMS / SK66	1019										X					X
061	SLMS / SK67	1019										X					X
062	SLMS / SK68	1019										X					X
063	SLMS / SK69	1020										X					X
064	SLMS / SK71	1022										X					X
Relinquished By		Date/Time		Date/Time		Received By		Date/Time									
[Signature]		7/19/23 1730		7/19/23 1730		[Signature]		7/19/23 1730								7/20/23 1200	
[Signature]		7/19/23 1800		7/19/23 1800		[Signature]		7/19/23 1800								7/21/23 1139	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 8 of 16 Work order # 23071465

pg. 8 of 16 Work order # 23071465

Client:	Blackstone Environmental, Inc.		
Address:	16200 Foster Street		
City / State / Zip	Overland Park, KS 66085		
Contact:	Lindsay E. James	Phone:	(913) 495-9990
E-Mail:	ljames@blackstone-env.com	Fax:	

Samples on:	<input type="checkbox"/> ICE	<input type="checkbox"/> BLUE ICE	<input type="checkbox"/> NO ICE	_____ °C	_____ LTG# _____
Preserved in:	<input type="checkbox"/> LAB	<input type="checkbox"/> FIELD	<u>FOR LAB USE ONLY</u>		
Lab Notes					
Client Comments:					

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name RS & BB		INDICATE ANALYSIS REQUESTED														
Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers		MATRIX						Date/Time						
Lab Use Only	Sample Identification	Date/Time Sampled	OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead	Received By	Date/Time
006	SCMS / SK72	7/19/23 1022									X					X		7/20/23 1200
007	SCMS / SK73	1022									X					X		7/20/23 1139
008	SCMS / SK74	1022									X					X		
009	SCMS / SK75	1022									X					X		
010	SCMS / SK76	1022									X					X		
011	SCMS / SK77	1022									X					X		
012	SCMS / SK78	1022									X					X		
013	SCMS / SK79										X					X		
014	SCMS / DE 80	1034									X					X		
015	SCMS / SK81	1035									X					X		

BottleOrder: 82000



CHAIN OF CUSTODY

pg. 9 of 16 Work order # 23071465

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG#
Address: 16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes
Contact: Lindsay E. James (913) 495-9990	
E-Mail: ljames@blackstone-env.com	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Summit Lakes MS

Project Name/Number		Sample Collector's Name	INDICATE ANALYSIS REQUESTED														
Lee's Summit School Dist. DW		ZS + BB	MATRIX														
<input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)	Results Requested	Billing Instructions	# and Type of Containers	OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead
Lab Use Only	Sample Identification	Date/Time Sampled															

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7/19/23 1730	<i>[Signature]</i>	7/20/23 1200
<i>[Signature]</i>	7/20/23 1600	<i>[Signature]</i>	7/21/23 1139

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 10 of 16 Work order # 23071465

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc. Address: 16200 Foster Street City / State / Zip: Overland Park, KS 66085 Contact: Lindsay E. James E-Mail: ljames@blackstone-env.com Phone: (913) 495-9990 Fax:	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG# _____ Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY Lab Notes Client Comments:
---	--

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name RS + BB		INDICATE ANALYSIS REQUESTED													
Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers		MATRIX						INDICATE ANALYSIS REQUESTED					
Lab Use Only	Sample Identification	Date/Time Sampled	OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead	
23071465	SLMS / SK92	7/19/23 1038									X					X	
085	SLMS / SK93	1050									X					X	
086	SLMS / SK94	1050									X					X	
087	SLMS / SK95	1050									X					X	
088	SLMS / SK96	1050									X					X	
089	SLMS / SK97	1050									X					X	
090	SLMS / SK98	1050									X					X	
091	SLMS / SK99	1050									X					X	
092	SLMS / SK100	1050									X					X	
093	SLMS / SK101	1052									X					X	

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7/19/23 1730	<i>[Signature]</i>	7/20/23 1200
<i>[Signature]</i>	7/19/23 1600	<i>[Signature]</i>	7/21/23 1139

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



5941103Z

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
Address: 16200 Foster Street
City / State / Zip: Overland Park, KS 66085
Contact: Lindsay E. James
E-Mail: ljames@blackstone-env.com
Phone: (913) 495-9990
Fax:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No



Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number Lee's Summit School Dist. DW	Sample Collector's Name RS & BB
---	------------------------------------

Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES
Lab Use Only		Sample Identification		

2307146.5	SK102	7/19/23	1055
094	SK103		1055
095	SK104		1055
096	SK105		1055
097	SK106		1055
098	SK107		1055
099	SK108		1055
100	SK109		1055
101	SK110		1055
102	SK111		1056

Relinquished By	Date/Time
	7/19/23 1730
	7/20/23 1600

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE _____ °C LTG# _____

Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY

Lab Notes

Client Comments:

Swain, T. L. MS

[illegible]

Received By	Date/Time
K. Gino	7/20/23
Maryann Peter (XX)	7/21/23 1:39

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.tekiabinc.com for terms and conditions.

BottleOrder: 82000



CHAIN OF CUSTODY

pg. 12 of 16 Work order # 23071465

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc. Address: 16200 Foster Street City / State / Zip: Overland Park, KS 66085 Contact: Lindsay E. James E-Mail: ljames@blackstone-env.com Phone: (913) 495-9990 Fax:	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> °C <input type="checkbox"/> LTG# Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY Lab Notes Client Comments: Summit Labs W/S
---	--

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED															
Lee's Summit School Dist. DW		RS + 38		Billing Instructions				Matrix				Date/Time							
Results Requested	Sample Identification	Date/Time Sampled	# and Type of Containers	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead	Aqueous	OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	
20071465	SCMS / DF112	7/19/23 1056	104	X					X										
105	SCMS / SK113	1105		X					X										
106	SCMS / SK114	1105		X					X										
107	SCMS / SK115	1105		X					X										
108	SCMS / SK116	1105		X					X										
109	SCMS / SK117	1105		X					X										
110	SCMS / SK118	1105		X					X										
111	SCMS / SK119	1105		X					X										
112	SCMS / SK120	1105		X					X										
113	SCMS / SK121	1105		X					X										

CHAIN OF CUSTODY

pg. 13 of 16 Work order # 23071465

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.
 Address: 16200 Foster Street
 City / State / Zip: Overland Park, KS 66085
 Contact: Lindsay E. James (913) 495-9990
 E-Mail: ljames@blackstone-env.com

Phone: _____ Fax: _____

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number: Lee's Summit School Dist. DW
 Sample Collector's Name: RS + BS

Results Requested: ☐ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)
 Billing Instructions: _____

Lab Use Only	Sample Identification	Date/Time Sampled	# and Type of Containers									
			OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES		
23071465	114 SAMS / DF 122	7/19/23 1108										
	115 SAMS / DF 123	1110										
	116 SAMS / DF 124	1110										
	117 SAMS / SK 125	1112										
	118 SAMS / SK 126	1120										
	119 SAMS / SK 127	1120										
	120 SAMS / SK 128	1120										
	121 SAMS / SK 129	1120										
	122 SAMS / SK 130	1120										
	123 SAMS / SK 131	1120										

Relinquished By: [Signature] Date/Time: 7/19/23 1730
 Received By: [Signature] Date/Time: 7/19/23 1200

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C ☐ LTG# _____
 Preserved in: ☐ LAB ☐ FIELD ☐ FOR LAB USE ONLY
 Lab Notes: _____

Client Comments: _____

Summit Lakes MS

MATRIX			INDICATE ANALYSIS REQUESTED									
Drinking Water												
Aqueous												
Soil												
Sludge												
Special Waste												
Groundwater												
DW Lead												

Received By: [Signature] Date/Time: 7/19/23 1200
 Received By: [Signature] Date/Time: 7/12/23 1309

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

pg. 14 of 16 Work order # 23071465

TEKLAL, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> LTG#
Address: 16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD FOR LAB USE ONLY
City / State / Zip: Overland Park, KS 66085	Lab Notes:
Contact: Lindsay E. James (913) 495-9990	Client Comments:
E-Mail: ljames@blackstone-env.com	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No
 Are these samples known to be hazardous? ☐ Yes ☐ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Summit Lakes MS

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name TJ & BB		INDICATE ANALYSIS REQUESTED													
Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers		MATRIX											
Lab Use Only	Sample Identification	Date/Time Sampled		OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead
23071465	SLMS1 SK132	7/19/23 1120										X					X
124	SLMS1 SK133	1120										X					X
125	SLMS1 SK134											X					X
126	SLMS1 SK135	1125										X					X
127	SLMS1 SK136	1125										X					X
128	SLMS1 SK137	1125										X					X
129	SLMS1 SK138	1125										X					X
130	SLMS1 SK139	1125										X					X
131	SLMS1 SK140	1125										X					X
132	SLMS1 SK141	1125										X					X

Relinquished By	Date/Time	Received By	Date/Time
W. B. [Signature]	7/19/23 1730	L. [Signature]	7/20/23 1200
	7/20/23 1600	W. [Signature]	7/21/23 1139

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



CHAIN OF CUSTODY

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Received By	Date/Time
<i>M. S. [Signature]</i>	7/20/23 1200
<i>Maryam Peta (XX)</i>	7/21/23 1139



pg. 16 of 16 Work order # 23071465

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: _____	Blackstone Environmental, Inc.	_____	_____	_____
Address: _____	16200 Foster Street	_____	_____	_____
City / State / Zip _____	Overland Park, KS 66085	_____	_____	_____
Contact: _____	Lindsay E. James	Phone: _____	(913) 495-9990	_____
E-Mail: _____	ljames@blackstone-env.com	Fax: _____	_____	_____

Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE _____ °C _____ LTG# _____
Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u>
Lab Notes
Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

Summit Lakes MS

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name RS & BS		INDICATE ANALYSIS REQUESTED														
Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers		MATRIX					Date/Time							
Lab Use Only	Sample Identification	Date/Time Sampled	OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead	Received By	Date/Time
23071405	143 SAMS / SK152	7/19/23 1138									X					X	W. G. H. H. H.	7/20/23 1300
144	SAMS / SK153	1142									X					X	W. G. H. H. H.	7/20/23 1300
145	SAMS / SK154	1142									X					X	W. G. H. H. H.	7/20/23 1300
146	SAMS / SK155										X					X	W. G. H. H. H.	7/20/23 1300
147	SAMS / SK156										X					X	W. G. H. H. H.	7/20/23 1300

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000

