

## **ATTACHMENT B**

---

**Summit Pointe Elementary  
Field Forms**

# Lee's Summit DW

Date Purged 7/20/23  
Date Sampled 7/21/23

School Summit Pointe Elementary

Team RS & BB

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
1	1	X			Sink in Warehouse B102	1207	855
2	1	X			Sink in Warehouse A111	1211	857
3	1	X			Sink in 152	1212	858
4	1	X			Sink in Laundry/RATH 152	1212	858
5	1	X			Sink in Lounge	1215	900
6	1			X	Dishwasher in Lounge	1215	900
7	1			X	ICE MACHINE in Lounge	1215	900
8	1		X		LEFT DW Fountain OUTSIDE A121	1220	907
9	1		X		RIGHT DW Fountain OUTSIDE A121	1220	907
10	1	X			Sink in A121	1225	909
11	1	X			Sink in A123	1225	909
12	1	X			Sink in A124	1225	909
13	1	X			Sink in A122	1225	909
14	1	X			RIGHT Sink in A130	1230	914
15	1	X			LEFT Sink in A130	1230	914
16	1	X			Sink in A125	1235	917
17	1	X			Sink in A127	1235	917
18	1	X			Sink in A128	1235	917
19	1	X			Sink in A124	1235	917
20	1	X			Sink in B118	1240	919
21	1		X		L DW Fountain OUTSIDE B121	1241	920
22	1		X		M DW Fountain OUTSIDE B121	1241	920
23	1		X		R DW Fountain OUTSIDE B121	1241	920
24	1	X			Sink in B125	1242	922



# Lee's Summit DW

Date Purged 7/20/23  
Date Sampled 7/21/23

School Summit Pointe ELEM

Date Purged 7/20/23  
Date Sampled 7/21/23

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
25	1	X			SINK IN B126	1242	922
26	1	X			SINK IN B124	1242	922
27	1	X			SINK IN B123	1242	922
28	1	X			SINK IN B121	1253	925
29	1	X			SINK IN B122	1253	925
30	1	X			SINK IN B120	1253	925
31	1	X			SINK IN B119	1253	925
32	1	X			SINK IN B119	1259	929
33	1		X		L DUS FOUNTAIN OUTSIDE C115	1300	930
34	1		X		M DUS FOUNTAIN OUTSIDE C115	1300	930
35	1		X		R DUS FOUNTAIN OUTSIDE C115	1300	930
36	1	X			SINK IN C119	1303	931
37	1	X			SINK IN C120	1303	931
38	1	X			SINK IN C118	1303	931
39	1	X			SINK IN C117	1303	931
40	1	X			SINK IN C115	1308	935
41	1	X			SINK IN C116	1308	935
42	1	X			SINK IN C114	1308	935
43	1	X			SINK IN C113	1308	935
44	1	X			SINK IN B140	1314	940
45	1	X			SINK IN C109	1316	941
46	1	X			SINK IN C107	1320	942
47	1	X			SINK IN C104	1324	943
48	1		X		L DUS FOUNTAIN OUTSIDE C140	1329	945

Team LS-RR

Date Purged	Date Sampled
7/20/23	7/21/23

School Summit Pointe ELSEN

**Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)**

[illegible]



## **ATTACHMENT C**

---

### **Summit Pointe Elementary Summary Table**

**Summary Table**  
**Summit Pointe Elementary**

Sample ID	Date	Analyte	Result	Unit	Reporting Limit
SPE1SK1	7/21/2023	Lead	ND	µg/L	1
SPE1SK2	7/21/2023	Lead	5.9	µg/L	1
SPE1SK3	7/21/2023	Lead	ND	µg/L	1
SPE1SK4	7/21/2023	Lead	ND	µg/L	1
SPE1SK5	7/21/2023	Lead	ND	µg/L	1
SPE1O6	7/21/2023	Lead	ND	µg/L	1
SPE1O7	7/21/2023	Lead	ND	µg/L	1
SPE1DF8	7/21/2023	Lead	ND	µg/L	1
SPE1DF9	7/21/2023	Lead	ND	µg/L	1
SPE1SK10	7/21/2023	Lead	1.8	µg/L	1
SPE1SK11	7/21/2023	Lead	1.1	µg/L	1
SPE1SK12	7/21/2023	Lead	1.1	µg/L	1
SPE1SK13	7/21/2023	Lead	ND	µg/L	1
SPE1SK14	7/21/2023	Lead	ND	µg/L	1
SPE1SK15	7/21/2023	Lead	ND	µg/L	1
SPE1SK16	7/21/2023	Lead	ND	µg/L	1
SPE1SK17	7/21/2023	Lead	ND	µg/L	1
SPE1SK18	7/21/2023	Lead	ND	µg/L	1
SPE1SK19	7/21/2023	Lead	2.4	µg/L	1
SPE1SK20	7/21/2023	Lead	ND	µg/L	1
SPE1DF21	7/21/2023	Lead	ND	µg/L	1
SPE1DF22	7/21/2023	Lead	ND	µg/L	1
SPE1DF23	7/21/2023	Lead	ND	µg/L	1
SPE1SK24	7/21/2023	Lead	1.1	µg/L	1
SPE1SK25	7/21/2023	Lead	ND	µg/L	1
SPE1SK26	7/21/2023	Lead	ND	µg/L	1
SPE1SK27	7/21/2023	Lead	ND	µg/L	1
SPE1SK28	7/21/2023	Lead	1.3	µg/L	1
SPE1SK29	7/21/2023	Lead	1.5	µg/L	1
SPE1SK30	7/21/2023	Lead	4.6	µg/L	1
SPE1SK31	7/21/2023	Lead	ND	µg/L	1
SPE1SK32	7/21/2023	Lead	1.5	µg/L	1
SPE1DF33	7/21/2023	Lead	ND	µg/L	1
SPE1DF34	7/21/2023	Lead	ND	µg/L	1
SPE1DF35	7/21/2023	Lead	ND	µg/L	1
SPE1SK36	7/21/2023	Lead	ND	µg/L	1
SPE1SK37	7/21/2023	Lead	ND	µg/L	1
SPE1SK38	7/21/2023	Lead	ND	µg/L	1
SPE1SK39	7/21/2023	Lead	ND	µg/L	1
SPE1SK40	7/21/2023	Lead	ND	µg/L	1
SPE1SK41	7/21/2023	Lead	ND	µg/L	1
SPE1SK42	7/21/2023	Lead	ND	µg/L	1
SPE1SK43	7/21/2023	Lead	ND	µg/L	1

SPE1SK44	7/21/2023	Lead	<b>1.2</b>	µg/L	1
SPE1SK45	7/21/2023	Lead	ND	µg/L	1
SPE1SK46	7/21/2023	Lead	ND	µg/L	1
SPE1SK47	7/21/2023	Lead	ND	µg/L	1
SPE1DF48	7/21/2023	Lead	ND	µg/L	1
SPE1DF49	7/21/2023	Lead	ND	µg/L	1
SPE1DF50	7/21/2023	Lead	ND	µg/L	1
SPE1DF51	7/21/2023	Lead	ND	µg/L	1
SPE1DF52	7/21/2023	Lead	ND	µg/L	1
SPE1SK53	7/21/2023	Lead	<b>11.4</b>	µg/L	1
SPE1O54	7/21/2023	Lead	ND	µg/L	1
SPE1SK55	7/21/2023	Lead	<b>5.0</b>	µg/L	1
SPE1SK56	7/21/2023	Lead	<b>14.2</b>	µg/L	1
SPE1SK57	7/21/2023	Lead	<b>2.3</b>	µg/L	1
SPE1SK58	7/21/2023	Lead	<b>2.1</b>	µg/L	1
SPE1SK59	7/21/2023	Lead	<b>1.2</b>	µg/L	1
SPE1SK60	7/21/2023	Lead	<b>1.3</b>	µg/L	1
SPE1SK61	7/21/2023	Lead	ND	µg/L	1
SPE1SK62	7/21/2023	Lead	ND	µg/L	1
SPE1O63	7/21/2023	Lead	<b>2.5</b>	µg/L	1

µg/L: micrograms per liter

Bolded results indicate detection above reporting limits

## **ATTACHMENT D**

---

### **Summit Pointe Elementary Laboratory Analytical Report**



August 31, 2023

Lindsay E. James  
Blackstone Environmental, Inc.  
16200 Foster Street  
Overland Park, KS 66085  
TEL: (913) 956-4160  
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

**RE:** Lees Summit School Dist DW Summit Pointe Elem.

**WorkOrder:** 23071563

Dear Lindsay E. James:

TEKLAB, INC received 63 samples on 7/24/2023 11:35:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley  
Project Manager  
(618)344-1004 ex 44  
[patrickriley@teklabinc.com](mailto:patrickriley@teklabinc.com)



## Report Contents

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**This reporting package includes the following:**

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	70
Chain of Custody	Appended

**Client:** Blackstone Environmental, Inc.**Work Order:** 23071563**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.**Report Date:** 31-Aug-23**Abbr Definition**

\* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count ( > 200 CFU )

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

### Qualifiers

- |   |  |
|---|--|
| # - Unknown hydrocarbon                               | B - Analyte detected in associated Method Blank              |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range                           |
| H - Holding times exceeded                            | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits        | M - Manual Integration used to determine area response       |
| ND - Not Detected at the Reporting Limit              | R - RPD outside accepted recovery limits                     |
| S - Spike Recovery outside recovery limits            | T - TIC(Tentatively identified compound)                     |
| X - Value exceeds Maximum Contaminant Level           |  |





## Case Narrative

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Cooler Receipt Temp:** NA °C

### Locations

#### Collinsville

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** jhriley@teklabinc.com

#### Collinsville Air

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** EHurley@teklabinc.com

#### Springfield

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415  
**Phone** (217) 698-1004  
**Fax** (217) 698-1005  
**Email** KKlostermann@teklabinc.com

#### Chicago

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515  
**Phone** (630) 324-6855  
**Fax**  
**Email** arenner@teklabinc.com

#### Kansas City

**Address** 8421 Nieman Road  
Lenexa, KS 66214  
**Phone** (913) 541-1998  
**Fax** (913) 541-1998  
**Email** jhriley@teklabinc.com

**Client:** Blackstone Environmental, Inc.**Work Order:** 23071563**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.**Report Date:** 31-Aug-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2023	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-001

**Client Sample ID:** SPE1SK1

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 8:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 13:59	210433



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-002

**Client Sample ID:** SPE1SK2

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 8:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.9	µg/L	5	08/30/2023 14:03	210434





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-003

**Client Sample ID:** SPE1SK3

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 8:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 18:37	210396



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-004

**Client Sample ID:** SPE1SK4

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 8:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 18:11	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-005

**Client Sample ID:** SPE1SK5

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 14:10	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-006

**Client Sample ID:** SPE106

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 18:26	210397





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-007

**Client Sample ID:** SPE107

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 18:29	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-008

**Client Sample ID:** SPE1DF8

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:07

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 18:33	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-009

**Client Sample ID:** SPE1DF9

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:07

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 19:24	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-010

**Client Sample ID:** SPE1SK10

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.8	µg/L	1	08/29/2023 18:48	210397





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-011

**Client Sample ID:** SPE1SK11

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.1	µg/L	1	08/29/2023 18:51	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-012

**Client Sample ID:** SPE1SK12

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.1	µg/L	5	08/30/2023 14:06	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-013

**Client Sample ID:** SPE1SK13

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:09

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 18:55	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-014

**Client Sample ID:** SPE1SK14

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:14

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 18:59	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-015

**Client Sample ID:** SPE1SK15

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:14

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 19:13	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-016

**Client Sample ID:** SPE1SK16

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 14:32	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-017

**Client Sample ID:** SPE1SK17

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 19:17	210397





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-018

**Client Sample ID:** SPE1SK18

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 14:36	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-019

**Client Sample ID:** SPE1SK19

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.4	µg/L	5	08/30/2023 14:39	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-020

**Client Sample ID:** SPE1SK20

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:19

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 19:21	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-021

**Client Sample ID:** SPE1DF21

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 19:35	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-022

**Client Sample ID:** SPE1DF22

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 20:12	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-023

**Client Sample ID:** SPE1DF23

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 19:39	210397



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-024

**Client Sample ID:** SPE1SK24

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.1	µg/L	5	08/30/2023 14:43	210434





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-025

**Client Sample ID:** SPE1SK25

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 19:43	210398



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-026

**Client Sample ID:** SPE1SK26

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 19:46	210398



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-027

**Client Sample ID:** SPE1SK27

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 20:01	210398



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-028

**Client Sample ID:** SPE1SK28

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.3	µg/L	5	08/30/2023 14:47	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-029

**Client Sample ID:** SPE1SK29

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.5	µg/L	5	08/30/2023 14:50	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-030

**Client Sample ID:** SPE1SK30

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		4.6	µg/L	5	08/30/2023 14:54	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-031

**Client Sample ID:** SPE1SK31

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:25

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 14:58	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-032

**Client Sample ID:** SPE1SK32

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.5	µg/L	5	08/30/2023 15:01	210434





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-033

**Client Sample ID:** SPE1DF33

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 20:05	210398



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-034

**Client Sample ID:** SPE1DF34

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 20:08	210398



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-035

**Client Sample ID:** SPE1DF35

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:30

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/30/2023 8:00	210398



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-036

**Client Sample ID:** SPE1SK36

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 20:23	210398



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-037

**Client Sample ID:** SPE1SK37

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 20:27	210398



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-038

**Client Sample ID:** SPE1SK38

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 20:30	210398



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-039

**Client Sample ID:** SPE1SK39

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:31

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 15:05	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-040

**Client Sample ID:** SPE1SK40

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 15:20	210434





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-041

**Client Sample ID:** SPE1SK41

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/30/2023 8:47	210398



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-042

**Client Sample ID:** SPE1SK42

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 15:23	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-043

**Client Sample ID:** SPE1SK43

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 15:27	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-044

**Client Sample ID:** SPE1SK44

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:40

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.2	µg/L	5	08/30/2023 15:31	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-045

**Client Sample ID:** SPE1SK45

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:41

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 15:45	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-046

**Client Sample ID:** SPE1SK46

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 15:34	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-047

**Client Sample ID:** SPE1SK47

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:43

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/29/2023 20:34	210399



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-048

**Client Sample ID:** SPE1DF48

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/30/2023 8:25	210399





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-049

**Client Sample ID:** SPE1DF49

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/30/2023 8:29	210399



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-050

**Client Sample ID:** SPE1DF50

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/30/2023 8:33	210399



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-051

**Client Sample ID:** SPE1DF51

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/30/2023 15:38	210434



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-052

**Client Sample ID:** SPE1DF52

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:47

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/30/2023 8:36	210399



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-053

**Client Sample ID:** SPE1SK53

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		11.4	µg/L	5	08/29/2023 9:07	210435



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-054

**Client Sample ID:** SPE1054

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/29/2023 9:33	210435



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-055

**Client Sample ID:** SPE1SK55

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.0	µg/L	5	08/29/2023 9:36	210435



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-056

**Client Sample ID:** SPE1SK56

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		14.2	µg/L	5	08/29/2023 9:11	210435





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-057

**Client Sample ID:** SPE1SK57

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.3	µg/L	1	08/29/2023 22:38	210399



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-058

**Client Sample ID:** SPE1SK58

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.1	µg/L	5	08/29/2023 0:32	210435



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-059

**Client Sample ID:** SPE1SK59

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.2	µg/L	1	08/30/2023 8:40	210399



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-060

**Client Sample ID:** SPE1SK60

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.3	µg/L	1	08/30/2023 8:44	210399



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-061

**Client Sample ID:** SPE1SK61

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:52

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	08/29/2023 9:40	210435



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-062

**Client Sample ID:** SPE1SK62

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	08/30/2023 9:09	210399



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071563

**Client Project:** Lees Summit School Dist DW Summit Pointe Elem.

**Report Date:** 31-Aug-23

**Lab ID:** 23071563-063

**Client Sample ID:** SPE1063

**Matrix:** DRINKING WATER

**Collection Date:** 07/21/2023 9:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.5	µg/L	1	08/30/2023 9:13	210399



## Receiving Check List

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071563

Client Project: Lees Summit School Dist DW Summit Pointe Elem.

Report Date: 31-Aug-23

Carrier: Skylar Mathis

Received By: MBP

Completed by:

*Elizabeth A. Hurley*

Reviewed by:

*Ellie Hopkins*

On:

26-Jul-23

Elizabeth A. Hurley

On:

26-Jul-23

Ellie Hopkins

Pages to follow:

Chain of custody

7

Extra pages included

0

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C

NA

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice

☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☒

No ☐

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.



## pg. 1 of 7 Work order # 23071563

**TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005**

<b>Client:</b>	Blackstone Environmental, Inc.
<b>Address:</b>	16200 Foster Street
<b>City / State / Zip</b>	Overland Park, KS 66085
<b>Contact:</b>	Lindsay E. James
<b>E-Mail:</b>	ljames@blackstone-env.com
	<b>Phone:</b> (913) 495-9990
	<b>Fax:</b>

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

**Client Comments:**

593

Samuel T. Roberts, Clerk

<b>Project Name/Number</b> Lee's Summit School Dist. DW		<b>Sample Collector's Name</b> RS + BS	
<b>Results Requested</b> <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other _____ <input type="checkbox"/> 3 Day (50% Surcharge)		<b># and Type of Containers</b> OTHER NaHSO4 MeOH HCL H2SO4 NaOH HNO3 UNPRES	
<b>Billing Instructions</b>		<b>Date/Time Sampled</b>	
<b>Lab Use Only</b>		<b>Sample Identification</b>	

[illegible]

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7/21/23 1300	<i>[Signature]</i>	7/21/23 1350
<i>[Signature]</i>	7/21/23 1600	↑ <i>[Signature]</i>	7/22/23
<i>[Signature]</i>	7/24/23 1135	<i>[Signature]</i>	7/24/23 135

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

BottleOrder: 82000



# CHAIN OF CUSTODY

pg. 2 of 7 Work order # 23071563

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.  
 Address: 16200 Foster Street  
 City / State / Zip: Overland Park, KS 66085  
 Contact: Lindsay E. James Phone: (913) 495-9990  
 E-Mail: ljames@blackstone-env.com Fax:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ °C LTG#  
 Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY  
 Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No  
 Are these samples known to be hazardous? ☐ Yes ☐ No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Summit Pointe Eden

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name ZS - BS	INDICATE ANALYSIS REQUESTED											
Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions	MATRIX											
Lab Use Only	Sample Identification	Date/Time Sampled	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead						
23071563-011	SPE1 SK11	7/21/23 909	X					X						
012	SPE1 SK12	909	X					X						
013	SPE1 SK13	909	X					X						
014	SPE1 SK14	914	X					X						
015	SPE1 SK15	914	X					X						
016	SPE1 SK16	917	X					X						
017	SPE1 SK17	917	X					X						
018	SPE1 SK18	917	X					X						
019	SPE1 SK19	917	X					X						
020	SPE1 SK20	919	X					X						

Relinquished By	Date/Time	Received By	Date/Time
[Signature]	7/21/23 1300	[Signature]	7/21/23 1350
[Signature]	7/21/23 1300	[Signature]	7/22/23
[Signature]	7/21/23 1135	[Signature]	7/24/23 135

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



# CHAIN OF CUSTODY

pg. 3 of 7 Work order # 23071563

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

<b>Client:</b> Blackstone Environmental, Inc.	Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE <input type="checkbox"/> LTG#
<b>Address:</b> 16200 Foster Street	Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <b>FOR LAB USE ONLY</b>
<b>City / State / Zip:</b> Overland Park, KS 66085	Lab Notes
<b>Contact:</b> Lindsay E. James (913) 495-9990	
<b>E-Mail:</b> ljames@blackstone-env.com	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No  
 Are these samples known to be hazardous? ☐ Yes ☐ No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Client Comments:

Summit Points ELEM

Project Name/Number		Sample Collector's Name	INDICATE ANALYSIS REQUESTED														
Lee's Summit School Dist. DW		RS v BB	MATRIX														
Results Requested		Billing Instructions	# and Type of Containers														
Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) Other <input type="checkbox"/> 3 Day (50% Surcharge)			OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead	
Lab Use Only	Sample Identification	Date/Time Sampled															
03071563-021	SPE1 DF21	7/2/23 920															
022	SPE1 DF22	920															
023	SPE1 DF23	920															
024	SPE1 SK24	922															
025	SPE1 SK25	922															
026	SPE1 SK26	922															
027	SPE1 SK27	922															
028	SPE1 SK28	925															
029	SPE1 SK29	925															
030	SPE1 SK30	925															

Received By

Date/Time

Relinquished By

Date/Time

<i>[Signature]</i>	7/2/23 1300	<i>[Signature]</i>	7/2/23 1350
<i>[Signature]</i>	7/2/23 1600	<i>[Signature]</i>	7/22/23 1135
<i>[Signature]</i>	7/24/23 1135	<i>[Signature]</i>	7/24/23 1135

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



# CHAIN OF CUSTODY

pg. 4 of 7 Work order # 23071563

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.  
 Address: 16200 Foster Street  
 City / State / Zip: Overland Park, KS 66085  
 Contact: Lindsay E. James (913) 495-9990  
 E-Mail: ljames@blackstone-env.com

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE ☐ LTG#  
 Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY  
 Lab Notes  
 Client Comments: Summit Pointe Green

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No  
 Are these samples known to be hazardous? ☐ Yes ☐ No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED	
Lee's Summit School Dist. DW		RS + RS			
Results Requested		Billing Instructions		MATRIX	
<input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		# and Type of Containers			
Lab Use Only	Sample Identification	Date/Time Sampled		Drinking Water	Aqueous
031	SPE1 SK31	7/24/23 925		X	
032	SPE1 SK32	929		X	
033	SPE1 DF33	930		X	
034	SPE1 DF34	930		X	
035	SPE1 DF35	930		X	
036	SPE1 SK36	931		X	
037	SPE1 SK37	931		X	
038	SPE1 SK38	931		X	
039	SPE1 SK39	931		X	
040	SPE1 SK40	935		X	
				DW Lead	
				Groundwater	
				Special Waste	
				Sludge	
				Soil	

  

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7/24/23 1500	<i>[Signature]</i>	7/24/23 1350
<i>[Signature]</i>	7/24/23 1600	<i>[Signature]</i>	7/24/23 135
<i>[Signature]</i>	7/24/23 1135	<i>[Signature]</i>	7/24/23 1135

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



pg. 6 of 7 Work order # 23071563

pg. 6 of 7 Work order # 23071563

pg. 6 of 7 Work order # 23071563

pg. 6 of 7 Work order # 23071563

pg. 6 of 7 Work order # 23071563

Bottle Order: 82000





pg. 7 of 7 Work order # 23071563

**TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005**

**Client:** Blackstone Environmental, Inc.  
**Address:** 16200 Foster Street  
**City / State / Zip:** Overland Park, KS 66085  
**Contact:** Lindsay E. James  
**E-Mail:** ljames@blackstone-env.com  
**Phone:** (913) 495-9990  
**Fax:**

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☐ No

Are these samples known to be hazardous? ☐ Yes ☐ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☐ No

Project Name/Number	Sample Collector's Name
Lee's Summit School Dist. DW	ES + BS

<input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other _____ <input type="checkbox"/> 3 Day (50% Surcharge)	<b>Billing Instructions</b>	<b># and Type of Containers</b>	OTHE
			NaHSO
			MeOH
			HCL
			H2SO
			NaOH
			HNO
			UNPRR

Lab Use Only	Sample Identification	Date/Time Sampled
20201513-1101	SE1 SK 61	7/21/23 952

2901305	29-MS-1305	956	1
2901305	29-MS-1305	956	1

[illegible][illegible][illegible][illegible]

Relinquished By	Date/Time
	7/24/23 1300

W. J. W. King	7/21/23	1600
Edna Mathis	7/24/23	135

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understood the following:

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE \_\_\_\_\_ °C LTG# \_\_\_\_\_

Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY

Lab Notes

Client Comments:

Summit Forest Center

[illegible]

Received By	Date/Time
W. J. H. H. H.	7/21/23 1350
W. J. H. H. H.	7/22/23
W. J. H. H. H.	7/24/23 1135

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

BottleOrder: 82000

