

**ATTACHMENT B**

---

**Sunset Valley Elementary  
Field Forms**

Lee's Summit DW

Team ES + BB

School SUMMIT VALLEY ELEMENTARY

Date Purged 7/25/23  
Date Sampled 7/26/23

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
1	1	X			SINK IN 152	1151	845
2	1	X			SINK IN 154	1151	845
3	1	X			SINK IN NURSE 111/109	1155	849
4	1	X			SINK IN LOUNGE 114	1158	850
5	1			X	DISHWASHER IN 114	1158	850
6	1			X	ICE MACHINE IN 114	1158	850
7	1		X		2ND FOUNTAIN (L) OUTSIDE 123	1200	855
8	1		X		2ND FOUNTAIN (R) OUTSIDE 123	1200	855
9	1	X			SINK IN 123	1202	857
10	1	X			SINK IN 124	1202	857
11	1	X			SINK IN 122	1202	857
12	1	X			SINK IN 121	1202	857
13	1	X			SINK IN 125	1209	900
14	1	X			SINK IN 126	1209	900
15	1	X			SINK IN 128	1209	900
16	1	X			SINK IN 127	1209	900
17	1	X			SINK IN 118	1213	905
18	1		X		L 2ND FOUNTAIN OUTSIDE	1215	905
19	1		X		M 2ND FOUNTAIN OUTSIDE	1215	905
20	1		X		R 2ND FOUNTAIN OUTSIDE	1215	905
21	1	X			SINK IN 125	1216	908
22	1	X			SINK IN 126	1216	908
23	1	X			SINK IN 124	1218	908
24	1	X			SINK IN 123	1218	908

Lee's Summit DW

Team KS + RB

School SUNSET VALLEY ELEM

Date Purged 7/25/23  
 Date Sampled 7/26/23

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
25	1	X			SINK 10 121	1218	912
26	1	X			SINK 10 122	1218	912
27	1	X			SINK 10 120	1218	912
28	1	X			SINK 10 119	1218	912
29	1	X			SINK 10 10Z OFF LIBRARY	1228	915
30	1	X			SINK 10 118	1232	918
31	1		X		L DO FOUNTAIN OUTSIDE	1233	918
32	1		X		M DO FOUNTAIN OUTSIDE	1233	918
33	1		X		R DO FOUNTAIN OUTSIDE	1233	918
34	1	X			SINK 10 146	1235	922
35	1	X			SINK 10 147	1235	922
36	1	X			SINK 10 145	1235	922
37	1	X			SINK 10 144	1235	922
38	1	X			SINK 10 142	1238	926
39	1	X			SINK 10 143	1238	926
40	1	X			SINK 10 141	1238	926
41	1	X			SINK 10 140	1238	926
42	1	X			R SINK 10 114	1245	932
43	1	X			L SINK 10 114	1245	932
44	1	X			SINK 10 157	1253	935
45	1	X			SINK 10 153	1253	935
46	1	X			SINK 10 152	1255	938
47	1	X			SINK 10 148	1255	938
48	1		X		L DO FOUNTAIN OUTSIDE CAGE	1305	941

Lee's Summit DW

Team RS-3B

School Sunset Valley Elem

Date Purged 7/25/23

Date Sampled 7/26/23

Sample ID = School abbrev + Floor - Type + Test number (Ex: ME1-DF1)

Test #	Floor #	Sink (SK)	Fountain (DF)	Other (O)	Location and Description	Time Purged	Time Sampled
49	1		X		M DW FOUNTAIN OUTSIDE CAFE	1305	941
50	1		X		R DW FOUNTAIN OUTSIDE CAFE	1305	941
51	1		X		L DW FOUNTAIN OUTSIDE KITCHEN	1308	942
52	1		X		R DW FOUNTAIN OUTSIDE KITCHEN	1308	942
53	1	X			SINK OPPOSITE 52	1309	945
54				X	DISHWASHER LEFT OF 53	1309	945
55		X			SINK ACROSS FROM 54	1310	945
56		X			L SINK ACROSS 54	1310	945
57		X			M SINK ACROSS 54	1310	945
58		X			R SINK ACROSS 54	1310	945
59		X			SINK OPPOSITE 56-58	1310	948
60		X			SINKS LEFT OF 59	1312	948
61		X			SINK ACROSS FROM FREEZER	1312	948
62		X			SINK OPPOSITE 61	1312	948
63		X			SINK RIGHT OF 64	1312	948
64				X	COMBI OVEN	1313	950
65		X			SINK/SPRAYER LEFT OF COMBI OVEN	1313	950

**ATTACHMENT C**

---

**Sunset Valley Elementary  
Summary Table**

**Summary Table  
Sunset Valley Elementary**

Sample ID	Date	Analyte	Result	Unit	Reporting Limit
SVEISK1	7/26/2023	Lead	ND	µg/L	1
SVEISK2	7/26/2023	Lead	1.2	µg/L	1
SVEISK3	7/26/2023	Lead	ND	µg/L	1
SVEISK4	7/26/2023	Lead	ND	µg/L	1
SVEIO5	7/26/2023	Lead	ND	µg/L	1
SVEIO6	7/26/2023	Lead	1.5	µg/L	1
SVEIDF7	7/26/2023	Lead	ND	µg/L	1
SVEIDF8	7/26/2023	Lead	ND	µg/L	1
SVEISK9	7/26/2023	Lead	1.3	µg/L	1
SVEISK10	7/26/2023	Lead	ND	µg/L	1
SVEISK11	7/26/2023	Lead	ND	µg/L	1
SVEISK12	7/26/2023	Lead	ND	µg/L	1
SVEISK13	7/26/2023	Lead	ND	µg/L	1
SVEISK14	7/26/2023	Lead	ND	µg/L	1
SVEISK15	7/26/2023	Lead	ND	µg/L	1
SVEISK16	7/26/2023	Lead	ND	µg/L	1
SVEISK17	7/26/2023	Lead	3.2	µg/L	1
SVEIDF18	7/26/2023	Lead	ND	µg/L	1
SVEIDF19	7/26/2023	Lead	ND	µg/L	1
SVEIDF20	7/26/2023	Lead	ND	µg/L	1
SVEISK21	7/26/2023	Lead	ND	µg/L	1
SVEISK22	7/26/2023	Lead	ND	µg/L	1
SVEISK23	7/26/2023	Lead	2.0	µg/L	1
SVEISK24	7/26/2023	Lead	1.7	µg/L	1
SVEISK25	7/26/2023	Lead	ND	µg/L	1
SVEISK26	7/26/2023	Lead	3.0	µg/L	1
SVEISK27	7/26/2023	Lead	ND	µg/L	1
SVEISK28	7/26/2023	Lead	ND	µg/L	1
SVEISK29	7/26/2023	Lead	ND	µg/L	1
SVEISK30	7/26/2023	Lead	3.0	µg/L	1
SVEIDF31	7/26/2023	Lead	ND	µg/L	1
SVEIDF32	7/26/2023	Lead	ND	µg/L	1
SVEIDF33	7/26/2023	Lead	ND	µg/L	1
SVEISK34	7/26/2023	Lead	ND	µg/L	1
SVEISK35	7/26/2023	Lead	1.6	µg/L	1
SVEISK36	7/26/2023	Lead	ND	µg/L	1
SVEISK37	7/26/2023	Lead	1.5	µg/L	1
SVEISK38	7/26/2023	Lead	ND	µg/L	1
SVEISK39	7/26/2023	Lead	ND	µg/L	1
SVEISK40	7/26/2023	Lead	2.9	µg/L	1
SVEISK41	7/26/2023	Lead	ND	µg/L	1
SVEISK42	7/26/2023	Lead	ND	µg/L	1
SVEISK43	7/26/2023	Lead	ND	µg/L	1

SVEISK44	7/26/2023	Lead	ND	µg/L	1
SVEISK45	7/26/2023	Lead	<b>1.6</b>	µg/L	1
SVEISK46	7/26/2023	Lead	ND	µg/L	1
SVEISK47	7/26/2023	Lead	<b>1.4</b>	µg/L	1
SVEIDF48	7/26/2023	Lead	ND	µg/L	1
SVEIDF49	7/26/2023	Lead	ND	µg/L	1
SVEIDF50	7/26/2023	Lead	ND	µg/L	1
SVEIDF51	7/26/2023	Lead	ND	µg/L	1
SVEIDF52	7/26/2023	Lead	ND	µg/L	1
SVEISK53	7/26/2023	Lead	<b>5.6</b>	µg/L	1
SVEIO54	7/26/2023	Lead	<b>2.1</b>	µg/L	1
SVEISK55	7/26/2023	Lead	ND	µg/L	1
SVEISK56	7/26/2023	Lead	<b>11.5</b>	µg/L	1
SVEISK57	7/26/2023	Lead	<b>1.3</b>	µg/L	1
SVEISK58	7/26/2023	Lead	ND	µg/L	1
SVEISK59	7/26/2023	Lead	<b>1.9</b>	µg/L	1
SVEISK60	7/26/2023	Lead	ND	µg/L	1
SVEISK61	7/26/2023	Lead	ND	µg/L	1
SVEISK62	7/26/2023	Lead	ND	µg/L	1
SVEISK63	7/26/2023	Lead	ND	µg/L	1
SVEIO64	7/26/2023	Lead	<b>8.3</b>	µg/L	1
SVEISK65	7/26/2023	Lead	<b>9.7</b>	µg/L	1

µg/L: micrograms per liter

Bolded results indicate detections above reporting limit

**ATTACHMENT D**

---

**Sunset Valley Elementary  
Laboratory Analytical Report**



September 14, 2023

Lindsay E. James  
Blackstone Environmental, Inc.  
16200 Foster Street  
Overland Park, KS 66085  
TEL: (913) 956-4160  
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

**RE:** Lees Summit School Dist DW Sunset Valley Elem.

**WorkOrder:** 23071996

Dear Lindsay E. James:

TEKLAB, INC received 65 samples on 7/28/2023 11:32:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley  
Project Manager  
(618)344-1004 ex 44  
[patrickriley@teklabinc.com](mailto:patrickriley@teklabinc.com)



## Report Contents

<http://www.teklabinc.com/>

---

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071996

**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.

**Report Date:** 14-Sep-23

---

**This reporting package includes the following:**

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	72
Chain of Custody	Appended

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071996

**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.

**Report Date:** 14-Sep-23

### Abbr Definition

\* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071996

**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.

**Report Date:** 14-Sep-23

### Qualifiers

- # - Unknown hydrocarbon
- C - RL shown is a Client Requested Quantitation Limit
- H - Holding times exceeded
- J - Analyte detected below quantitation limits
- ND - Not Detected at the Reporting Limit
- S - Spike Recovery outside recovery limits
- X - Value exceeds Maximum Contaminant Level
- B - Analyte detected in associated Method Blank
- E - Value above quantitation range
- I - Associated internal standard was outside method criteria
- M - Manual Integration used to determine area response
- R - RPD outside accepted recovery limits
- T - TIC(Tentatively identified compound)



## Case Narrative

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071996

**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.

**Report Date:** 14-Sep-23

**Cooler Receipt Temp:** NA °C

---

### Locations

#### Collinsville

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** jhriley@teklabinc.com

#### Collinsville Air

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** EHurley@teklabinc.com

#### Springfield

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415  
**Phone** (217) 698-1004  
**Fax** (217) 698-1005  
**Email** KKlostermann@teklabinc.com

#### Chicago

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515  
**Phone** (630) 324-6855  
**Fax**  
**Email** arenner@teklabinc.com

#### Kansas City

**Address** 8421 Nieman Road  
Lenexa, KS 66214  
**Phone** (913) 541-1998  
**Fax** (913) 541-1998  
**Email** jhriley@teklabinc.com



## Accreditations

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071996

**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.

**Report Date:** 14-Sep-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2023	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-001  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEISK1  
**Collection Date:** 07/26/2023 8:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 15:49	210744



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-002

Client Sample ID: SVEISK2

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.2	µg/L	1	09/08/2023 15:53	210744





## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-003

Client Sample ID: SVEISK3

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:49

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 15:57	210744



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-004  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEISK4  
**Collection Date:** 07/26/2023 8:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 16:00	210744



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-005

Client Sample ID: SVEIO5

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 16:15	210744



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-006

Client Sample ID: SVEIO6

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.5	µg/L	5	09/13/2023 11:30	210837



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-007

Client Sample ID: SVEIDF7

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 16:18	210744



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-008

Client Sample ID: SVEIDF8

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 16:22	210744



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-009

Client Sample ID: SVEISK9

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.3	µg/L	1	09/08/2023 16:26	210744



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-010

Client Sample ID: SVEISK10

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 16:29	210744





# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-011  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEISK11  
**Collection Date:** 07/26/2023 8:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 16:33	210744



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-012

Client Sample ID: SVEISK12

Matrix: DRINKING WATER

Collection Date: 07/26/2023 8:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 16:44	210744



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-013

Client Sample ID: SVEISK13

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	5	09/13/2023 11:33	210837



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-014  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEISK14  
**Collection Date:** 07/26/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 16:48	210744



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-015

Client Sample ID: SVEISK15

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 17:02	210744



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071996

**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.

**Report Date:** 14-Sep-23

**Lab ID:** 23071996-016

**Client Sample ID:** SVEISK16

**Matrix:** DRINKING WATER

**Collection Date:** 07/26/2023 9:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 17:06	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-017

Client Sample ID: SVEISK17

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.2	µg/L	1	09/08/2023 17:10	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-018

Client Sample ID: SVEIDF18

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 17:13	210775





# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-019  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23

**Client Sample ID:** SVEIDF19  
**Collection Date:** 07/26/2023 9:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 17:24	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-020

Client Sample ID: SVEIDF20

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 17:28	210775



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-021

Client Sample ID: SVEISK21

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 17:32	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-022

Client Sample ID: SVEISK22

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/08/2023 17:35	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-023

Client Sample ID: SVEISK23

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.0	µg/L	1	09/11/2023 6:46	210775



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-024

Client Sample ID: SVEISK24

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:08

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.7	µg/L	1	09/11/2023 6:49	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-025

Client Sample ID: SVEISK25

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 6:53	210775



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-026  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEISK26  
**Collection Date:** 07/26/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.0	µg/L	5	09/13/2023 11:48	210837





# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-027

Client Sample ID: SVEISK27

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 6:57	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-028

Client Sample ID: SVEISK28

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:12

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 7:00	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-029

Client Sample ID: SVEISK29

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 7:04	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-030

Client Sample ID: SVEISK30

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		3.0	µg/L	1	09/11/2023 7:08	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-031

Client Sample ID: SVEIDF31

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 7:19	210775



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-032  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23

**Client Sample ID:** SVEIDF32  
**Collection Date:** 07/26/2023 9:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 8:36	210775



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-033

Client Sample ID: SVEIDF33

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 8:39	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-034

Client Sample ID: SVEISK34

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 8:43	210775





# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-035

Client Sample ID: SVEISK35

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.6	µg/L	1	09/11/2023 8:47	210775



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-036

Client Sample ID: SVEISK36

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 8:50	210776



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-037

Client Sample ID: SVEISK37

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:22

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.5	µg/L	1	09/11/2023 8:54	210776



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071996

**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.

**Report Date:** 14-Sep-23

**Lab ID:** 23071996-038

**Client Sample ID:** SVEISK38

**Matrix:** DRINKING WATER

**Collection Date:** 07/26/2023 9:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 8:58	210776



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-039  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEISK39  
**Collection Date:** 07/26/2023 9:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 9:01	210776



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-040

Client Sample ID: SVEISK40

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.9	µg/L	5	09/13/2023 11:52	210837



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-041

Client Sample ID: SVEISK41

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:26

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 9:23	210776



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-042  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEISK42  
**Collection Date:** 07/26/2023 9:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 9:27	210776





# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-043  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEISK43  
**Collection Date:** 07/26/2023 9:32

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 9:31	210776



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-044

Client Sample ID: SVEISK44

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 9:34	210776



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071996

**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.

**Report Date:** 14-Sep-23

**Lab ID:** 23071996-045

**Client Sample ID:** SVEISK45

**Matrix:** DRINKING WATER

**Collection Date:** 07/26/2023 9:35

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.6	µg/L	1	09/11/2023 9:38	210776



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071996

**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.

**Report Date:** 14-Sep-23

**Lab ID:** 23071996-046

**Client Sample ID:** SVEISK46

**Matrix:** DRINKING WATER

**Collection Date:** 07/26/2023 9:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 9:42	210776



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-047

Client Sample ID: SVEISK47

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:38

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.4	µg/L	1	09/11/2023 9:45	210776



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-048

Client Sample ID: SVEIDF48

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:41

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 9:49	210776



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-049

Client Sample ID: SVEIDF49

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:41

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 9:52	210776



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071996

**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.

**Report Date:** 14-Sep-23

**Lab ID:** 23071996-050

**Client Sample ID:** SVEIDF50

**Matrix:** DRINKING WATER

**Collection Date:** 07/26/2023 9:41

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 10:07	210776





# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-051  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEIDF51  
**Collection Date:** 07/26/2023 9:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 10:11	210776



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-052

Client Sample ID: SVEIDF52

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:42

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 10:22	210776



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-053

Client Sample ID: SVEISK53

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		5.6	µg/L	5	09/13/2023 11:55	210837



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-054  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEIO54  
**Collection Date:** 07/26/2023 9:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.1	µg/L	1	09/11/2023 10:25	210776



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.

**Work Order:** 23071996

**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.

**Report Date:** 14-Sep-23

**Lab ID:** 23071996-055

**Client Sample ID:** SVEISK55

**Matrix:** DRINKING WATER

**Collection Date:** 07/26/2023 9:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 10:29	210776



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-056  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEISK56  
**Collection Date:** 07/26/2023 9:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		11.5	µg/L	5	09/13/2023 11:59	210837



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-057

Client Sample ID: SVEISK57

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.3	µg/L	1	09/11/2023 10:33	210777



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-058

Client Sample ID: SVEISK58

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:45

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 10:36	210777





# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-059  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEISK59  
**Collection Date:** 07/26/2023 9:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.9	µg/L	1	09/11/2023 10:40	210777



## Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-060

Client Sample ID: SVEISK60

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 10:55	210777



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-061

Client Sample ID: SVEISK61

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 11:06	210777



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-062

Client Sample ID: SVEISK62

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 11:09	210777



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-063  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEISK63  
**Collection Date:** 07/26/2023 9:48

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	09/11/2023 11:13	210777



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Blackstone Environmental, Inc.  
**Client Project:** Lees Summit School Dist DW Sunset Valley Elem.  
**Lab ID:** 23071996-064  
**Matrix:** DRINKING WATER

**Work Order:** 23071996  
**Report Date:** 14-Sep-23  
**Client Sample ID:** SVEIO64  
**Collection Date:** 07/26/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		8.3	µg/L	5	09/11/2023 12:12	210907



# Laboratory Results

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Lab ID: 23071996-065

Client Sample ID: SVEISK65

Matrix: DRINKING WATER

Collection Date: 07/26/2023 9:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		9.7	µg/L	5	09/11/2023 12:34	210907



# Receiving Check List

<http://www.teklabinc.com/>

Client: Blackstone Environmental, Inc.

Work Order: 23071996

Client Project: Lees Summit School Dist DW Sunset Valley Elem.

Report Date: 14-Sep-23

Carrier: Crossroads

Received By: CET

Completed by:

*Allison Colin*

Reviewed by:

*Ellie Hopkins*

On:

31-Jul-23

Allison Colin

On:

31-Jul-23

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

- Shipping container/cooler in good condition? Yes  No  Not Present  Temp °C **NA**
- Type of thermal preservation? None  Ice  Blue Ice  Dry Ice
- Chain of custody present? Yes  No
- Chain of custody signed when relinquished and received? Yes  No
- Chain of custody agrees with sample labels? Yes  No
- Samples in proper container/bottle? Yes  No
- Sample containers intact? Yes  No
- Sufficient sample volume for indicated test? Yes  No
- All samples received within holding time? Yes  No
- Reported field parameters measured: Field  Lab  NA
- Container/Temp Blank temperature in compliance? Yes  No

*When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.*

- Water – at least one vial per sample has zero headspace? Yes  No  No VOA vials
- Water - TOX containers have zero headspace? Yes  No  No TOX containers
- Water - pH acceptable upon receipt? Yes  No  NA
- NPDES/CWA TCN interferences checked/treated in the field? Yes  No  NA

**Any No responses must be detailed below or on the COC.**

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.



# CHAIN OF CUSTODY

pg. 1 of 7 Work order # 23071946

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.  
 Address: 16200 Foster Street  
 City / State / Zip: Overland Park, KS 66085  
 Contact: Lindsay E. James (913) 495-9990  
 E-Mail: james@blackstone-env.com

Samples on:  ICE  BLUE ICE  NO ICE NA °C LTG#  
 Preserved in:  LAB  FIELD FOR LAB USE ONLY  
 Lab Notes

Client Comments:  
Sunset Valley Elem

Project Name/Number: ee's Summit School Dist. DW  
 Sample Collector's Name: RS & RB

Results Requested:  Standard  1-2 Day (100% Surcharge)  Other  3 Day (50% Surcharge)

Billing Instructions:  Yes  No  
 Yes  No

Lab Use Only	Sample Identification	Date/Time Sampled	# and Type of Containers							
23071946 001	SVE/SK1	7/26/23 845	OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES
002	SVE/SK2	845								
003	SVE/SK3	849								
004	SVE/SK4	850								
005	SVE/SK5	850								
006	SVE/SK6	850								
007	SVE/SK7	855								
008	SVE/SK8	855								
009	SVE/SK9	857								
010	SVE/SK10	857								

MATRIX	INDICATE ANALYSIS REQUESTED										
Drinking Water	X	X	X	X	X	X	X	X	X	X	X
Aqueous											
Groundwater											
Special Waste											
Sludge											
Soil											
DW Lead	X	X	X	X	X	X	X	X	X	X	X

Relinquished By: [Signature] Date/Time: 7/26/23 1700  
 Received By: [Signature] Date/Time: 7/28/23 1322

# CHAIN OF CUSTODY

pg. 2 of 7 Work order # Z3071996

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Blackstone Environmental, Inc.  
 Address: 16200 Foster Street  
 City / State / Zip: Overland Park, KS 66085  
 Contact: Lindsay E. James (913) 495-9990  
 E-Mail: ljames@blackstone-env.com

Samples on:  ICE  BLUE ICE  NO ICE  °C  LTG#  
 Preserved in:  LAB  FIELD **FOR LAB USE ONLY**  
 Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section.  Yes  No

*Sunset Valley Elem*

Project Name/Number		Sample Collector's Name		INDICATE ANALYSIS REQUESTED																	
Lee's Summit School Dist. DW		RS + RD		Billing Instructions		Date/Time Sampled		Matrix		Groundwater		Special Waste		Sludge		Soil		Drinking Water		Aqueous	
Lab Use Only	Results Requested	Sample Identification	Date/Time Sampled	# and Type of Containers																Date/Time	
	Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) Other <input type="checkbox"/> 3 Day (50% Surcharge)			OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES										
011	SVE   SK11		7/20/23 857									X						X			7/27/23 1400
012	SVE   SK12		857									X						X			7/28/23 1122
013	SVE   SK13		900									X						X			
014	SVE   SK14		900									X						X			
015	SVE   SK15		900									X						X			
016	SVE   SK16		900									X						X			
017	SVE   SK17		905									X						X			
018	SVE   DF18		905									X						X			
019	SVE   DF19		905									X						X			
020	SVE   DF20		905									X						X			
Relinquished By		Date/Time		Received By		Date/Time															
<i>[Signature]</i>		7/26/23 1700		<i>[Signature]</i>		7/27/23 1400															
<i>[Signature]</i>		7/27/23 1600		<i>[Signature]</i>		7/28/23 1122															

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

**Client:** Blackstone Environmental, Inc.  
**Address:** 16200 Foster Street  
**City / State / Zip:** Overland Park, KS 66085  
**Contact:** Lindsay E. James Phone: (913) 495-9990  
**E-Mail:** ljames@blackstone-env.com Fax:

Samples on:  ICE  BLUE ICE  NO ICE  °C  LTG#  
 Preserved in:  LAB  FIELD **FOR LAB USE ONLY**  
 Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section.  Yes  No

SUNSET VALLEY ELEMENTARY

**Project Name/Number:** Lee's Summit School Dist. DW  
**Sample Collector's Name:** PS + BS

**Results Requested:**  Standard  1-2 Day (100% Surcharge)  Other  3 Day (50% Surcharge)  
**Billing Instructions:** **# and Type of Containers:** OTHER, NaHSO4, MeOH, HCL, H2SO4, NaOH, HNO3, UNPRES

MATRIX		INDICATE ANALYSIS REQUESTED													
Drinking Water	Aqueous	Soil	Sludge	Special Waste	Groundwater	DW Lead									
X	X					X									
X	X					X									
X	X					X									
X	X					X									
X	X					X									
X	X					X									
X	X					X									
X	X					X									

Lab Use Only	Sample Identification	Date/Time Sampled	Date/Time	Received By	Date/Time
23071996 021	SVE1SK21	7/20/23 908	7/26/23 1700	[Signature]	7/27/23 1400
022	SVE1SK22	908	7/27/23 1600	[Signature]	7-28-23 1632
023	SVE1SK23	908			
024	SVE1SK24	908			
025	SVE1SK25	912			
026	SVE1SK26	912			
027	SVE1SK27	912			
028	SVE1SK28	912			
029	SVE1SK29	915			
030	SVE1SK30	918			

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005


Samples on:  ICE  BLUE ICE  NO ICE  °C LTG# \_\_\_\_\_  
 Preserved in:  LAB  FIELD **FOR LAB USE ONLY**  
 Lab Notes \_\_\_\_\_  
 Client Comments: \_\_\_\_\_

Blackstone Environmental, Inc.  
 16200 Foster Street  
 Overland Park, KS 66085  
 Contact: Lindsay E. James Phone: (913) 495-9990  
 E-Mail: ljames@blackstone-env.com Fax: \_\_\_\_\_  
 Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section.  Yes  No

Project Name/Number Lee's Summit School Dist. DW		Sample Collector's Name RS - BB	INDICATE ANALYSIS REQUESTED							
Results Requested <input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions	MATRIX							
Lab Use Only	Sample Identification	Date/Time Sampled	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW Lead		
031	SVE/DF31	7/26/23 918	X					X		
032	SVE/DF32	918	X					X		
033	SVE/DF33	918	X					X		
034	SVE/SK34	922	X					X		
035	SVE/SK35	922	X					X		
036	SVE/SK36	922	X					X		
037	SVE/SK37	922	X					X		
038	SVE/SK38	926	X					X		
039	SVE/SK39	926	X					X		
040	SVE/SK40	926	X					X		
Relinquished By _____			Received By _____				Date/Time			
							7/26/23 1700			
							7/27/23 1400			
							7/27/23 1600			

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000



# CHAIN OF CUSTODY

pg. 5 of 7 Work order # Z5071996

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

**Client:** Blackstone Environmental, Inc.  
**Address:** 16200 Foster Street  
 Overland Park, KS 66085  
**City / State / Zip:**  
**Contact:** Lindsay E. James (913) 495-9990  
**E-Mail:** ljames@blackstone-env.com

Samples on:  ICE  BLUE ICE  NO ICE  °C  LTG#  
 Preserved in:  LAB  FIELD **FOR LAB USE ONLY**

Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section.  Yes  No

*Sunset Valley ELEM*

**Project Name/Number:** Lee's Summit School Dist. DW  
**Sample Collector's Name:** RS-BB  
**Results Requested:**  Standard  1-2 Day (100% Surcharge)  Other  3 Day (50% Surcharge)

Matrix	INDICATE ANALYSIS REQUESTED									
	Drinking Water Aqueous	Soil	Sludge	Special Waste	Groundwater	DW Lead				
X	X	X	X	X	X	X				
X	X	X	X	X	X	X				
X	X	X	X	X	X	X				
X	X	X	X	X	X	X				
X	X	X	X	X	X	X				
X	X	X	X	X	X	X				
X	X	X	X	X	X	X				

Lab Use Only	Sample Identification	Date/Time Sampled	# and Type of Containers							
			UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER
23071996 041	SVE1SK41	7/20/23 926								
042	SVE1SK42	932								
043	SVE1SK43	932								
044	SVE1SK44	938								
045	SVE1SK45	935								
046	SVE1SK46	938								
047	SVE1SK47	938								
048	SVE1DF48	941								
049	SVE1DF49	941								
050	SVE1DF50	941								

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7/26/23 1700	<i>[Signature]</i>	7/27/23 1400
<i>[Signature]</i>	7/27/23 1600	<i>[Signature]</i>	7/28/23 1132

# CHAIN OF CUSTODY

pg. 6 of 7 Work order # 23071996

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

**Client:** Blackstone Environmental, Inc.  
**Address:** 16200 Foster Street  
 Overland Park, KS 66085  
**City / State / Zip:** \_\_\_\_\_  
**Contact:** Lindsay E. James (913) 495-9990  
**E-Mail:** ljames@blackstone-env.com  
**Phone:** \_\_\_\_\_  
**Fax:** \_\_\_\_\_

**Samples on:**  ICE  BLUE ICE  NO ICE  °C  LTG# \_\_\_\_\_  
**Preserved in:**  LAB  FIELD **FOR LAB USE ONLY**  
**Lab Notes:** \_\_\_\_\_

**Client Comments:**

*Sunset Valley Elem*

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section.  Yes  No

**Project Name/Number:** Lee's Summit School Dist. DW  
**Sample Collector's Name:** JS + BB

Project Name/Number	Sample Collector's Name	Billing Instructions	Date/Time Sampled	# and Type of Containers										INDICATE ANALYSIS REQUESTED				
				OTHER	NaHSO4	MeOH	HCL	H2SO4	NaOH	HNO3	UNPRES	Drinking Water	Aqueous	Sludge	Special Waste	Groundwater	DW Lead	Received By
23071996 051	SVE/DF51		7/26/23 942												X	<i>[Signature]</i>	7/27/23 1400	
052	SVE/DF52		942												X			
053	SVE/SK53		945												X			
054	SVE/OS4		945												X			
055	SVE/SK55		945												X			
056	SVE/SK56		945												X			
057	SVE/SK57		945												X			
058	SVE/SK58		945												X			
059	SVE/SK59		948												X			
060	SVE/SK60		948												X			
<b>Relinquished By:</b> <i>[Signature]</i>				<b>Date/Time:</b> 7/26/23 1700				<b>Received By:</b> <i>[Signature]</i>				<b>Date/Time:</b> 7/27/23 1600						
<b>Relinquished By:</b> <i>[Signature]</i>				<b>Date/Time:</b> 7/27/23 1600				<b>Received By:</b> <i>[Signature]</i>				<b>Date/Time:</b> 7/28/23 1132						

# CHAIN OF CUSTODY

pg. 7 of 7 Work order # 23071996

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

**Client:** Blackstone Environmental, Inc.  
**Address:** 16200 Foster Street  
**City / State / Zip:** Overland Park, KS 66085  
**Contact:** Lindsay E. James (913) 495-9990  
**E-Mail:** ljames@blackstone-env.com

Samples on:  ICE  BLUE ICE  NO ICE  °C  LTG#  
 Preserved in:  LAB  FIELD **FOR LAB USE ONLY**  
**Lab Notes**

**Client Comments:**

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section.  Yes  No

Sweet Valley Glen

**Project Name/Number:** Lee's Summit School Dist. DW  
**Sample Collector's Name:** RS + BB

**MATRIX:** Drinking Water, Groundwater, Special Waste, Sludge, Soil, Aqueous

**INDICATE ANALYSIS REQUESTED**

**Results Requested:**  Standard  1-2 Day (100% Surcharge)  Other  3 Day (50% Surcharge)  
**Billing Instructions:**  
**# and Type of Containers:** OTHER, NaHSO4, MeOH, HCL, H2SO4, NaOH, HNO3, UNPRES

Lab Use Only	Sample Identification	Date/Time Sampled	Drinking Water	Groundwater	Special Waste	Sludge	Soil	Aqueous	DW Lead
23071996 001	SVE/SK61	7/26/23 948	X	X					X
002	SVE/SK62	948	X	X					X
003	SVE/SK63	948	X	X					X
004	SVE/1064	950	X	X					X
005	SVE/SK65	950	X	X					X

**Relinquished By:** [Signature] **Date/Time:** 7/26/23 1700  
**Received By:** [Signature] **Date/Time:** 7/27/23 1600

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

Bottle Order: 82000

