

1005 BOSTON POST ROAD
MADISON, CT 06443
Phone 203-245-0568
FAX 203-318-0830
Connecticut Certification PH-0535
www.eclinonline.com



ENVIRONMENTAL
CONSULTING LABORATORIES, INC.

Report of Analysis

Name: Amity Regional School District #5
25 Newton Road
Woodbridge, CT 06525
Attn: Steve Martoni

Sample Date: 2/2/2023
Receipt Date: 2/2/2023
Report Date: 2/7/2023
Sample Site: 3

Sample ID#: 155239
Sample Type: Water
Sample Source: Kitchen
Sampler: ECL - ST
PWS ID: CT0080162

RECEIVED
By Tracy Daigle at 11:09 am, Feb 08, 2023

Parameter	Sample Result	Units	Method	MDL	Analysis Date	Analyst
Volatile Organic Compounds						
001V - Benzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
005V - Bromobenzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
010V - Bromomethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
015V - n-Butyl Benzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
020V - Carbon Tetrachloride	ND	mg/L	524.2	0.0005	2/6/2023	CET
025V - Chlorobenzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
030V - Chloroethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
035V - Chloromethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
040V - o-Chlorotoluene	ND	mg/L	524.2	0.0005	2/6/2023	CET
045V - p-Chlorotoluene	ND	mg/L	524.2	0.0005	2/6/2023	CET
050V - Dibromomethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
055V - 1,3-Dichlorobenzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
060V - 1,4-Dichlorobenzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
065V - 1,2-Dichlorobenzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
070V - 1,1-Dichloroethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
075V - 1,2-Dichloroethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
080V - 1,1-Dichloroethylene	ND	mg/L	524.2	0.0005	2/6/2023	CET
085V - Cis-1,2-Dichloroethylene	ND	mg/L	524.2	0.0005	2/6/2023	CET
090V - Trans-1,2-Dichloroethylene	ND	mg/L	524.2	0.0005	2/6/2023	CET
095V - Methylene Chloride	ND	mg/L	524.2	0.0005	2/6/2023	CET
100V - 1,2-Dichloropropane	ND	mg/L	524.2	0.0005	2/6/2023	CET
105V - 1,3-Dichloropropane	ND	mg/L	524.2	0.0005	2/6/2023	CET
110V - 2,2-Dichloropropane	ND	mg/L	524.2	0.0005	2/6/2023	CET
115V - 1,1-Dichloropropene	ND	mg/L	524.2	0.0005	2/6/2023	CET
118V - 1,3 Dichloropropene	ND	mg/L	524.2	0.0005	2/6/2023	CET

ND = Not Detected

1005 BOSTON POST ROAD
MADISON, CT 06443
Phone 203-245-0568
FAX 203-318-0830
Connecticut Certification PH-0535
www.eclinonline.com



Report of Analysis

Name: Amity Regional School District #5
25 Newton Road
Woodbridge, CT 06525
Attn: Steve Martoni

Sample ID#: 155239
Sample Type: Water
Sample Source: Kitchen
Sampler: ECL - ST
PWS ID: CT0080162

Sample Date: 2/2/2023
Receipt Date: 2/2/2023
Report Date: 2/7/2023
Sample Site: 3

Parameter	Sample Result	Units	Method	MDL	Analysis Date	Analyst
Volatile Organic Compounds						
120V - Ethylbenzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
125V - Methyl Tert Butyl Ether	ND	mg/L	524.2	0.002	2/6/2023	CET
130V - Naphthalene	ND	mg/L	524.2	0.0005	2/6/2023	CET
135V - n-Propyl Benzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
140V - Styrene	ND	mg/L	524.2	0.0005	2/6/2023	CET
145V - 1,1,1,2-Tetrachloroethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
150V - 1,1,2,2-Tetrachloroethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
155V - Tetrachloroethylene	ND	mg/L	524.2	0.0005	2/6/2023	CET
160V - Toluene	ND	mg/L	524.2	0.0005	2/6/2023	CET
165V - Bromodichloromethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
170V - Bromoform	ND	mg/L	524.2	0.0005	2/6/2023	CET
175V - Chlorodibromomethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
180V - Chloroform	ND	mg/L	524.2	0.0005	2/6/2023	CET
185V - 1,1,1-Trichloroethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
190V - 1,1,2-Trichloroethane	ND	mg/L	524.2	0.0005	2/6/2023	CET
195V - 1,2,4-Trichlorobenzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
200V - Trichlorethylene	ND	mg/L	524.2	0.0005	2/6/2023	CET
205V - 1,2,3-Trichloropropane	ND	mg/L	524.2	0.0005	2/6/2023	CET
210V - 1,2,4-Trimethylbenzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
215V - 1,3,5-Trimethylbenzene	ND	mg/L	524.2	0.0005	2/6/2023	CET
217V - Vinyl Chloride	ND	mg/L	524.2	0.0005	2/6/2023	CET
221V - Xylene, Meta	ND	mg/L	524.2	0.0005	2/6/2023	CET
222V - Xylene, Ortho	ND	mg/L	524.2	0.0005	2/6/2023	CET
224V - Xylene, Para	ND	mg/L	524.2	0.0005	2/6/2023	CET

DAVID BARRIS - LABORATORY DIRECTOR

JORDAN BARRIS - CO-DIRECTOR

ND = Not Detected

Comments CET - CT PH-0116.

