

1005 BOSTON POST ROAD  
 MADISON, CT 06443  
 Phone 203-245-0568  
 FAX 203-318-0830  
 Connecticut Certification PH-0535  
 www.eclinonline.com



**ENVIRONMENTAL**  
 CONSULTING LABORATORIES, INC.

## Report of Analysis

<b>Name:</b>	Amity Regional School District #5 25 Newton Road Woodbridge, CT 06525 Attn: Steve Martoni	<b>Sample ID#:</b>	158774
		<b>Sample Type:</b>	Drinking Water
		<b>Sample Source:</b>	Bethany Middle School - Kitchen Sink
		<b>Sampler:</b>	ECL - ST
<b>Sample Date:</b>	5/25/2023	<b>PWS ID:</b>	CT0080162
<b>Receipt Date:</b>	5/25/2023		
<b>Report Date:</b>	5/30/2023		
<b>Sample Site:</b>	KITCHEN		

Parameter	Sample Result	Units	Method	MDL	Analysis Date	Analyst
<b>Biological</b>						
Coliform, E. Coli	ABSENT	P/A	Colilert-18	0	5/25/2023	JB
Coliform, Total	ABSENT	P/A	Colilert-18	0	5/25/2023	JB
<b>Chemical</b>						
Chlorine- Residual, Total	ND	mg/L	SM4500-Cl G	0.02	5/25/2023	ST

DAVID BARRIS - LABORATORY DIRECTOR

JORDAN BARRIS - CO-DIRECTOR

ND = Not Detected

1005 BOSTON POST ROAD  
 MADISON, CT 06443  
 Phone 203-245-0568  
 FAX 203-318-0830  
 Connecticut Certification PH-0535  
 www.eclinconline.com



**ENVIRONMENTAL**  
 CONSULTING LABORATORIES, INC.

### Report of Analysis

**Name:** Amity Regional School District #5  
 25 Newton Road  
 Woodbridge, CT 06525  
 Attn: Steve Martoni

**Sample ID#:** 158775  
**Sample Type:** Drinking Water  
**Sample Source:** Bethany Middle School - Kitchen Sink  
**Sampler:** ECL - ST  
**PWS ID:** CT0080162

**Sample Date:** 5/25/2023  
**Receipt Date:** 5/25/2023  
**Report Date:** 5/26/2023  
**Sample Site:** KITCHEN

Parameter	Sample Result	Units	Method	MDL	Analysis Date	Analyst
<b>Physical</b>						
Color	ND	CU	SM2120B	1	5/25/2023	JB
Odor	ND	TON	SM2150B	1	5/25/2023	JB
PH	7.96	pH	EPA 150.2	1	5/25/2023	JB
Turbidity	0.55	NTU	180.1	0.05	5/25/2023	JB

DAVID BARRIS - LABORATORY DIRECTOR

JORDAN BARRIS - CO-DIRECTOR

ND = Not Detected

