



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410  
PH (973) 636-9145 FAX (973) 636-9144  
Email: [Envirovision@optonline.net](mailto:Envirovision@optonline.net)

CLIENT: Park Ridge School District Project Number 21-413  
PROJECT: Lead (Pb) in Water Sampling East Brook Elementary School  
ADDRESS: 167 Sibbald Drive, Park Ridge NJ 07656  
FIELD TECHNICIANS: Jordan Pryske REPORT DATE: November 4, 2021

As per your request, EnviroVision Consultants, Inc. was contracted by Park Ridge School District to conduct Lead (Pb) in water sampling at the East Brook Elementary School on November 4, 2021. The sample locations, in addition to a unique sample location code was determined/assigned by school district personnel. The school district performed the proper flushing of outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

Samples were analyzed at Aqua Pro-Tech Laboratories in Fairfield, New Jersey \*(NJDEP# 07010), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Seven samples were taken as requested, including the required field blank. The sample locations were taken from the outlet inventory provided to EnviroVision Consultants prior to the sampling date.

Results: All of the samples analyzed were either "None Detected" or less than the EPA established threshold for lead in drinking water of 15 parts per billion (ppb). When a water outlet/faucet meets or exceeds the USEPA threshold, EnviroVision recommends that the outlet/faucet be immediately put out of service until the system can be further evaluated and proper remedial action is achieved.



Page 2 ( East Brook Elementary School)

Project Number 21-413

If you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,  
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager

Attached: Lab results, Associated data sheets,



AQUA PRO-TECH LABORATORIES  
Certified Environmental Testing



# ANALYTICAL RESULTS

## STANDARD DELIVERABLES FORMAT

APL WORK ORDER NUMBER: 1110258

EnviroVision Consultants, Inc.

Project: East Brook Elementary School

Brian Wood  
Laboratory Director

All Results meet the requirements of the National Environmental Laboratory Accreditation Conference and/or State specific certifications as applicable.

Report Date: Nov 23, 2021

1275 Bloomfield Ave., Bldg. 6, Fairfield, New Jersey 07004  
(t) 973.227.0422 (f) 973.227.2813 (w) www.aquaprotechlabs.com

NELAC National Environmental Laboratory Accreditation Conference  
NJDEP #07010 / NYDOH #11634



AQUA PRO-TECH LABORATORIES  
 Certified Environmental Testing

## Analytical Results Summary East Brook Elementary School

**Client:** EnviroVision Consultants, Inc.  
**APL Order ID:** 1110258

**Contact:** Cathy DiNardo  
**Received:** 11/04/21 11:05

Sample ID/Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
<b>1110258-01 (Drinking Water)</b>		EB-KC-KT		Collected:	11/04/21 08:36			
<b>Total Metals</b>								
Lead	EPA 200.8	11/22/21 20:03	11/22/21 20:03	1.00		0.137	2.00	ug/L
<b>1110258-02 (Drinking Water)</b>		EB-WC-BF1		Collected:	11/04/21 08:38			
<b>Total Metals</b>								
Lead	EPA 200.8	11/22/21 20:06	11/22/21 20:06	ND	U	0.137	2.00	ug/L
<b>1110258-03 (Drinking Water)</b>		EB-WC-BF2		Collected:	11/04/21 08:40			
<b>Total Metals</b>								
Lead	EPA 200.8	11/22/21 20:08	11/22/21 20:08	ND	U	0.137	2.00	ug/L
<b>1110258-04 (Drinking Water)</b>		EB-NS-N01		Collected:	11/04/21 08:42			
<b>Total Metals</b>								
Lead	EPA 200.8	11/22/21 20:10	11/22/21 20:10	1.47		0.137	2.00	ug/L
<b>1110258-05 (Drinking Water)</b>		EB-TL-01		Collected:	11/04/21 08:44			
<b>Total Metals</b>								
Lead	EPA 200.8	11/22/21 20:13	11/22/21 20:13	2.15		0.137	2.00	ug/L
<b>1110258-06 (Drinking Water)</b>		EB-WC-BF3		Collected:	11/04/21 08:46			
<b>Total Metals</b>								
Lead	EPA 200.8	11/22/21 20:15	11/22/21 20:15	ND	U	0.137	2.00	ug/L
<b>1110258-07 (Drinking Water)</b>		EB-Blank		Collected:	11/04/21 08:50			
<b>Total Metals</b>								
Lead	EPA 200.8	11/22/21 20:17	11/22/21 20:17	ND	U	0.137	2.00	ug/L

**FootNotes**

RL - Reporting limit  
 MDL - Minimum detection limit  
 ND, U - Indicates compound analyzed for but not detected  
 J - Indicates estimated value

B - Indicates compound found in associated blank  
 E - Concentration exceeds highest calibration standard  
 D - Indicates result is based on a dilution  
 P - Greater than 25% diff. between 2 GC columns.  
 H - Indicates a Hold Time violation

**APL 1110258**

AQUA PRO-TECH LABORATORIES



Building 6  
Fairfield, NJ 07004  
TEL: 973-227-0422  
FAX: 973-227-2813

Contamination Level

Low  
 Medium  
 High

**CHAIN OF CUSTODY**

Client: Environvision Consultants Inc Send Report To: Same  
 Address: 30-21 Wengrow Rd,  
 Phone: 973-636-9145  
 E-Mail: envision@optonline.net  
 Project Name: East Brook Elementary School  
 Project Manager: Cathy D. Nardo  
 Project of PO #: 21-413  
 Sampling Location: East Brook Elementary  
 Sampled By: Jordan Pysko

Turn-Around Time  
 APL Standard 2 Weeks  
 Rush (Choose One Below)  
 1 Day  
 2 Days  
 3 Days  
 1 Week  
 Other (Specify Below)

Date and Time Required: \_\_\_\_\_  
 \*\*May Need Lab Approval

Report / Electronic Format  
 Results Only / NY ASP-A  
 Reduced: NJ DEP  
 Full: NJ DEP / NY ASP-B  
 State Forms/EZ Reporting  
 Excel Summary  
 EQUIS  
 EnviroData  
 HazSite EDD

PWSID # \_\_\_\_\_ SRP# \_\_\_\_\_

Comments/Special Instructions:

Sample #	APL Order # (APL Will Provide)	Sample Source: Field ID	Matrix Abbreviations:				Matrix	Grab Comp	No. of Bottles	Preservative
			DB - Drinking Water	L - Lake	S - Soil	W - Wipes				
01	EB-KC-1KT		Pool SPA	01/14/21	0836	DW	✓	1	HNO3	
02	EB-WC-BF1		Pool SPA	11/14/21	0838	DW	✓	1	HNO3	
03	EB-WC-BF0		Pool SPA	11/14/21	0840	DW	✓	1	HNO3	
04	EB-NS-N01		Pool SPA	11/14/21	0842	DW	✓	1	HNO3	
05	EB-TL-01		Pool SPA	11/14/21	0844	DW	✓	1	HNO3	
06	EB-WC-BF3		Pool SPA	11/14/21	0846	DW	✓	1	HNO3	
07	EB-BLANK		Pool SPA	11/14/21	0850	DW	✓	1	HNO3	

ANALYSIS REQUESTED

Cooler Temp: 3.6

Lead in Drinking Water

RELINQUISHED BY: Jordan Pysko Print: Jordan Pysko Date: 11-14-2021  
 Sign: [Signature] Time: 10:55 AM  
 RECEIVED BY: [Signature] Print: [Signature] Date: 11-14-2021  
 Sign: [Signature] Time: 11:05 AM  
 RELINQUISHED BY: Jordan Pysko Print: Jordan Pysko Date: \_\_\_\_\_  
 Sign: \_\_\_\_\_ Time: \_\_\_\_\_  
 RECEIVED BY: \_\_\_\_\_ Print: \_\_\_\_\_ Date: \_\_\_\_\_  
 Sign: \_\_\_\_\_ Time: \_\_\_\_\_