

10 44 13 – Fire Protection Cabinets

DIVISION 10 – Specialties



STATEMENT OF PURPOSE & BACKGROUND

- Scope:
 - Selection and installation of cabinets for housing fire extinguishers.
- Statement of goals:
 - Provide a consistent, high quality cabinet that:
 - Is durable, safe and secure;
 - Is easily maintained.
- Revision history of section:
 - 06/15/18 (date of adoption)

OUTLINE SPECIFICATION

- Part 1 General
 - Quantities and locations of fire protection cabinets to be as indicated on Drawings and as required by all applicable building and fire codes.
 - Coordinate cabinet size with selected fire extinguishers.
 - Coordinate cabinet size, depth and location with wall depths.
- Part 2 Products
 - Acceptable Manufacturer(s):
 - JL Industries Inc.
 - Larsen's Manufacturing Co.
 - Nystrom Inc.
 - Potter Roemer LLC.
 - Equivalent manufacturers **approved, in writing, in advance, by the Architect**, may be substituted in accordance with the provisions of the Contract.
 - Cabinet Construction:
 - Nonrated.
 - Material: Cold rolled steel sheet, factory finished.
 - Shelf: Same material and finish as cabinet.
 - Style: Semi-Recessed Cabinet with one-piece combination trim and perimeter door frame overlapping surrounding wall surface with exposed trim face and wall return at outer edge.
 - Rolled-edge trim: 2-1/2" backbend depth.
 - Door style: Solid opaque panel with frame.
 - Hardware: Manufacturer's standard.
 - Door lock: Cam lock that allows door to be opened during emergency by pulling sharply on door handle.
 - Identification: Lettering complying with local authorities for style, size, spacing and location.
- Part 3 Execution
 - Per Consultant and / or manufacturer specification.
 - Provide blocking in walls as required for semi-recessed installation.
 - Install with top of cabinet at 54" AFF unless noted otherwise.

End of Section