

10 44 16 – Fire Extinguishers

DIVISION 10 - Specialties



STATEMENT OF PURPOSE & BACKGROUND

- Scope:
 - Selection of portable fire extinguishers and mounting brackets.
- Statement of goals:
 - Provide consistent, high quality products that comply with NFPA 10 and all other applicable standards for fire extinguishers.
- Revision history of section:
 - 06/15/2018 (date of adoption)

OUTLINE SPECIFICATION

- Part 1 General
 - Quantities and locations of fire extinguishers to be as indicated on drawings and as required by all applicable building and fire codes.
 - Coordinate selected fire extinguishers with proper cabinet sizes.
 - Refer to section 10 44 13 Fire Extinguisher Cabinets.
- Part 2 Products
 - Acceptable Manufacturer(s):
 - JL Industries Inc.
 - Larsen's Manufacturing Co.
 - Nystrom Inc.
 - Potter Roemer LLC
 - Kidde
 - Equivalent manufacturers **approved, in writing, in advance, by the Architect**, may be substituted in accordance with the provisions of the Contract.
 - Fire Extinguishers:
 - Multi-Purpose, Dry Chemical Type in steel container.
 - UL-Rated 4-A:60-B:C, 10-lb. nominal capacity, with monoammonium phosphate-based dry chemical in red enameled-steel container with pressure gauge.
 - Wet Chemical Type, Class K, 1.6 gallon (6 liter) in stainless steel container for kitchen and where required by code.
 - Brackets:
 - Formed steel, chrome-plated.
 - Identification:
 - Lettering complying with local authorities for style, size, spacing and location.
- Part 3 Execution
 - Per Consultant and / or manufacturer specification.
 - Install brackets with top of fire extinguisher at 54" AFF if not installed in fire extinguisher cabinets.

End of Section