

1157 Selby Avenue, Saint Paul, MN 55104

Chart C - All Materials List

The following list contains all events observed by the inspector, whether or not they actually contained asbestos, and are grouped by homogeneous area (material type).

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
K3A		Miscellaneous Flooring Epoxy Flooring -Red, Black, Gray, White (2021)				Total Amount - 700 Sq Ft
	1	THROUGHOUT BUILDING	NEW			700 Sq Ft
N0A		Drywall/Joint Compound Ceiling				Total Amount - 1175 Sq Ft
	4	GARAGE	<1 CH	041509ML-03	ML-03: ABOVE STORAGE.	750 Sq Ft
	5	OFFICE	<1 CH			350 Sq Ft
	6	RESTROOM	<1 CH			25 Sq Ft
	10	STORAGE WITH OUTSIDE ENTRANCE	<1 CH			50 Sq Ft
X0A		Miscellaneous Material Interior White Window Glazing				Total Amount - 7 Sq Ft
	2	GARAGE	2 CH	041509ML-01	ML-01: ABOVE STORAGE.	7 Sq Ft
X0B		Miscellaneous Material Interior Dark Window Glazing				Total Amount - 17 Sq Ft
	3	GARAGE	2 CH	041509ML-02		16 Sq Ft
	9	RESTROOM	2 CH			1 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
X1A		Miscellaneous Material 4" x 4" Pink Ceramic Wall Tile System				Total Amount - 90 Sq Ft
	7	RESTROOM	ASSUMED			90 Sq Ft
X1B		Miscellaneous Material 4" x 4" Blue Ceramic Floor Tile System				Total Amount - 25 Sq Ft
	8	RESTROOM	ASSUMED			25 Sq Ft