

Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

PLEASE NOTE: Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

| | | |
|-----------------------------------|--|--|
| EPA ASSESSMENT CATEGORIES: | 1 = Damaged or significantly damaged TSI ACM | 5 = ACBM with potential for damage |
| | 2 = Damaged friable surfacing ACM | 6 = ACBM with potential for significant damage |
| | 3 = Significantly damaged friable surfacing ACM | 7 = Remaining friable ACBM or friable suspect ACBM |
| | 4 = Damaged or significantly damaged friable miscellaneous ACM | |

| IEA Event No. | Material Type | Material Description/Id | Location | Estimated Amount Total | Friability | % of Asbestos | EPA Assess Category |
|-----------------------------|---------------|--|-------------------------------|------------------------|-----------------------|---------------|---------------------|
| 5 CAD #: | X0J | Miscellaneous Material Wired Window Glaze | THROUGHOUT BUILDING | 50 Sq Ft | N | 3 CH | 5 |
| Comments: | | | | | Sample #: 081012ML-02 | | |
| 8 CAD #: | P0A | Fire Doors Metal - 1.5 Hr Rating (Underwriter's Laboratories) | THROUGHOUT 1ST FLOOR HALLWAY | 160 Sq Ft | N | ASSUMED | 5 |
| Comments: EIGHT (8) DOORS. | | | | | Sample #: | | |
| 15 CAD #: | X0A | Miscellaneous Material Black Damp Proofing | ELEVATOR MECHANICAL ROOM 1203 | 2 Sq Ft | N | 15 CH | 5 |
| Comments: NORTH LOWER WALL. | | | | | Sample #: 020810ML-05 | | |
| 16 CAD #: | P0A | Fire Doors Metal - 1.5 Hr Rating (Underwriter's Laboratories) | ELEVATOR MECHANICAL ROOM 1203 | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: ONE (1) DOOR. | | | | | Sample #: | | |
| 19 CAD #: | X1A | Miscellaneous Material 6" X 6" Beige Ceramic Wall Tile System | BOYS' RESTROOM 1107 | 540 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 20 CAD #: | X1B | Miscellaneous Material 2" X 2" Tan Ceramic Floor Tile System | BOYS' RESTROOM 1107 | 168 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |

| IEA Event No. | Material Type | Material Description/Id | Location | Estimated Amount Total | Friability | % of Asbestos | EPA Assess Category |
|---|---------------|--|--------------------------|------------------------|------------|---------------|---------------------|
| 21 CAD #: | X1A | Miscellaneous Material 6" X 6" Beige Ceramic Wall Tile System | GIRLS' RESTROOM 1106 | 540 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 22 CAD #: | X1B | Miscellaneous Material 2" X 2" Tan Ceramic Floor Tile System | GIRLS' RESTROOM 1106 | 168 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 24 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 1105 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 25 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 1105 | 60 Sq Ft | N | ASSUMED | 5 |
| Comments: NORTH WALL BEHIND NEW CHALKBOARD. | | | | | Sample #: | | |
| 28 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 1104 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 31 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 1103 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 33 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 1103 | 5 Sq Ft | N | ASSUMED | 5 |
| Comments: NEAR SINK. | | | | | Sample #: | | |
| 35 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 1102 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 37 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 1102 | 2 Sq Ft | N | ASSUMED | 5 |
| Comments: NEAR ENTRANCE. | | | | | Sample #: | | |
| 39 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 1101 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 40 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 1101 | 10 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 41 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 1101 | 50 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 58 CAD #: | B2A | Millboard Pipe Insulation 1924 Addition | THROUGHOUT 1924 ADDITION | 40 Lin Ft | N | ASSUMED | 5 |
| Comments: ESTIMATED IN WALL CHASES. INACCESSIBLE. | | | | | Sample #: | | |
| 59 CAD #: | A2A | Mudded Pipe Joints on Millboard Insulation 1924 Addition | THROUGHOUT 1924 ADDITION | 8 Joints | N | ASSUMED | 5 |
| Comments: ESTIMATED IN WALL CHASES. INACCESSIBLE. | | | | | Sample #: | | |
| 62 CAD #: | X0I | Miscellaneous Material Wood Frame Chalkboard Adhesive (1924) | ROOM 1204 | 15 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 63 CAD #: | X0E | Miscellaneous Material Wood Frame Corkboard Adhesive (1924) | ROOM 1204 | 60 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |

| IEA Event No. | Material Type | Material Description/Id | Location | Estimated Amount Total | Friability | % of Asbestos | EPA Assess Category |
|---|---------------|--|---|------------------------|------------|---------------|---------------------|
| 64 CAD #: | S0B | Wood Floor Felt / Vapor Barrier 1924 Addition | ROOM 1204 | 350 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 66 CAD #: | S0B | Wood Floor Felt / Vapor Barrier 1924 Addition | ROOM 1208 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 67 CAD #: | X0I | Miscellaneous Material Wood Frame Chalkboard Adhesive (1924) | ROOM 1208 | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 68 CAD #: | X0E | Miscellaneous Material Wood Frame Corkboard Adhesive (1924) | ROOM 1208 | 230 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 72 CAD #: | S0B | Wood Floor Felt / Vapor Barrier 1924 Addition | ROOM 1205 | 240 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 73 CAD #: | X0I | Miscellaneous Material Wood Frame Chalkboard Adhesive (1924) | ROOM 1205 | 5 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 74 CAD #: | X0E | Miscellaneous Material Wood Frame Corkboard Adhesive (1924) | ROOM 1205 | 30 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 77 CAD #: | R0C | Baseboard/Mopboard Adhesive 4" Dark Brown Baseboard | HALLWAY 1200B BETWEEN ROOMS 1206 & 1207 | 5 Sq Ft | N | ASSUMED | 5 |
| Comments: EAST SECTION OF HALLWAY. | | | | | Sample #: | | |
| 86 CAD #: | P0A | Fire Doors Metal - 1.5 Hr Rating (Underwriter's Laboratories) | NORTH ENTRY 1300D NEAR CUSTODIAL OFFICE | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: ONE (1) DOOR. | | | | | Sample #: | | |
| 87 CAD #: | P0C | Fire Doors Metal - 1.5 Hr Rating (Warnock Hersey) | NORTH ENTRY 1300D NEAR CUSTODIAL OFFICE | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: ONE (1) DOOR. | | | | | Sample #: | | |
| 91 CAD #: | D2A | Interior Boiler Insulation Interior Refractory | BOILER ROOM 1303 | 60 Sq Ft | N | ASSUMED | 5 |
| Comments: TWO (2) BOILERS. BOILER #2 REFRACTORY HAS CHIPPED PIECES. RECOMMEND SAMPLING DURING NON-HEATING SEASON. | | | | | Sample #: | | |
| 99 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | THROUGHOUT 2ND FLOOR HALLWAY | 5 Sq Ft | N | ASSUMED | 5 |
| Comments: NEAR MEDIA CENTER. | | | | | Sample #: | | |
| 100 CAD #: | P0A | Fire Doors Metal - 1.5 Hr Rating (Underwriter's Laboratories) | THROUGHOUT 2ND FLOOR HALLWAY | 80 Sq Ft | N | ASSUMED | 5 |
| Comments: FOUR (4) DOORS. | | | | | Sample #: | | |
| 101 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 2104 | 10 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 102 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 2104 | 60 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 103 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 2104 | 300 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |

| IEA Event No. | Material Type | Material Description/Id | Location | Estimated Amount Total | Friability | % of Asbestos | EPA Assess Category |
|------------------------------------|---------------|---|----------------------|------------------------|------------|---------------|---------------------|
| 105 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 2103 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 106 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 2103 | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 107 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 2103 | 230 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 108 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 2105 | 1200 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 111 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 2105 | 15 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 112 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 2105 | 60 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 115 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 2102 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 116 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 2102 | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 117 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 2102 | 230 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 119 CAD #: | X0K | Miscellaneous Material Stone Panel Adhesive | GIRLS' RESTROOM 2106 | 80 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 121 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 2101 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 122 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 2101 | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 123 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 2101 | 230 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 125 CAD #: | X0K | Miscellaneous Material Stone Panel Adhesive | BOYS' RESTROOM 2107 | 60 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 135 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | MEDIA CENTER 2208 | 1500 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. SOUTH END. | | | | | Sample #: | | |
| 136 CAD #: | S0B | Wood Floor Felt / Vapor Barrier 1924 Addition | MEDIA CENTER 2208 | 450 Sq Ft | N | ASSUMED | 5 |
| Comments: NORTH END. UNDER CARPET. | | | | | Sample #: | | |

| IEA Event No. | Material Type | Material Description/Id | Location | Estimated Amount Total | Friability | % of Asbestos | EPA Assess Category |
|---------------------------|---------------|--|------------------------------|------------------------|------------|---------------|---------------------|
| 140 CAD #: | X0I | Miscellaneous Material Wood Frame Chalkboard Adhesive (1924) | ROOM 2203 | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 141 CAD #: | X0E | Miscellaneous Material Wood Frame Corkboard Adhesive (1924) | ROOM 2203 | 80 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 143 CAD #: | S0B | Wood Floor Felt / Vapor Barrier 1924 Addition | ROOM 2203 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 144 CAD #: | S0B | Wood Floor Felt / Vapor Barrier 1924 Addition | SERVER ROOM 2207 | 90 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 159 CAD #: | P0A | Fire Doors Metal - 1.5 Hr Rating (Underwriter's Laboratories) | THROUGHOUT 3RD FLOOR HALLWAY | 80 Sq Ft | N | ASSUMED | 5 |
| Comments: FOUR (4) DOORS. | | | | | Sample #: | | |
| 175 CAD #: | R0C | Baseboard/Mopboard Adhesive 4" Dark Brown Baseboard | ROOM 3205 | 10 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 183 CAD #: | S0B | Wood Floor Felt / Vapor Barrier 1924 Addition | ROOM 3203 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 186 CAD #: | S0B | Wood Floor Felt / Vapor Barrier 1924 Addition | ROOM 3208 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 189 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 3209 | 250 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 193 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 3210 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 194 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 3210 | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 195 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 3210 | 230 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 198 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 3211 | 364 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 200 CAD #: | X0K | Miscellaneous Material Stone Panel Adhesive | BOYS' RESTROOM 3107 | 60 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 202 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 3101 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 203 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 3101 | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |

| IEA Event No. | Material Type | Material Description/Id | Location | Estimated Amount Total | Friability | % of Asbestos | EPA Assess Category |
|--|---------------|---|----------------------|------------------------|------------|---------------|---------------------|
| 204 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 3101 | 230 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 206 CAD #: | X0K | Miscellaneous Material Stone Panel Adhesive | GIRLS' RESTROOM 3106 | 80 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 208 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 3102 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 209 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 3102 | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 210 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 3102 | 230 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 212 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 3105 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 213 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 3105 | 5 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 214 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 3105 | 180 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 216 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 3103 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 217 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 3103 | 20 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 218 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 3103 | 230 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 220 CAD #: | S0A | Wood Floor Felt / Vapor Barrier 1922 Original Building | ROOM 3104 | 750 Sq Ft | N | ASSUMED | 5 |
| Comments: UNDER CARPET. | | | | | Sample #: | | |
| 221 CAD #: | X0B | Miscellaneous Material Wood Frame Chalkboard Adhesive (1922) | ROOM 3104 | 10 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 222 CAD #: | X0C | Miscellaneous Material Wood Frame Corkboard Adhesive (1922) | ROOM 3104 | 40 Sq Ft | N | ASSUMED | 5 |
| Comments: | | | | | Sample #: | | |
| 223 CAD #: | POD | Fire Doors Pieced Metal | LOWER LEVEL | 40 Sq Ft | N | ASSUMED | 5 |
| Comments: TWO (2) DOORS AT BOTTOM OF CENTER STAIRWELL. PAINTED BLUE. | | | | | Sample #: | | |