

1317 Charles Avenue, Saint Paul, MN 55104

**Chart C - All Materials List**

The following list contains all events observed by the inspector, whether or not they actually contained asbestos, and are grouped by homogeneous area (material type).

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
A4A		Mudded Pipe Joints on Fiberglass Insulation Foil-Wrapped				<b>Total Amount - 296 Joints</b>
	9	BOILER ROOM (1161)	NONE DETECTED	467-JJT-6		6 Joints
	16	TUNNEL UNDER MAIN HALLWAY	NONE DETECTED	100-M1A, M1B, M1C		120 Joints
	29	KITCHEN (1163)	NONE DETECTED			30 Joints
	34	KITCHEN STORAGE (1209)	NONE DETECTED			6 Joints
	37	KITCHEN OFFICE (1209C)	NONE DETECTED	467-JJT-26	ABOVE CEILING HATCH.	7 Joints
	40	KITCHEN CUSTODIAL CLOSET (1209A)	NONE DETECTED			3 Joints
	52	HALLWAY 1205	NONE DETECTED			8 Joints
	56	MECHANICAL ROOM (TE-1)	NONE DETECTED			15 Joints
	61	ROOM 1207	NONE DETECTED			8 Joints
	72	ROOM 1208A	NONE DETECTED			5 Joints
	74	ROOM 1208C (SPRINKLER VALVE ROOM)	NONE DETECTED			4 Joints
	142	SOUTHWEST CUSTODIAL CLOSET (1148)	NONE DETECTED			15 Joints

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	175	ROOM 0102	NONE DETECTED			10 Joints
	204	2ND FLOOR GIRLS' RESTROOM (2247)	NONE DETECTED			5 Joints
	206	CUSTODIAL ROOM (TA1)	NONE DETECTED			25 Joints
	209	PENTHOUSE OFF OF ROOM 2299D	NONE DETECTED			18 Joints
	214	2ND FLOOR BOYS' RESTROOM	NONE DETECTED			11 Joints
<b>A4B</b>	<b>Mudded Pipe Joints on Fiberglass Insulation Canvas-Wrapped</b>					<b>Total Amount - 175 Joints</b>
	10	BOILER ROOM (1161)	NONE DETECTED	509-Q-7P, 8P		120 Joints
	30	KITCHEN (1163)	NONE DETECTED			2 Joints
	35	KITCHEN STORAGE (1209)	NONE DETECTED			2 Joints
	41	KITCHEN CUSTODIAL CLOSET (1209A)	NONE DETECTED			3 Joints
	53	HALLWAY 1205	NONE DETECTED			23 Joints
	57	MECHANICAL ROOM (TE-1)	NONE DETECTED	467-JJT-22	TOP OF THE LADDER.	11 Joints
	62	ROOM 1207	NONE DETECTED			2 Joints
	73	ROOM 1208A	NONE DETECTED			4 Joints
	75	ROOM 1208C (SPRINKLER VALVE ROOM)	NONE DETECTED			2 Joints
	207	CUSTODIAL ROOM 2299D	NONE DETECTED			2 Joints

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	210	PENTHOUSE OFF OF ROOM 2299D	NONE DETECTED			4 Joints
<b>C3A</b>	Miscellaneous Tank Insulation 1974 Original Building					<b>Total Amount - 12 Sq Ft</b>
	11	BOILER ROOM (1161)	NONE DETECTED	467-JJT-27, 28, 29	ON TANK.	12 Sq Ft
<b>D1A</b>	Boiler Gaskets Burner Gasket					<b>Total Amount - 2 Sq Ft</b>
	12	BOILER ROOM (1161)	NONE DETECTED	102308MV-2	BOILER ROOM.	2 Sq Ft
<b>G1A</b>	Sprayed-On Acoustical Finish White Texture					<b>Total Amount - 85 Sq Ft</b>
	111	ROOMS 1141-1146	NONE DETECTED	467-JJT-12	ROOM 1145B.	20 Sq Ft
	139	HALLWAY OUTSIDE ROOMS 1140-1146	NONE DETECTED			10 Sq Ft
	152	ROOM 1153	NONE DETECTED	467-JJT-30	HALLWAY OUTSIDE ROOM 1203.	4 Sq Ft
	158	ROOM 1154	NONE DETECTED	467-JJT-35	JJT-35: LOWER LEVEL AREA 0100 HALLWAY OUTSIDE ELEVATOR (SINCE REMOVED).	9 Sq Ft
	163	ROOM 1155	NONE DETECTED	102308MV-27; 467-JJT-8	ABOVE DOOR.	9 Sq Ft
	171	LOWER LEVEL AREA 0100	NONE DETECTED	102308MV-7, 467-JJT-35	35: HALLWAY OUTSIDE ELEVATOR	5 Sq Ft
	196	ROOM 2245	NONE DETECTED	467-JJT-3	JJT-3: ROOM 2244 ABOVE DOOR BEHIND PIPE (SINCE REMOVED).	5 Sq Ft
	218	ROOM 2253A	NONE DETECTED			4 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	220	ROOM 2253	NONE DETECTED			10 Sq Ft
	222	ROOM 2253C	NONE DETECTED			5 Sq Ft
	225	ROOM 2254	NONE DETECTED			4 Sq Ft
<b>G1B</b>	<b>Sprayed-On Acoustical Finish Tan Texture (Re-Spray)</b>					<b>Total Amount - 10750 Sq Ft</b>
	42	ROOM 1202	NONE DETECTED			2000 Sq Ft
	80	ROOM 1203	NONE DETECTED			1500 Sq Ft
	84	ROOM 1203A	NONE DETECTED			300 Sq Ft
	87	ROOM 1203B	NONE DETECTED			400 Sq Ft
	90	ROOM 1201	NONE DETECTED			1400 Sq Ft
	172	LOWER LEVEL AREA 0100	NONE DETECTED	102308MV-9		150 Sq Ft
	192	MEDIA CENTER & 1ST FLOOR HALLWAY	NONE DETECTED			5000 Sq Ft
<b>G1C</b>	<b>Sprayed-On Acoustical Finish White Fluffy (2011)</b>					<b>Total Amount - 7000 Sq Ft</b>
	68	GYMNASIUM (1208)	NEW			7000 Sq Ft
<b>11A</b>	<b>1' x 1' Acoustical Ceiling Tile Grubs w/Nail &amp; Pin Holes</b>					<b>Total Amount - 390 Sq Ft</b>
	43	ROOM 1202	NONE DETECTED	2001-1901-GEW-1B	NOT COLLECTED IN THIS LOCATION.	390 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
I2C	2' x 2' Acoustical Ceiling Tile Bumpy w/Pin & Nail Holes					<b>Total Amount - 2210 Sq Ft</b>
	47	ROOM 1202B (STORAGE CLOSET)	NONE DETECTED			50 Sq Ft
	49	ROOM 1202A (OFFICE)	NONE DETECTED			50 Sq Ft
	54	HALLWAY 1205	NONE DETECTED	467-JJT-13	NOT SAMPLED AT THIS LOCATION.	330 Sq Ft
	63	ROOM 1207	NONE DETECTED			480 Sq Ft
	110	1ST FLOOR SOUTHEAST STAIRWELL (1999B)	NONE DETECTED			60 Sq Ft
	168	1ST FLOOR NORTHWEST STAIRWELL	NONE DETECTED			80 Sq Ft
	176	ROOM 0102	NONE DETECTED			500 Sq Ft
	181	ROOM 0102 TIMEOUT ROOM	NONE DETECTED			80 Sq Ft
	184	ROOM 0101	NONE DETECTED			500 Sq Ft
	188	ROOM 0101 STORAGE	NONE DETECTED			80 Sq Ft
I2D	2' x 2' Acoustical Ceiling Tile Dents w/Pin Holes					<b>Total Amount - 2000 Sq Ft</b>
	99	MAIN OFFICE	NONE DETECTED	102308MV-15		2000 Sq Ft
I2E	2' x 2' Acoustical Ceiling Tile Vinyl-Coated Gypsum (2011)					<b>Total Amount - 740 Sq Ft</b>
	31	KITCHEN (1163)	NSM			740 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
I3A	2' x 4' Ceiling Tile Chicken Scratch w/Pin Holes		<b>Total Amount - 1200 Sq Ft</b>			
	95	EAST/WEST HALLWAY FROM ROOM 1202 TO CAFETERIA	NONE DETECTED	467-JJT-23	JJT-23: GYMNASIUM (1208) NORTHEAST EXIT DOOR BY CEILING (SINCE REMOVED).	1200 Sq Ft
I3B	2' x 4' Ceiling Tile Spray-On Look w/Revealed Edge (2014)		<b>Total Amount - 18100 Sq Ft</b>			
	112	ROOMS 1141-1146	NEW			4000 Sq Ft
	149	ROOMS 1153-1155	NEW			4500 Sq Ft
	173	LOWER LEVEL AREA 0100	NEW			600 Sq Ft
	193	THROUGHOUT 2ND FLOOR	NEW			9000 Sq Ft
I3E	2' x 4' Ceiling Tile Vinyl-Coated Fiberglass (2011)		<b>Total Amount - 2680 Sq Ft</b>			
	18	CAFETERIA (1162)	NSM			2200 Sq Ft
	69	GYMNASIUM (1208)	NSM			480 Sq Ft
J3A	Miscellaneous Cementitious Material Black Window Sills		<b>Total Amount - 300 Sq Ft</b>			
	6	THROUGHOUT BUILDING	5 CH	102308MV-22	ROOM 1141.	300 Sq Ft
K2A	12" x 12" Vinyl Floor Tile & Mastic Light Brown w/Brown & Tan Smudges		<b>Total Amount - 2555 Sq Ft</b>			
	21	CAFETERIA STORAGE (1162D)	NONE DETECTED			40 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	23	CAFETERIA STORAGE (1162C)	NONE DETECTED			65 Sq Ft
	27	CUSTODIAL OFFICE (1162A)	NONE DETECTED			255 Sq Ft
	81	ROOM 1203	NONE DETECTED			900 Sq Ft
	85	ROOM 1203A	NONE DETECTED			190 Sq Ft
	88	ROOM 1203B	NONE DETECTED			260 Sq Ft
	91	ROOM 1201	NONE DETECTED	2001-1501-AH-1	ROOM 1146 HALLWAY (SINCE REMOVED).	800 Sq Ft
	189	ROOM 0101 STORAGE	NONE DETECTED			45 Sq Ft
<b>K2B</b>	12" x 12" Vinyl Floor Tile & Mastic Tan w/Brown & White Streaks					<b>Total Amount - 4800 Sq Ft</b>
	70	GYMNASIUM (1208)	NONE DETECTED	2001-1501-AH-2		4800 Sq Ft
<b>K2E</b>	12" x 12" Vinyl Floor Tile & Mastic Aqua Mottle					<b>Total Amount - 2530 Sq Ft</b>
	19	CAFETERIA (1162)	NONE DETECTED			2200 Sq Ft
	55	HALLWAY 1205	NONE DETECTED	467-JJT-31		330 Sq Ft
<b>K2F</b>	12" x 12" Vinyl Floor Tile & Mastic White w/Red/Blue/Yellow Smears					<b>Total Amount - 960 Sq Ft</b>
	129	ROOM 1145	NONE DETECTED	102308MV-23; 467-JJT-9	JJT-9: ADJACENT TO MAIN ENTRY DOOR TO ROOM 1154 (SINCE REMOVED).	960 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
K2G	12" x 12" Vinyl Floor Tile & Mastic White w/Multi-Colored Flecks (2005)					<b>Total Amount - 820 Sq Ft</b>
	105	MAINTENANCE STORAGE	NONE DETECTED			20 Sq Ft
	106	NURSE'S AREA (1002)	NONE DETECTED	102308MV-14		800 Sq Ft
K2H	12" x 12" Vinyl Floor Tile & Mastic Solid Color Mottle (2008)					<b>Total Amount - 1000 Sq Ft</b>
	96	MAIN ENTRY & HALLWAY BY MAIN OFFICE	NONE DETECTED	102308MV-20		1000 Sq Ft
K2I	12" x 12" Vinyl Floor Tile & Mastic Beige w/Multi-Colored Smudges					<b>Total Amount - 250 Sq Ft</b>
	177	ROOM 0102	NONE DETECTED	102308MV-10		50 Sq Ft
	185	ROOM 0101	NONE DETECTED			200 Sq Ft
K2J	12" x 12" Vinyl Floor Tile & Mastic Light Gray Mottle (2019)					<b>Total Amount - 255 Sq Ft</b>
	25	KITCHEN DRY STORAGE (1162B)	NEW			255 Sq Ft
K3A	Miscellaneous Flooring 2' x 2' Light & Dark Gray Tile (2014)					<b>Total Amount - 14560 Sq Ft</b>
	113	ROOMS 1141-1146	NEW			4660 Sq Ft
	140	HALLWAY OUTSIDE ROOMS 1140-1146	NEW			1000 Sq Ft
	150	ROOMS 1153-1155	NEW			5900 Sq Ft
	194	THROUGHOUT 2ND FLOOR	NEW			3000 Sq Ft



Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
K3B	Miscellaneous Flooring Gray Stair Tread (2014)					<b>Total Amount - 140 Sq Ft</b>
169	THROUGHOUT LOWER LEVEL STAIRWELLS	NEW				140 Sq Ft
LOB	Flexible Duct Connector Black Vinyl					<b>Total Amount - 20 Sq Ft</b>
14	BOILER ROOM (1161)	NONE DETECTED	2001-1501-AH-3			5 Sq Ft
59	MECHANICAL ROOM (TE-1)	NONE DETECTED				2 Sq Ft
211	PENTHOUSE OFF OF ROOM 2299D	NONE DETECTED				13 Sq Ft
M0A	Plaster 1974 Original Building					<b>Total Amount - 1435 Sq Ft</b>
33	KITCHEN STORAGE (1209)	NONE DETECTED				275 Sq Ft
36	KITCHEN OFFICE (1209C)	NONE DETECTED				80 Sq Ft
38	KITCHEN RESTROOM (1209B)	NONE DETECTED				40 Sq Ft
76	MEN'S GYMNASIUM RESTROOM	NONE DETECTED				120 Sq Ft
78	WOMEN'S GYMNASIUM RESTROOM	NONE DETECTED				120 Sq Ft
143	1ST FLOOR GIRLS' RESTROOM (1147)	NONE DETECTED	102308MV-8	MV-8: ROOM 0106 (SINCE REMOVED).		200 Sq Ft
145	1ST FLOOR BOYS' RESTROOM (1149)	NONE DETECTED	467-JJT-16			200 Sq Ft
203	2ND FLOOR GIRLS' RESTROOM (2247)	NONE DETECTED				200 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	213	2ND FLOOR BOYS' RESTROOM	NONE DETECTED			200 Sq Ft
<b>NOA</b>	Drywall/Joint Compound Walls & Ceilings					<b>Total Amount - 15000 Sq Ft</b>
	1	THROUGHOUT BUILDING	NONE DETECTED	2001-1501-AHQC1	ROOM 1157.	15000 Sq Ft
<b>NOB</b>	Drywall/Joint Compound Smooth Soffit					<b>Total Amount - 5000 Sq Ft</b>
	2	THROUGHOUT BUILDING	NONE DETECTED	467-JJT-4	ROOM 2241.	5000 Sq Ft
<b>NOC</b>	Drywall/Joint Compound Divider Wall Panels					<b>Total Amount - 20000 Sq Ft</b>
	3	THROUGHOUT BUILDING	NONE DETECTED	102308MV-21	ROOM 2254.	20000 Sq Ft
<b>NOD</b>	Drywall/Joint Compound 2005 Addition					<b>Total Amount - 4000 Sq Ft</b>
	98	MAIN OFFICE	NONE DETECTED	102308MV-19	NURSE'S OFFICE.	4000 Sq Ft
<b>POA</b>	Fire Doors Wood Composite - 1.5 Hr Rating (Eggers)					<b>Total Amount - 20 Sq Ft</b>
	60	MECHANICAL ROOM (TE-1)	ASSUMED			20 Sq Ft
<b>POB</b>	Fire Doors Metal -1.5 Hour (Underwriter Laboratories)					<b>Total Amount - 10 Sq Ft</b>
	208	CUSTODIAL ROOM 2299D	ASSUMED			10 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
Q0A		Carpet Adhesive Brown Berber Carpet			<b>Total Amount - 1000 Sq Ft</b>	
	45	ROOM 1202	NONE DETECTED	080415BV-03	BV-03: ROOM 1202.	1000 Sq Ft
Q0B		Carpet Adhesive Dark Gray w/Light Gray Carpet Squares (2014)			<b>Total Amount - 8220 Sq Ft</b>	
	114	ROOM 1141	NEW			380 Sq Ft
	120	ROOM 1142	NEW			380 Sq Ft
	125	ROOM 1143	NEW			120 Sq Ft
	127	ROOM 1144	NEW			120 Sq Ft
	170	LOWER LEVEL AREA 0100	NEW			2000 Sq Ft
	197	ROOMS 2245	NEW			2220 Sq Ft
	217	ROOMS 2252-2254	NEW			3000 Sq Ft
Q0C		Carpet Adhesive Brown w/Dark Brown Carpet			<b>Total Amount - 200 Sq Ft</b>	
	48	ROOM 1202B (STORAGE CLOSET)	NONE DETECTED	2001-1901-ZZ-6B		50 Sq Ft
	50	ROOM 1202A (OFFICE)	NONE DETECTED			50 Sq Ft
	51	ROOM 1202C (SERVER ROOM)	NONE DETECTED			100 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount	
Q0E		Carpet Adhesive Light Blue w/White & Pink Specks Berber Carpet				<b>Total Amount - 480 Sq Ft</b>	
64	ROOM 1207	NONE DETECTED	467-JJT-24	BEHIND THE MAIN DOOR.	480 Sq Ft		
Q0F		Carpet Adhesive Blue Multi-Shaded Carpet				<b>Total Amount - 5000 Sq Ft</b>	
100	MAIN OFFICE	NONE DETECTED	102308MV-17		2000 Sq Ft		
151	ROOMS 1153-1155	NONE DETECTED			3000 Sq Ft		
Q0G		Carpet Adhesive Gray/Tan Berber Carpet				<b>Total Amount - 4000 Sq Ft</b>	
4	THROUGHOUT BUILDING	NONE DETECTED	102308MV-12	LOWER LEVEL HALLWAY BY STAIRS.	4000 Sq Ft		
Q0H		Carpet Adhesive Bright Green Berber Carpet				<b>Total Amount - 80 Sq Ft</b>	
182	ROOM 0102 TIMEOUT ROOM	NONE DETECTED	080415BV-02	BV-02: ROOM 0102.	80 Sq Ft		
R0B		Baseboard/Mopboard Adhesive 4" Dark Brown Baseboard				<b>Total Amount - 220 Sq Ft</b>	
22	CAFETERIA STORAGE (1162D)	NONE DETECTED			5 Sq Ft		
24	CAFETERIA STORAGE (1162C)	NONE DETECTED			10 Sq Ft		
26	KITCHEN DRY STORAGE (1162B)	NONE DETECTED			15 Sq Ft		
28	CUSTODIAL OFFICE (1162A)	NONE DETECTED			15 Sq Ft		
71	GYMNASIUM (1208)	NONE DETECTED	2001-1901-ZZ-5B	5B: ROOM 1146 (SINCE REMOVED).	75 Sq Ft		

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	82	ROOM 1203	NONE DETECTED			35 Sq Ft
	86	ROOM 1203A	NONE DETECTED			15 Sq Ft
	89	ROOM 1203B	NONE DETECTED			15 Sq Ft
	178	ROOM 0102	NONE DETECTED			35 Sq Ft
ROC	Baseboard/Mopboard Adhesive Black Baseboard (2014)					<b>Total Amount - 465 Sq Ft</b>
	115	ROOM 1141	NEW			10 Sq Ft
	121	ROOM 1142	NEW			380 Sq Ft
	126	ROOM 1143	NEW			10 Sq Ft
	128	ROOM 1144	NEW			10 Sq Ft
	130	ROOM 1145	NEW			50 Sq Ft
	135	ROOM 1146	NEW			5 Sq Ft
ROD	Baseboard/Mopboard Adhesive Pink 4" Baseboard					<b>Total Amount - 30 Sq Ft</b>
	65	ROOM 1207	NONE DETECTED	080415BV-04	BV-04: ROOM 1207.	30 Sq Ft
ROE	Baseboard/Mopboard Adhesive Black Baseboard					<b>Total Amount - 90 Sq Ft</b>
	20	CAFETERIA (1162)	NONE DETECTED	102308MV-29		90 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
ROF		Baseboard/Mopboard Adhesive 4" Dark Gray Baseboard				<b>Total Amount - 405 Sq Ft</b>
	97	MAIN ENTRY & HALLWAY BY MAIN OFFICE	NONE DETECTED			40 Sq Ft
	107	NURSE'S AREA (1002)	NONE DETECTED	102308MV-18		20 Sq Ft
	153	ROOM 1153	NONE DETECTED			45 Sq Ft
	195	THROUGHOUT 2ND FLOOR	NONE DETECTED			250 Sq Ft
	198	ROOMS 2245	NONE DETECTED			50 Sq Ft
ROG		Baseboard/Mopboard Adhesive 4" Light Blue Baseboard				<b>Total Amount - 50 Sq Ft</b>
	101	MAIN OFFICE	NONE DETECTED	102308MV-13		50 Sq Ft
VOA		Sink Undercoating Black				<b>Total Amount - 70 Sq Ft</b>
	66	ROOM 1207	3 CH	2001-1501-EE1		5 Sq Ft
	92	ROOM 1201	3 CH			20 Sq Ft
	132	ROOM 1145	3 CH			30 Sq Ft
	136	ROOM 1146	3 CH			5 Sq Ft
	179	ROOM 0102	3 CH			5 Sq Ft
	190	ROOM 0101 STORAGE	3 CH			5 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
VOB	Sink Undercoating Gray					<b>Total Amount - 10 Sq Ft</b>
	102	MAIN OFFICE	NONE DETECTED	102308MV-16		10 Sq Ft
VOC	Sink Undercoating Gray (2014)					<b>Total Amount - 56 Sq Ft</b>
	116	ROOM 1141	NEW			5 Sq Ft
	122	ROOM 1142	NEW			5 Sq Ft
	154	ROOM 1153	NEW			10 Sq Ft
	159	ROOM 1154	NEW			10 Sq Ft
	164	ROOM 1155	NEW			5 Sq Ft
	187	ROOM 0101	NEW			5 Sq Ft
	199	ROOMS 2245A	NEW			4 Sq Ft
	200	ROOMS 2245C	NEW			4 Sq Ft
	219	ROOM 2253A	NEW			4 Sq Ft
	224	ROOM 2253C	NEW			4 Sq Ft
W1A	1' x 1' Ceiling Tile Adhesive Dark Brown - Associated w/I1A					<b>Total Amount - 183 Sq Ft</b>
	17	CAFETERIA (1162)	NONE DETECTED			10 Sq Ft
	44	ROOM 1202	NONE DETECTED			88 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	134	ROOM 1146	NONE DETECTED			5 Sq Ft
	148	ROOMS 1153-1155	NONE DETECTED			10 Sq Ft
	202	ROOMS 2244-2246 & HALLWAY	NONE DETECTED			20 Sq Ft
	216	ROOMS 2252-2259 & ASSOCIATED HALLWAY	NONE DETECTED	102308MV-24	ROOM 2253.	50 Sq Ft
<b>XOA</b>		Miscellaneous Material AHU Seam Tar Gasket				<b>Total Amount - 35 Sq Ft</b>
	13	BOILER ROOM (1161)	3 CH	102308MV-1		20 Sq Ft
	58	MECHANICAL ROOM (TE-1)	3 CH			10 Sq Ft
	212	PENTHOUSE OFF OF ROOM 2299D	3 CH			5 Sq Ft
<b>XOB</b>		Miscellaneous Material Black Damp Proofing				<b>Total Amount - 150 Sq Ft</b>
	15	TUNNEL UNDER ROOM 1160B	NONE DETECTED	102308MV-3	TUNNEL UNDER ROOM 1160B.	150 Sq Ft
<b>XOC</b>		Miscellaneous Material Red Fire Stop				<b>Total Amount - 200 Sq Ft</b>
	7	THROUGHOUT BUILDING	NONE DETECTED	102308MV-4	BOILER ROOM.	200 Sq Ft
<b>XOD</b>		Miscellaneous Material Dark & Light Brown Laminate Countertop				<b>Total Amount - 25 Sq Ft</b>
	67	ROOM 1207	NONE DETECTED	467-JJT-25	RIGHT OF SINK.	25 Sq Ft



Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
XOF	Miscellaneous Material Wired Window Glaze					<b>Total Amount - 24 Sq Ft</b>
	83	ROOM 1203	5 CH			5 Sq Ft
	93	ROOM 1201	5 CH			5 Sq Ft
	174	LOWER LEVEL AREA 0100	5 CH			4 Sq Ft
	180	ROOM 0102	5 CH	102308MV-11		5 Sq Ft
	186	ROOM 0101	5 CH			5 Sq Ft
XOG	Miscellaneous Material Brown & Tan Countertop					<b>Total Amount - 105 Sq Ft</b>
	133	ROOM 1145	NONE DETECTED	467-JJT-25		75 Sq Ft
	137	ROOM 1146	NONE DETECTED			30 Sq Ft
XOH	Miscellaneous Material Red Duct Seam Caulk					<b>Total Amount - 85 Sq Ft</b>
	138	ROOM 1146	NONE DETECTED	102308MV-5		5 Sq Ft
	141	HALLWAY OUTSIDE ROOMS 1140-1146	NONE DETECTED			10 Sq Ft
	147	ROOMS 1152-1158 & HALLWAY	NONE DETECTED			50 Sq Ft
	201	ROOMS 2244-2246 & HALLWAY	NONE DETECTED			20 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
XOK	Miscellaneous Material Light Yellow Countertop		<b>Total Amount - 210 Sq Ft</b>			
94	ROOM 1201	NONE DETECTED	467-JJT-14	JJT-14: ROOM 0102 RIGHT OF SINK (SINCE REMOVED).	210 Sq Ft	
XOM	Miscellaneous Material Corkboard Adhesive		<b>Total Amount - 2 Sq Ft</b>			
46	ROOM 1202A & 1202B	NONE DETECTED	080415BV-01	BV-01: ROOM 1202B.	2 Sq Ft	
X1A	Miscellaneous Material Chalkboard Adhesive		<b>Total Amount - 95 Sq Ft</b>			
117	ROOM 1141	NONE DETECTED	032514BF-1	BF-1: ROOM 2252 (SINCE REMOVE).	40 Sq Ft	
131	ROOM 1145	NONE DETECTED			20 Sq Ft	
155	ROOM 1153	NONE DETECTED			5 Sq Ft	
160	ROOM 1154	NONE DETECTED			15 Sq Ft	
165	ROOM 1155	NONE DETECTED			5 Sq Ft	
221	ROOM 2253	NONE DETECTED			5 Sq Ft	
223	ROOM 2253C	NONE DETECTED			5 Sq Ft	
X1B	Miscellaneous Material 6" Brown Quarry Tile		<b>Total Amount - 400 Sq Ft</b>			
5	THROUGHOUT BUILDING	ASSUMED			400 Sq Ft	

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
X1C	Miscellaneous Material 6" Red Quarry Tile					<b>Total Amount - 740 Sq Ft</b>
	32	KITCHEN (1163)	ASSUMED			740 Sq Ft
X1D	Miscellaneous Material 1" X 1" Yellow Ceramic Floor Tile Systems					<b>Total Amount - 1200 Sq Ft</b>
	8	THROUGHOUT 1973 ORIGINAL BUILDING RESTROOMS	ASSUMED			1200 Sq Ft
X1E	Miscellaneous Material 6" Gray Ceramic Floor Tile (2005)					<b>Total Amount - 100 Sq Ft</b>
	103	MAIN OFFICE RESTROOM	NEW			50 Sq Ft
	108	NURSE'S RESTROOM 1004	NEW			50 Sq Ft
X1F	Miscellaneous Material 4" Peach Ceramic Wall Tile System (2005)					<b>Total Amount - 180 Sq Ft</b>
	104	MAIN OFFICE RESTROOM	NEW			80 Sq Ft
	109	NURSE'S RESTROOM 1004	NEW			100 Sq Ft
X1G	Miscellaneous Material 12" Gray Ceramic Floor Tile System (2014)					<b>Total Amount - 299 Sq Ft</b>
	118	ROOM 1141 RESTROOM	NEW			50 Sq Ft
	123	ROOM 1142 RESTROOM	NEW			50 Sq Ft
	156	ROOM 1153 RESTROOM	NEW			50 Sq Ft
	161	ROOM 1154 RESTROOM	NEW			100 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	166	ROOM 1155 RESTROOM	NEW			49 Sq Ft
X1H	Miscellaneous Material 6" x 12" Gray Ceramic Wall Tile System (2014)					<b>Total Amount - 600 Sq Ft</b>
	119	ROOM 1141 RESTROOM	NEW			100 Sq Ft
	124	ROOM 1142 RESTROOM	NEW			100 Sq Ft
	157	ROOM 1153 RESTROOM	NEW			100 Sq Ft
	162	ROOM 1154 RESTROOM	NEW			200 Sq Ft
	167	ROOM 1155 RESTROOM	NEW			100 Sq Ft
X1I	Miscellaneous Material 2" X 2" Beige Ceramic Floor Tile System (20xx)					<b>Total Amount - 30 Sq Ft</b>
	183	ROOM 0102 RESTROOM	NEW			30 Sq Ft
X1J	Miscellaneous Material 1" X 2" Cream Ceramic Floor Tile System					<b>Total Amount - 1655 Sq Ft</b>
	39	KITCHEN RESTROOM (1209B)	ASSUMED			25 Sq Ft
	77	MEN'S GYMNASIUM RESTROOM	ASSUMED			125 Sq Ft
	79	WOMEN'S GYMNASIUM RESTROOM	ASSUMED			125 Sq Ft
	144	1ST FLOOR GIRLS' RESTROOM (1147)	ASSUMED			350 Sq Ft
	146	1ST FLOOR BOYS' RESTROOM (1149)	ASSUMED			350 Sq Ft
	191	ROOM 0101 RESTROOM	ASSUMED			80 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	205	2ND FLOOR GIRLS' RESTROOM (2247)	ASSUMED			300 Sq Ft
	215	2ND FLOOR BOYS' RESTROOM	ASSUMED			300 Sq Ft