

Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

PLEASE NOTE: Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

EPA ASSESSMENT CATEGORIES:	1 = Damaged or significantly damaged TSI ACM	5 = ACBM with potential for damage
	2 = Damaged friable surfacing ACM	6 = ACBM with potential for significant damage
	3 = Significantly damaged friable surfacing ACM	7 = Remaining friable ACBM or friable suspect ACBM
	4 = Damaged or significantly damaged friable miscellaneous ACM	

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
8 CAD #:	D2A	Interior Boiler Insulation Burner Refractory (1963)	BOILER ROOM	90 Sq Ft	N	ASSUMED	5
Comments: THREE (3) BOILERS.					Sample #:		
14 CAD #:	J2A	Transite Piping/Ducting 6" Electrical Conduit	BASEMENT HIGH VOLTAGE ELECTRICAL ROOM (SMALL ROOM) OFF OUTSIDE AREA	10 Sq Ft	N	30 CH	5
Comments:					Sample #: 324-PDT-A (NOVA)		
15 CAD #:	J3A	Miscellaneous Cementitious Material Black Panels	BASEMENT HIGH VOLTAGE ELECTRICAL ROOM (SMALL ROOM) OFF OUTSIDE AREA	36 Sq Ft	N	ASSUMED	5
Comments: THREE (3) PANELS.					Sample #:		
18 CAD #:	LOA	Flexible Duct Connector Green Canvas	1963 ORIGINAL BUILDING PENTHOUSE MECHANICAL ROOM	4 Sq Ft	N	ASSUMED	5
Comments: TWO (2) JOINTS.					Sample #:		
22 CAD #:	J1D	Cementitious Panels Exterior Kiln Walls	KILN ROOM 1220 OFF RECEIVING	80 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
23 CAD #:	X0N	Miscellaneous Material Interior Kiln Insulation	KILN ROOM 1220 OFF RECEIVING	80 Sq Ft	Y	45 CH	5
Comments: INTERIOR INSULATION EXPOSED DUE TO BROKEN EXTERIOR KILN PANEL ON RIGHT SIDE.					Sample #: 082615JP-01		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
38 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	AUDITORIUM	3 Joints	N	20 CH, 10 AM	5
Comments: <u>VISIBLE FROM CATWALK. ROOF DRAIN LINE.</u>					Sample #:		
39 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray Marble w/Black Flecks	AUDITORIUM	2700 Sq Ft	N	7 CH (TILE & MASTIC)	5
Comments: <u> AISLE AREAS. SMALL PIECES MISSING IN AISLE THAT RUNS EAST/WEST, BY METAL RAILING LEGS. TILES CHIPPED W/PIECES MISSING NEXT TO SEATS M15, C1, M1, Z15, M31, N29, M33, M45. RECOMMEND SEALING WITH WAX.</u>					Sample #: 215-12		
40 CAD #:	S0A	Wood Floor Felt / Vapor Barrier Elevated (1963)	AUDITORIUM STAGE (1231)	3500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
41 CAD #:	K3G	Miscellaneous Flooring Gray Stair Treads w/Raised Circles	AUDITORIUM STAGE (1231)	100 Sq Ft	N	ASSUMED	5
Comments: <u>STAIRS AND RAMP IN NORTHEAST CORNER.</u>					Sample #:		
42 CAD #:	X0B	Miscellaneous Material White Proscenium Curtain	AUDITORIUM STAGE (1231)	1200 Sq Ft	N	ASSUMED	5
Comments: <u>CURTAIN TORN & FRAYED IN MIDDLE. STORED IN BUNDLE ON FLOOR.</u>					Sample #:		
43 CAD #:	T0A	Light Cord Insulation White, Fuzzy	AUDITORIUM STAGE (1231)	80 Lin Ft	N	ASSUMED	5
Comments: <u>STORED UNDER SPIRAL STAIRCASE TO CATWALK.</u>					Sample #:		
44 CAD #:	P0B	Fire Doors Wood Composite - 1 Hr Rating (Weldwood)	AUDITORIUM STAGE (1231)	20 Sq Ft	N	10 CH, 5 AM	4
Comments: <u>ONE (1) DOOR TO CATWALK. TWO (2) HOLES NEAR DOOR HANDLE.</u>					Sample #: 120109-JC-07		
48 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	GIRLS' STAGE DRESSING ROOM (1233)	110 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: <u>TILES CHIPPING AT WEST ENTRANCE.</u>					Sample #:		
52 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' STAGE DRESSING ROOM RESTROOM (1233A)	21 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
55 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	BOYS' STAGE DRESSING ROOM AREA (1232)	110 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: <u>TILE CHIPPING AT WEST ENTRANCE.</u>					Sample #:		
59 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' STAGE DRESSING ROOM RESTROOM (1232A)	21 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
63 CAD #:	S0A	Wood Floor Felt / Vapor Barrier Elevated (1963)	ROOM 1215 (THEATRE ARTS)	300 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
66 CAD #:	S0A	Wood Floor Felt / Vapor Barrier Elevated (1963)	ROOMS 1215A & B	260 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
79 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	RESTROOMS 1201 & 1202	600 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
83 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1244	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
86 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1242	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
88 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1245	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
92 CAD #:	J2A	Transite Piping/Ducting 6" Electrical Conduit	HIGH VOLTAGE ELECTRICAL ROOM 1250A	10 Sq Ft	N	30 CH	5
Comments:					Sample #:		
94 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1240 (WOOD SHOP)	5 Sq Ft	N	ASSUMED	5
Comments: ESTIMATED BEHIND WHITEBOARD.					Sample #:		
99 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1301	900 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: TILE WEAR AT TEACHERS DESK. SEALED WITH WAX. MONITOR. ONE MISSING TILE AND ONE CHIPPED TILE BY FIRE EXTINGUISHER.					Sample #:		
100 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1301	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
102 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1303	80 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED TILE NEAR DESK.					Sample #:		
103 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1302	1400 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: CRACKED AT ENTRANCE AND WORN THROUGHOUT. SEALED WITH WAX.					Sample #: 120309-MV-28		
105 CAD #:	J3D	Miscellaneous Cementitious Material 1-1/4" Gray Countertop	ROOM 1302	25 Sq Ft	N	10 CH	5
Comments: COVERED WITH WOOD SHEETING.					Sample #: 120309-MV-25		
106 CAD #:	J3I	Miscellaneous Cementitious Material Gray 1/4" Pottery Trays	ROOM 1302	50 Sq Ft	N	ASSUMED	5
Comments: FIFTY (50) CIRCULAR & SQUARE-SHAPED TRAYS STORED ON NORTHEAST SHELF.					Sample #:		
107 CAD #:	V0B	Sink Undercoating Black	ROOM 1302	20 Sq Ft	N	10 CH	5
Comments: THREE (3) SINKS.					Sample #: 120309-MV-43		
111 CAD #:	X00	Miscellaneous Material Milkboard Adhesive	ROOM 1302 STORAGE/WORK ROOM	72 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
114 CAD #:	X0I	Miscellaneous Material Black Wall Panel Adhesive	ROOM 1304	10 Sq Ft	N	3 CH	5
Comments: INCLUDES SOME EXPOSED MATERIAL BEHIND SHELF ON WEST WALL.					Sample #: 120309-MV-12		
116 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1305	784 Sq Ft	N	8 CH (TILE ONLY)	5
Comments:					Sample #: 120309-MV-29		
118 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1305	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
120 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1306	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TILE CHIPPED AT ENTRANCE AND BY COURTYARD EXIT.					Sample #:		
124 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1307	784 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: INCLUDES FIFTEEN (15) GREEN REPLACEMENT TILES.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
126 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1307	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
128 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1308	1000 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
133 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1308	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
136 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1308A (STORAGE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
139 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1308B (OFFICE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
142 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1309	280 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
144 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1310	1000 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: <u>TILE MISSING EAST END BY SINK. CHIPPED TILE NORTHWEST SIDE.</u>					Sample #:		
145 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1310	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
152 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1310A (STORAGE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
155 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1311	784 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: <u>UNDER CARPET.</u>					Sample #:		
156 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1311	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
159 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1313	1120 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: <u>TILE WORN UNDER CHAIRS. SEALED WITH WAX.</u>					Sample #:		
161 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1313	6 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
163 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1312	1000 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: <u>TILE CHIPPED AROUND ROUND METAL FLOOR COVERS AND ON EAST SIDE.</u>					Sample #:		
166 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1312	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
172 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1312A (STORAGE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
175 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1314 (OFFICE)	70 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TILE WORN UNDER TEACHER'S CHAIR, RECOMMEND CHAIR MAT.					Sample #:		
179 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1315	784 Sq Ft	N	8 CH (TILE ONLY)	5
Comments:					Sample #:		
181 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1315	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
183 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1317	784 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CRACKING AT ENTRANCE.					Sample #:		
185 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1317	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
188 CAD #:	J2A	Transite Piping/Ducting 6" Electrical Conduit	HIGH VOLTAGE ELECTRICAL ROOM 1321	10 Sq Ft	N	30 CH	5
Comments: USE CAUTION IN AREA. ELECTRICAL HAZARDS.					Sample #:		
190 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	RESTROOMS 1318 & 1322	900 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
194 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1316	1000 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: INCLUDES TWO (2) ROWS OF 12" TILES AT WEST WALL.					Sample #:		
197 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1316	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
199 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1316A (OFFICE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
203 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1325	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: THREE (3) TILES BROKEN IN NORTHWEST OF ROOM.					Sample #:		
204 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1325	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
205 CAD #:	J1A	Cementitious Panels Loose Panels	ROOM 1325	40 Sq Ft	N	30 CH	5
Comments: APPROXIMATELY TWENTY (20) PANELS. STORED IN LAB TABLES.					Sample #: 324-PTP-A		
209 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1327 (OFFICE)	150 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
211 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1327 (OFFICE) STORAGE 1327A	150 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
214 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1325A (STORAGE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
217 CAD #:	U0A	Light Pad Insulation Light Fixtures	ROOM 1326	96 Sq Ft	Y	75 CH	5
Comments: TWELVE (12) 2' X 4' FIXTURES. ONE (1) FIXTURE MISSING COVER.					Sample #:		
219 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1328	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: MISSING TILE UNDER LAB TABLE LEG.					Sample #:		
222 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1328	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
226 CAD #:	U0A	Light Pad Insulation Light Fixtures	ROOM 1340 (IMC)	96 Sq Ft	Y	75 CH	5
Comments: TWELVE (12) 2' X 4' FIXTURES.					Sample #:		
229 CAD #:	U0A	Light Pad Insulation Light Fixtures	ROOM 1340A	8 Sq Ft	Y	75 CH	5
Comments: TWO (2) 1' X 4' LIGHT FIXTURES.					Sample #:		
230 CAD #:	U0A	Light Pad Insulation Light Fixtures	ROOM 1343	16 Sq Ft	Y	75 CH	5
Comments: FOUR (4) 1' X 4' LIGHT FIXTURES.					Sample #:		
231 CAD #:	U0A	Light Pad Insulation Light Fixtures	ROOM 1344	16 Sq Ft	N	75 CH	5
Comments: FOUR (4) 1' X 4' LIGHT FIXTURES.					Sample #:		
232 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1344	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
234 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1329	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
239 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1329	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
241 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1331	150 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
245 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1333	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: MISSING TILE W/EXPOSED MASTIC AT NORTH END OF ROOM.					Sample #:		
250 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1333	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
251 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1346	95 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: TILE MISSING AT ENTRANCE TO ROOM 1346A.					Sample #:		
253 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1334	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
258 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1334	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
260 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1335	120 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
261 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1335A	120 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
262 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1334A	100 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
264 CAD #:	J2A	Transite Piping/Ducting 6" Electrical Conduit	HIGH VOLTAGE ELECTRICAL ROOM 1353	10 Sq Ft	N	30 CH	5
Comments: USE CAUTION IN AREA. ELECTRICAL HAZARDS.					Sample #:		
274 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	ROOM 1356A STORAGE	48 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
275 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	RESTROOMS 1357A & 1357C	800 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
280 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1358	6 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
287 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1359	6 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SOUTHEAST CORNER. SMALL PIECE MISSING.					Sample #:		
293 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1361	350 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		
297 CAD #:	X1B	Miscellaneous Material 2" X 2" Beige Ceramic Floor Tile System	RESTROOM 1361A	64 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
301 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1363	620 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		
304 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1364	825 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		
307 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1380 (HEALTH SERVICES)	100 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: REMAINS UNDER WALLS.					Sample #:		
315 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1366	900 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		
335 CAD #:	X1G	Miscellaneous Material 2" X 2" Gray Ceramic Floor Tile System	RESTROOM NEAR ROOM 1133	64 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
357 CAD #:	K3J	Miscellaneous Flooring 18" X 18" Tan w/Raised Circles	COMMONS/LINK (TA38) TO CAFETERIA	300 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
360 CAD #:	R0H	Baseboard/Mopboard Adhesive 4" Black Baseboard (1995)	CAFETERIA ENTRY & STORE 1101A	50 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
367 CAD #:	U0A	Light Pad Insulation Light Fixtures	CAFETERIA 1101	448 Sq Ft	Y	75 CH	5
Comments: TWENTY-EIGHT (28), 4' X 4' LIGHT FIXTURES.					Sample #:		
375 CAD #:	X1C	Miscellaneous Material 6" Red Quarry Tile System	KITCHEN 1102	1200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
377 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	KITCHEN OFFICE 1103	250 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
384 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	HALLWAY TO KITCHEN LOADING DOCK 1104	160 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TILES CHIPPED AT HALLWAY ENTRANCES.					Sample #: 215-2		
387 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	KITCHEN LOCKER/BREAK ROOM 1105	2 Joints	N	20 CH, 10 AM	5
Comments: ABOVE CEILING. ROOF DRAIN. VISIBLE FROM CEILING HATCH.					Sample #:		
395 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	ROOM 1107	265 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
397 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	GYMNASIUM STORAGE 1108	1 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TWO (2) TILES REMAINING ONLY AT ENTRANCE. MASTIC THROUGHOUT.					Sample #:		
399 CAD #:	J2A	Transite Piping/Ducting 6" Electrical Conduit	ELECTRICAL ROOM 1108A	10 Sq Ft	N	30 CH	5
Comments:					Sample #:		
408 CAD #:	L0A	Flexible Duct Connector Green Canvas	GYMNASIUM/POOL PENTHOUSE 1199C	20 Sq Ft	N	ASSUMED	5
Comments: FIVE (5) JOINTS.					Sample #:		
413 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' POOL LOCKER ROOM 1113 SHOWER AREAS	700 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
414 CAD #:	X1F	Miscellaneous Material 1" X 1" Beige Ceramic Tile System	GIRLS' POOL LOCKER ROOM 1113 SHOWER AREAS	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
415 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' POOL LOCKER ROOM 1113 RESTROOM AREAS	500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
419 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' POOL LOCKER ROOM COACHES' OFFICE RESTROOM 1114B	48 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
420 CAD #:	G2A	Trowelled-On Acoustical Finish White	POOL AREA 1115	1000 Sq Ft	Y	ASSUMED	5
Comments: FOUR (4), 4' WIDE SECTIONS & TWO (2) STRIPS AT WALLS. NEED LIFT OR EXTENSION LADDER TO SAMPLE.					Sample #:		
421 CAD #:	X1D	Miscellaneous Material 1" Blue Ceramic Tile System (Pool)	POOL AREA 1115	4000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
424 CAD #:	X1E	Miscellaneous Material 1" X 1" Yellow Ceramic Floor Tile System	GIRLS' VARSITY LOCKER ROOM 0112 SHOWERS	400 Sq Ft	N	ASSUMED	5
Comments: INCLUDES RESTROOM AREA.					Sample #:		
425 CAD #:	X1E	Miscellaneous Material 1" X 1" Yellow Ceramic Floor Tile System	GIRLS' VARSITY LOCKER ROOM 0112 COACHES' SHOWERS	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
436 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' POOL LOCKER ROOM 1116	800 Sq Ft	N	ASSUMED	5
Comments: RESTROOM & SHOWER AREAS.					Sample #:		
437 CAD #:	X1F	Miscellaneous Material 1" X 1" Beige Ceramic Tile System	BOYS' POOL LOCKER ROOM 1116	100 Sq Ft	N	ASSUMED	5
Comments: SHOWER AREA.					Sample #:		
441 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' POOL LOCKER ROOM COACHES' OFFICE RESTROOM 1117B	48 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
444 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' VARSITY LOCKER ROOM 1118 SHOWERS	500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
445 CAD #:	X1F	Miscellaneous Material 1" X 1" Beige Ceramic Tile System	BOYS' VARSITY LOCKER ROOM 1118 SHOWERS	50 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
449 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' VARSITY LOCKER ROOM COACHES' OFFICE RESTROOM 1119B	48 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
450 CAD #:	X1F	Miscellaneous Material 1" X 1" Beige Ceramic Tile System	BOYS' VARSITY LOCKER ROOM COACHES' OFFICE RESTROOM 1119B	3 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
451 CAD #:	L0A	Flexible Duct Connector Green Canvas	BOYS' VARSITY LOCKER ROOM STORAGE 1118D	6 Sq Ft	N	ASSUMED	5
Comments: TWO (2) JOINTS.					Sample #:		
460 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	ROOM 1122 OFF HALLWAY BY WRESTLING ROOM	200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
461 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	UNEXCAVATED AREA UNDER 1963 ORIGINAL BUILDING GYMNASIUM	1 Joints	N	20 CH, 10 AM	5
Comments: MATERIAL ENCAPSULATED IN PIPE PENETRATION IN SOUTHEAST CORNER OF CRAWL SPACE. ACCESS OFF HALLWAY THROUGH DOOR NEXT TO "BALCONY" DOOR.					Sample #:		
464 CAD #:	X1G	Miscellaneous Material 2" X 2" Gray Ceramic Floor Tile System	RESTROOMS 1125A & 1125C	572 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
465 CAD #:	X1H	Miscellaneous Material 4" X 4" White w/Gray Flecks Ceramic Wall Tile System	RESTROOMS 1125A & 1125C	224 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
473 CAD #:	K3G	Miscellaneous Flooring Gray Stair Treads w/Raised Circles	1995 ADDITION MAIN HALLWAY	600 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
481 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1402	6 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
485 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1404	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
486 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 1403	2 Joints	N	20 CH, 10 AM	5
Comments: INACCESSIBLE IN WALL UNDER SINK.					Sample #:		
497 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1407	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
500 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1406	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
505 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1410	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
509 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1409	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
513 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1411	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
517 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1412	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
522 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' RESTROOM BY ROOM 1413	200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
525 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' RESTROOM BY ROOM 1415	200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
529 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1415	4 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: VISIBLE UNDER WOOD CABINET.					Sample #:		
533 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1416	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
540 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1420	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		
544 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1423	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
549 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1425	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
552 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1424	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
555 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1427	6 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
561 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	FAN ROOM BELOW ROOM 1430	40 Joints	N	20 CH, 10 AM	5
Comments: ACCESS THROUGH FLOOR HATCH. UNDER FIBERGLASS & PVC. AMOUNT ESTIMATED.					Sample #:		
566 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1433	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SLIGHT CRACKING ALONG SOUTH WALL.					Sample #: 2001-1501-AE-2;; 2001-1901-XX-40B		
567 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1433	6 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
572 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1435	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED PIECE BY TEACHER'S DESK.					Sample #:		
573 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1435	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
578 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1437	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SLIGHT CRACKING ALONG SOUTH WALL. CHIPPED TILE SIX (6) FEET FROM ENTRY.					Sample #:		
579 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1437	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
582 CAD #:	R0H	Baseboard/Mopboard Adhesive 4" Black Baseboard (1995)	COPY ROOM 1439	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
590 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1419	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
594 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1440	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
607 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1445	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: ONE (1) MISSING TILE AT ENTRANCE. BROKEN TILE AT CENTER OF ROOM. OTHER TILES COMING LOOSE THROUGHOUT. INCLUDES TWENTY-FIVE (25) MAROON TILES.					Sample #:		
608 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1445	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
611 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1446	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED AT ENTRANCE.					Sample #:		
612 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1446	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
614 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' RESTROOM BY ROOM 1446	200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
618 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' RESTROOM BY ROOM 1448	200 Sq Ft	N	ASSUMED	5
Comments:							
621 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1448	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments:							
622 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1448	8 Sq Ft	N	ASSUMED	5
Comments:							
626 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1450	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments:							
627 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1450	10 Sq Ft	N	ASSUMED	5
Comments:							
630 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1451	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED PIECES OF TILE AND CRACKING ALONG NORTH WALL. SIX (6) VARIOUS REPLACEMENT TILES.							
631 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1451	10 Sq Ft	N	ASSUMED	5
Comments:							
634 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1453	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED AT ENTRANCE.							
635 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1453	10 Sq Ft	N	ASSUMED	5
Comments:							
636 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 1452	2 Joints	N	20 CH, 10 AM	5
Comments: INACCESSIBLE IN WALL. UNDER SINK. MAY HAVE BEEN REMOVED, BUT UNABLE TO VERIFY.							
639 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1452	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: UNDER CARPET.							
643 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1454	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SMALL CHIP AT ENTRANCE.							
644 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1454	10 Sq Ft	N	ASSUMED	5
Comments:							
647 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1455	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CRACKING ALONG NORTH AND SOUTH WALL.							
648 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1455	10 Sq Ft	N	ASSUMED	5
Comments:							
651 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1456	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED PIECE MIDDLE OF ROOM TOWARDS WHITEBOARDS AND AT ENTRANCE. TEN (10) GREEN REPLACEMENT TILES MISSING							

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
652 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1456	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
655 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1457	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SLIGHT CRACKING ALONG WALL NEXT TO ENTRANCE. THREE (3) WHITE REPLACEMENT TILES.					Sample #:		
656 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1457	14 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
661 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1459	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SMALL CHIP AT ENTRANCE AND 8 FT IN FRONT OF ENTRANCE					Sample #:		
662 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1459	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		