

2188 Londin Lane, Saint Paul, MN 55119

**Chart C - All Materials List**

The following list contains all events observed by the inspector, whether or not they actually contained asbestos, and are grouped by homogeneous area (material type).

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
A4A		Mudded Pipe Joints on Fiberglass Insulation 1974 Original Building				<b>Total Amount - 609 Joints</b>
	8	BOILER ROOM (2401)	NONE DETECTED	207L2A-509Y/5, 6; 205-TS11-A; 240-TS11-A		150 Joints
	40	THROUGHOUT MAIN OFFICE AREA	NONE DETECTED			40 Joints
	89	ROOM 2020B (IMC)	NONE DETECTED			6 Joints
	105	MECHANICAL ROOM (1611)	NONE DETECTED	450GG-A4, A5		75 Joints
	112	EXTERIOR WEST ENTRANCE NEAR HALLWAY 1100	NONE DETECTED			15 Joints
	122	STORAGE ROOM 1107A	NONE DETECTED			30 Joints
	123	MECHANICAL/STORAGE ROOM 1108A	NONE DETECTED	082019-BF-1	BF-1: MECHANICAL/STORAGE ROOM 1108A	70 Joints
	131	GYMNASIUM (2104)	NONE DETECTED			20 Joints
	137	GYMNASIUM STORAGE (2104B)	NONE DETECTED	021809ML-40		3 Joints
	140	THROUGHOUT 1974 ORIGINAL BUILDING TUNNEL SYSTEMS	NONE DETECTED			200 Joints

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
C2A	Water Tank Insulation 1974 Original Building					<b>Total Amount - 115 Sq Ft</b>
	9	BOILER ROOM (2401)	NONE DETECTED	207L1A-509Y/3, 4; 770-TS11-A		115 Sq Ft
C3A	Miscellaneous Tank Insulation Expansion Tank					<b>Total Amount - 15 Sq Ft</b>
	10	BOILER ROOM (2401)	NONE DETECTED	021809ML-04, 05, 06		15 Sq Ft
D1A	Boiler Gaskets Front Doors					<b>Total Amount - 4 Sq Ft</b>
	11	BOILER ROOM (2401)	NONE DETECTED	021809ML-01		4 Sq Ft
D1B	Boiler Gaskets Boiler Stack Box Access					<b>Total Amount - 2 Sq Ft</b>
	12	BOILER ROOM (2401)	85 CH	021809ML-02		2 Sq Ft
D2A	Interior Boiler Insulation Interior Refractory					<b>Total Amount - 100 Sq Ft</b>
	13	BOILER ROOM (2401)	ASSUMED			100 Sq Ft
EOA	Stack Insulation					<b>Total Amount - 450 Sq Ft</b>
	14	BOILER ROOM (2401)	NONE DETECTED	450GG-A1-3		450 Sq Ft
E1A	Stack Gasket Boiler Stack					<b>Total Amount - 1 Sq Ft</b>
	15	BOILER ROOM (2401)	NONE DETECTED	021809ML-07		1 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
E2A	Interior Stack Insulation Boiler Stack Refractory					<b>Total Amount - 90 Sq Ft</b>
16	BOILER ROOM (2401)	ASSUMED				90 Sq Ft
E2B	Interior Stack Insulation Furnace Stack Refractory					<b>Total Amount - 50 Sq Ft</b>
17	BOILER ROOM (2401)	ASSUMED				50 Sq Ft
I1A	1' x 1' Acoustical Ceiling Tile Nail Holes					<b>Total Amount - 750 Sq Ft</b>
33	KITCHEN (2407)	NONE DETECTED	207L3A			750 Sq Ft
I1C	1' x 1' Acoustical Ceiling Tile Fissured					<b>Total Amount - 330 Sq Ft</b>
113	ROOM 1103	NONE DETECTED				180 Sq Ft
119	ROOM 1107	NONE DETECTED	021809ML-15			150 Sq Ft
I2A	2' x 2' Acoustical Ceiling Tile Grubs & Pin Holes					<b>Total Amount - 500 Sq Ft</b>
127	SMALL LOWER LEVEL GYMNASIUM (1108)	NONE DETECTED	021809ML-43			500 Sq Ft
I2B	2' x 2' Acoustical Ceiling Tile Cloth-Covered Fiberglass					<b>Total Amount - 30000 Sq Ft</b>
24	THROUGHOUT 1974 ORIGINAL BUILDING	NSM				30000 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
I2C	2' x 2' Acoustical Ceiling Tile Tectum					<b>Total Amount - 300 Sq Ft</b>
126	SMALL LOWER LEVEL GYMNASIUM (1108)	NSM				300 Sq Ft
I2D	2' x 2' Acoustical Ceiling Tile Light Texture w/Revealed Edge (1999)					<b>Total Amount - 12000 Sq Ft</b>
2	THROUGHOUT BUILDING	NONE DETECTED	021809ML-24	ML-24: ROOM 2302.		12000 Sq Ft
I2E	2' x 2' Acoustical Ceiling Tile Pin Holes (1999)					<b>Total Amount - 560 Sq Ft</b>
144	1999 ADDITION RESTROOMS	NEW				560 Sq Ft
I4A	Acoustical Ceiling Tile 3' x 5' Light Texture w/Pin Holes					<b>Total Amount - 4500 Sq Ft</b>
133	GYMNASIUM (2104)	NONE DETECTED	2001-1501 HW-1	HW-1: GYMNASIUM CEILING		4500 Sq Ft
I4B	Acoustical Ceiling Tile Miscellaneous-Sized Panels w/Random Nail & Pin Holes					<b>Total Amount - 1984 Sq Ft</b>
134	GYMNASIUM (2104)	NONE DETECTED	2001-1501 HW-2	HW-2: GYMNASIUM WALL		1984 Sq Ft
J3A	Miscellaneous Cementitious Material White Window Sill					<b>Total Amount - 30 Sq Ft</b>
136	GYMNASIUM OFFICE (2104A)	20 CH	021809ML-21			10 Sq Ft
138	GYMNASIUM STORAGE (2104B)	20 CH				10 Sq Ft
139	GYMNASIUM STORAGE (2104C)	20 CH				10 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
K1B	Sheet Vinyl Flooring & Adhesive Gray w/Multi-Colored Terrazzo-Look					<b>Total Amount - 800 Sq Ft</b>
	81	NURSE'S AREA (2220)	NONE DETECTED	021809ML-34		240 Sq Ft
	83	NURSE'S OFFICE (2221)	NONE DETECTED			120 Sq Ft
	85	TREATMENT ROOM (2225)	NONE DETECTED			70 Sq Ft
	87	COT ROOM (2222)	NONE DETECTED			170 Sq Ft
	88	ISOLATION ROOM (2223)	NONE DETECTED			80 Sq Ft
	148	ROOM 2318 - LOCKDOWN ROOMS (2)	NONE DETECTED			120 Sq Ft
K2B	12" x 12" Vinyl Floor Tile & Mastic Light Tan w/Brown & White Streaks					<b>Total Amount - 2300 Sq Ft</b>
	42	CAFETERIA	NONE DETECTED	021809ML-38; 310-FT2-A		2300 Sq Ft
K2C	12" x 12" Vinyl Floor Tile & Mastic Light Blue w/White Smudges					<b>Total Amount - 250 Sq Ft</b>
	23	CUSTODIAL OFFICE (2403)	NONE DETECTED	021809ML-08		250 Sq Ft
K2D	12" x 12" Vinyl Floor Tile & Mastic Light Brown w/Brown & White Streaks					<b>Total Amount - 9456 Sq Ft</b>
	47	ROOM 2424	6-7 CH (MASTIC ONLY)			625 Sq Ft
	49	ROOM 2425	6-7 CH (MASTIC ONLY)			625 Sq Ft
	51	HALLWAY OUTSIDE ROOM 2506	6-7 CH (MASTIC ONLY)			80 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	54	ROOM 2506	6-7 CH (MASTIC ONLY)			20 Sq Ft
	56	ROOM 2507	6-7 CH (MASTIC ONLY)			20 Sq Ft
	58	HALLWAY OUTSIDE ROOM 2503	6-7 CH (MASTIC ONLY)			80 Sq Ft
	61	ROOM 2503	6-7 CH (MASTIC ONLY)			20 Sq Ft
	63	ROOM 2502	6-7 CH (MASTIC ONLY)			20 Sq Ft
	65	HALLWAY OUTSIDE ROOM 2606	6-7 CH (MASTIC ONLY)			80 Sq Ft
	68	HALLWAY OUTSIDE ROOM 2603	6-7 CH (MASTIC ONLY)			80 Sq Ft
	72	ROOM 2201	6-7 CH (MASTIC ONLY)	021809ML-44		800 Sq Ft
	75	STORAGE ROOM 2201B	6-7 CH (MASTIC ONLY)			25 Sq Ft
	77	ROOM 2203	6-7 CH (MASTIC ONLY)			800 Sq Ft
	80	STORAGE ROOM 2203B	6-7 CH (MASTIC ONLY)			25 Sq Ft
	90	ROOM 2020B	6-7 CH (MASTIC ONLY)			220 Sq Ft
	91	ROOM 2020A	6-7 CH (MASTIC ONLY)			140 Sq Ft
	92	HALLWAY OUTSIDE ROOM 1506	6-7 CH (MASTIC ONLY)			62 Sq Ft
	96	HALLWAY OUTSIDE ROOM 1502	6-7 CH (MASTIC ONLY)			74 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	100	ROOM 1502 NORTH	6-7 CH (MASTIC ONLY)			500 Sq Ft
	101	ROOM 1502 SOUTH	6-7 CH (MASTIC ONLY)			500 Sq Ft
	107	HALLWAY OUTSIDE ROOM 1606	6-7 CH (MASTIC ONLY)			80 Sq Ft
	110	HALLWAY OUTSIDE ROOM 1603	6-7 CH (MASTIC ONLY)			80 Sq Ft
	132	GYMNASIUM (2104)	6-7 CH (MASTIC ONLY)	310-FT1-A		4500 Sq Ft
K2E	12" x 12" Vinyl Floor Tile & Mastic Dark Brown w/Tan Flecks					<b>Total Amount - 330 Sq Ft</b>
	117	OLD KITCHEN (1112)	10 CH (MASTIC ONLY)			150 Sq Ft
	118	EQUIPMENT ROOM 1105	10 CH (MASTIC ONLY)	021809ML-18		180 Sq Ft
K2F	12" x 12" Vinyl Floor Tile & Mastic Light Tan w/Brown & White					<b>Total Amount - 1350 Sq Ft</b>
	128	SMALL LOWER LEVEL GYMNASIUM (1108)	8 CH (MASTIC ONLY)	021809ML-20		1350 Sq Ft
K2G	12" x 12" Vinyl Floor Tile & Mastic Cream w/Tan Smudges (1999)					<b>Total Amount - 3280 Sq Ft</b>
	29	ROOM 2406	NONE DETECTED	021809ML-25		370 Sq Ft
	32	STORAGE ROOM 2406A	NONE DETECTED			80 Sq Ft
	36	ROOM 2230	NONE DETECTED			350 Sq Ft
	48	ROOM 2424	NONE DETECTED			70 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	71	ROOM 2201	NONE DETECTED			420 Sq Ft
	76	ROOM 2203	NONE DETECTED			420 Sq Ft
	129	SMALL LOWER LEVEL GYMNASIUM (1108)	NONE DETECTED			50 Sq Ft
	143	HALLWAY OUTSIDE 1999 ADDITION RESTROOMS	NONE DETECTED			180 Sq Ft
	146	ROOM 2318	NONE DETECTED			140 Sq Ft
	149	ROOM 2317	NONE DETECTED			200 Sq Ft
	151	ROOM 2315	NONE DETECTED			200 Sq Ft
	153	ROOM 2313	NONE DETECTED			200 Sq Ft
	155	ROOM 2316	NONE DETECTED			130 Sq Ft
	157	ROOM 2314	NONE DETECTED			200 Sq Ft
	159	ROOM 2312	NONE DETECTED			130 Sq Ft
	161	ROOM 2303 & STORAGE	NONE DETECTED			140 Sq Ft
K2H	12" x 12" Vinyl Floor Tile & Mastic Gray Mottle					<b>Total Amount - 120 Sq Ft</b>
	46	ROOM 2422	NONE DETECTED	021809ML-27		120 Sq Ft
K2I	12" x 12" Vinyl Floor Tile & Mastic Tan Mottle					<b>Total Amount - 36 Sq Ft</b>
	97	HALLWAY OUTSIDE ROOM 1502	NONE DETECTED			6 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	147	ROOM 2318	NONE DETECTED	021809ML-36		30 Sq Ft
<b>K2J</b>	12" x 12" Vinyl Floor Tile & Mastic Brown, Tan & Cream Smudges					<b>Total Amount - 18 Sq Ft</b>
	93	HALLWAY OUTSIDE ROOM 1506	5 CH (MASTIC ONLY)	021809ML-35		18 Sq Ft
<b>K2K</b>	12" x 12" Vinyl Floor Tile & Mastic Red Mottle (2011)					<b>Total Amount - 80 Sq Ft</b>
	44	CAFETERIA	NEW			80 Sq Ft
<b>K3A</b>	Miscellaneous Flooring Black w/White Stair Treads					<b>Total Amount - 18 Sq Ft</b>
	115	HALLWAY LL33	NONE DETECTED	021809ML-17		18 Sq Ft
<b>K3C</b>	Miscellaneous Flooring Black Mastic					<b>Total Amount - 2300 Sq Ft</b>
	43	CAFETERIA	5 CH	021809ML-38		2300 Sq Ft
<b>L0A</b>	Flexible Duct Connector Black Vinyl					<b>Total Amount - 40 Sq Ft</b>
	19	BOILER ROOM (2401)	NSM			20 Sq Ft
	106	MECHANICAL ROOM (1611)	NSM			15 Sq Ft
	125	MECHANICAL/STORAGE ROOM 1108A	NSM			5 Sq Ft
<b>N0A</b>	Drywall/Joint Compound					<b>Total Amount - 5000 Sq Ft</b>
	1	THROUGHOUT BUILDING	NONE DETECTED	021809ML-42; 509Y2	ML-42: MAIN OFFICE AREA.	5000 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
POA	Fire Doors Hollow Metal -1.5 Hr Rating (Underwriters Laboratories)					<b>Total Amount - 20 Sq Ft</b>
21	BOILER ROOM (2401)	NSM				20 Sq Ft
Q0A	Carpet Adhesive Tan, Brown & Gray Berber					<b>Total Amount - 10000 Sq Ft</b>
25	THROUGHOUT 1974 ORIGINAL BUILDING	NONE DETECTED	021809ML-11	ML-11: HALLWAY OUTSIDE CUSTODIAL OFFICE.	10000 Sq Ft	
Q0B	Carpet Adhesive Blue, Gray & Red Berber (1999)					<b>Total Amount - 12000 Sq Ft</b>
3	THROUGHOUT BUILDING	NONE DETECTED	021809ML-14	ML-14: ROOM 2313.	12000 Sq Ft	
ROA	Baseboard/Mopboard Adhesive 4" Dark Brown Baseboard					<b>Total Amount - 200 Sq Ft</b>
26	THROUGHOUT 1974 ORIGINAL BUILDING	NONE DETECTED	021809ML-09	ML-09: CAFETERIA.	200 Sq Ft	
ROB	Baseboard/Mopboard Adhesive 4" Blue Baseboard (1999)					<b>Total Amount - 200 Sq Ft</b>
4	THROUGHOUT BUILDING	NONE DETECTED	021809ML-23	ML-23: ROOM 2317.	200 Sq Ft	
ROC	Baseboard/Mopboard Adhesive 4" Gray Baseboard					<b>Total Amount - 200 Sq Ft</b>
5	THROUGHOUT BUILDING	NONE DETECTED	021809ML-29	ML-29: ROOM 2424.	200 Sq Ft	
ROD	Baseboard/Mopboard Adhesive 3" White Baseboard					<b>Total Amount - 39 Sq Ft</b>
53	HALLWAY OUTSIDE ROOM 2506	NONE DETECTED	073015BV-02	BV-02: HALLWAY BY ROOM 2606.	4 Sq Ft	

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	60	HALLWAY OUTSIDE ROOM 2503	NONE DETECTED			5 Sq Ft
	67	HALLWAY OUTSIDE ROOM 2606	NONE DETECTED			5 Sq Ft
	69	HALLWAY OUTSIDE ROOM 2603	NONE DETECTED			5 Sq Ft
	95	HALLWAY OUTSIDE ROOM 1506	NONE DETECTED			5 Sq Ft
	99	HALLWAY OUTSIDE ROOM 1502	NONE DETECTED			5 Sq Ft
	102	ROOM 1502 SOUTH	NONE DETECTED			5 Sq Ft
	109	HALLWAY OUTSIDE ROOM 1603	NONE DETECTED			5 Sq Ft
VOA	Sink Undercoating Gray					<b>Total Amount - 10 Sq Ft</b>
	38	STAFF LOUNGE (2005)	NONE DETECTED	021809ML-12		6 Sq Ft
	50	ROOM 2425	NONE DETECTED			4 Sq Ft
VOC	Sink Undercoating Gray (1999)					<b>Total Amount - 50 Sq Ft</b>
	31	ROOM 2406	NONE DETECTED			4 Sq Ft
	37	ROOM 2230	NONE DETECTED			4 Sq Ft
	82	NURSE'S AREA (2220)	NONE DETECTED			4 Sq Ft
	86	TREATMENT ROOM (2225)	NONE DETECTED			4 Sq Ft
	150	ROOM 2317	NONE DETECTED			4 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	152	ROOM 2315	NONE DETECTED			4 Sq Ft
	154	ROOM 2313	NONE DETECTED			4 Sq Ft
	156	ROOM 2316	NONE DETECTED			4 Sq Ft
	158	ROOM 2314	NONE DETECTED			4 Sq Ft
	160	ROOM 2312	NONE DETECTED			4 Sq Ft
	162	ROOM 2303 & STORAGE	NONE DETECTED			6 Sq Ft
	163	ROOM 2309 (STAFF/WORKROOM)	NONE DETECTED	021809ML-26		4 Sq Ft
V0D	Sink Undercoating Black					<b>Total Amount - 64 Sq Ft</b>
	41	MAIN OFFICE WORK ROOM (2003)	5 CH			4 Sq Ft
	52	HALLWAY OUTSIDE ROOM 2506	5 CH			4 Sq Ft
	55	ROOM 2506	5 CH	021809ML-32		4 Sq Ft
	57	ROOM 2507	5 CH			4 Sq Ft
	59	HALLWAY OUTSIDE ROOM 2503	5 CH			4 Sq Ft
	62	ROOM 2503	5 CH			4 Sq Ft
	64	ROOM 2502	5 CH			4 Sq Ft
	66	HALLWAY OUTSIDE ROOM 2606	5 CH			4 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	70	HALLWAY OUTSIDE ROOM 2603	5 CH			4 Sq Ft
	73	ROOM 2201	5 CH			4 Sq Ft
	78	ROOM 2203	5 CH			4 Sq Ft
	94	HALLWAY OUTSIDE ROOM 1506	5 CH			4 Sq Ft
	98	HALLWAY OUTSIDE ROOM 1502	5 CH			4 Sq Ft
	103	ROOM 1502 SOUTH	5 CH			4 Sq Ft
	108	HALLWAY OUTSIDE ROOM 1606	5 CH			4 Sq Ft
	111	HALLWAY OUTSIDE ROOM 1603	5 CH			4 Sq Ft
<b>W1A</b>	<b>1' x 1' Ceiling Tile Adhesive Associated w/I1A</b>					<b>Total Amount - 190 Sq Ft</b>
	34	KITCHEN (2407)	NONE DETECTED	021809ML-10		190 Sq Ft
<b>W1C</b>	<b>1' x 1' Ceiling Tile Adhesive Associated w/I1C</b>					<b>Total Amount - 80 Sq Ft</b>
	114	ROOM 1103	NONE DETECTED			45 Sq Ft
	120	ROOM 1107	NONE DETECTED	021809ML-15		35 Sq Ft
<b>W4B</b>	<b>Ceiling Tile Adhesive Associated w/I4B</b>					<b>Total Amount - 395 Sq Ft</b>
	135	GYMNASIUM (2104)	3 CH	021809ML-22		395 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
XOA		Miscellaneous Material Black Tar AHU Gasket (McQuay)				<b>Total Amount - 55 Sq Ft</b>
	20	BOILER ROOM (2401)	5 CH	021809ML-03		15 Sq Ft
	104	MECHANICAL ROOM (1611)	5 CH			30 Sq Ft
	124	MECHANICAL/STORAGE ROOM 1108A	5 CH			10 Sq Ft
XOB		Miscellaneous Material Wired Window Glaze				<b>Total Amount - 5 Sq Ft</b>
	39	STAFF LOUNGE (2005)	NONE DETECTED	021809ML-13		2 Sq Ft
	130	HALLWAY 2100	NONE DETECTED			3 Sq Ft
XOC		Miscellaneous Material 1' x 2'-1/4" Thick Floor & Associated Mastic				<b>Total Amount - 1030 Sq Ft</b>
	116	HALLWAY LL33	10 CH (MASTIC ONLY)			180 Sq Ft
	121	ROOM 1107	10 CH (MASTIC ONLY)	021809ML-16		850 Sq Ft
XOD		Miscellaneous Material Wired Window Glaze (1999)				<b>Total Amount - 11 Sq Ft</b>
	30	ROOM 2406	NONE DETECTED			1 Sq Ft
	141	THROUGHOUT 1999 ADDITION	NONE DETECTED	021809ML-41	ML-41: ROOM 2302.	10 Sq Ft
XOE		Miscellaneous Material Cream Caulk				<b>Total Amount - 50 Sq Ft</b>
	6	THROUGHOUT BUILDING	NONE DETECTED	021809ML-33	ML-33: OUTSIDE ROOM 2507.	50 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
XOH	Miscellaneous Material Vermiculite					<b>Total Amount - 10000 Sq Ft</b>
	27	THROUGHOUT 1974 ORIGINAL BUILDING	<1 ACT	072111ML-01, 02, 03	ML-01: ROOM 2203. ML-02: ROOM 2104A. ML-03: ROOM 2427.	10000 Sq Ft
XOI	Miscellaneous Material Foam Mastic					<b>Total Amount - 100 Sq Ft</b>
	22	TUNNEL SYSTEM OFF OF BOILER ROOM	NONE DETECTED	021809ML-39		100 Sq Ft
XOJ	Miscellaneous Material Red Fire Stop					<b>Total Amount - 21 Sq Ft</b>
	18	BOILER ROOM (2401)	NONE DETECTED			1 Sq Ft
	142	THROUGHOUT 1999 ADDITION	NONE DETECTED	021809ML-37		20 Sq Ft
XOK	Miscellaneous Material Tackboard Adhesive (1974)					<b>Total Amount - 300 Sq Ft</b>
	28	THROUGHOUT 1974 ORIGINAL BUILDING	NONE DETECTED	072511MV-01	MV-01: CUSTODIAL OFFICE.	300 Sq Ft
XOL	Miscellaneous Material Window Glazing					<b>Total Amount - 3 Sq Ft</b>
	45	HALLWAY 2420	6 CH	073015BV-01	BV-01: HALLWAY 2420.	1 Sq Ft
	74	ROOM 2201	6 CH			1 Sq Ft
	79	ROOM 2203	6 CH			1 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
X1A	Miscellaneous Material 6" Red Quarry Tile					<b>Total Amount - 2750 Sq Ft</b>
	7	THROUGHOUT BUILDING	ASSUMED			2000 Sq Ft
	35	KITCHEN (2407)	ASSUMED			750 Sq Ft
X1B	Miscellaneous Material 2" White w/Gray Specks Ceramic Floor Tile System (20XX)					<b>Total Amount - 50 Sq Ft</b>
	84	NURSE'S RESTROOM	NEW			50 Sq Ft
X1C	Miscellaneous Material 2" Light Gray Ceramic Floor Tile System (1999)					<b>Total Amount - 592 Sq Ft</b>
	145	1999 ADDITION RESTROOMS	ASSUMED			560 Sq Ft
	164	ROOM 2309 RESTROOM (2309A)	ASSUMED			32 Sq Ft