

## Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

**PLEASE NOTE:** Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

EPA ASSESSMENT CATEGORIES:	1 = Damaged or significantly damaged TSI ACM	5 = ACBM with potential for damage
	2 = Damaged friable surfacing ACM	6 = ACBM with potential for significant damage
	3 = Significantly damaged friable surfacing ACM	7 = Remaining friable ACBM or friable suspect ACBM
	4 = Damaged or significantly damaged friable miscellaneous ACM	

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
6 CAD #:	X1H	Miscellaneous Material 1' X 2' Streaked Gray Ceramic Floor Tile System	THROUGHOUT BUILDING RESTROOMS	3000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
10 CAD #:	B2A	Millboard Pipe Insulation 1963 Original Building	THROUGHOUT 1963 ORIGINAL BUILDING	200 Lin Ft	N	10 CH	5
Comments: INACCESSIBLE. INSIDE WALLS. AMOUNT ESTIMATED. FOR DRINKING FOUNTAINS, LOCKER ROOM FIXTURES, ETC.					Sample #: ACB450-AB-01		
11 CAD #:	A2A	Mudded Pipe Joints on Millboard Insulation 1963 Original Building	THROUGHOUT 1963 ORIGINAL BUILDING	50 Joints	N	30 CH	5
Comments: INACCESSIBLE. INSIDE WALLS. AMOUNT ESTIMATED. FOR DRINKING FOUNTAINS, LOCKER ROOM FIXTURES, ETC.					Sample #:		
12 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	THROUGHOUT 1963 ORIGINAL BUILDING	100 Joints	N	35 CH	5
Comments: INACCESSIBLE. INSIDE WALLS. AMOUNT ESTIMATED.					Sample #: 2001-1501-JN-04		
17 CAD #:	X1A	Miscellaneous Material 1" X 1" Blue Ceramic Floor Tile System	BOYS' PHY ED LOCKER ROOM 0306	800 Sq Ft	N	ASSUMED	5
Comments: RESTROOM & SHOWER AREAS.					Sample #:		
21 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	BOYS' LOCKER ROOM OFFICE 0307	180 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: SMALL CIRCULAR INDENTS THROUGHOUT. CRACKING BEHIND DOOR.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
22 CAD #:	X1A	Miscellaneous Material 1" X 1" Blue Ceramic Floor Tile System	BOYS' LOCKER ROOM OFFICE 0307 RESTROOM	20 Sq Ft	N	ASSUMED	5
Comments: SHOWER AREA.					Sample #:		
23 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	BOYS' LOCKER ROOM BIKE STORAGE ROOM 0308	276 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments:					Sample #:		
25 CAD #:	X0C	Miscellaneous Material Pipe/Valve Flange Gaskets	POOL MECHANICAL ROOM 0311	3 Sq Ft	N	55 CH	5
Comments: THREE (3) OLD GASKETS.					Sample #:		
28 CAD #:	X1A	Miscellaneous Material 1" X 1" Blue Ceramic Floor Tile System	GIRLS' PHY ED LOCKER ROOM 0301	540 Sq Ft	N	ASSUMED	5
Comments: SHOWER & RESTROOM AREAS.					Sample #:		
29 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	GIRLS' PHY ED LOCKER ROOM OFFICE 0302 AND CLOSET	100 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: UNDER CARPET EXCEPT IN CLOSET.					Sample #:		
30 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	GIRLS' PHY ED LOCKER ROOM OFFICE 0302	6 Sq Ft	N	5 CH	5
Comments:					Sample #:		
31 CAD #:	X1A	Miscellaneous Material 1" X 1" Blue Ceramic Floor Tile System	GIRLS' PHY ED LOCKER ROOM OFFICE 0302 RESTROOM	20 Sq Ft	N	ASSUMED	5
Comments: SHOWER AREA.					Sample #:		
32 CAD #:	X1B	Miscellaneous Material 1" X 1" Gray/Blue/White Pool Ceramic Tile System	POOL AREA 0305	4000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
33 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	CUSTODIAL CLOSET 0304A	25 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
35 CAD #:	X1C	Miscellaneous Material 1" X 1" Beige Ceramic Floor Tile System	GIRLS' VARSITY LOCKER ROOM 0401	315 Sq Ft	N	ASSUMED	5
Comments: SHOWER & RESTROOM AREAS.					Sample #:		
37 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	GIRLS' VARSITY LOCKER ROOM OFFICE 0402	4 Sq Ft	N	5 CH	5
Comments:					Sample #:		
38 CAD #:	X1C	Miscellaneous Material 1" X 1" Beige Ceramic Floor Tile System	GIRLS' VARSITY LOCKER ROOM OFFICE 0402 RESTROOM	20 Sq Ft	N	ASSUMED	5
Comments: SHOWER AREA.					Sample #:		
40 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	CUSTODIAL CLOSET 0216D	25 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
51 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	ROOM 0216	660 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
53 CAD #:	J3A	Miscellaneous Cementitious Material Black Table Tops w/Metal Legs	ROOM 0218 (CERAMICS CLASSROOM)	20 Sq Ft	N	20 CH	5
Comments: TWO (2) TABLES. CHIPPED CORNERS.					Sample #:		
55 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 0218 (CERAMICS CLASSROOM)	35 Sq Ft	N	5 CH	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
56 CAD #:	V0A	Sink Undercoating Black	ROOM 0217B (KILN AREA)	5 Sq Ft	N	6 CH	5
Comments: ONE (1) SINK.					Sample #: 021610-MA-09		
60 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 0217	25 Sq Ft	N	5 CH	5
Comments:					Sample #:		
61 CAD #:	J1A	Cementitious Panels Gray Panels	ROOM 0215C (BACK CORNER)	1 Sq Ft	N	ASSUMED	5
Comments: ROUND POTTERY WHEELS IN STORAGE LOCKER #2.					Sample #:		
62 CAD #:	J3A	Miscellaneous Cementitious Material Black Table Tops w/Metal Legs	ROOM 0215A (ART STORAGE)	20 Sq Ft	N	20 CH	5
Comments: TWO (2) TABLES.					Sample #:		
64 CAD #:	L0A	Flexible Duct Connector Coarse White Fabric	ROOM 0215C (MECHANICAL ROOM)	48 Sq Ft	N	50-90 CH	5
Comments: FIVE (5) JOINTS, INCLUDING ONE (1) INSIDE AHU 3 BY UNEXCAVATED GATE.					Sample #: 2001-1504-D3; ACB450-AB-A004		
65 CAD #:	X0D	Miscellaneous Material AHU Tar Gasket	ROOM 0215C (MECHANICAL ROOM)	10 Sq Ft	N	2 CH	5
Comments:					Sample #: 021610-MA-07		
67 CAD #:	X0C	Miscellaneous Material Pipe/Valve Flange Gaskets	ROOM 0215C (MECHANICAL ROOM)	135 Sq Ft	N	55 CH	5
Comments: APPROXIMATELY ONE HUNDRED THIRTY-FIVE (135) OLD FLANGE GASKETS.					Sample #: 021610-MA-11		
68 CAD #:	P0C	Fire Doors Metal Jacket -1.5 Hr Rating (Underwriters Laboratories)	MECHANICAL ROOM 0215A	50 Sq Ft	N	ASSUMED	5
Comments: TWO (2) DOORS.					Sample #:		
71 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 0215	10 Sq Ft	N	5 CH	5
Comments:					Sample #:		
74 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 0214	10 Sq Ft	N	5 CH	5
Comments:					Sample #:		
76 CAD #:	L0A	Flexible Duct Connector Coarse White Fabric	GROUNDS STORAGE 0213	12 Sq Ft	N	50-90 CH	5
Comments: THREE (3) JOINTS.					Sample #:		
77 CAD #:	X0D	Miscellaneous Material AHU Tar Gasket	GROUNDS STORAGE 0213	5 Sq Ft	N	2 CH	5
Comments:					Sample #:		
79 CAD #:	X0R	Miscellaneous Material Tan Mirror Adhesive (Thin Metal Frame)	ROOM 0212 (WEIGHT ROOM)	8 Sq Ft	N	ASSUMED	5
Comments: EXPOSED ADHESIVE WHERE CENTER MIRROR WAS.					Sample #:		
80 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 0212 (WEIGHT ROOM) OFFICE 0212C	90 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE CHIPPED IN MULTIPLE LOCATIONS. MONITOR.					Sample #:		
84 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 0211 (WOOD SHOP CLASSROOM)	5 Sq Ft	N	5 CH	5
Comments:					Sample #:		
86 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 0208 (WOOD SHOP)	10 Sq Ft	N	5 CH	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
87 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 0208 (WOOD SHOP) OFFICE 0208C	90 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: WEAR THROUGHOUT. RECOMMEND SEALING WITH WAX AND COVER WITH CHAIR MAT.							Sample #:
90 CAD #:	B2A	Millboard Pipe Insulation 1963 Original Building	RESTROOM 0206 PIPE CHASE	30 Lin Ft	N	10 CH	5
Comments: VISIBLE FROM ABOVE CEILING IN RESTROOM. INACCESSIBLE FOR REMOVAL.							Sample #:
91 CAD #:	A2A	Mudded Pipe Joints on Millboard Insulation 1963 Original Building	RESTROOM 0206 PIPE CHASE	4 Joints	N	30 CH	5
Comments: VISIBLE FROM ABOVE CEILING IN RESTROOM. INACCESSIBLE FOR REMOVAL.							Sample #:
92 CAD #:	B3B	Pre-Formed Pipe Insulation Water Lines	RESTROOM 0206 PIPE CHASE	30 Lin Ft	N	ASSUMED	5
Comments: VISIBLE FROM ABOVE CEILING IN RESTROOM. INACCESSIBLE FOR REMOVAL OR SAMPLING. SAMPLE 01 WAS ANALYZED AS "NONE DETECTED", BUT TWO (2) ADDITIONAL SAMPLES ARE REQUIRED TO CONFIRM.							Sample #: 072512MA-01
93 CAD #:	A3B	Mudded Pipe Joints on Pre-formed Insulation Water Lines	RESTROOM 0206 PIPE CHASE	6 Joints	N	20 CH	5
Comments: VISIBLE FROM ABOVE CEILING IN RESTROOM. INACCESSIBLE FOR REMOVAL.							Sample #: 072512MA-02
94 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	CUSTODIAL CLOSET 0205	25 Sq Ft	N	ASSUMED	5
Comments:							Sample #:
97 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 0204	5 Sq Ft	N	5 CH	5
Comments:							Sample #:
110 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	STAIRWELL 1299D	1000 Sq Ft	N	ASSUMED	5
Comments:							Sample #:
117 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1201	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: REPLACEMENT TILES IN SOUTHEAST CORNER. CHIPPED TILE 10' FROM ENTRANCE.							Sample #:
118 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1201	10 Sq Ft	N	5 CH	5
Comments:							Sample #:
119 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1201	15 Sq Ft	N	5 CH	5
Comments:							Sample #:
120 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1207	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: CHIPPED TILE IN NORTHWEST CORNER UNDER TEACHER'S DESK. REPLACEMENT TILES IN SOUTHWEST CORNER.							Sample #:
121 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1209	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE PIECES MISSING BETWEEN 1209 & 1211A OFFICE. SMALL CHIP BY EAST WALL.							Sample #:
122 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1211/1211A	380 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments:							Sample #:
123 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1211/1211A	8 Sq Ft	N	5 CH	5
Comments:							Sample #:
124 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	CUSTODIAL CLOSET 1204	15 Sq Ft	N	ASSUMED	5
Comments:							Sample #:

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
126 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1213	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE STARTING TO WEAR & CRACK BY TEACHER'S DESK. RECOMMEND CHAIR MAT.					Sample #:		
127 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1213	10 Sq Ft	N	5 CH	5
Comments: ASSUMED PRESENT BEHIND TACKBOARD.					Sample #:		
128 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1213	15 Sq Ft	N	5 CH	5
Comments:					Sample #:		
130 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1208	10 Sq Ft	N	5 CH	5
Comments:					Sample #:		
131 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1208	10 Sq Ft	N	5 CH	5
Comments:					Sample #:		
133 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1215	5 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
134 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1215	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
135 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	STAIRWELL 1299E	1000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
136 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1212	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: ONE (1) TILE MISSING BY EAST WALL.					Sample #:		
137 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1212	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
138 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1212	20 Sq Ft	N	5 CH	5
Comments: THREE (3) BOARDS.					Sample #:		
140 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1217	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
141 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1217	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
142 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1214	420 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE WEARING UNDER TEACHER'S DESK. RECOMMEND CHAIR MAT.					Sample #:		
143 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1214	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
144 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1219	1350 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: INCLUDES MATERIAL UNDER 12" TILES. TABLES & CHAIRS SCRATCHING FLOOR TILE. RECOMMEND CHAIR MAT.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
146 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1219	10 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
147 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1219	10 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
148 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1219 OFFICE & STORAGE ROOMS (1219A, B & C)	460 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments:					Sample #: 021610-MA-39		
149 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1218	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE WEARING UNDER TEACHER'S DESK. RECOMMEND CHAIR MAT.					Sample #:		
150 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1218	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS. WEST BOARD COVERED WITH TACKBOARD.					Sample #:		
151 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1218	10 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
152 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1221	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE WEARING UNDER TEACHER'S DESK. RECOMMEND CHAIR MAT.					Sample #:		
153 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1221	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS COVERED WITH WHITEBOARD PAPER.					Sample #:		
154 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1221	10 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
155 CAD #:	B2A	Millboard Pipe Insulation 1963 Original Building	RESTROOM ACROSS FROM 1221	10 Lin Ft	N	10 CH	5
Comments: ASSUMED PRESENT IN NARROW PART OF CHASE. INACCESSIBLE W/O DEMOLITION.					Sample #:		
156 CAD #:	A2A	Mudded Pipe Joints on Millboard Insulation 1963 Original Building	RESTROOM ACROSS FROM 1221	4 Joints	N	30 CH	5
Comments: ASSUMED PRESENT IN NARROW PART OF CHASE. INACCESSIBLE W/O DEMOLITION.					Sample #: 207W-4A, 6A		
157 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	STAIRWELL 1499F	2000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
162 CAD #:	S0A	Wood Floor Felt / Vapor Barrier On-Grade (1963)	ROOM 1302 (CLAIR MCMANN GYMNASIUM)	12000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
163 CAD #:	X1I	Miscellaneous Material 1" X 1" White Ceramic Floor Tile System	ROOM 1302 (CLAIR MCMANN GYMNASIUM)	25 Sq Ft	N	ASSUMED	5
Comments: AT DRINKING FOUNTAINS.					Sample #:		
164 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1302 (CLAIR MCMANN GYMNASIUM)	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD. SOUTH ENTRANCE.					Sample #:		
165 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	STAIRWELL 1399G	700 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
166 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	STAIRWELL 1399H	700 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
167 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	STORAGE 1305	8 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
171 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	THROUGHOUT KITCHEN AREA	2000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
172 CAD #:	L0A	Flexible Duct Connector Coarse White Fabric	KITCHEN DRY STORAGE/MECHANICAL 1412	20 Sq Ft	N	50-90 CH	5
Comments: THREE (3) JOINTS.					Sample #:		
173 CAD #:	X0D	Miscellaneous Material AHU Tar Gasket	KITCHEN DRY STORAGE/MECHANICAL 1412	10 Sq Ft	N	2 CH	5
Comments:					Sample #:		
174 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	KITCHEN CUSTODIAL CLOSET 1413	25 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
175 CAD #:	X0B	Miscellaneous Material Adhesive for Yellow Milkboard	KITCHEN STORAGE 1403	80 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
176 CAD #:	X0B	Miscellaneous Material Adhesive for Yellow Milkboard	KITCHEN DISHWASHING AREA	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
177 CAD #:	B3A	Pre-Formed Pipe Insulation 1963 Original Building - Heating Lines	KITCHEN BREAK AREA 1409	8 Lin Ft	N	60 AM	5
Comments: IN WALL CHASE AT BOTTOM OF STAIRS. INACCESSIBLE FOR REMOVAL. RECOMMEND VERIFICATION SAMPLING IF POSSIBLE.					Sample #: 207W1A		
178 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	KITCHEN BREAK AREA 1409	310 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE CRACKING AT ENTRANCE.					Sample #:		
180 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	STAIRWELL 1399I	1000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
182 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	CUSTODIAL CLOSET 1306	15 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
184 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	STAIRWELL 1399J	600 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
186 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	CUSTODIAL HALLWAY 1309A	30 Sq Ft	N	ASSUMED	5
Comments: AT SLOP SINK.					Sample #:		
188 CAD #:	X0R	Miscellaneous Material Tan Mirror Adhesive (Thin Metal Frame)	CUSTODIAL BREAK ROOM 1311	1 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
191 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ENGINEER'S OFFICE 1310	8 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
192 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	STAIRWELL 1499K	1000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
198 CAD #:	X1K	Miscellaneous Material 1" X 1" Gray w/White & Blue Accents Ceramic Floor Tile System	1996 ADDITION FIELDHOUSE RESTROOMS	432 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
200 CAD #:	S0B	Wood Floor Felt / Vapor Barrier Elevated (1963)	AUDITORIUM STAGE 1504	2000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
203 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	AUDITORIUM LOBBY 1501	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD. NORTH WALL, EAST END.					Sample #:		
207 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	CUSTODIAL CLOSET 1010B	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
209 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1017	8 Sq Ft	N	5 CH	5
Comments: BEHIND WOOD PANEL.					Sample #:		
210 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1017	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
212 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1018	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
214 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	STAIRWELL 1099B	1000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
215 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	NURSE'S OFFICE ROOM 1019	275 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: WEARING UNDER CHAIRS W/WHEELS. CHAIR MAT INSTALLED. SMALL CHIP BY ENTRANCE.					Sample #:		
217 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	NURSE'S OFFICE ROOM 1019	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
218 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	NURSE'S OFFICE ROOM 1020	225 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments:					Sample #:		
219 CAD #:	X0R	Miscellaneous Material Tan Mirror Adhesive (Thin Metal Frame)	NURSE'S OFFICE ROOM 1020	1 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
220 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	NURSE'S OFFICE ROOM 1020A	30 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: PIECE MISSING NEAR ENTRANCE.					Sample #:		
221 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	NURSE'S OFFICE RESTROOM 1020B	48 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: REPLACEMENT TILES AT TOILET & SINK.					Sample #:		
222 CAD #:	R0F	Baseboard/Mopboard Adhesive 4" Dark Brown Baseboard	NURSE'S OFFICE RESTROOM 1020B	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		



IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
223 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	NURSE'S OFFICE ROOM 1021	187 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments:					Sample #:		
224 CAD #:	X0R	Miscellaneous Material Tan Mirror Adhesive (Thin Metal Frame)	NURSE'S OFFICE ROOM 1021	1 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
225 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Brown w/Dark Brown & Beige Streaks	RESTROOM 1021A	45 Sq Ft	N	5 CH (MASTIC ONLY)	5
Comments:					Sample #: 021610-MA-41		
227 CAD #:	R0F	Baseboard/Mopboard Adhesive 4" Dark Brown Baseboard	STORAGE 1021B AND RESTROOM	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
230 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	CLINIC AREA 1022	6 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
232 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1210	8 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
233 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1102	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: CHIPPED TILE IN SW CORNER.					Sample #:		
234 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1102	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
235 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1102	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
236 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1101	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: WEARING & SCRATCHING UNDER TEACHER'S DESK. RECOMMEND CHAIR MAT.					Sample #:		
237 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1101	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
238 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1104	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
239 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1104	20 Sq Ft	N	5 CH	5
Comments: FOUR (4) BOARDS.					Sample #:		
242 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1103	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILES COMING LOOSE DOWN MIDDLE OF ROOM. REPLACEMENT TILES AT ENTRANCES & WINDOWS.					Sample #:		
243 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1103	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
244 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1103	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
246 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1105/1103A	420 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TWO (2) ROOMS. WEARING UNDER CHAIRS. RECOMMEND CHAIR MAT.					Sample #:		
247 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1105	3 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
248 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1107	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: SMALL CHIP AT ENTRANCE.					Sample #:		
249 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	CUSTODIAL CLOSET 1106	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
250 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	STAIRWELL 1199C	1000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
252 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1109	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
255 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 1113	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: WEARING UNDER DESKS & CHAIRS. RECOMMEND CHAIR MAT.					Sample #:		
256 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1113	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
257 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1113	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
259 CAD #:	B2A	Millboard Pipe Insulation 1963 Original Building	LIBRARY 1110	80 Lin Ft	N	10 CH	5
Comments: INACCESSIBLE ABOVE PLASTER CEILING.					Sample #:		
260 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	LIBRARY 1110	80 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD, PAINTED WHITE. ON SOUTH WALL BETWEEN 1114 & 1116.					Sample #:		
266 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 1119	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
267 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 1119	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
275 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2203	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.					Sample #:		
277 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2203	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
278 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	CUSTODIAL CLOSET 2204	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
280 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2206	8 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
281 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2205	400 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE WEARING UNDER TEACHER'S DESK. RECOMMEND CHAIR MAT.					Sample #:		
282 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2205	10 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
283 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2205	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
284 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2208	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE WEAR UNDER TEACHER'S DESK. RECOMMEND CHAIR MAT.					Sample #:		
285 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2208	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.					Sample #:		
286 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2208	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
287 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2207	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.					Sample #:		
288 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2208	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
289 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2207	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: CRACKS IN TILE IN SW CORNER.					Sample #:	2001-1501-JN02	
290 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2207	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
291 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2207	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
292 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2210	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.					Sample #:		
295 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2210	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
296 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2210	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
297 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2209	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
298 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2209	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: WEARING UNDER TEACHER'S DESK. RECOMMEND CHAIR MAT. CHIP IN TILE 6' FROM DOOR							Sample #:
299 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2209	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.							Sample #:
300 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2209	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.							Sample #:
304 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2211	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.							Sample #:
305 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2211	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.							Sample #:
307 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2218	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: WEARING UNDER COMPUTER CHAIRS. RECOMMEND CHAIR MAT.							Sample #:
308 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2218	10 Sq Ft	N	5 CH	5
Comments: THREE (3) BOARDS.							Sample #:
309 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2218	10 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.							Sample #:
310 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2220	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.							Sample #:
311 CAD #:	K0C	9" x 9" Vinyl Floor Tile & Mastic Beige w/Gray & Dark Brown Flecks	ROOM 2220	1100 Sq Ft	N	3 CH (TILE ONLY)	5
Comments: INCLUDES PATCHES. APPROXIMATELY 30 SQ FT. ONLY SAMPLE MA-15 ANALYZED TO CONTAIN ASBESTOS. CHIPPED PIECE BY OVEN.							Sample #: 021610-MA-15; 230-4; 2001-1501-JN-15
312 CAD #:	U0A	Light Pad Insulation Small, Round Light Fixture	ROOM 2220	1 Sq Ft	Y	ASSUMED	4
Comments: GLOBE MISSING. BY RESTROOM. STARTING TO FALL APART. RECOMMEND REMOVAL AND REPLACEMENT.							Sample #:
313 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2220	6 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.							Sample #:
315 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	2ND FLOOR TEACHERS' LOUNGE 2222	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.							Sample #:
322 CAD #:	X1M	Miscellaneous Material 6" X 6" Red Quarry Tile System	ROOM 2213	1750 Sq Ft	N	ASSUMED	5
Comments:							Sample #:
323 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2213	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD. BEHIND WHITEBOARD.							Sample #:
324 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2213	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD. BEHIND WHITEBOARD.							Sample #:

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
325 CAD #:	X0A	Miscellaneous Material Milkboard Adhesive	ROOM 2213	800 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
326 CAD #:	X1M	Miscellaneous Material 6" X 6" Red Quarry Tile System	STORAGE ROOM 2213A	72 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
328 CAD #:	X0R	Miscellaneous Material Tan Mirror Adhesive (Thin Metal Frame)	STAFF RESTROOM NEAR STORAGE 2302	3 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
329 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	WEST ENTRY 2419 TO ROOMS 2402 (CHOIR) & 2409 (BAND)	150 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments:					Sample #:		
331 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2409 (BAND) & ASSOCIATED ROOMS	2700 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: UNDER CARPET EXCEPT IN PERCUSSION STORAGE (2412), ROBE STORAGE (2411) & INSTRUMENT STORAGE (2410) ROOMS. LARGE CRACK IN 2411.					Sample #:		
332 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2409 (BAND)	8 Sq Ft	N	5 CH	5
Comments:					Sample #:		
333 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2409 (BAND)	15 Sq Ft	N	5 CH	5
Comments: THREE (3) BOARDS.					Sample #:		
334 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	BAND OFFICE 2418	4 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
335 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2402 (CHOIR) & ASSOCIATED ROOMS	2500 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: UNDER CARPET EXCEPT IN ROBE STORAGE ROOM 2406.					Sample #:		
337 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2402 (CHOIR)	8 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
338 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2402 (CHOIR)	8 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
339 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	CHOIR OFFICE 2407	4 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
340 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	EAST ENTRY 2417 TO ROOMS 2402 (CHOIR) & 2409 (BAND)	150 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments:					Sample #:		
341 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2401	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.					Sample #:		
343 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2401	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
344 CAD #:	L0A	Flexible Duct Connector Coarse White Fabric	WEST PENTHOUSE MECHANICAL ROOM BY ROOM 2304	84 Sq Ft	N	50-90 CH	5
Comments: FIFTEEN (15) JOINTS.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
345 CAD #:	X0D	Miscellaneous Material AHU Tar Gasket	WEST PENTHOUSE MECHANICAL ROOM BY ROOM 2304	40 Sq Ft	N	2 CH	5
Comments: FOUR (4) MCQUAY AHU'S.					Sample #:		
347 CAD #:	A3C	Mudded Pipe Joints on Pre-formed Insulation Kalo	AREA ABOVE BAND & CHOIR AREAS	2 Joints	N	8 CH	5
Comments: TWO (2) ROOF DRAINS. LIMITED VISIBILITY. ACCESS FROM WEST PENTHOUSE.					Sample #: 071816-BF-4, 5, 6		
349 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2420	8 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
351 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2421	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
355 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2102	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.					Sample #:		
357 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2102	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
358 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	HALLWAY 2501 OFF AUDITORIUM BALCONY	600 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE MISSING AT ENTRANCE TO 2502.					Sample #:		
359 CAD #:	X0R	Miscellaneous Material Tan Mirror Adhesive (Thin Metal Frame)	WOMEN'S STAFF RESTROOM NEAR ROOM 2425	1 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
361 CAD #:	X0R	Miscellaneous Material Tan Mirror Adhesive (Thin Metal Frame)	ROOM 2425	2 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
363 CAD #:	J1B	Cementitious Panels Window Panels	ROOM 2426	30 Sq Ft	N	ASSUMED	5
Comments: THREE (3) PANELS. PAINTED WHITE.					Sample #:		
364 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2426	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
365 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2426	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
366 CAD #:	X0R	Miscellaneous Material Tan Mirror Adhesive (Thin Metal Frame)	ROOM 2427 (STAGE)	10 Sq Ft	N	ASSUMED	5
Comments: SIX (6) MIRRORS.					Sample #:		
368 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	DRESSING ROOMS 2506 & 2508 & HALLWAY 2505 OFF OF WEST STAGE MEZZANINE	200 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: ACCESSIBLE FROM STAGE LADDER OR 2ND FLOOR HALLWAY. CHIPPED IN 2506.					Sample #:		
369 CAD #:	X0R	Miscellaneous Material Tan Mirror Adhesive (Thin Metal Frame)	DRESSING ROOMS 2506 & 2508 & HALLWAY 2505 OFF OF WEST STAGE MEZZANINE	15 Sq Ft	N	ASSUMED	5
Comments: TEN (10) MIRRORS.					Sample #:		
370 CAD #:	L0A	Flexible Duct Connector Coarse White Fabric	EAST PENTHOUSE MECHANICAL ROOM	42 Sq Ft	N	50-90 CH	5
Comments: EIGHT (8) JOINTS.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
371 CAD #:	X0D	Miscellaneous Material AHU Tar Gasket	EAST PENTHOUSE MECHANICAL ROOM	20 Sq Ft	N	2 CH	5
Comments: TWO (2) AHU'S.							Sample #:
372 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	NORTHEAST STAIRWELL 2299H	2 Joints	N	35 CH	5
Comments: INSIDE WALL. VISIBLE THROUGH UNIVENT. INACCESSIBLE.							Sample #:
376 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2108	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.							Sample #:
377 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2108	1200 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: CHIPPED TILE AT SEVERAL AREAS, SEALED WITH WAX.							Sample #: 021017-BF-1
378 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2108	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD BEHIND WHITEBOARD.							Sample #:
379 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2108	5 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.							Sample #:
382 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2110	1200 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE WEARING UNDER TEACHER'S DESK. RECOMMEND CHAIR MAT.							Sample #:
383 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2110	12 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.							Sample #:
384 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2110	12 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.							Sample #:
391 CAD #:	L0A	Flexible Duct Connector Coarse White Fabric	MECHANICAL ROOM 2216	12 Sq Ft	N	50-90 CH	5
Comments: TWO (2) JOINTS. ONE (1) JOINT COVERED W/SILVER FIBERGLASS INSULATION.							Sample #:
392 CAD #:	X0D	Miscellaneous Material AHU Tar Gasket	MECHANICAL ROOM 2216	10 Sq Ft	N	2 CH	5
Comments:							Sample #:
393 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2112	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.							Sample #:
394 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2112	750 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments:							Sample #:
395 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2112	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.							Sample #: 060713-BF-2, 4
396 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2112	30 Sq Ft	N	5 CH	5
Comments: ALSO SAMPLED IN ROOM 1009 (060713-BF-1) & 2201 (060713-BF-5). ANALYZED AS "NONE DETECTED" IN ROOM 2201. TWO (2) BOARDS.							Sample #: 060713-BF-1, 3, 5
397 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2114	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.							Sample #:

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
400 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2114	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
401 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2114	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
402 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2107	1200 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: PIECE OF TILE MISSING IN FRONT OF HEATER.					Sample #:		
405 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2107	10 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
406 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2107A	200 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments: TILE CHIPPED AT DOOR BETWEEN 2107A & 2109.					Sample #:		
408 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2109	200 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments:					Sample #:		
411 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 2111	2 Joints	N	35 CH	5
Comments: INSIDE UNIVENT.					Sample #:		
412 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/White Streaks	ROOM 2111	1200 Sq Ft	N	3-8 CH (TILE ONLY)	5
Comments:					Sample #:		
414 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2111	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
415 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2111	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
419 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2113	10 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
420 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2113	8 Sq Ft	N	5 CH	5
Comments: ONE (1) BOARD.					Sample #:		
434 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2118	20 Sq Ft	N	5 CH	5
Comments: FOUR (4) BOARDS.					Sample #:		
436 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2115	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
439 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2115	15 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
442 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2120	10 Sq Ft	N	5 CH	5
Comments: BEHIND WHITEBOARDS.					Sample #:		



IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
443 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2120	10 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
450 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2120B	6 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
454 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2122	10 Sq Ft	N	5 CH	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
455 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2122	10 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		
462 CAD #:	X0G	Miscellaneous Material Metal Framed Chalkboard Adhesive -Black	ROOM 2117	5 Sq Ft	N	5 CH	5
Comments:					Sample #: 060713-BF-6		
463 CAD #:	X0M	Miscellaneous Material Tackboard Adhesive	ROOM 2117	10 Sq Ft	N	5 CH	5
Comments: TWO (2) BOARDS.					Sample #:		