

Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

PLEASE NOTE: Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

EPA ASSESSMENT CATEGORIES:	1 = Damaged or significantly damaged TSI ACM	5 = ACBM with potential for damage
	2 = Damaged friable surfacing ACM	6 = ACBM with potential for significant damage
	3 = Significantly damaged friable surfacing ACM	7 = Remaining friable ACBM or friable suspect ACBM
	4 = Damaged or significantly damaged friable miscellaneous ACM	

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
6 CAD #:	Q0A	Carpet Adhesive Green with White and Pink Berber Carpet (Yellow Adhesive)	THROUGHOUT 1925 ORIGINAL BUILDING (EAST)	20000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
7 CAD #:	X0P	Miscellaneous Material Exterior Door & Transom Caulk (1925)	1925 ORIGINAL BUILDING 1ST FLOOR ENTRANCES	16 Sq Ft	N	3 CH	5
Comments: THREE (3) DOUBLE DOORS. TWO (2) SINGLE DOORS.					Sample #: 051712-MV-01		
8 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 1301	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 2ND FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
12 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 1301	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
14 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 1302	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 2ND FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
17 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 1302	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
23 CAD #:	X1C	Miscellaneous Material 6" X 6" Red Quarry Tile System	1925 ORIGINAL BUILDING SOUTH STAIRWELL	130 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
24 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 1303	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 2ND FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
25 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 1303	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET & SHEET VINYL FLOORING.					Sample #:		
27 CAD #:	V0C	Sink Undercoating Black	ROOM 1303	6 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #: 033009ML-10		
28 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Tan w/Brown & Beige Streaks	1925 ORIGINAL BUILDING 1ST FLOOR HALLWAY 1300	800 Sq Ft	N	7 CH (TILE), NONE DETECTED (MASTIC)	5
Comments: UNDER CARPET. INLAID IN CENTER OF HALLWAY. AMOUNT ESTIMATED.					Sample #: 033009ML-08		
30 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 1306 & ASSOCIATED ROOMS	4 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 2ND FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
33 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 1306 & ASSOCIATED ROOMS	350 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET & FLOOR TILE.					Sample #:		
34 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Tan w/Brown & Beige Streaks	ROOM 1306 & ASSOCIATED ROOMS	350 Sq Ft	N	7 CH (TILE), NONE DETECTED (MASTIC)	5
Comments: UNDER CARPET EXCEPT IN CLOSET 1304A. LOOSE TILES IN ROOM 1304A.					Sample #:		
36 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 1307	12 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 2ND FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
39 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Gray w/Pink & White Streaks	ROOM 1307	900 Sq Ft	N	5 CH (TILE & MASTIC)	5
Comments: UNDER CARPET. INCLUDES FELT UNDERLAYMENT. FELT & FELT MASTIC WERE ANALYZED AS "NONE DETECTED".					Sample #: 033009ML-11		
40 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 1307	900 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET & FLOOR TILE.					Sample #:		
44 CAD #:	X0B	Miscellaneous Material Pipe/Valve Flange Gaskets	1926 ADDITION TUNNEL LINK 0300	24 Sq Ft	N	ASSUMED	5
Comments: APPROXIMATELY TWENTY-FOUR (24) GASKETS.					Sample #:		
47 CAD #:	S0AA	Wood Floor Felt / Vapor Barrier Renovation #1	1925 ORIGINAL BUILDING GYMNASIUM 1317	2400 Sq Ft	N	ASSUMED	5
Comments: WOOD FLOOR REPLACED. OLD FELT LAYER, ETC. MAY STILL BE PRESENT.					Sample #:		
48 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	1925 ORIGINAL BUILDING GYMNASIUM STORAGE 1317A	70 Sq Ft	N	ASSUMED	5
Comments: OLDER WOOD FLOOR THAN GYMNASIUM.					Sample #:		
50 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	CUSTODIAL CLOSET 1317B OFF GYMNASIUM 1317	50 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
51 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 1308	12 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 2ND FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
54 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 1308	900 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
56 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	CLOSET 1308A	2 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 2ND FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
57 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 1309	10 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 2ND FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
60 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 1309	1000 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
62 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Tan w/Brown & White Streaks	1925 ORIGINAL BUILDING NORTH STAIRWELL 1399B	340 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: ON LANDINGS. CHIPPED TILE W/EXPOSED MASTIC NEAR RADIATOR LINE.					Sample #:	033009ML-15	
64 CAD #:	X1C	Miscellaneous Material 6" X 6" Red Quarry Tile System	1925 ORIGINAL BUILDING NORTH STAIRWELL 1399B	130 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
66 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	1925 ORIGINAL BUILDING 1ST FLOOR HALLWAY 1300B	150 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET & FLOOR TILE.					Sample #:		
67 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Tan w/Brown & White Streaks	1925 ORIGINAL BUILDING 1ST FLOOR HALLWAY 1300B	150 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: UNDER CARPET.					Sample #:		
69 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 1312	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 2ND FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
70 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 1312	900 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET. INCLUDES STAGE.					Sample #:		
71 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	STORAGE 1312A	4 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 2ND FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
72 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 1312B	4 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 2ND FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
73 CAD #:	B2A	Millboard Pipe Insulation 1925 Original Building	ROOM 1314	4 Lin Ft	N	ASSUMED	5
Comments: ABOVE PLASTER CEILING. ROOF DRAIN. INACCESSIBLE FOR SAMPLING/REMOVAL.					Sample #:		
74 CAD #:	A2A	Mudded Pipe Joints on Millboard Insulation 1925 Original Building	ROOM 1314	2 Joints	N	ASSUMED	5
Comments: ABOVE PLASTER CEILING. INACCESSIBLE FOR SAMPLING/REMOVAL.					Sample #:		
76 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Tan w/Brown & White Streaks	ROOM 1314	160 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: UNDER CARPET.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
78 CAD #:	X1D	Miscellaneous Material Brown 6" X 6" 1966 Quarry Tile System	ROOM 1313	700 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
79 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ROOM 1313B	50 Sq Ft	N	5 CH (TILE), 10 CH (MASTIC)	5
Comments: DIRTY & WATER-DAMAGED. BROKEN BY ENTRANCE W/FOUR (4) PIECES MISSING. TILES BECOMING LOOSE IN SEVERAL LOCATIONS.					Sample #: 033009ML-21		
82 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Tan w/Brown & Beige Streaks	1925 ORIGINAL BUILDING 2ND FLOOR HALLWAY 2300	800 Sq Ft	N	7 CH (TILE), NONE DETECTED (MASTIC)	5
Comments: UNDER CARPET. INLAID IN CENTER OF HALLWAY. AMOUNT ESTIMATED.					Sample #:		
84 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2301	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
85 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 2301	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
86 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2302	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
87 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 2302	660 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
89 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2303	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
92 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 2303	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
93 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2305 & CLOSET 2305A	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
94 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 2305 & CLOSET 2305A	260 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
97 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2307	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
98 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 2307	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
100 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2308	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
101 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 2308	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
102 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2309	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
103 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 2309	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
104 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2310	4 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
105 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 2310	280 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
106 CAD #:	K0Q	9" x 9" Vinyl Floor Tile & Mastic White with Gray Streaks and Flecks	ROOM 2310 RESTROOM	35 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
109 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2311	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
110 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 2311	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
112 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2312	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
115 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 2312	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
117 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2313	8 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
120 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 2313	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
121 CAD #:	B1A	Air Cell Pipe Insulation 1925 Original Building	ROOM 2314	4 Lin Ft	N	ASSUMED	5
Comments: ABOVE CEILING. ASSUMED PRESENT FOR 3RD FLOOR RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #:		
124 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 3301	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
125 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 3302	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
127 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Tan w/Brown & Beige Streaks	1925 ORIGINAL BUILDING 3RD FLOOR HALLWAY 3300	800 Sq Ft	N	7 CH (TILE), NONE DETECTED (MASTIC)	5
Comments: UNDER CARPET. INLAID IN CENTER OF HALLWAY. AMOUNT ESTIMATED.					Sample #:		
130 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 3303	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
131 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 3304	350 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET EXCEPT IN STORAGE ROOM.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
133 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 3305	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
134 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 3306	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
135 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 3307	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
136 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 3308	350 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
138 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 3309	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
139 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 3311	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
141 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1925 Original Building	ROOM 3312	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
149 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1975 ADDITION HALLWAY 1300D	40 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: IN TWO (2) DISPLAY CASES. TILE CRACKING IN THE NORTH DISPLAY CASE.					Sample #:		
160 CAD #:	R0B	Baseboard/Mopboard Adhesive 4" Brown	ROOM 1116	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
165 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 1117	180 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: SMALL CHIP UNDER RADIATOR.					Sample #: 033009ML-33		
166 CAD #:	R0C	Baseboard/Mopboard Adhesive 4" Black	ROOM 1117	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
169 CAD #:	Q0B	Carpet Adhesive Brown with Red Accents Berber Carpet (Yellow Adhesive)	ROOM 1114	450 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
170 CAD #:	R0C	Baseboard/Mopboard Adhesive 4" Black	ROOM 1114	50 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
171 CAD #:	V0D	Sink Undercoating Black w/Horizontal Faucet	ROOM 1114	5 Sq Ft	N	4 CH	5
Comments: ONE (1) SINK.					Sample #: 033009ML-35		
185 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	MEDIA CENTER ROOM 1110A (SERVER)	160 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: SLIGHT CRACKING THROUGHOUT.					Sample #:		
190 CAD #:	R0B	Baseboard/Mopboard Adhesive 4" Brown	ROOM 1118	30 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
193 CAD #:	Q0D	Carpet Adhesive Blue with Red Accents Berber Carpet	ROOM 1119	220 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
194 CAD #:	R0D	Baseboard/Mopboard Adhesive 4" Blue	ROOM 1119	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
199 CAD #:	R0B	Baseboard/Mopboard Adhesive 4" Brown	ROOM 1120	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
204 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 1121	180 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: OFF OF ROOM 1120. CRACKING AT ENTRY.					Sample #:		
205 CAD #:	R0C	Baseboard/Mopboard Adhesive 4" Black	ROOM 1121	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
215 CAD #:	X1B	Miscellaneous Material 1" X 1" Tan/Brown Ceramic Floor Tile System	MAIN OFFICE RESTROOMS	60 Sq Ft	N	ASSUMED	5
Comments: 2 RESTROOMS					Sample #:		
219 CAD #:	X1B	Miscellaneous Material 1" X 1" Tan/Brown Ceramic Floor Tile System	NURSE'S OFFICE 1011 RESTROOM	60 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
220 CAD #:	X1F	Miscellaneous Material 2" X 2" Gray with White Specks	NURSE'S OFFICE 1012 RESTROOM	45 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
228 CAD #:	X1A	Miscellaneous Material 6" X 6" Quarry Floor Tile System	KITCHEN 1104	1100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
239 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1975 ADDITION HALLWAY OUTSIDE ROOM 1101	22 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: IN DISPLAY CASE.					Sample #:		
243 CAD #:	X0N	Miscellaneous Material Tackboard Adhesive (1926)	THROUGHOUT 1926 ADDITION (WEST)	1200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
244 CAD #:	B1B	Air Cell Pipe Insulation 1926 Addition	THROUGHOUT 1926 ADDITION 1ST & 2ND FLOOR ROOMS	200 Lin Ft	N	20 CH	5
Comments: ABOVE PLASTER CEILING. ASSUMED PRESENT FEEDING RADIATORS. INACCESSIBLE FOR REMOVAL.					Sample #: 207H-8A		
257 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1926 ADDITION BASEMENT HALLWAY 0200/0200A	2360 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: MISSING TILE W/EXPOSED MASTIC OUTSIDE 0203 & 0202 SOUTH ENTRANCE. WARPED/CHIPPED TILE OUTSIDE 0207.					Sample #:		
263 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 0214	700 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
266 CAD #:	K0F	9" x 9" Vinyl Floor Tile & Mastic Brown w/Black & Beige Streaks	ROOM 0217	230 Sq Ft	N	5 CH (TILE)	5
Comments: MOST UNDER CARPET.					Sample #: 033009ML-55		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
272 CAD #:	X0I	Miscellaneous Material Coarse White Asbestos Gloves	ROOM 0218A (KILN ROOM)	6 Sq Ft	N	ASSUMED	5
Comments: THREE (3) PAIRS. FINGERTIPS FRAYING.				Sample #:			
274 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 0213	810 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: UNDER CARPET.				Sample #:			
276 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 0212	910 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: UNDER CARPET.				Sample #: 033009ML-54			
277 CAD #:	U0A	Light Pad Insulation Round Light Pads	BASEMENT STAIRWELL WEST	1 Sq Ft	N	65 CH	5
Comments: ONE (1) LIGHT.				Sample #: 033009ML-56			
280 CAD #:	K0F	9" x 9" Vinyl Floor Tile & Mastic Brown w/Black & Beige Streaks	CUSTODIAL STORAGE 0218B	140 Sq Ft	N	5 CH (TILE)	5
Comments: MOST UNDER CARPET.				Sample #:			
281 CAD #:	X1G	Miscellaneous Material 2' X 2' Tan Ceramic Floor Tile System	CUSTODIAL STORAGE 0210	130 Sq Ft	N	ASSUMED	5
Comments:				Sample #:			
284 CAD #:	K0F	9" x 9" Vinyl Floor Tile & Mastic Brown w/Black & Beige Streaks	ELECTRICAL ROOM 0211	120 Sq Ft	N	5 CH (TILE)	5
Comments: INCLUDES REPLACEMENT TILES. SLIGHT WEAR THROUGHOUT.				Sample #:			
285 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	BASEMENT STAIRWELL 0299E (DEAD END)	16 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments:				Sample #: 033009ML-55			
287 CAD #:	U0B	Light Pad Insulation Suspended Light	BASEMENT STAIRWELL 0299E	2 Sq Ft	N	ASSUMED	5
Comments:				Sample #:			
288 CAD #:	K0H	9" x 9" Vinyl Floor Tile & Mastic Tan w/Beige Marbling	ROOM 0208	450 Sq Ft	N	2 CH (TILE), 10 CH (MASTIC)	5
Comments: UNDER CARPET.				Sample #: 033009ML-57			
289 CAD #:	K0H	9" x 9" Vinyl Floor Tile & Mastic Tan w/Beige Marbling	STAFF RESTROOM 0207	30 Sq Ft	N	2 CH (TILE), 10 CH (MASTIC)	5
Comments: INCLUDES PATCHED TILES.				Sample #:			
291 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 0201 (ELEVATOR LOBBY)	110 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments:				Sample #:			
292 CAD #:	B1B	Air Cell Pipe Insulation 1926 Addition	CUSTODIAL CLOSET 1207A	15 Lin Ft	N	20 CH	5
Comments: ACCESS THROUGH CEILING HATCH. ONE (1) RISER IN CHASE. INACCESSIBLE FOR REMOVAL.				Sample #:			
296 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 1209	600 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: MULTIPLE BROKEN TILES NEAR SINK WHERE THERE IS WATER DAMAGE.				Sample #:			
298 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOMS 1210, 1211 & 1212	350 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: UNDER CARPET.				Sample #:			

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
302 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 1214	240 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: UNDER CARPET.						Sample #:	
304 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	HALLWAY 1200D	280 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments: CRACKING AT DOOR TO HALLWAY.						Sample #:	
307 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 1226	160 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments:						Sample #:	
310 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 1225	120 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments:						Sample #:	
312 CAD #:	X1B	Miscellaneous Material 1" X 1" Tan/Brown Ceramic Floor Tile System	ROOM 1225 RESTROOM	50 Sq Ft	N	ASSUMED	5
Comments:						Sample #:	
314 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 1224	150 Sq Ft	N	3-5 CH (TILE), 10 CH (MASTIC)	5
Comments:						Sample #:	
326 CAD #:	K2K	12" x 12" Vinyl Floor Tile & Mastic Tan w/Thin Brown & Beige Streaks	ROOM 1215A - SERVER ROOM	50 Sq Ft	N	2 CH (TILE), 10 CH (MASTIC)	5
Comments: ONE (1) BROKEN TILE.						Sample #: 033009ML-61	
330 CAD #:	U0A	Light Pad Insulation Round Light Pads	ROOM 1217A	1 Sq Ft	N	65 CH	5
Comments: ONE (1) LIGHT.						Sample #:	
332 CAD #:	K0J	9" x 9" Vinyl Floor Tile & Mastic Gray	1926 ADDITION 1ST FLOOR HALLWAY 1200	1500 Sq Ft	N	15 CH (TILE)	5
Comments: UNDER CARPET. INLAID IN CENTER OF HALLWAY. AMOUNT ESTIMATED.						Sample #:	
334 CAD #:	A2B	Mudded Pipe Joints on Millboard Insulation 1926 Addition	1926 ADDITION 1ST FLOOR NORTH HALLWAY 1200B	11 Joints	N	35-40 CH	5
Comments: ABOVE PLASTER CEILING OUTSIDE RESTROOMS. INACCESSIBLE FOR REMOVAL.						Sample #: 2001-1901-WMW-2A, 3A, 4A	
339 CAD #:	X0L	Miscellaneous Material Tan Terrazzo-Look Countertops	ROOM 1219	60 Sq Ft	N	35 CH	5
Comments: ADHESIVE LAYER ANALYZED AS "NONE DETECTED".						Sample #: 033009ML-63	
349 CAD #:	B1B	Air Cell Pipe Insulation 1926 Addition	1926 ADDITION 2ND FLOOR HALLWAY 2200	150 Lin Ft	N	20 CH	5
Comments: SOME VISIBLE ABOVE PLASTER CEILING ON NORTH SIDE. ADDITIONAL MATERIAL ASSUMED PRESENT IN REST OF HALLWAY, BUT INACCESSIBLE FOR REMOVAL DUE TO DUCTWORK.						Sample #:	
350 CAD #:	A1B	Mudded Pipe Joints on Air Cell Insulation 1926 Addition	1926 ADDITION 2ND FLOOR HALLWAY 2200	20 Joints	N	ASSUMED	5
Comments: ABOVE PLASTER CEILING. INACCESSIBLE FOR REMOVAL DUE TO DUCTWORK.						Sample #:	
351 CAD #:	K0J	9" x 9" Vinyl Floor Tile & Mastic Gray	1926 ADDITION 2ND FLOOR HALLWAY 2200	1500 Sq Ft	N	15 CH (TILE)	5
Comments: UNDER CARPET. INLAID IN CENTER OF HALLWAY. AMOUNT ESTIMATED.						Sample #: 040209ML-73	
371 CAD #:	K0G	9" x 9" Vinyl Floor Tile & Mastic Tan w/Red & Butterscotch Streaks	ROOM 2211A	20 Sq Ft	N	7 CH (TILE)	5
Comments: BROKEN & MISSING TILE. WEARING AT FRONT OF DOOR TO ROOM 2212.						Sample #: 033009ML-71	

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
372 CAD #:	U0A	Light Pad Insulation Round Light Pads	ROOM 2211A	1 Sq Ft	N	65 CH	5
Comments: ONE (1) LIGHT.					Sample #:		
387 CAD #:	K2L	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 2205	12 Sq Ft	N	8 CH (MASTIC)	5
Comments: UNDER SHEET VINYL FLOORING.					Sample #:		
389 CAD #:	K2L	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 2204	600 Sq Ft	N	8 CH (MASTIC)	5
Comments: UNDER CARPET.					Sample #: 040209ML-75		
390 CAD #:	K0K	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/Brown & Beige Streaks	ROOM 2204	600 Sq Ft	N	2 CH (TILE), 8 CH (MASTIC)	5
Comments: UNDER 12" TILE & CARPET.					Sample #: 040209ML-76		
392 CAD #:	K2L	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 2203	600 Sq Ft	N	8 CH (MASTIC)	5
Comments: UNDER CARPET.					Sample #:		
393 CAD #:	K0K	9" x 9" Vinyl Floor Tile & Mastic Light Brown w/Brown & Beige Streaks	ROOM 2203	600 Sq Ft	N	2 CH (TILE), 8 CH (MASTIC)	5
Comments: UNDER 12" TILE & CARPET.					Sample #:		
394 CAD #:	B1B	Air Cell Pipe Insulation 1926 Addition	1926 ADDITION 2ND FLOOR CUSTODIAL CLOSET 2203A	16 Lin Ft	N	20 CH	5
Comments: ONE (1) RISER IN CHASE & ABOVE CEILING. INACCESSIBLE FOR REMOVAL.					Sample #:		
395 CAD #:	A1B	Mudded Pipe Joints on Air Cell Insulation 1926 Addition	1926 ADDITION 2ND FLOOR CUSTODIAL CLOSET 2203A	1 Joints	N	ASSUMED	5
Comments: INACCESSIBLE FOR REMOVAL.					Sample #:		
399 CAD #:	K0J	9" x 9" Vinyl Floor Tile & Mastic Gray	1926 ADDITION 3RD FLOOR HALLWAY 3200	1500 Sq Ft	N	15 CH (TILE)	5
Comments: UNDER CARPET. INLAID IN CENTER OF HALLWAY. AMOUNT ESTIMATED.					Sample #:		
402 CAD #:	B1B	Air Cell Pipe Insulation 1926 Addition	1926 ADDITION 3RD FLOOR CUSTODIAL CLOSET 3203A	5 Lin Ft	N	20 CH	5
Comments: ASSUMED PRESENT BEHIND WALL FOR SINK. INACCESSIBLE FOR REMOVAL.					Sample #:		
404 CAD #:	K0C	9" x 9" Vinyl Floor Tile & Mastic Black w/White Streaks	1926 ADDITION 3RD FLOOR CUSTODIAL CLOSET 3203A	4 Sq Ft	N	3-6 CH (TILE)	5
Comments: BELOW SLOP SINK. HOMOGENEOUS TO 1925 ORIGINAL BUILDING. INACCESSIBLE FOR REMOVAL.					Sample #: 040209ML-78; 033009ML-14		
408 CAD #:	K2L	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 3205	10 Sq Ft	N	8 CH (MASTIC)	5
Comments: UNDER SHEET VINYL FLOORING.					Sample #:		
418 CAD #:	K2L	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 3209	12 Sq Ft	N	8 CH (MASTIC)	5
Comments: UNDER SHEET VINYL FLOORING.					Sample #:		
421 CAD #:	K2L	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 3210	12 Sq Ft	N	8 CH (MASTIC)	5
Comments: UNDER SHEET VINYL FLOORING.					Sample #:		
427 CAD #:	K2L	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	ROOM 3213	12 Sq Ft	N	8 CH (MASTIC)	5
Comments: UNDER SHEET VINYL FLOORING.					Sample #:		
432 CAD #:	K2M	12" x 12" Vinyl Floor Tile & Mastic Light Brown w/Tan & Beige Mottle	RESTROOM 3217	25 Sq Ft	N	3 CH (MASTIC)	5
Comments:					Sample #: 040209ML-82		