

Chart C - All Materials List

The following list contains all events observed by the inspector, whether or not they actually contained asbestos, and are grouped by homogeneous area (material type).

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
I2A 2' x 2' Acoustical Ceiling Tile Glacial w/Revealed Edge						Total Amount: 200 Sq. Ft.
	15	HALLWAY NORTH OF CAFETERIA	NONE DETECTED	110211MV-12		200 Sq. Ft.
I3A 2' x 4' Ceiling Tile Sparse Widthwise Fissures & Pin Holes						Total Amount: 9,000 Sq. Ft.
	1	THROUGHOUT SPACE	NONE DETECTED	110211MV-01		9000 Sq. Ft.
I3B 2' x 4' Ceiling Tile 2' x 2' Look Grubs & Pin Holes						Total Amount: 1,300 Sq. Ft.
	10	CAFETERIA	NONE DETECTED	110211MV-09		1300 Sq. Ft.
I3C 2' x 4' Ceiling Tile Vinyl-Coated Sheetrock						Total Amount: 1,000 Sq. Ft.
	13	STORAGE ROOM #1 BY CAFETERIA	NSM			1000 Sq. Ft.
I3D 2' x 4' Ceiling Tile Large Grubs, Pockmarks & Pin Holes						Total Amount: 3,000 Sq. Ft.
	2	THROUGHOUT SPACE	NONE DETECTED	110211MV-02	MV-02: TRAINING ROOM (LARGE).	3000 Sq. Ft.
I3E 2' x 4' Ceiling Tile Small Widthwise Fissures & Pin Holes						Total Amount: 1,500 Sq. Ft.
	3	THROUGHOUT SPACE	NONE DETECTED	110211MV-03	MV-03: STORAGE #3.	1500 Sq. Ft.
I3F 2' x 4' Ceiling Tile Small Pockmarks & Pin Holes						Total Amount: 500 Sq. Ft.
	17	MEN'S & WOMEN'S RESTROOMS WEST	NONE DETECTED	110211MV-14		500 Sq. Ft.
K2A 12" x 12" Vinyl Floor Tile & Mastic Tan w/Light Tan & Brown Swirls						Total Amount: 300 Sq. Ft.
	14	HALLWAY NORTH OF CAFETERIA	NONE DETECTED	110211MV-11		300 Sq. Ft.

Chart C - All Materials List - Brown & Bigelow Leased Space (cont.)

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
K2B 12" x 12" Vinyl Floor Tile & Mastic Tan						Total Amount: 1,300 Sq. Ft.
	11	CAFETERIA	5 CH (MASTIC ONLY)	110211MV-10		1300 Sq. Ft.
N0A Drywall/Joint Compound						Total Amount: 10,000 Sq. Ft.
	6	THROUGHOUT SPACE	NONE DETECTED	110211MV-06	MV-06: HALLWAY NORTH OF CAFETERIA.	10000 Sq. Ft.
Q0A Carpet Adhesive Tan Berber Carpet						Total Amount: 500 Sq. Ft.
	8	RECEPTION & DIRECTOR'S OFFICE	NONE DETECTED	110211MV-07		500 Sq. Ft.
Q0B Carpet Adhesive Dark Blue Berber Carpet						Total Amount: 200 Sq. Ft.
	9	SUN ROOM	NONE DETECTED	110211MV-08		200 Sq. Ft.
Q0C Carpet Adhesive Light Tan/Green Berber Carpet						Total Amount: 1,300 Sq. Ft.
	12	CAFETERIA	NONE DETECTED	110211MV-10		1300 Sq. Ft.
Q0D Carpet Adhesive Gray/Purple Berber Carpet						Total Amount: 11,000 Sq. Ft.
	4	THROUGHOUT SPACE	NONE DETECTED	110211MV-04	MV-04: TRAINING ROOM #2.	11000 Sq. Ft.
R0A Baseboard/Mopboard Adhesive 4" Black Baseboard						Total Amount: 500 Sq. Ft.
	5	THROUGHOUT SPACE	NONE DETECTED	110211MV-05	MV-05: STORAGE ROOM #2.	500 Sq. Ft.
R0B Baseboard/Mopboard Adhesive 4" Brown Baseboard						Total Amount: 10 Sq. Ft.
	16	HALLWAY NORTH OF CAFETERIA	NONE DETECTED	110211MV-13		10 Sq. Ft.
X0A Miscellaneous Material White Duct Seam Tape						Total Amount: 500 Sq. Ft.
	7	THROUGHOUT BUILDING	NONE DETECTED	110211MV-15		500 Sq. Ft.