

## Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

**PLEASE NOTE:** Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

| EPA ASSESSMENT CATEGORIES: | 1 = Damaged or significantly damaged TSI ACM                   | 5 = ACBM with potential for damage                 |
|----------------------------|--|--|
|                            | 2 = Damaged friable surfacing ACM                              | 6 = ACBM with potential for significant damage     |
|                            | 3 = Significantly damaged friable surfacing ACM                | 7 = Remaining friable ACBM or friable suspect ACBM |
|                            | 4 = Damaged or significantly damaged friable miscellaneous ACM |  |

| IEA Event No.                                | Material Type | Material Description/Id                                    | Location                                    | Estimated Amount Total | Friability             | % of Asbestos | EPA Assess Category |
|--|---------------|--|---|------------------------|------------------------|---------------|---------------------|
| 6<br>CAD #:                                  | X0H           | Miscellaneous Material<br>Slate Chalkboard Adhesive (1926) | THROUGHOUT 1926 ORIGINAL BUILDING           | 400 Sq Ft              | N                      | ASSUMED       | 5                   |
| Comments:                                    |               |  |   |                        | Sample #:              |               |                     |
| 7<br>CAD #:                                  | X0I           | Miscellaneous Material<br>Tackboard Adhesive (1926)        | THROUGHOUT 1926 ORIGINAL BUILDING           | 1000 Sq Ft             | N                      | ASSUMED       | 5                   |
| Comments:                                    |               |  |   |                        | Sample #:              |               |                     |
| 8<br>CAD #:                                  | X0J           | Miscellaneous Material<br>Marble Adhesive                  | THROUGHOUT 1926 ORIGINAL BUILDING RESTROOMS | 60 Sq Ft               | N                      | ASSUMED       | 5                   |
| Comments:                                    |               |  |   |                        | Sample #:              |               |                     |
| 9<br>CAD #:                                  | B2A           | Millboard Pipe Insulation<br>1926 Original Building        | ENTRY TO FAN ROOM 0202                      | 1 Lin Ft               | N                      | 5 CH          | 5                   |
| Comments: AT PENETRATION TO FAN ROOM.        |               |  |   |                        | Sample #: 2001-01152-2 |               |                     |
| 17<br>CAD #:                                 | X0A           | Miscellaneous Material<br>Pipe & Valve Flange Gaskets      | BOILER ROOM 0103                            | 30 Sq Ft               | N                      | 25 CH         | 5                   |
| Comments: APPROXIMATELY THIRTY (30) GASKETS. |               |  |   |                        | Sample #:              |               |                     |
| 18<br>CAD #:                                 | X0A           | Miscellaneous Material<br>Pipe & Valve Flange Gaskets      | ROOM 0103C OFF BOILER ROOM                  | 5 Sq Ft                | N                      | 25 CH         | 5                   |
| Comments: FIVE (5) GASKETS.                  |               |  |   |                        | Sample #: 041409ML-01  |               |                     |

| IEA Event No.  | Material Type | Material Description/Id  | Location                                      | Estimated Amount Total | Friability            | % of Asbestos         | EPA Assess Category |
|--|---------------|--|---|------------------------|-----------------------|-----------------------|---------------------|
| 27<br>CAD #:   | X0D           | Miscellaneous Material<br>Tackboard w/Dark Brown Trim -Adhesive                            | ROOM 0204                                     | 30 Sq Ft               | N                     | ASSUMED               | 5                   |
| Comments:  |               |  |   |                        | Sample #:             |                       |                     |
| 34<br>CAD #:   | X0C           | Miscellaneous Material<br>Black Chalkboards w/Dark Brown Trim - Adhesive                   | ROOM 0207                                     | 8 Sq Ft                | N                     | ASSUMED               | 5                   |
| Comments: <b>MOST COVERED BY WHITEBOARD.</b>   |               |  |   |                        | Sample #:             |                       |                     |
| 35<br>CAD #:   | X0D           | Miscellaneous Material<br>Tackboard w/Dark Brown Trim -Adhesive                            | ROOM 0207                                     | 80 Sq Ft               | N                     | ASSUMED               | 5                   |
| Comments: <b>TWO (2) BOARDS.</b>   |               |  |   |                        | Sample #:             |                       |                     |
| 40<br>CAD #:   | X0E           | Miscellaneous Material<br>Vermiculite  | ROOM 0101                                     | 1 Sq Ft                | Y                     | ASSUMED               | 5                   |
| Comments: <b>FOUR (4) SMALL BOXES ON SHELF.</b>  |               |  |   |                        | Sample #:             |                       |                     |
| 41<br>CAD #:   | V0A           | Sink Undercoating<br>Coarse Black  | ROOM 0101                                     | 30 Sq Ft               | N                     | 5 CH                  | 5                   |
| Comments: <b>ONE (1) LARGE SINK W/THREE (3) FAUCETS.</b>                                       |               |  |   |                        | Sample #: 041409ML-09 |                       |                     |
| 45<br>CAD #:   | X0C           | Miscellaneous Material<br>Black Chalkboards w/Dark Brown Trim - Adhesive                   | ROOM 0107                                     | 16 Sq Ft               | N                     | ASSUMED               | 5                   |
| Comments: <b>MOST BEHIND WHITEBOARD.</b>   |               |  |   |                        | Sample #:             |                       |                     |
| 46<br>CAD #:   | X0D           | Miscellaneous Material<br>Tackboard w/Dark Brown Trim -Adhesive                            | ROOM 0107                                     | 36 Sq Ft               | N                     | ASSUMED               | 5                   |
| Comments:  |               |  |   |                        | Sample #:             |                       |                     |
| 49<br>CAD #:   | X0C           | Miscellaneous Material<br>Black Chalkboards w/Dark Brown Trim - Adhesive                   | ROOM 0108                                     | 16 Sq Ft               | N                     | ASSUMED               | 5                   |
| Comments: <b>MOST BEHIND WHITEBOARD.</b>   |               |  |   |                        | Sample #:             |                       |                     |
| 50<br>CAD #:   | X0D           | Miscellaneous Material<br>Tackboard w/Dark Brown Trim -Adhesive                            | ROOM 0108                                     | 36 Sq Ft               | N                     | ASSUMED               | 5                   |
| Comments:  |               |  |   |                        | Sample #:             |                       |                     |
| 53<br>CAD #:   | X0C           | Miscellaneous Material<br>Black Chalkboards w/Dark Brown Trim - Adhesive                   | ROOM 0109                                     | 16 Sq Ft               | N                     | ASSUMED               | 5                   |
| Comments: <b>MOST BEHIND WHITEBOARD.</b>   |               |  |   |                        | Sample #:             |                       |                     |
| 54<br>CAD #:   | X0D           | Miscellaneous Material<br>Tackboard w/Dark Brown Trim -Adhesive                            | ROOM 0109                                     | 24 Sq Ft               | N                     | ASSUMED               | 5                   |
| Comments:  |               |  |   |                        | Sample #:             |                       |                     |
| 67<br>CAD #:   | X1A           | Miscellaneous Material<br>1" X 1" Tan and Gray with White Flecks Ceramic Floor Tile System | 1ST FLOOR STAFF RESTROOMS BY CUSTODIAL OFFICE | 142 Sq Ft              | N                     | ASSUMED               | 5                   |
| Comments:  |               |  |   |                        | Sample #:             |                       |                     |
| 71<br>CAD #:   | V0B           | Sink Undercoating<br>Black w/Gooseneck Faucet  | ROOM 1209                                     | 5 Sq Ft                | N                     | 5 CH                  | 5                   |
| Comments: <b>ONE (1) SINK.</b>   |               |  |   |                        | Sample #: 041409ML-13 |                       |                     |
| 73<br>CAD #:   | K0A           | 9" x 9" Vinyl Floor Tile & Mastic<br>Tan w/White Streaks                                   | ROOM 1205 (CHOIR)                             | 800 Sq Ft              | N                     | 10 CH (TILE & MASTIC) | 5                   |
| Comments: <b>UNDER CARPET ON RISERS. EXPOSED AT ENTRY TO 1964 ADDITION. CRACKING AT ENTRY.</b> |               |  |   |                        | Sample #: 041409ML-15 |                       |                     |
| 75<br>CAD #:   | X0F           | Miscellaneous Material<br>Slate Chalkboard Adhesive (1964)                                 | ROOM 1205 (CHOIR)                             | 5 Sq Ft                | N                     | ASSUMED               | 5                   |
| Comments: <b>CHALKBOARD INSTALLED W/1964 ADDITION/RENOVATION. BEHIND SMARTBOARD.</b>           |               |  |   |                        | Sample #:             |                       |                     |
| 76<br>CAD #:   | X0G           | Miscellaneous Material<br>Tackboard Adhesive (1964)  | ROOM 1205 (CHOIR)                             | 25 Sq Ft               | N                     | ASSUMED               | 5                   |
| Comments: <b>TACKBOARD INSTALLED W/1964 ADDITION.</b>  |               |  |   |                        | Sample #:             |                       |                     |

| IEA Event No.  | Material Type | Material Description/Id  | Location                          | Estimated Amount Total | Friability | % of Asbestos         | EPA Assess Category |
|--|---------------|--|-----------------------------------|------------------------|------------|-----------------------|---------------------|
| 78<br>CAD #:   | K0A           | 9" x 9" Vinyl Floor Tile & Mastic<br>Tan w/White Streaks                                   | ROOM 1212 (BAND)                  | 1000 Sq Ft             | N          | 10 CH (TILE & MASTIC) | 5                   |
| Comments: UNDER CARPET ON RISERS. EXPOSED AT ENTRY TO 1964 ADDITION. TILES CHIPPING IN DOORWAY TO 1964 ADDITION. |               |  |                                   |                        | Sample #:  |                       |                     |
| 80<br>CAD #:   | X0F           | Miscellaneous Material<br>Slate Chalkboard Adhesive (1964)                                 | ROOM 1212 (BAND)                  | 5 Sq Ft                | N          | ASSUMED               | 5                   |
| Comments: CHALKBOARD INSTALLED W/1964 ADDITION/RENOVATION. BEHIND WHITEBOARD.                                    |               |  |                                   |                        | Sample #:  |                       |                     |
| 81<br>CAD #:   | X0G           | Miscellaneous Material<br>Tackboard Adhesive (1964)  | ROOM 1212 (BAND)                  | 25 Sq Ft               | N          | ASSUMED               | 5                   |
| Comments: TACKBOARD INSTALLED W/1964 ADDITION.   |               |  |                                   |                        | Sample #:  |                       |                     |
| 86<br>CAD #:   | V0B           | Sink Undercoating<br>Black w/Gooseneck Faucet  | MAIN OFFICE ROOM 1007 (WORK ROOM) | 5 Sq Ft                | N          | 5 CH                  | 5                   |
| Comments: ONE (1) SINK.  |               |  |                                   |                        | Sample #:  |                       |                     |
| 87<br>CAD #:   | X1A           | Miscellaneous Material<br>1" X 1" Tan and Gray with White Flecks Ceramic Floor Tile System | MAIN OFFICE RESTROOM              | 32 Sq Ft               | N          | ASSUMED               | 5                   |
| Comments:  |               |  |                                   |                        | Sample #:  |                       |                     |
| 88<br>CAD #:   | V0C           | Sink Undercoating<br>Pink w/Gooseneck Faucet   | NURSE'S OFFICE 1015               | 5 Sq Ft                | N          | 10 CH                 | 5                   |
| Comments: ONE (1) SINK.  |               |  |                                   |                        | Sample #:  | 041409ML-16           |                     |
| 89<br>CAD #:   | X1A           | Miscellaneous Material<br>1" X 1" Tan and Gray with White Flecks Ceramic Floor Tile System | NURSE'S OFFICE RESTROOM           | 30 Sq Ft               | N          | ASSUMED               | 5                   |
| Comments:  |               |  |                                   |                        | Sample #:  |                       |                     |
| 103<br>CAD #:  | X0C           | Miscellaneous Material<br>Black Chalkboards w/Dark Brown Trim - Adhesive                   | ROOM 2111                         | 10 Sq Ft               | N          | ASSUMED               | 5                   |
| Comments: BEHIND SMARTBOARD.   |               |  |                                   |                        | Sample #:  |                       |                     |
| 104<br>CAD #:  | X0D           | Miscellaneous Material<br>Tackboard w/Dark Brown Trim -Adhesive                            | ROOM 2111                         | 32 Sq Ft               | N          | ASSUMED               | 5                   |
| Comments:  |               |  |                                   |                        | Sample #:  |                       |                     |
| 105<br>CAD #:  | K2A           | 12" x 12" Vinyl Floor Tile & Mastic<br>White w/Thin Brown Streaks                          | ROOM 2119                         | 160 Sq Ft              | N          | 3 CH (TILE)           | 5                   |
| Comments: TILE WEAR UNDER MAIN DESK. RECOMMEND CHAIR MAT. CHIPPING THROUGHOUT.                                   |               |  |                                   |                        | Sample #:  | 041409ML-07           |                     |
| 107<br>CAD #:  | V0C           | Sink Undercoating<br>Pink w/Gooseneck Faucet   | ROOM 2119                         | 5 Sq Ft                | N          | 10 CH                 | 5                   |
| Comments: ONE (1) SINK.  |               |  |                                   |                        | Sample #:  |                       |                     |
| 113<br>CAD #:  | R0C           | Baseboard/Mopboard Adhesive<br>4" Brown  | STAFF WORK ROOM 2107              | 20 Sq Ft               | N          | ASSUMED               | 5                   |
| Comments:  |               |  |                                   |                        | Sample #:  |                       |                     |
| 115<br>CAD #:  | X1B           | Miscellaneous Material<br>4" X 4" Mauve Ceramic Wall Tile System                           | STAFF WORK RESTROOM 2107          | 220 Sq Ft              | N          | ASSUMED               | 5                   |
| Comments:  |               |  |                                   |                        | Sample #:  |                       |                     |
| 116<br>CAD #:  | X1C           | Miscellaneous Material<br>2" X 2" Gray with Black Specks Ceramic Floor Tile System         | STAFF WORK RESTROOM 2107          | 56 Sq Ft               | N          | ASSUMED               | 5                   |
| Comments:  |               |  |                                   |                        | Sample #:  |                       |                     |
| 118<br>CAD #:  | X0C           | Miscellaneous Material<br>Black Chalkboards w/Dark Brown Trim - Adhesive                   | ROOM 2109                         | 10 Sq Ft               | N          | ASSUMED               | 5                   |
| Comments:  |               |  |                                   |                        | Sample #:  |                       |                     |
| 119<br>CAD #:  | X0D           | Miscellaneous Material<br>Tackboard w/Dark Brown Trim -Adhesive                            | ROOM 2109                         | 32 Sq Ft               | N          | ASSUMED               | 5                   |
| Comments:  |               |  |                                   |                        | Sample #:  |                       |                     |

| IEA Event No.  | Material Type | Material Description/Id  | Location                              | Estimated Amount Total | Friability | % of Asbestos | EPA Assess Category |
|--|---------------|--|---------------------------------------|------------------------|------------|---------------|---------------------|
| 121<br>CAD #:  | X0C           | Miscellaneous Material<br>Black Chalkboards w/Dark Brown Trim - Adhesive | ROOM 2108                             | 10 Sq Ft               | N          | ASSUMED       | 5                   |
| Comments: MOST COVERED BY WHITEBOARD.  |               |  |                                       |                        | Sample #:  |               |                     |
| 122<br>CAD #:  | X0D           | Miscellaneous Material<br>Tackboard w/Dark Brown Trim -Adhesive          | ROOM 2108                             | 32 Sq Ft               | N          | ASSUMED       | 5                   |
| Comments:  |               |  |                                       |                        | Sample #:  |               |                     |
| 124<br>CAD #:  | X0C           | Miscellaneous Material<br>Black Chalkboards w/Dark Brown Trim - Adhesive | ROOM 2105                             | 10 Sq Ft               | N          | ASSUMED       | 5                   |
| Comments:  |               |  |                                       |                        | Sample #:  |               |                     |
| 125<br>CAD #:  | X0D           | Miscellaneous Material<br>Tackboard w/Dark Brown Trim -Adhesive          | ROOM 2105                             | 32 Sq Ft               | N          | ASSUMED       | 5                   |
| Comments: SOME COVERED BY SMARTBOARD.  |               |  |                                       |                        | Sample #:  |               |                     |
| 132<br>CAD #:  | X0Q           | Miscellaneous Material<br>Shiny Metal Frame Corkboard                    | ROOM 3103                             | 40 Sq Ft               | N          | ASSUMED       | 5                   |
| Comments:  |               |  |                                       |                        | Sample #:  |               |                     |
| 144<br>CAD #:  | X0K           | Miscellaneous Material<br>Fume Hood Tar Paper                            | ROOM 3114                             | 20 Sq Ft               | N          | 20 CH         | 5                   |
| Comments:  |               |  |                                       |                        | Sample #:  | 041409ML-28   |                     |
| 154<br>CAD #:  | X0L           | Miscellaneous Material<br>Coarse White Proscenium Curtain                | STAGE 1301                            | 600 Sq Ft              | N          | ASSUMED       | 5                   |
| Comments:  |               |  |                                       |                        | Sample #:  |               |                     |
| 155<br>CAD #:  | T0A           | Light Cord Insulation<br>Black Fuzzy                                     | STAGE 1301                            | 48 Lin Ft              | N          | ASSUMED       | 5                   |
| Comments: SIXTEEN (16) LIGHT FIXTURES W/DOUBLE CORDS.  |               |  |                                       |                        | Sample #:  |               |                     |
| 156<br>CAD #:  | X0P           | Miscellaneous Material<br>White Coarse Weave Fire Curtain                | STAGE 1301                            | 200 Sq Ft              | N          | ASSUMED       | 5                   |
| Comments:  |               |  |                                       |                        | Sample #:  |               |                     |
| 160<br>CAD #:  | B3B           | Pre-Formed Pipe Insulation<br>1964 Addition                              | 1964 ADDITION 1ST FLOOR HALLWAY 1300A | 150 Lin Ft             | Y          | 20 AM         | 1                   |
| Comments: ABOVE CEILING. OPEN ENDS. INACCESSIBLE FOR REPAIR/REMOVAL.   |               |  |                                       |                        | Sample #:  | ACB450X-A8    |                     |
| 161<br>CAD #:  | A3B           | Mudded Pipe Joints on Pre-formed Insulation<br>1964 Addition             | 1964 ADDITION 1ST FLOOR HALLWAY 1300A | 22 Joints              | N          | ASSUMED       | 5                   |
| Comments: ABOVE CEILING. INACCESSIBLE FOR REMOVAL.   |               |  |                                       |                        | Sample #:  |               |                     |
| 162<br>CAD #:  | B2B           | Millboard Pipe Insulation<br>1964 Addition                               | 1964 ADDITION 1ST FLOOR HALLWAY 1300  | 50 Lin Ft              | N          | 40 CH         | 5                   |
| Comments: ABOVE PLASTER CEILING. ROOF DRAIN. ACCESS HATCH ON WEST END.   |               |  |                                       |                        | Sample #:  | 041609ML-36   |                     |
| 163<br>CAD #:  | A2B           | Mudded Pipe Joints on Millboard Insulation<br>1964 Addition              | 1964 ADDITION 1ST FLOOR HALLWAY 1300  | 2 Joints               | N          | ASSUMED       | 5                   |
| Comments: ABOVE PLASTER CEILING. ROOF DRAIN. ACCESS HATCH ON WEST END.   |               |  |                                       |                        | Sample #:  |               |                     |
| 164<br>CAD #:  | B2B           | Millboard Pipe Insulation<br>1964 Addition                               | AUDITORIUM/CAFETERIA 1302             | 30 Lin Ft              | N          | 40 CH         | 5                   |
| Comments: ABOVE CEILING. ROOF DRAIN. BOWL & FIRST 5' HAVE BEEN REMOVED. INACCESSIBLE FOR REMOVAL.                    |               |  |                                       |                        | Sample #:  |               |                     |
| 169<br>CAD #:  | B2B           | Millboard Pipe Insulation<br>1964 Addition                               | 1964 ADDITION GYMNASIUM 1306          | 40 Lin Ft              | N          | 40 CH         | 5                   |
| Comments: ABOVE CEILING. ROOF DRAIN. BOWL & FIRST 5' HAVE BEEN REMOVED. INACCESSIBLE FOR REMOVAL.                    |               |  |                                       |                        | Sample #:  |               |                     |
| 178<br>CAD #:  | B2B           | Millboard Pipe Insulation<br>1964 Addition                               | BOYS' LOCKER ROOM                     | 1 Lin Ft               | Y          | 40 CH         | 1                   |
| Comments: ABOVE CEILING IN SOUTHWEST CORNER. 6" STUB AT HALLWAY WALL W/EXPOSED END. INACCESSIBLE FOR REPAIR/REMOVAL. |               |  |                                       |                        | Sample #:  |               |                     |

| IEA Event No.  | Material Type | Material Description/Id   | Location                             | Estimated Amount Total | Friability                                 | % of Asbestos | EPA Assess Category |
|--|---------------|---|--------------------------------------|------------------------|--|---------------|---------------------|
| 179<br>CAD #:  | X1D           | Miscellaneous Material<br>1" X 1" Taupe and Brown with White Flecks Ceramic Floor Tile System | BOYS' LOCKER ROOM SHOWER             | 255 Sq Ft              | N  | ASSUMED       | 5                   |
| Comments:  |               |   |                                      |                        | Sample #:                                  |               |                     |
| 180<br>CAD #:  | X1E           | Miscellaneous Material<br>1" X 1" Brown with White Flecks Ceramic Floor Tile System           | BOYS' LOCKER ROOM RESTROOMS          | 81 Sq Ft               | N  | ASSUMED       | 5                   |
| Comments:  |               |   |                                      |                        | Sample #:                                  |               |                     |
| 181<br>CAD #:  | X1E           | Miscellaneous Material<br>1" X 1" Brown with White Flecks Ceramic Floor Tile System           | BOYS' LOCKER ROOM COACHES' RESTROOM  | 35 Sq Ft               | N  | ASSUMED       | 5                   |
| Comments:  |               |   |                                      |                        | Sample #:                                  |               |                     |
| 182<br>CAD #:  | X1D           | Miscellaneous Material<br>1" X 1" Taupe and Brown with White Flecks Ceramic Floor Tile System | GIRLS' LOCKER ROOM RESTROOM          | 255 Sq Ft              | N  | ASSUMED       | 5                   |
| Comments:  |               |   |                                      |                        | Sample #:                                  |               |                     |
| 183<br>CAD #:  | X1E           | Miscellaneous Material<br>1" X 1" Brown with White Flecks Ceramic Floor Tile System           | GIRLS' LOCKER ROOM RESTROOM          | 81 Sq Ft               | N  | ASSUMED       | 5                   |
| Comments:  |               |   |                                      |                        | Sample #:                                  |               |                     |
| 184<br>CAD #:  | X1E           | Miscellaneous Material<br>1" X 1" Brown with White Flecks Ceramic Floor Tile System           | GIRLS' LOCKER ROOM COACHES' RESTROOM | 35 Sq Ft               | N  | ASSUMED       | 5                   |
| Comments:  |               |   |                                      |                        | Sample #:                                  |               |                     |
| 185<br>CAD #:  | X0M           | Miscellaneous Material<br>Vermiculite Fill  | 1977 ADDITION GYMNASIUM 1305         | 10000 Sq Ft            | Y  | ASSUMED       | 5                   |
| Comments: ASSUMED PRESENT IN EXTERIOR WALLS. VISIBLE FROM HALLWAY.       |               |   |                                      |                        | Sample #:                                  |               |                     |
| 193<br>CAD #:  | B2B           | Millboard Pipe Insulation<br>1964 Addition  | 1964 ADDITION 2ND FLOOR HALLWAY 2300 | 38 Lin Ft              | N  | 40 CH         | 5                   |
| Comments: ABOVE CEILING. ROOF DRAIN. TIGHT ACCESS.                       |               |   |                                      |                        | Sample #:                                  |               |                     |
| 194<br>CAD #:  | A2B           | Mudded Pipe Joints on Millboard Insulation<br>1964 Addition                                   | 1964 ADDITION 2ND FLOOR HALLWAY 2300 | 1 Joints               | N  | ASSUMED       | 5                   |
| Comments: ABOVE CEILING. ROOF DRAIN. SOUTH END OF HALLWAY. TIGHT ACCESS. |               |   |                                      |                        | Sample #:                                  |               |                     |
| 198<br>CAD #:  | B2B           | Millboard Pipe Insulation<br>1964 Addition  | ROOM 2302                            | 40 Lin Ft              | N  | 40 CH         | 5                   |
| Comments: ABOVE CEILING. INACCESSIBLE FOR REMOVAL.                       |               |   |                                      |                        | Sample #:                                  |               |                     |
| 202<br>CAD #:  | V0C           | Sink Undercoating<br>Pink w/Gooseneck Faucet  | ROOM 2302                            | 10 Sq Ft               | N  | 10 CH         | 5                   |
| Comments: DOUBLE SINK.   |               |   |                                      |                        | Sample #:                                  |               |                     |
| 203<br>CAD #:  | X0N           | Miscellaneous Material<br>Black Chalkboard w/Wood Frame Adhesive                              | ROOM 2302                            | 6 Sq Ft                | N  | ASSUMED       | 5                   |
| Comments: MOST COVERED BY SMARTBOARD.                                    |               |   |                                      |                        | Sample #:                                  |               |                     |
| 204<br>CAD #:  | X0O           | Miscellaneous Material<br>Tackboard w/Silver Frame Adhesive                                   | ROOM 2302                            | 80 Sq Ft               | N  | ASSUMED       | 5                   |
| Comments:  |               |   |                                      |                        | Sample #:                                  |               |                     |
| 205<br>CAD #:  | B2B           | Millboard Pipe Insulation<br>1964 Addition  | ROOM 2302A                           | 50 Lin Ft              | N  | 40 CH         | 5                   |
| Comments: ROOF DRAIN. ABOVE PLASTER CEILING. INACCESSIBLE FOR REMOVAL.   |               |   |                                      |                        | Sample #:                                  |               |                     |
| 206<br>CAD #:  | A2B           | Mudded Pipe Joints on Millboard Insulation<br>1964 Addition                                   | ROOM 2302A                           | 3 Joints               | N  | ASSUMED       | 5                   |
| Comments: ROOF DRAIN. ABOVE PLASTER CEILING. INACCESSIBLE FOR REMOVAL.   |               |   |                                      |                        | Sample #:                                  |               |                     |
| 207<br>CAD #:  | F2C           | Exterior Duct Insulation<br>Soft Plaster w/Vermiculite  | ROOM 2302A                           | 20 Sq Ft               | N  | 30 CH         | 5                   |
| Comments: AT WALL PENETRATIONS & ON CMU BLOCK.                           |               |   |                                      |                        | Sample #: 041609ML-38; 2001-1501-K-5, 6, 7 |               |                     |

| IEA Event No.                             | Material Type | Material Description/Id   | Location  | Estimated Amount Total | Friability | % of Asbestos                          | EPA Assess Category |
|---|---------------|---|-----------|------------------------|------------|--|---------------------|
| 210<br>CAD #:                             | K0B           | 9" x 9" Vinyl Floor Tile & Mastic<br>Tan w/Dark Brown & Beige Streaks | ROOM 2303 | 120 Sq Ft              | N          | 1-3 CH (TILE),<br>5 CH (MASTIC)        | 5                   |
| Comments: ASSUMED PRESENT UNDER CABINETS. |               |   |           |                        |            | Sample #: 041609ML-39; 2001-1901-RJH-3 |                     |