


INSPECTION CERTIFICATION for Saint Paul Public Schools -- Wheelock Early Education


STATEMENT OF BUILDING ACCESS

On behalf of Saint Paul Public Schools for Wheelock Early Education, I certify that I have provided access to all areas within the building to IEA's inspector identified below for the purpose of inspecting for asbestos-containing building materials (ACBM) as mandated by 40 CFR 763.85, "Inspections and Reinspections."

Additionally, I have discussed any concerns I have regarding identified or non-identified ACBM within this building.



Signature



Date of Inspection


INSPECTOR


As mandated by 40 CFR 763.85, "Inspections and Reinspections," I certify that I have inspected all accessible areas in Wheelock Early Education for the purpose of identifying and assessing asbestos-containing building materials. I have completed an EPA-approved course and all appropriate refresher courses and am an accredited AHERA Inspector. A copy of my certification/accreditation is attached.



Signature


Print Name





Date of Inspection


State Certification/Accreditation Number


MANAGEMENT PLANNER


I certify that I have reviewed all of the inspection data for Wheelock Early Education and have appropriately provided assessments and response actions for identified asbestos-containing building materials. I have completed an EPA-approved course and all appropriate refresher courses and am an accredited AHERA Management Planner. A copy of my certification/accreditation is attached.



Signature


Print Name



Date of Review


State Certification/Accreditation Number

Inspector State Certification/Accreditation




m ASBESTOS
DEPARTMENT OF HEALTH INSPECTOR
Certified by:
State of Minnesota
Department of Health
Expires: 09/02/2021
Spencer D. West
4227 Penn Ave N
Minneapolis, MN 55412

Spencer D. West
Director, Env. Health Div.

No. A14511 Issued: 09/22/2020

Management Planner State Certification/Accreditation



m ASBESTOS
DEPARTMENT OF HEALTH MANAGEMENT
Certified by: **PLANNER**
State of Minnesota
Department of Health
Expires: 08/06/2022
Matthew A Lindberg
11816 Ghia St NE
Blaine, MN 55449

Matthew A Lindberg
Director, Env. Health Div.

No. AM3896 Issued: 08/24/2021

Chart A - Immediate Response Situations

The following is a list of those events that contain damaged asbestos material and should be considered to be potential hazards. It is imperative that the following immediate response situations are corrected as soon as possible but no later than six months from the date of this inspection to avoid increased risk of exposure to airborne asbestos fibers. The district should take extra precaution to ensure that properly trained personnel use appropriate techniques to implement these responses.

Following is an explanation of the immediate Response Action codes identified in this report.

EPA ASSESSMENT CATEGORY	RESPONSE ACTION
1 = Damaged or significantly damaged TSI ACM.	A = Cleanup ACM debris.
2 = Damaged friable surfacing ACM.	B = Encapsulate slight damage on TSI.
3 = Significantly damaged friable surfacing ACM.	C = Patch TSI and/or repair ACM cover.
4 = Damaged or significantly damaged friable miscellaneous ACM.	D = Enclose or protect accessible sections with protective barrier.
5 = ACBM with potential for damage.	E = Remove section of damaged ACM.
6 = ACBM with potential for significant damage.	F = Remove ACM and replace with non-ACM.
7 = Remaining friable ACBM or friable suspected ACBM.	G = Isolate area until repaired/removed.
	H = Encapsulate slight damage.
	I = Remove and replace damaged or loose tile section.
	J = Monitor condition of material(s).

IEA Event No.	Material Type	Material Id/Desc	Location	Estimated Amount Total	Estimated Amount of Damage	EPA Assess.	Immediate Response Action	Comments
14 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic White w/Light Streaks	THROUGHOUT MAIN OFFICE 1001	1500 Sq Ft	3 Sq Ft	5	D	INCLUDES ROOMS 1002-1006. WEARING UNDER RECEPTIONIST'S DESK & NURSE'S OFFICE & PRINCIPAL'S OFFICE. RECOMMEND CHAIR MATS. CHIPPED AT DOOR 1000B.
40 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic White w/Light Streaks	ROOM 1203	1200 Sq Ft	2 Sq Ft	5	I	SLIGHT WEARING NEAR ENTRANCE. SEVERAL TILES LOOSE NEAR WEST WHITEBOARD.
42 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic White w/Light Streaks	ROOM 1204	1200 Sq Ft	2 Sq Ft	5	I	SLIGHT WEARING NEAR ENTRANCE. REPLACEMENT TILES BY EXTERIOR ENTRANCE. CHIPPED TILE IN NORTHEAST CORNER. SEVERAL TILES LOOSE NEAR WEST WHITEBOARD.
48 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic White w/Light Streaks	ROOM 1206	1200 Sq Ft	2 Sq Ft	5	I	SLIGHT WEARING NEAR ENTRANCE. SEVERAL TILES COMING LOOSE NEAR EXTERIOR ENTRANCE. REPLACEMENT TILES AT EXTERIOR ENTRANCE.